Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Karitane Bowls	D-0058H	Free Available Chlorine	09/04/2020	10:35	0.79	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	09/04/2020	10:35	0.9	g/m³	
	Karitane Bowls	D-0084	Turbidity	09/04/2020	10:35	0.1	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	09/04/2020	10:35	6.1	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/04/2020	10:35	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/04/2020	10:35	<1	MPN/100ml	(0 - 0)
	Waikouaiti Pre Treatment	84	Turbidity	22/04/2020	11:10	0.93	NTU	(- 2.5)
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	22/04/2020	11:10	Completed		
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	22/04/2020	11:10	110	MPN/100mL (105.4 x 1)	

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Karitane Bowls	D-0058H	Free Available Chlorine	01/05/2020	11:00	1.2	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	01/05/2020	11:00	1.3	g/m³	
	Karitane Bowls	D-0084	Turbidity	01/05/2020	11:00	0.11	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	01/05/2020	11:00	8.2	Deg C	
	Karitane Bowls	D-M0411	E. coli by Colilert MPN 51 Wells - Drinking Water	01/05/2020	11:00	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412	Total Coliforms by Colilert MPN -51 Wells -Drinking Water	01/05/2020	11:00	<1	MPN/100ml	(0 - 0)
	TAB Waikouaiti	D-0058H	Free Available Chlorine	07/05/2020	14:10	1	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	07/05/2020	14:10	1.1	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	07/05/2020	14:10	0.15	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	07/05/2020	14:10	9.1	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	07/05/2020	14:10	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	07/05/2020	14:10	<1	MPN/100ml	(0 - 0)
	Waikouaiti Pumping Main	1	pH	08/05/2020	09:00	7.7		(1 - 14)
	Waikouaiti Pumping Main	52	Alkalinity - Total	08/05/2020	09:00	67	g CaCO3/m³	
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	08/05/2020	09:00	21.1	mS/m (210.7 x .1)	
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	08/05/2020	09:00	0.01	g/m³	
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	08/05/2020	09:00	99	g/m³	
	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	08/05/2020	09:00	18.4	g/m³	
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	08/05/2020	09:00	8.47	g/m³	
	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	08/05/2020	09:00	81	g CaCO3/m³	
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	08/05/2020	09:00	46	g CaCO3/m³	
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	08/05/2020	09:00	<0.005	g/m³	
	Waikouaiti Pumping Main	P1859	Sample Filtration	08/05/2020	09:00	Completed		
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	08/05/2020	09:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	08/05/2020	09:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH031	MCPA in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH034	MCPB in water	08/05/2020	09:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH043	Picloram in water	08/05/2020	09:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	08/05/2020	09:00	<0.0005	mg/L	
	Waikouaiti Pre Treatment	84	Turbidity	19/05/2020	12:30	1.15	NTU	(- 2.5)
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	19/05/2020	12:30	21	MPN/100mL (21.3 x 1)	
	Waikouaiti Pre Treatment	DC-1201	Sampling / Inspection 15 Mins	19/05/2020	12:30	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	19/05/2020	12:50	1.1	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	19/05/2020	12:50	1.1	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	19/05/2020	12:50	0.08	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	19/05/2020	12:50	2.7	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/05/2020	12:50	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/05/2020	12:50	<1	MPN/100ml	(0 - 0)
	Karitane Bowls	D-0058H	Free Available Chlorine	27/05/2020	11:15	0.42	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	27/05/2020	11:15	0.5	g/m³	
	Karitane Bowls	D-0084	Turbidity	27/05/2020	11:15	0.05	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	27/05/2020	11:15	5.4	Deg C	

	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	27/05/2020	11:15	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	27/05/2020	11:15	<1	MPN/100ml	(0 - 0)

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	6001	Aluminium - Acid Soluble	03/06/2020	13:55	0.012	g/m³	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	6017	Iron - Acid Soluble	03/06/2020	13:55	0.01	g/m³	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	6021	Manganese - Acid Soluble	03/06/2020	13:55	0.012	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	03/06/2020	14:00	<0.002	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	03/06/2020	14:00	0.13	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	03/06/2020	14:00	0.0104	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	03/06/2020	14:00	12	cfu/100ml (12 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	03/06/2020	14:10	9	cfu/100ml (9 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	03/06/2020	14:25	15	cfu/100ml (15 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	03/06/2020	14:00	3	cfu/100mL (3 x 1)	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	03/06/2020	13:55	<1	cfu/100mL (<1 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	03/06/2020	14:10	3	cfu/100mL (3 x 1)	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	03/06/2020	14:15	<1	cfu/100mL (<1 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	03/06/2020	14:25	5	cfu/100mL (5 x 1)	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	03/06/2020	14:30	<1	cfu/100mL (<1 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	03/06/2020	14:00	120	MPN/100ml (121 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	03/06/2020	14:10	100	MPN/100ml (104 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	03/06/2020	14:25	110	MPN/100ml (108 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	03/06/2020	14:00	13	MPN/100mL (13 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	03/06/2020	14:10	17	MPN/100mL (17 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	03/06/2020	14:25	17	MPN/100mL (17 x 1)	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	03/06/2020	13:55	<1	cfu/100mL	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	03/06/2020	14:15	<1	cfu/100mL	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	03/06/2020	14:30	<1	cfu/100mL	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/06/2020	13:55	<1	MPN/100mL	(0 - 0)
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/06/2020	14:15	<1	MPN/100mL	(0 - 0)
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/06/2020	14:30	<1	MPN/100mL	(0 - 0)
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/06/2020	13:55	<1	MPN/100ml	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/06/2020	14:15	<1	MPN/100ml	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/06/2020	14:30	<1	MPN/100ml	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	03/06/2020	14:00	Completed		
	Waikouaiti Pumping Main	2	Suspended Solids - Total	04/06/2020	16:10	<6	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	04/06/2020	15:25	<6	g/m³	
	Waikouaiti Pumping Main	3	Oil and Grease	04/06/2020	16:10	<4	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	3	Oil and Grease	04/06/2020	15:25	<4	g/m³	
	Waikouaiti Pumping Main	40	Total Non-Purgeable Organic Carbon	04/06/2020	16:10	1.3	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	40	Total Non-Purgeable Organic Carbon	04/06/2020	15:25	1.3	g/m³	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	40	Total Non-Purgeable Organic Carbon	04/06/2020	15:20	0.8	g/m³	
	Waikouaiti Pumping Main	84	Turbidity	04/06/2020	16:10	0.71	NTU	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	84	Turbidity	04/06/2020	15:25	0.94	NTU	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	84	Turbidity	04/06/2020	15:20	0.06	NTU	
	Waikouaiti Pumping Main	85	BOD5 - Total	04/06/2020	16:10	<1	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	85	BOD5 - Total	04/06/2020	15:25	1	g/m³	
	Waikouaiti Pumping Main	440	Dissolved (NP) Organic Carbon	04/06/2020	16:10	1.3	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	440	Dissolved (NP) Organic Carbon	04/06/2020	15:25	1.2	g/m³	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	440	Dissolved (NP) Organic Carbon	04/06/2020	15:20	0.8	g/m³	
	Waikouaiti Pumping Main	1250	Transmissivity @ 253.7nm	04/06/2020	16:10	90.2	%	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	04/06/2020	15:25	89.8	%	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	1250	Transmissivity @ 253.7nm	04/06/2020	15:20	97.2	%	
	Waikouaiti Pumping Main	6601	Aluminium - Total	04/06/2020	16:10	0.006	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	04/06/2020	15:25	<0.005	g/m³	
	Waikouaiti Pumping Main	6617	Iron - Total	04/06/2020	16:10	0.2	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	04/06/2020	15:25	0.2	g/m³	
	Waikouaiti Pumping Main	6621	Manganese - Total	04/06/2020	16:10	0.016	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	04/06/2020	15:25	0.015	g/m³	
	Waikouaiti Pumping Main	6701	Aluminium - Dissolved	04/06/2020	16:10	<0.002	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	04/06/2020	15:25	<0.002	g/m³	
	Waikouaiti Pumping Main	6717	Iron - Dissolved	04/06/2020	16:10	0.14	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	04/06/2020	15:25	0.12	g/m³	
	Waikouaiti Pumping Main	6721	Manganese - Dissolved	04/06/2020	16:10	0.016	g/m³	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	04/06/2020	15:25	0.01	g/m³	

	Waikouaiti Pumping Main	D-1202	Sampling / Inspection 30 Mins	04/06/2020	16:10	Completed		
	Waikouaiti Pumping Main	D-1205	Sampling / Inspection 2 hours	04/06/2020	16:10	Completed		
	Waikouaiti Pumping Main	D-M0102	Faecal Coliforms by MF - Environmental Water	04/06/2020	16:10	17	cfu/100ml (17 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	04/06/2020	15:25	17	cfu/100ml (17 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	04/06/2020	15:35	16	cfu/100ml (16 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	04/06/2020	15:50	16	cfu/100ml (16 x 1)	
	Waikouaiti Pumping Main	D-M0107	Enterococci - Environmental water	04/06/2020	16:10	6	cfu/100mL (6 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	04/06/2020	15:25	4	cfu/100mL (4 x 1)	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	04/06/2020	15:20	<1	cfu/100mL (<1 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	04/06/2020	15:35	2	cfu/100mL (2 x 1)	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	04/06/2020	15:30	<1	cfu/100mL (<1 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	04/06/2020	15:50	4	cfu/100mL (4 x 1)	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0107	Enterococci - Environmental water	04/06/2020	15:45	<1	cfu/100mL (<1 x 1)	
	Waikouaiti Pumping Main	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	04/06/2020	16:10	180	MPN/100ml (178.9 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	04/06/2020	15:25	140	MPN/100ml (140.1 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	04/06/2020	15:35	120	MPN/100ml (118.7 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	04/06/2020	15:50	86	MPN/100ml (85.5 x 1)	
	Waikouaiti Pumping Main	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	04/06/2020	16:10	17	MPN/100mL (17.3 x 1)	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	04/06/2020	15:25	18	MPN/100mL (17.5 x 1)	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	04/06/2020	15:35	22	MPN/100mL (21.6 x 1)	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	04/06/2020	15:50	12	MPN/100mL (12.1 x 1)	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	04/06/2020	15:20	<1	cfu/100mL	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	04/06/2020	15:30	<1	cfu/100mL	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0408	Faecal Coliforms by MF - Drinking Water	04/06/2020	15:45	<1	cfu/100mL	
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/06/2020	15:20	<1	MPN/100mL	(0 - 0)
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/06/2020	15:30	<1	MPN/100mL	(0 - 0)
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/06/2020	15:45	<1	MPN/100mL	(0 - 0)
1	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/06/2020	15:20	<1	MPN/100ml	
2	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/06/2020	15:30	<1	MPN/100ml	
3	Waikouaiti WTP - Containerised Plant Filtrate ? Run-to-Waste	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/06/2020	15:45	<1	MPN/100ml	
	Waikouaiti Pumping Main	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/06/2020	16:10	Completed		
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/06/2020	15:25	Completed		
	Waikouaiti Pumping Main	P1859	Sample Filtration	04/06/2020	16:10	Completed		
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	04/06/2020	15:25	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	05/06/2020	12:05	1.2	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	05/06/2020	12:05	1.2	g/m³	
	Karitane Bowls	D-0084	Turbidity	05/06/2020	12:05	0.26	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	05/06/2020	12:05	7.7	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	05/06/2020	12:05	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	05/06/2020	12:05	<1	MPN/100ml	(0 - 0)
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	15/06/2020	14:05	91	%	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	15/06/2020	14:35	90.9	%	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	15/06/2020	15:05	91	%	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	15/06/2020	14:15	97.3	%	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	15/06/2020	14:40	97.9	%	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	15/06/2020	15:00	98.1	%	
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	15/06/2020	14:00	98.4	%	
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	15/06/2020	14:25	98	%	
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	15/06/2020	14:50	98.7	%	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	15/06/2020	14:15	0.004	g/m³	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	15/06/2020	14:40	0.004	g/m³	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	15/06/2020	15:00	0.004	g/m³	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	15/06/2020	14:05	<0.002	g/m³	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	15/06/2020	14:35	<0.002	g/m³	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	15/06/2020	15:05	<0.002	g/m³	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	9401	ICP-MS - 1 Element	15/06/2020	14:15	Completed		
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	9401	ICP-MS - 1 Element	15/06/2020	14:40	Completed		
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	9401	ICP-MS - 1 Element	15/06/2020	15:00	Completed		
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/06/2020	14:00	0.93	g/m³	
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/06/2020	14:25	0.92	g/m³	
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/06/2020	14:50	0.93	g/m³	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	15/06/2020	14:05	0.57	NTU	

Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	15/06/2020	14:35	0.57	NTU	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	15/06/2020	15:05	0.62	NTU	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	15/06/2020	14:15	0.07	NTU	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	15/06/2020	14:40	0.07	NTU	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	15/06/2020	15:00	0.05	NTU	
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	15/06/2020	14:00	0.14	NTU	
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	15/06/2020	14:25	0.17	NTU	
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	15/06/2020	14:50	0.19	NTU	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	15/06/2020	14:05	Completed		
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	15/06/2020	14:05	Completed		
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	15/06/2020	14:05	8	cfu/100ml (8 x 1)	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	15/06/2020	14:35	9	cfu/100ml (9 x 1)	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	15/06/2020	15:05	7	cfu/100ml (7 x 1)	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	15/06/2020	14:05	1	cfu/100mL (1 x 1)	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	15/06/2020	14:35	<1	cfu/100mL (<1 x 1)	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	15/06/2020	15:05	2	cfu/100mL (2 x 1)	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	15/06/2020	14:15	<1	cfu/100mL (<1 x 1)	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	15/06/2020	14:40	<1	cfu/100mL (<1 x 1)	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	15/06/2020	15:00	<1	cfu/100mL (<1 x 1)	
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	15/06/2020	14:00	<1	cfu/100mL (<1 x 1)	
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	15/06/2020	14:25	<1	cfu/100mL (<1 x 1)	
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	15/06/2020	14:50	<1	cfu/100mL (<1 x 1)	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	15/06/2020	14:05	47	MPN/100ml (47.3 x 1)	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	15/06/2020	14:35	69	MPN/100ml (69.1 x 1)	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	15/06/2020	15:05	93	MPN/100ml (93.3 x 1)	
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	15/06/2020	14:05	19	MPN/100mL (18.9 x 1)	
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	15/06/2020	14:35	15	MPN/100mL (14.6 x 1)	
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	15/06/2020	15:05	11	MPN/100mL (10.9 x 1)	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	14:15	<1	cfu/100mL	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	14:40	<1	cfu/100mL	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	15:00	<1	cfu/100mL	
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	14:00	<1	cfu/100mL	
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	14:25	<1	cfu/100mL	
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	15/06/2020	14:50	<1	cfu/100mL	
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	14:15	<1	MPN/100mL	(0 - 0)
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	14:40	<1	MPN/100mL	(0 - 0)
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	15:00	<1	MPN/100mL	(0 - 0)
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	14:00	<1	MPN/100mL	(0 - 0)
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	14:25	<1	MPN/100mL	(0 - 0)
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/06/2020	14:50	<1	MPN/100mL	(0 - 0)
Sample 01	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	14:15	<1	MPN/100ml	
Sample 02	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	14:40	<1	MPN/100ml	
Sample 03	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	15:00	<1	MPN/100ml	
Sample 01	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	14:00	<1	MPN/100ml	(0 - 0)
Sample 02	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	14:25	<1	MPN/100ml	(0 - 0)
Sample 03	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/06/2020	14:50	<1	MPN/100ml	(0 - 0)
Sample 01	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	15/06/2020	14:05	Completed		
Sample 02	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	15/06/2020	14:35	Completed		
Sample 03	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	15/06/2020	15:05	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	19/06/2020	11:00	0.88	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	19/06/2020	11:00	0.9	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	19/06/2020	11:00	0.2	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	19/06/2020	11:00	5.2	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/06/2020	11:00	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/06/2020	11:00	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	22/06/2020	12:15	91.3	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	22/06/2020	12:35	90.9	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	22/06/2020	12:50	91.4	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	22/06/2020	12:10	97.4	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	22/06/2020	12:30	97.5	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	22/06/2020	12:45	97.5	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	22/06/2020	12:05	97.6	%	

	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	22/06/2020	12:25	98	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	22/06/2020	12:40	97.8	%	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/06/2020	12:05	0.85	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/06/2020	12:25	0.86	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/06/2020	12:40	0.88	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	22/06/2020	12:15	0.45	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	22/06/2020	12:35	0.58	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	22/06/2020	12:50	0.43	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	22/06/2020	12:10	0.07	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	22/06/2020	12:30	0.52	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	22/06/2020	12:45	0.2	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	22/06/2020	12:05	0.15	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	22/06/2020	12:25	0.16	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	22/06/2020	12:40	0.16	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	22/06/2020	12:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	22/06/2020	12:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	22/06/2020	12:15	17	cfu/100ml (17 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	22/06/2020	12:35	19	cfu/100ml (19 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	22/06/2020	12:50	25	cfu/100ml (25 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	22/06/2020	12:15	2	cfu/100mL (2 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	22/06/2020	12:35	1	cfu/100mL (1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	22/06/2020	12:50	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	22/06/2020	12:10	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	22/06/2020	12:30	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0107	Enterococci - Environmental water	22/06/2020	12:45	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	22/06/2020	12:05	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	22/06/2020	12:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	22/06/2020	12:40	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	22/06/2020	12:15	60	MPN/100ml (60.2 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	22/06/2020	12:35	96	MPN/100ml (96.1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114A	Total Coliforms by Colilert-18 MPN 97wells- Enviro Water	22/06/2020	12:50	86	MPN/100ml (86 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	22/06/2020	12:15	12	MPN/100mL (12.2 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	22/06/2020	12:35	16	MPN/100mL (16.1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	22/06/2020	12:50	13	MPN/100mL (13.4 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:10	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:30	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:45	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:05	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:25	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	22/06/2020	12:40	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:10	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:30	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:45	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:05	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/06/2020	12:40	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:10	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:30	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:45	<1	MPN/100ml	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:05	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:25	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/06/2020	12:40	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	24/06/2020	14:25	7.9		(1 - 14)
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	1	pH	24/06/2020	14:05	7.9		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	24/06/2020	14:30	7.9		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	24/06/2020	14:40	7.9		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	24/06/2020	15:15	7.9		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	24/06/2020	14:25	<6	g/m³	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	24/06/2020	14:05	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	24/06/2020	14:30	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	24/06/2020	14:40	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	24/06/2020	15:15	<6	g/m³	

	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	24/06/2020	14:25	3.53	NTU	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	84	Turbidity	24/06/2020	14:05	0.66	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	24/06/2020	14:30	4.02	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	24/06/2020	14:40	0.48	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	24/06/2020	15:15	0.38	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	85	BOD5 - Total	24/06/2020	14:25	<3	g/m³	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	85	BOD5 - Total	24/06/2020	14:05	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	85	BOD5 - Total	24/06/2020	14:30	<3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	85	BOD5 - Total	24/06/2020	14:40	<3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	85	BOD5 - Total	24/06/2020	15:15	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	607	Sulphate - Add P1859 Filtration	24/06/2020	14:25	11.2	g/m³	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	607	Sulphate - Add P1859 Filtration	24/06/2020	14:05	13.8	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	607	Sulphate - Add P1859 Filtration	24/06/2020	14:30	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	24/06/2020	14:40	15.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	607	Sulphate - Add P1859 Filtration	24/06/2020	15:15	16.1	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	24/06/2020	14:25	0.003	g/m³	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	24/06/2020	14:05	0.054	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	24/06/2020	14:30	0.02	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	24/06/2020	14:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	24/06/2020	15:15	0.006	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	24/06/2020	14:25	Completed		
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	24/06/2020	14:05	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	24/06/2020	14:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	24/06/2020	14:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	24/06/2020	15:15	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	24/06/2020	14:25	4.5	Deg C	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	24/06/2020	14:05	4.6	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	24/06/2020	14:30	3.9	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	24/06/2020	14:40	3.1	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	24/06/2020	15:15	2.7	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	24/06/2020	14:25	<0.05	g/m³	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	24/06/2020	14:05	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	24/06/2020	14:30	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	24/06/2020	14:40	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	24/06/2020	15:15	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	24/06/2020	14:25	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1204	Sampling / Inspection 60 Mins	24/06/2020	14:25	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	14:25	4	cfu/100ml (4 x 1)	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	14:05	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	14:30	8	cfu/100ml (8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	14:40	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	15:15	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	24/06/2020	14:25	<4	cfu/100mL (<4 x 1)	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	24/06/2020	14:05	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	24/06/2020	14:30	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	24/06/2020	14:40	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	24/06/2020	15:15	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	14:25	330	MPN/100ml (325.5 x 1)	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	14:05	<1	MPN/100ml (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	14:30	160	MPN/100ml (156.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	14:40	62	MPN/100ml (62.4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	15:15	36	MPN/100ml (35.9 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	14:25	15	MPN/100mL (14.5 x 1)	
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	14:05	<1	MPN/100mL (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	14:30	17	MPN/100mL (17.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	14:40	4	MPN/100mL (4.1 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	15:15	3	MPN/100mL (3.1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	P1859	Sample Filtration	24/06/2020	14:25	Completed		
Sludge Pond 3 Discharge	Waikouaiti WTP - Consent Discharge	P1859	Sample Filtration	24/06/2020	14:05	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	P1859	Sample Filtration	24/06/2020	14:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	24/06/2020	14:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	P1859	Sample Filtration	24/06/2020	15:15	Completed		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	24/06/2020	15:35	92.4	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	24/06/2020	15:50	92.1	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	24/06/2020	16:05	91.8	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	24/06/2020	15:30	98.4	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	24/06/2020	15:45	98.1	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	24/06/2020	16:00	98.4	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	24/06/2020	15:25	98.7	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	24/06/2020	15:40	98.9	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	24/06/2020	15:55	98.8	%	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/06/2020	15:25	0.93	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/06/2020	15:40	1.1	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/06/2020	15:55	1.1	g/m^3	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	24/06/2020	15:35	0.42	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	24/06/2020	15:50	0.42	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	24/06/2020	16:05	0.42	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	24/06/2020	15:30	0.11	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	24/06/2020	15:45	0.06	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	24/06/2020	16:00	0.09	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	24/06/2020	15:25	0.14	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	24/06/2020	15:40	0.16	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	24/06/2020	15:55	0.15	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	24/06/2020	15:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	24/06/2020	15:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	15:35	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	15:50	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	24/06/2020	16:05	12	cfu/100ml (12 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	24/06/2020	15:35	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	24/06/2020	15:50	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	24/06/2020	16:05	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	15:35	61	MPN/100ml (60.5 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	15:50	70	MPN/100ml (70.3 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	24/06/2020	16:05	54	MPN/100ml (53.7 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	15:35	11	MPN/100mL (10.9 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	15:50	10	MPN/100mL (9.8 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	24/06/2020	16:05	7	MPN/100mL (7.2 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	24/06/2020	15:30	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	24/06/2020	15:45	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	24/06/2020	16:00	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	24/06/2020	15:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	24/06/2020	15:40	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	24/06/2020	15:55	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	15:30	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	15:45	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	16:00	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	15:25	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	15:40	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	24/06/2020	15:55	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	15:30	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	15:45	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	16:00	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	15:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	15:40	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/06/2020	15:55	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	15:30	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	15:45	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	16:00	<1	MPN/100ml	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	15:25	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	15:40	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/06/2020	15:55	<1	MPN/100ml	(0 - 0)
	Waikouaiti Pre Treatment	84	Turbidity	26/06/2020	14:00	0.37	NTU	(- 2.5)
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	26/06/2020	14:00	Completed		
	Waikouaiti Pre Treatment	D-M0115B	E. coli by Colilert MPN-18-97 Wells- Environmental Water	26/06/2020	14:00	5	MPN/100mL (5.1 x 1)	

	Karitane Bowls	D-0058H	Free Available Chlorine	26/06/2020	11:00	0.83	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	26/06/2020	11:00	0.9	g/m³	
	Karitane Bowls	D-0084	Turbidity	26/06/2020	11:00	0.21	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	26/06/2020	11:00	6.2	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	26/06/2020	11:00	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	26/06/2020	11:00	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	29/06/2020	13:50	91	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	29/06/2020	15:30	90.7	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	29/06/2020	15:55	90.6	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	29/06/2020	15:20	98.4	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	29/06/2020	15:25	97.2	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	29/06/2020	15:50	97.3	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	29/06/2020	13:45	97.7	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	29/06/2020	15:25	97.9	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	29/06/2020	15:40	97.9	%	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/06/2020	13:45	0.85	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/06/2020	15:25	0.86	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/06/2020	15:40	0.86	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	29/06/2020	13:50	0.47	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	29/06/2020	15:30	0.48	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0084	Turbidity	29/06/2020	15:55	0.52	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	29/06/2020	15:20	0.06	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	29/06/2020	15:25	0.05	NTU	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0084	Turbidity	29/06/2020	15:50	0.06	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	29/06/2020	13:45	0.17	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	29/06/2020	15:25	0.15	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0084	Turbidity	29/06/2020	15:40	0.16	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	13:50	18	cfu/100ml (18 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	15:30	19	cfu/100ml (19 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	15:55	26	cfu/100ml (26 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	29/06/2020	13:50	1	cfu/100mL (1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	29/06/2020	15:30	2	cfu/100mL (2 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	29/06/2020	15:55	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	13:50	86	MPN/100ml (86 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	15:30	58	MPN/100ml (58.1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	15:55	86	MPN/100ml (85.5 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	13:50	17	MPN/100mL (17.1 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	15:30	20	MPN/100mL (19.7 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	15:55	15	MPN/100mL (14.8 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	29/06/2020	15:20	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	29/06/2020	15:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0407	Enterococci - Drinking Water	29/06/2020	15:50	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	29/06/2020	13:45	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	29/06/2020	15:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	29/06/2020	15:40	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	15:20	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	15:25	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	15:50	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	13:45	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	15:25	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	29/06/2020	15:40	<1	cfu/100mL	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	15:20	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	15:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	15:50	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	13:45	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	15:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/06/2020	15:40	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	15:20	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	15:25	<1	MPN/100ml	
	Waikouaiti WTP - Containerised Plant Filtrate	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	15:50	<1	MPN/100ml	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	13:45	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	15:25	<1	MPN/100ml	(0 - 0)

	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/06/2020	15:40	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	29/06/2020	14:15	8		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	29/06/2020	14:00	7.9		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	29/06/2020	14:30	7.9		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	29/06/2020	14:50	8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	29/06/2020	15:15	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	29/06/2020	14:15	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	29/06/2020	14:00	42	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	29/06/2020	14:30	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	29/06/2020	14:50	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	29/06/2020	15:15	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	40	Total Non-Purgeable Organic Carbon	29/06/2020	14:00	2	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	56	Dissolved Oxygen	29/06/2020	14:15	11.7	g O2/m³	
	Waikouaiti WTP - Consent Discharge	56	Dissolved Oxygen	29/06/2020	14:00	11.8	g O2/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	56	Dissolved Oxygen	29/06/2020	14:30	11.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	56	Dissolved Oxygen	29/06/2020	14:50	11.9	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	56	Dissolved Oxygen	29/06/2020	15:15	12	g O2/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	29/06/2020	14:15	2.99	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	29/06/2020	14:00	5.73	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	29/06/2020	14:30	2.66	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	29/06/2020	14:50	1.62	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	29/06/2020	15:15	1.36	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	85	BOD5 - Total	29/06/2020	14:15	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	85	BOD5 - Total	29/06/2020	14:00	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	85	BOD5 - Total	29/06/2020	14:30	<1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	85	BOD5 - Total	29/06/2020	14:50	<1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	85	BOD5 - Total	29/06/2020	15:15	<1	g/m³	
	Waikouaiti WTP - Consent Discharge	440	Dissolved (NP) Organic Carbon	29/06/2020	14:00	1.8	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	607	Sulphate - Add P1859 Filtration	29/06/2020	14:15	11.6	g/m³	
	Waikouaiti WTP - Consent Discharge	607	Sulphate - Add P1859 Filtration	29/06/2020	14:00	14.4	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	607	Sulphate - Add P1859 Filtration	29/06/2020	14:30	11.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	29/06/2020	14:50	9.24	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	607	Sulphate - Add P1859 Filtration	29/06/2020	15:15	9.82	g/m³	
	Waikouaiti WTP - Consent Discharge	1250	Transmissivity @ 253.7nm	29/06/2020	14:00	84.4	%	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	29/06/2020	14:15	0.01	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	29/06/2020	14:00	0.328	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	29/06/2020	14:30	0.009	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	29/06/2020	14:50	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	29/06/2020	15:15	0.007	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	29/06/2020	14:15	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	29/06/2020	14:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	29/06/2020	14:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	29/06/2020	14:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	29/06/2020	15:15	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	29/06/2020	14:15	7.5	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	29/06/2020	14:00	7.6	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	29/06/2020	14:30	7.5	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	29/06/2020	14:50	5.7	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	29/06/2020	15:15	5.4	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	29/06/2020	14:15	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	29/06/2020	14:00	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	29/06/2020	14:30	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	29/06/2020	14:50	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	29/06/2020	15:15	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	29/06/2020	14:15	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1204	Sampling / Inspection 60 Mins	29/06/2020	14:15	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	14:15	46	cfu/100ml (46 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	14:00	<1	cfu/100ml (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	14:30	47	cfu/100ml (47 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	14:50	100	cfu/100ml (100 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	29/06/2020	15:15	88	cfu/100ml (88 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	29/06/2020	14:15	5	cfu/100mL (5 x 1)	

	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	29/06/2020	14:00	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	29/06/2020	14:30	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	29/06/2020	14:50	5	cfu/100mL (5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	29/06/2020	15:15	7	cfu/100mL (7 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	14:15	120	MPN/100ml (123.2 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	14:00	110	MPN/100ml (108.6 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	14:30	210	MPN/100ml (207.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	14:50	250	MPN/100ml (250 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	29/06/2020	15:15	390	MPN/100ml (387.3 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	14:15	28	MPN/100mL (27.8 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	14:00	<1	MPN/100mL (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	14:30	44	MPN/100mL (43.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	14:50	70	MPN/100mL (69.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	29/06/2020	15:15	96	MPN/100mL (95.9 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	P1859	Sample Filtration	29/06/2020	14:15	Completed		
	Waikouaiti WTP - Consent Discharge	P1859	Sample Filtration	29/06/2020	14:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	P1859	Sample Filtration	29/06/2020	14:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	29/06/2020	14:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	P1859	Sample Filtration	29/06/2020	15:15	Completed		
	Waikouaiti WTP - Consent Discharge	SC023	ADBP - Halogenated Acetic Acids	29/06/2020	14:00	Attached		
	Waikouaiti WTP - Consent Discharge	SC024	NDBP - Halogenated Volatile Disinfection By-Products	29/06/2020	14:00	Attached		

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	TAB Waikouaiti	D-0058H	Free Available Chlorine	02/07/2020	13:35	1.1	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	02/07/2020	13:35	1.1	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	02/07/2020	13:35	0.26	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	02/07/2020	13:35	4.7	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	02/07/2020	13:35	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	02/07/2020	13:35	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	08/07/2020	12:55	8		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	08/07/2020	14:00	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	08/07/2020	13:10	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	08/07/2020	13:25	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	08/07/2020	13:45	7.6		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	08/07/2020	12:55	<5	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	08/07/2020	14:00	24	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	08/07/2020	13:10	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	08/07/2020	13:25	9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	08/07/2020	13:45	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	08/07/2020	12:55	2.63	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	08/07/2020	14:00	21.1	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	08/07/2020	13:10	2.46	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	08/07/2020	13:25	3.11	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	08/07/2020	13:45	2.52	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	08/07/2020	12:55	0.013	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	08/07/2020	14:00	3.72	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	08/07/2020	13:10	0.034	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	08/07/2020	13:25	0.092	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	08/07/2020	13:45	0.079	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	08/07/2020	12:55	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	08/07/2020	14:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	08/07/2020	13:10	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	08/07/2020	13:25	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	08/07/2020	13:45	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	08/07/2020	12:55	9.5	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	08/07/2020	14:00	10.2	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	08/07/2020	13:10	9.7	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	08/07/2020	13:25	9.5	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	08/07/2020	13:45	10.1	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	08/07/2020	12:55	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	08/07/2020	14:00	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	08/07/2020	13:10	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	08/07/2020	13:25	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	08/07/2020	13:45	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1206	Sampling / Inspection 3 hours	08/07/2020	12:55	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	08/07/2020	12:55	34	cfu/100ml (34 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	08/07/2020	14:00	8	cfu/100ml (8 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	08/07/2020	13:10	43	cfu/100ml (43 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	08/07/2020	13:25	120	cfu/100ml (124 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	08/07/2020	13:45	150	cfu/100ml (146 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	08/07/2020	12:55	5	cfu/100mL (5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	08/07/2020	14:00	3	cfu/100mL (3 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	08/07/2020	13:10	6	cfu/100mL (6 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	08/07/2020	13:25	40	cfu/100mL (40 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	08/07/2020	13:45	24	cfu/100mL (24 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/07/2020	12:55	520	MPN/100ml (517.2 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/07/2020	14:00	160	MPN/100ml (163.8 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/07/2020	13:10	240	MPN/100ml (241.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/07/2020	13:25	380	MPN/100ml (381.1 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/07/2020	13:45	240	MPN/100ml (244.5 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/07/2020	12:55	36	MPN/100mL (35.9 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/07/2020	14:00	6	MPN/100mL (6.3 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/07/2020	13:10	41	MPN/100mL (40.8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/07/2020	13:25	100	MPN/100mL (104.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/07/2020	13:45	73	MPN/100mL (72.8 x 1)	
	Karitane Bowls	D-0058H	Free Available Chlorine	09/07/2020	09:05	0.82	g/m³	(.2 - 5)

	Karitane Bowls	D-0066H	Total Chlorine	09/07/2020	09:05	0.8	g/m³	
	Karitane Bowls	D-0084	Turbidity	09/07/2020	09:05	0.2	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	09/07/2020	09:05	6.1	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/07/2020	09:05	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/07/2020	09:05	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	17/07/2020	10:40	7.6		(1 - 14)
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	1	pH	17/07/2020	10:20	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	17/07/2020	10:50	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	17/07/2020	11:05	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	17/07/2020	11:30	7.7		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	17/07/2020	10:40	<6	g/m³	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	17/07/2020	10:20	13	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	17/07/2020	10:50	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	17/07/2020	11:05	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	17/07/2020	11:30	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	17/07/2020	10:40	2.55	NTU	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	84	Turbidity	17/07/2020	10:20	10.9	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	17/07/2020	10:50	1.5	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	17/07/2020	11:05	0.48	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	17/07/2020	11:30	0.51	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	17/07/2020	10:40	0.005	g/m³	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	17/07/2020	10:20	2.57	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	17/07/2020	10:50	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	17/07/2020	11:05	0.009	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	17/07/2020	11:30	0.007	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	17/07/2020	10:40	Completed		
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	17/07/2020	10:20	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	17/07/2020	10:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	17/07/2020	11:05	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	17/07/2020	11:30	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	17/07/2020	10:40	1.5	Deg C	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	17/07/2020	10:20	1.8	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	17/07/2020	10:50	1.3	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	17/07/2020	11:05	2.6	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	17/07/2020	11:30	2.4	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	17/07/2020	10:40	<0.05	g/m³	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	17/07/2020	10:20	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	17/07/2020	10:50	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	17/07/2020	11:05	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	17/07/2020	11:30	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	17/07/2020	10:40	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1205	Sampling / Inspection 2 hours	17/07/2020	10:40	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	17/07/2020	10:40	8	cfu/100ml (8 x 1)	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	17/07/2020	10:20	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	17/07/2020	10:50	8	cfu/100ml (8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	17/07/2020	11:05	15	cfu/100ml (15.3846153846 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	17/07/2020	11:30	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	17/07/2020	10:40	<4	cfu/100mL (<4 x 1)	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	17/07/2020	10:20	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	17/07/2020	10:50	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	17/07/2020	11:05	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	17/07/2020	11:30	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	17/07/2020	10:40	160	MPN/100ml (159.7 x 1)	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	17/07/2020	10:20	33	MPN/100ml (32.7 x 1)	

	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	17/07/2020	10:50	150	MPN/100ml (150 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	17/07/2020	11:05	93	MPN/100ml (93.2 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	17/07/2020	11:30	93	MPN/100ml (93.3 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	17/07/2020	10:40	11	MPN/100mL (10.9 x 1)	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	17/07/2020	10:20	<1	MPN/100mL (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	17/07/2020	10:50	12	MPN/100mL (11.9 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	17/07/2020	11:05	9	MPN/100mL (8.6 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	17/07/2020	11:30	5	MPN/100mL (5.2 x 1)	
Sample taken from bottom of sump due to no flow at the	Waikouaiti WTP - Consent Discharge	O1420	Sampler Observation	17/07/2020	10:20	Sample	taken from bottom of sump due to no flow at the discharge pipe	
	Waikouaiti Pre Treatment	84	Turbidity	24/07/2020	10:00	0.43	NTU	(- 2.5)
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	24/07/2020	10:00	Completed		
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	10:00	10	MPN/100mL (9.7 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	24/07/2020	08:45	7.6		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	24/07/2020	09:50	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	24/07/2020	09:00	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	24/07/2020	09:15	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	24/07/2020	09:35	7.7		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	24/07/2020	08:45	9	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	24/07/2020	09:50	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	24/07/2020	09:00	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	24/07/2020	09:15	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	24/07/2020	09:35	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	24/07/2020	08:45	2.63	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	24/07/2020	09:50	4.26	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	24/07/2020	09:00	1.13	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	24/07/2020	09:15	0.46	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	24/07/2020	09:35	0.44	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	24/07/2020	08:45	0.004	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	24/07/2020	09:50	1.59	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	24/07/2020	09:00	0.003	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	24/07/2020	09:15	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	24/07/2020	09:35	0.005	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	24/07/2020	08:45	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	24/07/2020	09:50	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	24/07/2020	09:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	24/07/2020	09:15	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	24/07/2020	09:35	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	24/07/2020	08:45	2.1	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	24/07/2020	09:50	3.7	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	24/07/2020	09:00	2.1	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	24/07/2020	09:15	2.7	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	24/07/2020	09:35	2.6	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	24/07/2020	08:45	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	24/07/2020	09:50	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	24/07/2020	09:00	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	24/07/2020	09:15	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	24/07/2020	09:35	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	24/07/2020	08:45	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1205	Sampling / Inspection 2 hours	24/07/2020	08:45	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/07/2020	08:45	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	24/07/2020	09:50	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/07/2020	09:00	12	cfu/100ml (12 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/07/2020	09:15	8	cfu/100ml (8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	24/07/2020	09:35	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	24/07/2020	08:45	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	24/07/2020	09:50	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	24/07/2020	09:00	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	24/07/2020	09:15	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	24/07/2020	09:35	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	24/07/2020	08:45	220	MPN/100ml (218.7 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	24/07/2020	09:50	150	MPN/100ml (145 x 1)	

	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	24/07/2020	09:00	310	MPN/100ml (307.6 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	24/07/2020	09:15	120	MPN/100ml (124.6 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	24/07/2020	09:35	96	MPN/100ml (95.9 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	08:45	9	MPN/100mL (8.5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	09:50	<1	MPN/100mL (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	09:00	7	MPN/100mL (7.4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	09:15	8	MPN/100mL (7.5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	24/07/2020	09:35	11	MPN/100mL (10.9 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	31/07/2020	13:30	7.7		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	31/07/2020	13:00	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	31/07/2020	13:40	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	31/07/2020	13:50	7.9		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	31/07/2020	14:10	7.8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	31/07/2020	13:30	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	31/07/2020	13:00	20	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	31/07/2020	13:40	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	31/07/2020	13:50	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	31/07/2020	14:10	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	56	Dissolved Oxygen	31/07/2020	13:40	11.3	g O2/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	31/07/2020	13:30	3.95	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	31/07/2020	13:00	7.98	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	31/07/2020	13:40	1.6	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	31/07/2020	13:50	0.42	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	31/07/2020	14:10	0.46	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	85	BOD5 - Total	31/07/2020	13:40	<3	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	607	Sulphate - Add P1859 Filtration	31/07/2020	13:40	13.8	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	31/07/2020	13:30	0.008	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	31/07/2020	13:00	4.15	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	31/07/2020	13:40	0.037	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	31/07/2020	13:50	0.004	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	31/07/2020	14:10	0.004	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	31/07/2020	13:30	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	31/07/2020	13:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	31/07/2020	13:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	31/07/2020	13:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	31/07/2020	14:10	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	31/07/2020	13:30	6.9	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	31/07/2020	13:00	9.8	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	31/07/2020	13:40	6.8	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	31/07/2020	13:50	4.9	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	31/07/2020	14:10	5.1	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	31/07/2020	13:30	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	31/07/2020	13:00	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	31/07/2020	13:40	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	31/07/2020	13:50	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	31/07/2020	14:10	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	31/07/2020	13:30	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1205	Sampling / Inspection 2 hours	31/07/2020	13:30	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	31/07/2020	13:30	28	cfu/100ml (28 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	31/07/2020	13:00	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	31/07/2020	13:40	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	31/07/2020	13:50	8	cfu/100ml (8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	31/07/2020	14:10	16	cfu/100ml (16 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	31/07/2020	13:30	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	31/07/2020	13:00	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	31/07/2020	13:40	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	31/07/2020	13:50	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	31/07/2020	14:10	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	31/07/2020	13:30	270	MPN/100ml (272.3 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	31/07/2020	13:00	43	MPN/100ml (42.8 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	31/07/2020	13:40	390	MPN/100ml (387.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	31/07/2020	13:50	68	MPN/100ml (68.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Wate	31/07/2020	14:10	44	MPN/100ml (43.5 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Wate	31/07/2020	13:30	19	MPN/100mL (18.7 x 1)	

	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	31/07/2020	13:00	3	MPN/100mL (3.1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	31/07/2020	13:40	11	MPN/100mL (11 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	31/07/2020	13:50	9	MPN/100mL (8.6 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	31/07/2020	14:10	3	MPN/100mL (3.1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	P1859	Sample Filtration	31/07/2020	13:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	31/07/2020	12:35	7.7		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	31/07/2020	12:20	7.6		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	31/07/2020	12:40	7.7		(1 - 14)
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	31/07/2020	11:50	7.6		(1 - 14)
	Karitane Bowls	1	pH	31/07/2020	10:50	7.8		(1 - 14)
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	1	pH	31/07/2020	15:10	7.8		(1 - 14)
	TAB Waikouaiti	1	pH	31/07/2020	14:40	7.7		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	40	Total Non-Purgeable Organic Carbon	31/07/2020	12:35	1.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	40	Total Non-Purgeable Organic Carbon	31/07/2020	12:20	1.3	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	40	Total Non-Purgeable Organic Carbon	31/07/2020	12:40	1.6	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	40	Total Non-Purgeable Organic Carbon	31/07/2020	11:50	1	g/m³	
	Karitane Bowls	40	Total Non-Purgeable Organic Carbon	31/07/2020	10:50	0.9	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	40	Total Non-Purgeable Organic Carbon	31/07/2020	15:10	1.4	g/m³	
	Karitane Bowls	52	Alkalinity - Total	31/07/2020	10:50	49	g CaCO3/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	52	Alkalinity - Total	31/07/2020	15:10	48	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	31/07/2020	14:40	49	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	440	Dissolved (NP) Organic Carbon	31/07/2020	12:35	2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	440	Dissolved (NP) Organic Carbon	31/07/2020	12:20	1.4	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	440	Dissolved (NP) Organic Carbon	31/07/2020	12:40	0.9	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	440	Dissolved (NP) Organic Carbon	31/07/2020	11:50	1	g/m³	
	Karitane Bowls	440	Dissolved (NP) Organic Carbon	31/07/2020	10:50	1	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	440	Dissolved (NP) Organic Carbon	31/07/2020	15:10	1.3	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	31/07/2020	10:50	13.1	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	31/07/2020	15:10	12.5	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	31/07/2020	14:40	13	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	31/07/2020	12:35	0.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	601	Fluoride - Add P1859 Filtration	31/07/2020	12:20	0.09	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	31/07/2020	11:50	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	31/07/2020	12:35	11.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	31/07/2020	12:20	12.9	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	31/07/2020	11:50	14.2	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	31/07/2020	10:50	14.4	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	31/07/2020	15:10	14.6	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	31/07/2020	14:40	14.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	31/07/2020	12:35	0.02	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	605	Nitrate - Nitrogen - Add P1859 Filtration	31/07/2020	12:20	0.01	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	31/07/2020	11:50	0.02	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	31/07/2020	12:35	11.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	31/07/2020	12:20	11.5	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	31/07/2020	11:50	11.4	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	31/07/2020	10:50	11.5	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	31/07/2020	15:10	11.5	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	31/07/2020	14:40	11.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	708	Bromate - Ultra Trace	31/07/2020	12:35	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	708	Bromate - Ultra Trace	31/07/2020	12:20	<0.005	g/m³	

During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	708	Bromate - Ultra Trace	31/07/2020	11:50	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	31/07/2020	12:35	88.2	%	
	Waikouaiti WTP - Containerised Plant Filtrate	1250	Transmissivity @ 253.7nm	31/07/2020	12:20	95.9	%	
	Waikouaiti WTP - Supernatant Tube Settler	1250	Transmissivity @ 253.7nm	31/07/2020	12:40	88.7	%	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	31/07/2020	11:50	97	%	
	Karitane Bowls	1250	Transmissivity @ 253.7nm	31/07/2020	10:50	94.8	%	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	1250	Transmissivity @ 253.7nm	31/07/2020	15:10	77.9	%	
	TAB Waikouaiti	1250	Transmissivity @ 253.7nm	31/07/2020	14:40	96.3	%	
	Karitane Bowls	1643	Silica by OES	31/07/2020	10:50	4.3	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	1643	Silica by OES	31/07/2020	15:10	5	g/m³	
	TAB Waikouaiti	1643	Silica by OES	31/07/2020	14:40	4.22	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	31/07/2020	12:20	0.005	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	31/07/2020	11:50	0.005	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	31/07/2020	10:50	0.005	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	31/07/2020	15:10	0.093	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	31/07/2020	14:40	0.006	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6002	Antimony - Acid Soluble	31/07/2020	12:20	<0.001	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	31/07/2020	11:50	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	31/07/2020	12:20	<0.001	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	31/07/2020	11:50	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6004	Barium - Acid Soluble	31/07/2020	12:20	0.01	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	31/07/2020	11:50	0.009	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6007	Boron - Acid Soluble	31/07/2020	12:20	<0.03	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	31/07/2020	11:50	<0.03	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	31/07/2020	12:20	<0.0002	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	31/07/2020	11:50	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	31/07/2020	12:20	14.9	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	31/07/2020	11:50	14.5	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	31/07/2020	10:50	14.9	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	31/07/2020	15:10	14.8	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	31/07/2020	14:40	14.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	31/07/2020	12:20	<0.001	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	31/07/2020	11:50	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	31/07/2020	12:20	<0.0005	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	31/07/2020	11:50	0.0011	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	31/07/2020	10:50	0.0092	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6013	Copper - Acid Soluble	31/07/2020	15:10	0.291	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	31/07/2020	14:40	0.0587	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	31/07/2020	12:20	<0.01	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	31/07/2020	11:50	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	31/07/2020	10:50	<0.01	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6017	Iron - Acid Soluble	31/07/2020	15:10	2.8	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	31/07/2020	14:40	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	31/07/2020	12:20	<0.0005	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	31/07/2020	11:50	0.0008	g/m³	

	Karitane Bowls	6018	Lead - Acid Soluble	31/07/2020	10:50	<0.0005	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6018	Lead - Acid Soluble	31/07/2020	15:10	0.0295	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	31/07/2020	14:40	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	31/07/2020	12:20	6.66	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	31/07/2020	11:50	6.55	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	31/07/2020	10:50	6.32	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	31/07/2020	15:10	6.01	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	31/07/2020	14:40	6.52	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	31/07/2020	12:20	0.0099	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	31/07/2020	11:50	0.0086	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	31/07/2020	10:50	0.002	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	31/07/2020	15:10	0.0702	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	31/07/2020	14:40	0.0105	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	31/07/2020	12:20	<0.0005	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	31/07/2020	11:50	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	31/07/2020	12:20	<0.0005	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	31/07/2020	11:50	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	31/07/2020	10:50	<0.0005	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	31/07/2020	15:10	0.0008	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	31/07/2020	14:40	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	31/07/2020	12:20	<0.002	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	31/07/2020	11:50	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6031	Sodium - Acid Soluble	31/07/2020	12:20	9.9	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	31/07/2020	11:50	10.4	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	31/07/2020	10:50	0.015	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	31/07/2020	15:10	0.121	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	31/07/2020	14:40	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	31/07/2020	12:35	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6602	Antimony - Total	31/07/2020	12:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	31/07/2020	12:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6604	Barium - Total	31/07/2020	12:35	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6607	Boron - Total	31/07/2020	12:35	<0.05	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	31/07/2020	12:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	31/07/2020	12:35	15.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	31/07/2020	12:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	31/07/2020	12:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	31/07/2020	12:35	0.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	31/07/2020	12:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	31/07/2020	12:35	6.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	31/07/2020	12:35	0.012	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	31/07/2020	12:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	31/07/2020	12:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	31/07/2020	12:35	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6631	Sodium - Total	31/07/2020	12:35	9.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9403	ICP-MS - 3 Elements	31/07/2020	12:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9407	ICP-MS - 7 Elements	31/07/2020	12:20	Completed		
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	9407	ICP-MS - 7 Elements	31/07/2020	11:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	31/07/2020	12:35	4.6	Deg C	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0053F	Temperature - Field	31/07/2020	12:20	4.6	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	31/07/2020	12:40	5.7	Deg C	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	31/07/2020	11:50	7.8	Deg C	

	Karitane Bowls	D-0053F	Temperature - Field	31/07/2020	10:50	7	Deg C	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	D-0053F	Temperature - Field	31/07/2020	15:10	8.8	Deg C	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	31/07/2020	10:50	14.1	g O2/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	31/07/2020	15:10	11	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	31/07/2020	14:40	12	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0058H	Free Available Chlorine	31/07/2020	12:35	<0.05	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	31/07/2020	12:20	<0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	31/07/2020	12:40	<0.05	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	31/07/2020	11:50	0.53	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	31/07/2020	10:50	0.47	g/m³	(.2 - 5)
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	31/07/2020	15:10	0.14	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	31/07/2020	14:40	0.52	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0066H	Total Chlorine	31/07/2020	12:35	<0.05	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	31/07/2020	12:20	<0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	31/07/2020	12:40	<0.05	g/m³	
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	31/07/2020	11:50	0.5	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	31/07/2020	10:50	0.5	g/m³	
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	D-0066H	Total Chlorine	31/07/2020	15:10	0.2	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	31/07/2020	14:40	0.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	31/07/2020	12:35	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	31/07/2020	12:35	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	12:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	12:20	Completed		
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	11:50	Completed		
	Karitane Bowls	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	10:50	Completed		
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	15:10	Completed		
	TAB Waikouaiti	P1855	Aqueous Total Metal Digestion for ICPMS codes	31/07/2020	14:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	31/07/2020	12:35	Complete		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	31/07/2020	12:20	Complete		
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	31/07/2020	11:50	Complete		
	Karitane Bowls	P1859	Sample Filtration	31/07/2020	10:50	Complete		
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	P1859	Sample Filtration	31/07/2020	15:10	Complete		
	TAB Waikouaiti	P1859	Sample Filtration	31/07/2020	14:40	Complete		
	Karitane Bowls	Prob1	Problem Sample - INITIAL VALIDATION HERE:	31/07/2020	10:50	Resolved		
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	Prob1	Problem Sample - INITIAL VALIDATION HERE:	31/07/2020	15:10	Resolved		
	TAB Waikouaiti	Prob1	Problem Sample - INITIAL VALIDATION HERE:	31/07/2020	14:40	Resolved		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	12:35	Attached		
	Waikouaiti WTP - Containerised Plant Filtrate	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	12:20	Attached		
	Waikouaiti WTP - Supernatant Tube Settler	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	12:40	Attached		
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	11:50	Attached		
	Karitane Bowls	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	10:50	Attached		
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	SC023	ADBP - Halogenated Acetic Acids	31/07/2020	15:10	Attached		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	12:35	Attached		
	Waikouaiti WTP - Containerised Plant Filtrate	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	12:20	Attached		
	Waikouaiti WTP - Supernatant Tube Settler	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	12:40	Attached		
During flushing water ran orange for 3 seconds at start of	Waikouaiti WTP - Post Treated Water Reservoir	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	11:50	Attached		
	Karitane Bowls	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	10:50	Attached		
Yellow in apperance. 5 Minute flush	Waikouaiti Golf Club	SC024	NDBP - Halogenated Volatile Disinfection By-Products	31/07/2020	15:10	Attached		
	Karitane Bowls	D-0058H	Free Available Chlorine	31/07/2020	10:50	0.47	g/m³	(.2 - 5)

	Karitane Bowls	D-0066H	Total Chlorine	31/07/2020	10:50	0.5	g/m³	
	Karitane Bowls	D-0084	Turbidity	31/07/2020	10:50	0.09	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	31/07/2020	10:50	6.1	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	31/07/2020	10:50	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	31/07/2020	10:50	<1	MPN/100ml	(0 - 0)

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	TAB Waikouaiti	D-0058H	Free Available Chlorine	06/08/2020	14:20	0.4	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	06/08/2020	14:20	0.6	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	06/08/2020	14:20	0.14	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	06/08/2020	14:20	8.6	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	06/08/2020	14:20	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	06/08/2020	14:20	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	07/08/2020	11:20	7.9		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	07/08/2020	11:05	7.6		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	07/08/2020	11:30	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	07/08/2020	11:40	7.9		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	07/08/2020	12:10	7.9		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	07/08/2020	11:20	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	07/08/2020	11:05	11	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	07/08/2020	11:30	31	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	07/08/2020	11:40	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	07/08/2020	12:10	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	07/08/2020	11:20	2.42	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	07/08/2020	11:05	2.07	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	07/08/2020	11:30	9.54	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	07/08/2020	11:40	0.57	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	07/08/2020	12:10	0.64	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	07/08/2020	11:20	0.007	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	07/08/2020	11:05	5.77	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	07/08/2020	11:30	0.224	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	07/08/2020	11:40	0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	07/08/2020	12:10	0.004	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	07/08/2020	11:20	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	07/08/2020	11:05	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	07/08/2020	11:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	07/08/2020	11:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	07/08/2020	12:10	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	07/08/2020	11:20	6.3	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	07/08/2020	11:05	8.8	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	07/08/2020	11:30	6.5	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	07/08/2020	11:40	5.8	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	07/08/2020	12:10	5.9	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	07/08/2020	11:20	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	07/08/2020	11:05	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	07/08/2020	11:30	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	07/08/2020	11:40	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	07/08/2020	12:10	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	07/08/2020	11:20	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1205	Sampling / Inspection 2 hours	07/08/2020	11:20	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	07/08/2020	11:20	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	07/08/2020	11:05	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	07/08/2020	11:30	16	cfu/100ml (16 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	07/08/2020	11:40	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	07/08/2020	12:10	20	cfu/100ml (20 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	07/08/2020	11:20	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	07/08/2020	11:05	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	07/08/2020	11:30	8	cfu/100mL (8 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	07/08/2020	11:40	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	07/08/2020	12:10	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/08/2020	11:20	2,400	MPN/100ml (2419.6 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/08/2020	11:05	<1	MPN/100ml (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/08/2020	11:30	290	MPN/100ml (290.9 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/08/2020	11:40	63	MPN/100ml (62.7 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/08/2020	12:10	110	MPN/100ml (111.2 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/08/2020	11:20	15	MPN/100mL (14.5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/08/2020	11:05	<1	MPN/100mL (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/08/2020	11:30	12	MPN/100mL (12.2 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/08/2020	11:40	6	MPN/100mL (6.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/08/2020	12:10	8	MPN/100mL (8.4 x 1)	
	Waikouaiti Pumping Main	1	pH	14/08/2020	09:30	7.8		(1 - 14)
	Waikouaiti Pumping Main	52	Alkalinity - Total	14/08/2020	09:30	67	g CaCO3/m³	
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	14/08/2020	09:30	19.7	mS/m (196.7 x .1)	
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	14/08/2020	09:30	0.02	g/m³	
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	14/08/2020	09:30	106	g/m³	

	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	14/08/2020	09:30	17	g/m³	
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	14/08/2020	09:30	7.54	g/m³	
	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	14/08/2020	09:30	73	g CaCO3/m³	
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	14/08/2020	09:30	42	g CaCO3/m³	
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	14/08/2020	09:30	<0.005	g/m³	
	Waikouaiti Pumping Main	P1859	Sample Filtration	14/08/2020	09:30	Completed		
	Waikouaiti Pumping Main	Prob1	Problem Sample - INITIAL VALIDATION HERE:	14/08/2020	09:30	Problem	resolved and closed.	
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	14/08/2020	09:30	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	14/08/2020	09:30	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH031	MCPA in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH034	MCPB in water	14/08/2020	09:30	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH043	Picloram in water	14/08/2020	09:30	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	14/08/2020	09:30	<0.0005	mg/L	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	14/08/2020	10:00	7.7		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	14/08/2020	09:25	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	14/08/2020	09:50	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	14/08/2020	10:10	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	14/08/2020	09:40	7.9		(1 - 14)
	Waikouaiti WTP - Sludge Pond 3 Discharge	1	pH	14/08/2020	09:10	8.1		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	14/08/2020	10:00	<5	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	14/08/2020	09:25	<5	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	14/08/2020	09:50	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	14/08/2020	10:10	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	14/08/2020	09:40	<5	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	2	Suspended Solids - Total	14/08/2020	09:10	5	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	14/08/2020	10:00	2.72	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	14/08/2020	09:25	0.24	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	14/08/2020	09:50	2.09	NTU	
	Waikouaiti WTP - Waikouaiti River ? Upstream	84	Turbidity	14/08/2020	10:10	0.62	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	14/08/2020	09:40	0.44	NTU	
	Waikouaiti WTP - Sludge Pond 3 Discharge	84	Turbidity	14/08/2020	09:10	0.8	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	14/08/2020	10:00	0.01	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	14/08/2020	09:25	0.368	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	14/08/2020	09:50	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6001	Aluminium - Acid Soluble	14/08/2020	10:10	0.004	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	14/08/2020	09:40	0.003	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	6001	Aluminium - Acid Soluble	14/08/2020	09:10	6.55	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	14/08/2020	10:00	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	14/08/2020	09:25	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	14/08/2020	09:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9401	ICP-MS - 1 Element	14/08/2020	10:10	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	14/08/2020	09:40	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	9401	ICP-MS - 1 Element	14/08/2020	09:10	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	14/08/2020	10:00	2.7	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	14/08/2020	09:25	7	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	14/08/2020	09:50	3.3	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	14/08/2020	10:10	4.1	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	14/08/2020	09:40	3.6	Deg C	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0053F	Temperature - Field	14/08/2020	09:10	3.6	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	14/08/2020	10:00	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	14/08/2020	09:25	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	14/08/2020	09:50	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0058H	Free Available Chlorine	14/08/2020	10:10	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	14/08/2020	09:40	<0.05	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0058H	Free Available Chlorine	14/08/2020	09:10	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1202	Sampling / Inspection 30 Mins	14/08/2020	10:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-1205	Sampling / Inspection 2 hours	14/08/2020	10:00	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	10:00	15	cfu/100ml (15.3846153846 x 1)	

	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	09:25	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	09:50	12	cfu/100ml (12 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	10:10	12	cfu/100ml (12 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	09:40	27	cfu/100ml (26.9230769231 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	14/08/2020	09:10	4	cfu/100ml (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	14/08/2020	10:00	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	14/08/2020	09:25	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	14/08/2020	09:50	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0107	Enterococci - Environmental water	14/08/2020	10:10	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	14/08/2020	09:40	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0107	Enterococci - Environmental water	14/08/2020	09:10	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	10:00	550	MPN/100ml (547.5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	09:25	2	MPN/100ml (2 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	09:50	520	MPN/100ml (517.2 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	10:10	130	MPN/100ml (133.3 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	09:40	130	MPN/100ml (127.4 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/08/2020	09:10	220	MPN/100ml (224.7 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	10:00	26	MPN/100mL (25.9 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	09:25	<1	MPN/100mL (0 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	09:50	19	MPN/100mL (18.9 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	10:10	16	MPN/100mL (16.1 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	09:40	15	MPN/100mL (14.5 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/08/2020	09:10	5	MPN/100mL (5.2 x 1)	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	602	Chloride - Add P1859 Filtration	14/08/2020	14:10	14.7	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	602	Chloride - Add P1859 Filtration	14/08/2020	14:20	14.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	602	Chloride - Add P1859 Filtration	14/08/2020	14:30	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	602	Chloride - Add P1859 Filtration	14/08/2020	14:40	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	602	Chloride - Add P1859 Filtration	14/08/2020	14:50	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	607	Sulphate - Add P1859 Filtration	14/08/2020	14:10	11.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	607	Sulphate - Add P1859 Filtration	14/08/2020	14:20	11.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	607	Sulphate - Add P1859 Filtration	14/08/2020	14:30	11.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	607	Sulphate - Add P1859 Filtration	14/08/2020	14:40	11.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	607	Sulphate - Add P1859 Filtration	14/08/2020	14:50	11.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6001	Aluminium - Acid Soluble	14/08/2020	14:10	0.043	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6001	Aluminium - Acid Soluble	14/08/2020	14:20	0.035	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6001	Aluminium - Acid Soluble	14/08/2020	14:30	0.026	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6001	Aluminium - Acid Soluble	14/08/2020	14:40	0.028	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6001	Aluminium - Acid Soluble	14/08/2020	14:50	0.024	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6010	Calcium - Acid Soluble	14/08/2020	14:10	18.3	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6010	Calcium - Acid Soluble	14/08/2020	14:20	18.1	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6010	Calcium - Acid Soluble	14/08/2020	14:30	19.1	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6010	Calcium - Acid Soluble	14/08/2020	14:40	17.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6010	Calcium - Acid Soluble	14/08/2020	14:50	18.1	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6013	Copper - Acid Soluble	14/08/2020	14:10	0.0012	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6013	Copper - Acid Soluble	14/08/2020	14:20	0.0006	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6013	Copper - Acid Soluble	14/08/2020	14:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6013	Copper - Acid Soluble	14/08/2020	14:40	0.0006	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6013	Copper - Acid Soluble	14/08/2020	14:50	0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6017	Iron - Acid Soluble	14/08/2020	14:10	1.22	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6017	Iron - Acid Soluble	14/08/2020	14:20	1.7	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6017	Iron - Acid Soluble	14/08/2020	14:30	1.01	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6017	Iron - Acid Soluble	14/08/2020	14:40	0.98	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6017	Iron - Acid Soluble	14/08/2020	14:50	0.93	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6018	Lead - Acid Soluble	14/08/2020	14:10	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6018	Lead - Acid Soluble	14/08/2020	14:20	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6018	Lead - Acid Soluble	14/08/2020	14:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6018	Lead - Acid Soluble	14/08/2020	14:40	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6018	Lead - Acid Soluble	14/08/2020	14:50	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6020	Magnesium - Acid Soluble	14/08/2020	14:10	7.03	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6020	Magnesium - Acid Soluble	14/08/2020	14:20	6.88	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6020	Magnesium - Acid Soluble	14/08/2020	14:30	7.35	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6020	Magnesium - Acid Soluble	14/08/2020	14:40	7.51	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6020	Magnesium - Acid Soluble	14/08/2020	14:50	7.49	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6021	Manganese - Acid Soluble	14/08/2020	14:10	0.0407	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6021	Manganese - Acid Soluble	14/08/2020	14:20	0.0761	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6021	Manganese - Acid Soluble	14/08/2020	14:30	0.0311	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6021	Manganese - Acid Soluble	14/08/2020	14:40	0.0356	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6021	Manganese - Acid Soluble	14/08/2020	14:50	0.0341	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6024	Nickel - Acid Soluble	14/08/2020	14:10	<0.0005	g/m³	

	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6024	Nickel - Acid Soluble	14/08/2020	14:20	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6024	Nickel - Acid Soluble	14/08/2020	14:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6024	Nickel - Acid Soluble	14/08/2020	14:40	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6024	Nickel - Acid Soluble	14/08/2020	14:50	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6038	Zinc - Acid Soluble	14/08/2020	14:10	0.003	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6038	Zinc - Acid Soluble	14/08/2020	14:20	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6038	Zinc - Acid Soluble	14/08/2020	14:30	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6038	Zinc - Acid Soluble	14/08/2020	14:40	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6038	Zinc - Acid Soluble	14/08/2020	14:50	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	P1859	Sample Filtration	14/08/2020	14:10	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	P1859	Sample Filtration	14/08/2020	14:20	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	P1859	Sample Filtration	14/08/2020	14:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	P1859	Sample Filtration	14/08/2020	14:40	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	P1859	Sample Filtration	14/08/2020	14:50	Completed		
	Waikouaiti Pre Treatment	D-0084	Turbidity	18/08/2020	11:25	0.44	NTU	
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	18/08/2020	11:25	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	18/08/2020	11:02	0.76	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	18/08/2020	11:02	0.9	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	18/08/2020	11:02	0.1	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	18/08/2020	11:02	4.6	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	18/08/2020	11:02	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	18/08/2020	11:02	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Sludge Pond 3 Discharge	1	pH	20/08/2020	08:10	7.8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Upstream	1	pH	20/08/2020	08:40	7.6		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	20/08/2020	08:25	8		(1 - 14)
	Waikouaiti WTP - Discharge to Tributary ? Downstream	1	pH	20/08/2020	08:55	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	20/08/2020	09:20	7.7		(1 - 14)
	Waikouaiti WTP - Sludge Pond 3 Discharge	2	Suspended Solids - Total	20/08/2020	08:10	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	2	Suspended Solids - Total	20/08/2020	08:40	<6	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	20/08/2020	08:25	<6	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	2	Suspended Solids - Total	20/08/2020	08:55	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	20/08/2020	09:20	<6	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	84	Turbidity	20/08/2020	08:10	0.84	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	84	Turbidity	20/08/2020	08:40	2.41	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	20/08/2020	08:25	0.18	NTU	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	84	Turbidity	20/08/2020	08:55	1.31	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	20/08/2020	09:20	0.74	NTU	
	Waikouaiti WTP - Sludge Pond 3 Discharge	6001	Aluminium - Acid Soluble	20/08/2020	08:10	3.13	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	6001	Aluminium - Acid Soluble	20/08/2020	08:40	0.003	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	20/08/2020	08:25	0.033	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	6001	Aluminium - Acid Soluble	20/08/2020	08:55	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	20/08/2020	09:20	0.004	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	9401	ICP-MS - 1 Element	20/08/2020	08:10	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Upstream	9401	ICP-MS - 1 Element	20/08/2020	08:40	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	20/08/2020	08:25	Completed		
	Waikouaiti WTP - Discharge to Tributary ? Downstream	9401	ICP-MS - 1 Element	20/08/2020	08:55	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	20/08/2020	09:20	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0053F	Temperature - Field	20/08/2020	08:10	7.6	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0053F	Temperature - Field	20/08/2020	08:40	5.4	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	20/08/2020	08:25	7.4	Deg C	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0053F	Temperature - Field	20/08/2020	08:55	5.8	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	20/08/2020	09:20	5.5	Deg C	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0058H	Free Available Chlorine	20/08/2020	08:10	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-0058H	Free Available Chlorine	20/08/2020	08:40	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	20/08/2020	08:25	<0.05	g/m³	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-0058H	Free Available Chlorine	20/08/2020	08:55	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	20/08/2020	09:20	<0.05	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-1202	Sampling / Inspection 30 Mins	20/08/2020	08:10	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-1205	Sampling / Inspection 2 hours	20/08/2020	08:10	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	20/08/2020	08:10	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0102	Faecal Coliforms by MF - Environmental Water	20/08/2020	08:40	24	cfu/100ml (24 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	20/08/2020	08:25	<4	cfu/100ml (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	20/08/2020	08:55	12	cfu/100ml (12 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	20/08/2020	09:20	24	cfu/100ml (24 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0107	Enterococci - Environmental water	20/08/2020	08:10	4	cfu/100mL (4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0107	Enterococci - Environmental water	20/08/2020	08:40	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	20/08/2020	08:25	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0107	Enterococci - Environmental water	20/08/2020	08:55	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	20/08/2020	09:20	<4	cfu/100mL (<4 x 1)	

	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	20/08/2020	08:10	190	MPN/100ml (193.5 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	20/08/2020	08:40	550	MPN/100ml (547.5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	20/08/2020	08:25	<1	MPN/100ml (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	20/08/2020	08:55	1,700	MPN/100ml (1732.9 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	20/08/2020	09:20	150	MPN/100ml (146.7 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	08:10	<1	MPN/100mL (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Upstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	08:40	9	MPN/100mL (8.5 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	08:25	<1	MPN/100mL (<1 x 1)	
	Waikouaiti WTP - Discharge to Tributary ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	08:55	16	MPN/100mL (16 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	09:20	19	MPN/100mL (18.5 x 1)	
Unable to sample due to cattle present in paddock	Waikouaiti WTP - Waikouaiti River ? Upstream	O1420	Sampler Observation	20/08/2020	09:00	Unable	to sample due to cattle present in paddock	
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	20/08/2020	08:00	5	MPN/100mL (5.2 x 1)	
	Karitane Bowls	D-0058H	Free Available Chlorine	26/08/2020	13:50	0.44	g/m^3	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	26/08/2020	13:50	0.5	g/m^3	
	Karitane Bowls	D-0084	Turbidity	26/08/2020	13:50	0.09	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	26/08/2020	13:50	3.2	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	26/08/2020	13:50	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	26/08/2020	13:50	<1	MPN/100ml	(0 - 0)
Before Flush	TAB Waikouaiti	52	Alkalinity - Total	28/08/2020	09:10	64	$g\ CaCO3/m^3$	
	TAB Waikouaiti	52	Alkalinity - Total	28/08/2020	09:20	54	$g\ CaCO3/m^3$	
Before Flush	Karitane Bowls	52	Alkalinity - Total	28/08/2020	08:35	62	$g\ CaCO3/m^3$	
	Karitane Bowls	52	Alkalinity - Total	28/08/2020	08:45	56	$g\ CaCO3/m^3$	
Before Flush	Waikouaiti Golf Club	52	Alkalinity - Total	28/08/2020	09:35	60	$g\ CaCO3/m^3$	
Sample discoloured after flush.	Waikouaiti Golf Club	52	Alkalinity - Total	28/08/2020	09:45	59	$g\ CaCO3/m^3$	
Before Flush	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	28/08/2020	09:10	15.7	g/m^3	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	28/08/2020	09:20	14.3	g/m^3	
Before Flush	Karitane Bowls	0440D	Dissolved Inorganic Carbon	28/08/2020	08:35	16.5	g/m^3	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	28/08/2020	08:45	14.5	g/m^3	
Before Flush	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	28/08/2020	09:35	15.4	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	28/08/2020	09:45	15.4	g/m^3	
Before Flush	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	28/08/2020	09:10	15	g/m^3	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	28/08/2020	09:20	16	g/m^3	
Before Flush	Karitane Bowls	602	Chloride - Add P1859 Filtration	28/08/2020	08:35	15.3	g/m^3	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	28/08/2020	08:45	16.1	g/m^3	
Before Flush	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	28/08/2020	09:35	15.6	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	28/08/2020	09:45	15.6	g/m^3	
Before Flush	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	28/08/2020	09:10	11.7	g/m^3	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	28/08/2020	09:20	11.1	g/m^3	
Before Flush	Karitane Bowls	607	Sulphate - Add P1859 Filtration	28/08/2020	08:35	11.7	g/m^3	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	28/08/2020	08:45	11.3	g/m^3	
Before Flush	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	28/08/2020	09:35	11.5	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	28/08/2020	09:45	11.5	g/m^3	
Before Flush	TAB Waikouaiti	6001	Aluminium - Acid Soluble	28/08/2020	09:10	0.002	g/m^3	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	28/08/2020	09:20	0.004	g/m^3	
Before Flush	Karitane Bowls	6001	Aluminium - Acid Soluble	28/08/2020	08:35	0.002	g/m^3	
	Karitane Bowls	6001	Aluminium - Acid Soluble	28/08/2020	08:45	0.005	g/m^3	
Before Flush	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	28/08/2020	09:35	0.004	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	28/08/2020	09:45	0.025	g/m^3	
Before Flush	TAB Waikouaiti	6010	Calcium - Acid Soluble	28/08/2020	09:10	18.7	g/m^3	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	28/08/2020	09:20	16.6	g/m^3	
Before Flush	Karitane Bowls	6010	Calcium - Acid Soluble	28/08/2020	08:35	19.8	g/m^3	
	Karitane Bowls	6010	Calcium - Acid Soluble	28/08/2020	08:45	17.8	g/m^3	
Before Flush	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	28/08/2020	09:35	18.6	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	28/08/2020	09:45	18.4	g/m^3	
Before Flush	TAB Waikouaiti	6013	Copper - Acid Soluble	28/08/2020	09:10	1.62	g/m^3	
	TAB Waikouaiti	6013	Copper - Acid Soluble	28/08/2020	09:20	0.0332	g/m^3	
Before Flush	Karitane Bowls	6013	Copper - Acid Soluble	28/08/2020	08:35	0.0255	g/m^3	
	Karitane Bowls	6013	Copper - Acid Soluble	28/08/2020	08:45	0.0066	g/m^3	
Before Flush	Waikouaiti Golf Club	6013	Copper - Acid Soluble	28/08/2020	09:35	0.0259	g/m^3	
Sample discoloured after flush.	Waikouaiti Golf Club	6013	Copper - Acid Soluble	28/08/2020	09:45	0.0912	g/m^3	
Before Flush	TAB Waikouaiti	6017	Iron - Acid Soluble	28/08/2020	09:10	<0.01	g/m^3	

	TAB Waikouaiti	6017	Iron - Acid Soluble	28/08/2020	09:20	<0.01	g/m³	
Before Flush	Karitane Bowls	6017	Iron - Acid Soluble	28/08/2020	08:35	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	28/08/2020	08:45	<0.01	g/m³	
Before Flush	Waikouaiti Golf Club	6017	Iron - Acid Soluble	28/08/2020	09:35	0.04	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6017	Iron - Acid Soluble	28/08/2020	09:45	0.92	g/m³	
Before Flush	TAB Waikouaiti	6018	Lead - Acid Soluble	28/08/2020	09:10	0.0005	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	28/08/2020	09:20	<0.0005	g/m³	
Before Flush	Karitane Bowls	6018	Lead - Acid Soluble	28/08/2020	08:35	0.0011	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	28/08/2020	08:45	<0.0005	g/m³	
Before Flush	Waikouaiti Golf Club	6018	Lead - Acid Soluble	28/08/2020	09:35	0.0008	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6018	Lead - Acid Soluble	28/08/2020	09:45	0.0055	g/m³	
Before Flush	TAB Waikouaiti	6020	Magnesium - Acid Soluble	28/08/2020	09:10	6.52	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	28/08/2020	09:20	6.31	g/m³	
Before Flush	Karitane Bowls	6020	Magnesium - Acid Soluble	28/08/2020	08:35	6.47	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	28/08/2020	08:45	6.26	g/m³	
Before Flush	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	28/08/2020	09:35	6.42	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	28/08/2020	09:45	6.2	g/m³	
Before Flush	TAB Waikouaiti	6021	Manganese - Acid Soluble	28/08/2020	09:10	0.0011	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	28/08/2020	09:20	0.0061	g/m³	
Before Flush	Karitane Bowls	6021	Manganese - Acid Soluble	28/08/2020	08:35	0.0033	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	28/08/2020	08:45	0.003	g/m³	
Before Flush	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	28/08/2020	09:35	0.0013	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	28/08/2020	09:45	0.0174	g/m³	
Before Flush	TAB Waikouaiti	6024	Nickel - Acid Soluble	28/08/2020	09:10	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	28/08/2020	09:20	<0.0005	g/m³	
Before Flush	Karitane Bowls	6024	Nickel - Acid Soluble	28/08/2020	08:35	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	28/08/2020	08:45	<0.0005	g/m³	
Before Flush	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	28/08/2020	09:35	<0.0005	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	28/08/2020	09:45	<0.0005	g/m³	
Before Flush	TAB Waikouaiti	6038	Zinc - Acid Soluble	28/08/2020	09:10	0.028	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	28/08/2020	09:20	0.002	g/m³	
Before Flush	Karitane Bowls	6038	Zinc - Acid Soluble	28/08/2020	08:35	0.056	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	28/08/2020	08:45	0.005	g/m³	
Before Flush	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	28/08/2020	09:35	0.051	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	28/08/2020	09:45	0.057	g/m³	
Before Flush	TAB Waikouaiti	9402	ICP-MS - 2 Elements	28/08/2020	09:10	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	28/08/2020	09:20	Completed		
Before Flush	Karitane Bowls	9402	ICP-MS - 2 Elements	28/08/2020	08:35	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	28/08/2020	08:45	Completed		
Before Flush	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	28/08/2020	09:35	Completed		
Sample discoloured after flush.	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	28/08/2020	09:45	Completed		
Before Flush	TAB Waikouaiti	D-0001F	pH - Field	28/08/2020	09:10	6.9		
	TAB Waikouaiti	D-0001F	pH - Field	28/08/2020	09:20	6.9		
Before Flush	Karitane Bowls	D-0001F	pH - Field	28/08/2020	08:35	6.3		
	Karitane Bowls	D-0001F	pH - Field	28/08/2020	08:45	6.7		
Before Flush	Waikouaiti Golf Club	D-0001F	pH - Field	28/08/2020	09:35	7		
Sample discoloured after flush.	Waikouaiti Golf Club	D-0001F	pH - Field	28/08/2020	09:45	7.1		
Before Flush	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	28/08/2020	09:10	8.4	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	28/08/2020	09:20	9.2	g O2/m³	
Before Flush	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	28/08/2020	08:35	14.7	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	28/08/2020	08:45	9.2	g O2/m³	
Before Flush	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	28/08/2020	09:35	10.2	g O2/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	28/08/2020	09:45	9.4	g O2/m³	
Before Flush	TAB Waikouaiti	D-0058H	Free Available Chlorine	28/08/2020	09:10	<0.05	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0058H	Free Available Chlorine	28/08/2020	09:20	1	g/m³	(.2 - 5)
Before Flush	Karitane Bowls	D-0058H	Free Available Chlorine	28/08/2020	08:35	0.35	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	28/08/2020	08:45	1	g/m³	(.2 - 5)
Before Flush	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	28/08/2020	09:35	0.26	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	28/08/2020	09:45	0.42	g/m³	

Before Flush	TAB Waikouaiti	D-0066H	Total Chlorine	28/08/2020	09:10	0.1	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	28/08/2020	09:20	1	g/m³	
Before Flush	Karitane Bowls	D-0066H	Total Chlorine	28/08/2020	08:35	0.4	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	28/08/2020	08:45	1.1	g/m³	
Before Flush	Waikouaiti Golf Club	D-0066H	Total Chlorine	28/08/2020	09:35	0.3	g/m³	
Sample discoloured after flush.	Waikouaiti Golf Club	D-0066H	Total Chlorine	28/08/2020	09:45	0.5	g/m³	
Before Flush	TAB Waikouaiti	D-1202	Sampling / Inspection 30 Mins	28/08/2020	09:10	Completed		
Before Flush	TAB Waikouaiti	D-1205	Sampling / Inspection 2 hours	28/08/2020	09:10	Completed		
Sample discoloured after flush.	Waikouaiti Golf Club	O1420	Sampler Observation	28/08/2020	09:45	Sample	discolored after flush.	
Before Flush	TAB Waikouaiti	P1859	Sample Filtration	28/08/2020	09:10	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	28/08/2020	09:20	Completed		
Before Flush	Karitane Bowls	P1859	Sample Filtration	28/08/2020	08:35	Completed		
	Karitane Bowls	P1859	Sample Filtration	28/08/2020	08:45	Completed		
Before Flush	Waikouaiti Golf Club	P1859	Sample Filtration	28/08/2020	09:35	Completed		
Sample discoloured after flush.	Waikouaiti Golf Club	P1859	Sample Filtration	28/08/2020	09:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	61	Chloride	28/08/2020	10:55	13	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	61	Chloride	28/08/2020	10:35	14	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	61	Chloride	28/08/2020	10:45	15	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	182	Sulphite	28/08/2020	10:55	<2	g/m³ as SO3	
	Waikouaiti WTP - Containerised Plant Filtrate	182	Sulphite	28/08/2020	10:35	<2	g/m³ as SO3	
	Waikouaiti WTP - Post Treated Water Reservoir	182	Sulphite	28/08/2020	10:45	<2	g/m³ as SO3	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	28/08/2020	10:55	0.11	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	601	Fluoride - Add P1859 Filtration	28/08/2020	10:35	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	28/08/2020	10:45	0.11	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	28/08/2020	10:55	0.79	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	605	Nitrate - Nitrogen - Add P1859 Filtration	28/08/2020	10:35	0.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	28/08/2020	10:45	0.03	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	704	Bromide - Ultra Trace	28/08/2020	10:55	0.02	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	704	Bromide - Ultra Trace	28/08/2020	10:35	0.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	704	Bromide - Ultra Trace	28/08/2020	10:45	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	28/08/2020	10:35	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	28/08/2020	10:45	0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6002	Antimony - Acid Soluble	28/08/2020	10:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	28/08/2020	10:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	28/08/2020	10:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	28/08/2020	10:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6004	Barium - Acid Soluble	28/08/2020	10:35	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	28/08/2020	10:45	0.011	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6007	Boron - Acid Soluble	28/08/2020	10:35	<0.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	28/08/2020	10:45	<0.03	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	28/08/2020	10:35	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	28/08/2020	10:45	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	28/08/2020	10:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	28/08/2020	10:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	28/08/2020	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	28/08/2020	10:45	0.0009	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	28/08/2020	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	28/08/2020	10:45	0.0056	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	28/08/2020	10:35	0.0067	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	28/08/2020	10:45	0.0063	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	28/08/2020	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	28/08/2020	10:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	28/08/2020	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	28/08/2020	10:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	28/08/2020	10:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	28/08/2020	10:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	28/08/2020	10:55	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6702	Antimony - Dissolved	28/08/2020	10:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	28/08/2020	10:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6704	Barium - Dissolved	28/08/2020	10:55	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6707	Boron - Dissolved	28/08/2020	10:55	<0.03	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	28/08/2020	10:55	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	28/08/2020	10:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	28/08/2020	10:55	0.0014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	28/08/2020	10:55	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	28/08/2020	10:55	0.006	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	28/08/2020	10:55	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	28/08/2020	10:55	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	28/08/2020	10:55	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9405	ICP-MS - 5 Elements	28/08/2020	10:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9405	ICP-MS - 5 Elements	28/08/2020	10:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9405	ICP-MS - 5 Elements	28/08/2020	10:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	28/08/2020	10:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	28/08/2020	10:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	28/08/2020	10:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	28/08/2020	10:45	Completed		

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	602	Chloride - Add P1859 Filtration	03/09/2020	10:20:00	15.2	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	602	Chloride - Add P1859 Filtration	03/09/2020	10:30:00	15.3	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	602	Chloride - Add P1859 Filtration	03/09/2020	10:40:00	15.5	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	602	Chloride - Add P1859 Filtration	03/09/2020	10:50:00	15.4	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	602	Chloride - Add P1859 Filtration	03/09/2020	11:00:00	14.9	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	607	Sulphate - Add P1859 Filtration	03/09/2020	10:20:00	10.9	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	607	Sulphate - Add P1859 Filtration	03/09/2020	10:30:00	11.2	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	607	Sulphate - Add P1859 Filtration	03/09/2020	10:40:00	11.3	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	607	Sulphate - Add P1859 Filtration	03/09/2020	10:50:00	11.2	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	607	Sulphate - Add P1859 Filtration	03/09/2020	11:00:00	10.9	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6001	Aluminium - Acid Soluble	03/09/2020	10:20:00	0.033	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6001	Aluminium - Acid Soluble	03/09/2020	10:30:00	0.035	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6001	Aluminium - Acid Soluble	03/09/2020	10:40:00	0.026	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6001	Aluminium - Acid Soluble	03/09/2020	10:50:00	0.022	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6001	Aluminium - Acid Soluble	03/09/2020	11:00:00	0.019	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6010	Calcium - Acid Soluble	03/09/2020	10:20:00	17	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6010	Calcium - Acid Soluble	03/09/2020	10:30:00	16.9	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6010	Calcium - Acid Soluble	03/09/2020	10:40:00	16.9	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6010	Calcium - Acid Soluble	03/09/2020	10:50:00	16.7	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6010	Calcium - Acid Soluble	03/09/2020	11:00:00	16.6	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6013	Copper - Acid Soluble	03/09/2020	10:20:00	0.0011	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6013	Copper - Acid Soluble	03/09/2020	10:30:00	0.0009	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6013	Copper - Acid Soluble	03/09/2020	10:40:00	0.0008	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6013	Copper - Acid Soluble	03/09/2020	10:50:00	0.0006	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6013	Copper - Acid Soluble	03/09/2020	11:00:00	0.0006	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6017	Iron - Acid Soluble	03/09/2020	10:20:00	1.14	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6017	Iron - Acid Soluble	03/09/2020	10:30:00	1.12	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6017	Iron - Acid Soluble	03/09/2020	10:40:00	0.93	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6017	Iron - Acid Soluble	03/09/2020	10:50:00	0.77	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6017	Iron - Acid Soluble	03/09/2020	11:00:00	0.62	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6018	Lead - Acid Soluble	03/09/2020	10:20:00	<0.0005	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6018	Lead - Acid Soluble	03/09/2020	10:30:00	<0.0005	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6018	Lead - Acid Soluble	03/09/2020	10:40:00	<0.0005	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6018	Lead - Acid Soluble	03/09/2020	10:50:00	<0.0005	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6018	Lead - Acid Soluble	03/09/2020	11:00:00	<0.0005	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6020	Magnesium - Acid Soluble	03/09/2020	10:20:00	6.13	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6020	Magnesium - Acid Soluble	03/09/2020	10:30:00	6.14	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6020	Magnesium - Acid Soluble	03/09/2020	10:40:00	6.21	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6020	Magnesium - Acid Soluble	03/09/2020	10:50:00	6.17	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6020	Magnesium - Acid Soluble	03/09/2020	11:00:00	6.15	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6021	Manganese - Acid Soluble	03/09/2020	10:20:00	0.0452	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6021	Manganese - Acid Soluble	03/09/2020	10:30:00	0.0745	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6021	Manganese - Acid Soluble	03/09/2020	10:40:00	0.0566	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6021	Manganese - Acid Soluble	03/09/2020	10:50:00	0.0487	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6021	Manganese - Acid Soluble	03/09/2020	11:00:00	0.0488	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6024	Nickel - Acid Soluble	03/09/2020	10:20:00	<0.0005	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6024	Nickel - Acid Soluble	03/09/2020	10:30:00	<0.0005	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6024	Nickel - Acid Soluble	03/09/2020	10:40:00	<0.0005	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6024	Nickel - Acid Soluble	03/09/2020	10:50:00	<0.0005	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6024	Nickel - Acid Soluble	03/09/2020	11:00:00	<0.0005	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6038	Zinc - Acid Soluble	03/09/2020	10:20:00	0.002	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6038	Zinc - Acid Soluble	03/09/2020	10:30:00	0.003	g/m³	
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6038	Zinc - Acid Soluble	03/09/2020	10:40:00	<0.002	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6038	Zinc - Acid Soluble	03/09/2020	10:50:00	<0.002	g/m³	
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6038	Zinc - Acid Soluble	03/09/2020	11:00:00	<0.002	g/m³	
3.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	P1859	Sample Filtration	03/09/2020	10:20:00	Completed		
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1B	P1859	Sample Filtration	03/09/2020	10:30:00	Completed		
2.2 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1C	P1859	Sample Filtration	03/09/2020	10:40:00	Completed		
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1D	P1859	Sample Filtration	03/09/2020	10:50:00	Completed		
2.1 L/s	Waikouaiti DZ ? Golf Club Metals Investigation 1E	P1859	Sample Filtration	03/09/2020	11:00:00	Completed		
Before Flush	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	03/09/2020	07:45	57	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	03/09/2020	07:55	50	g CaCO3/m³	
Before Flush	Karitane Bowls - Pre-flush	52	Alkalinity - Total	03/09/2020	08:50	50	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	03/09/2020	09:00	50	g CaCO3/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	03/09/2020	08:15	52	g CaCO3/m³	

Slightly discoloured	Waikouaiti Golf Club	52	Alkalinity - Total	03/09/2020	08:25	54	g CaCO3/m³	
Before Flush	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	03/09/2020	07:45	15	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	03/09/2020	07:55	13.5	g/m³	
Before Flush	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	03/09/2020	08:50	13.9	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	03/09/2020	09:00	13.7	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	03/09/2020	08:15	14.6	g/m³	
Slightly discoloured	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	03/09/2020	08:25	14.6	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	03/09/2020	07:45	16.2	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	03/09/2020	07:55	14.8	g/m³	
Before Flush	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	03/09/2020	08:50	15.4	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	03/09/2020	09:00	14.9	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	03/09/2020	08:15	15.3	g/m³	
Slightly discoloured	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	03/09/2020	08:25	15.5	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	03/09/2020	07:45	10.9	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	03/09/2020	07:55	10.7	g/m³	
Before Flush	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	03/09/2020	08:50	11	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	03/09/2020	09:00	10.8	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	03/09/2020	08:15	10.9	g/m³	
Slightly discoloured	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	03/09/2020	08:25	11.2	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	03/09/2020	07:45	0.004	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	03/09/2020	07:55	0.005	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	03/09/2020	08:50	0.003	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	03/09/2020	09:00	0.006	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	03/09/2020	08:15	0.004	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	03/09/2020	08:25	0.012	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	03/09/2020	07:45	16.8	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	03/09/2020	07:55	16	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	03/09/2020	08:50	16.5	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	03/09/2020	09:00	16.7	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	03/09/2020	08:15	17	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	03/09/2020	08:25	17	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	03/09/2020	07:45	1.43	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	03/09/2020	07:55	0.0581	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	03/09/2020	08:50	0.0292	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	03/09/2020	09:00	0.0051	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	03/09/2020	08:15	0.0234	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6013	Copper - Acid Soluble	03/09/2020	08:25	0.0375	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	03/09/2020	07:45	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	03/09/2020	07:55	<0.01	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	03/09/2020	08:50	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	03/09/2020	09:00	<0.01	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	03/09/2020	08:15	0.08	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6017	Iron - Acid Soluble	03/09/2020	08:25	0.32	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	03/09/2020	07:45	0.0016	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	03/09/2020	07:55	0.0007	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	03/09/2020	08:50	0.0038	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	03/09/2020	09:00	<0.0005	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	03/09/2020	08:15	0.0009	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6018	Lead - Acid Soluble	03/09/2020	08:25	0.0021	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	03/09/2020	07:45	6.69	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	03/09/2020	07:55	6.31	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	03/09/2020	08:50	6.16	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	03/09/2020	09:00	6.13	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	03/09/2020	08:15	6.76	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	03/09/2020	08:25	6.14	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	03/09/2020	07:45	0.0016	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	03/09/2020	07:55	0.0097	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	03/09/2020	08:50	0.0009	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	03/09/2020	09:00	0.0022	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	03/09/2020	08:15	0.0049	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	03/09/2020	08:25	0.0145	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	03/09/2020	07:45	0.0006	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	03/09/2020	07:55	<0.0005	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	03/09/2020	08:50	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	03/09/2020	09:00	<0.0005	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	03/09/2020	08:15	<0.0005	g/m³	

Slightly discoloured	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	03/09/2020	08:25	<0.0005	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	03/09/2020	07:45	0.063	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	03/09/2020	07:55	0.003	g/m³	
Before Flush	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	03/09/2020	08:50	0.111	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	03/09/2020	09:00	0.004	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	03/09/2020	08:15	0.057	g/m³	
Slightly discoloured	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	03/09/2020	08:25	0.035	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	03/09/2020	07:45	6.9		
	TAB Waikouaiti	D-0001F	pH - Field	03/09/2020	07:55	6.9		
Before Flush	Karitane Bowls - Pre-flush	D-0001F	pH - Field	03/09/2020	08:50	7		
	Karitane Bowls	D-0001F	pH - Field	03/09/2020	09:00	7.1		
Before Flush	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	03/09/2020	08:15	7.2		
Slightly discoloured	Waikouaiti Golf Club	D-0001F	pH - Field	03/09/2020	08:25	7.2		
Before Flush	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	03/09/2020	07:45	6.8	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	03/09/2020	07:55	6.9	g O2/m³	
Before Flush	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	03/09/2020	08:50	6.5	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	03/09/2020	09:00	6.4	g O2/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	03/09/2020	08:15	6.8	g O2/m³	
Slightly discoloured	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	03/09/2020	08:25	6.9	g O2/m³	
Before Flush	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	03/09/2020	07:45	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	03/09/2020	07:55	0.27	g/m³	(.2 - 5)
Before Flush	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	03/09/2020	08:50	0.12	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	03/09/2020	09:00	0.39	g/m³	(.2 - 5)
Before Flush	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	03/09/2020	08:15	<0.05	g/m³	
Slightly discoloured	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	03/09/2020	08:25	0.18	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	03/09/2020	07:45	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	03/09/2020	07:55	0.3	g/m³	
Before Flush	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	03/09/2020	08:50	0.3	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	03/09/2020	09:00	0.5	g/m³	
Before Flush	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	03/09/2020	08:15	0.1	g/m³	
Slightly discoloured	Waikouaiti Golf Club	D-0066H	Total Chlorine	03/09/2020	08:25	0.2	g/m³	
Before Flush	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	03/09/2020	07:45	Completed		
Before Flush	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	03/09/2020	07:45	Completed		
Slightly discoloured	Waikouaiti Golf Club	O1420	Sampler Observation	03/09/2020	08:25	Slightly	discoloured	
Before Flush	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	03/09/2020	07:45	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	03/09/2020	07:55	Completed		
Before Flush	Karitane Bowls - Pre-flush	P1859	Sample Filtration	03/09/2020	08:50	Completed		
	Karitane Bowls	P1859	Sample Filtration	03/09/2020	09:00	Completed		
Before Flush	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	03/09/2020	08:15	Completed		
Slightly discoloured	Waikouaiti Golf Club	P1859	Sample Filtration	03/09/2020	08:25	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	04/09/2020	10:30	0.56	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	04/09/2020	10:30	0.7	g/m³	
	Karitane Bowls	D-0084	Turbidity	04/09/2020	10:30	0.1	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	04/09/2020	10:30	10.1	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/09/2020	10:30	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/09/2020	10:30	<1	MPN/100ml	(0 - 0)
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	602	Chloride - Add P1859 Filtration	10/09/2020	13:00	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	602	Chloride - Add P1859 Filtration	10/09/2020	13:15	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	602	Chloride - Add P1859 Filtration	10/09/2020	13:30	14.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	602	Chloride - Add P1859 Filtration	10/09/2020	13:45	14.7	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	602	Chloride - Add P1859 Filtration	10/09/2020	14:00	14.7	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	607	Sulphate - Add P1859 Filtration	10/09/2020	13:00	11.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	607	Sulphate - Add P1859 Filtration	10/09/2020	13:15	11.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	607	Sulphate - Add P1859 Filtration	10/09/2020	13:30	11.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	607	Sulphate - Add P1859 Filtration	10/09/2020	13:45	12.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	607	Sulphate - Add P1859 Filtration	10/09/2020	14:00	12.3	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6001	Aluminium - Acid Soluble	10/09/2020	13:00	0.012	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6001	Aluminium - Acid Soluble	10/09/2020	13:15	0.014	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6001	Aluminium - Acid Soluble	10/09/2020	13:30	0.013	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6001	Aluminium - Acid Soluble	10/09/2020	13:45	0.012	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6001	Aluminium - Acid Soluble	10/09/2020	14:00	0.012	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6010	Calcium - Acid Soluble	10/09/2020	13:00	16.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6010	Calcium - Acid Soluble	10/09/2020	13:15	15.3	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6010	Calcium - Acid Soluble	10/09/2020	13:30	15.3	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6010	Calcium - Acid Soluble	10/09/2020	13:45	14.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6010	Calcium - Acid Soluble	10/09/2020	14:00	15.5	g/m³	

Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6013	Copper - Acid Soluble	10/09/2020	13:00	0.0011	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6013	Copper - Acid Soluble	10/09/2020	13:15	0.0008	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6013	Copper - Acid Soluble	10/09/2020	13:30	0.0009	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6013	Copper - Acid Soluble	10/09/2020	13:45	0.0009	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6013	Copper - Acid Soluble	10/09/2020	14:00	0.0009	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6017	Iron - Acid Soluble	10/09/2020	13:00	0.53	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6017	Iron - Acid Soluble	10/09/2020	13:15	0.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6017	Iron - Acid Soluble	10/09/2020	13:30	0.54	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6017	Iron - Acid Soluble	10/09/2020	13:45	0.49	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6017	Iron - Acid Soluble	10/09/2020	14:00	0.49	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6018	Lead - Acid Soluble	10/09/2020	13:00	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6018	Lead - Acid Soluble	10/09/2020	13:15	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6018	Lead - Acid Soluble	10/09/2020	13:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6018	Lead - Acid Soluble	10/09/2020	13:45	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6018	Lead - Acid Soluble	10/09/2020	14:00	<0.0005	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6020	Magnesium - Acid Soluble	10/09/2020	13:00	6.12	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6020	Magnesium - Acid Soluble	10/09/2020	13:15	6.15	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6020	Magnesium - Acid Soluble	10/09/2020	13:30	6.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6020	Magnesium - Acid Soluble	10/09/2020	13:45	6.34	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6020	Magnesium - Acid Soluble	10/09/2020	14:00	6.13	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6021	Manganese - Acid Soluble	10/09/2020	13:00	0.0205	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6021	Manganese - Acid Soluble	10/09/2020	13:15	0.0247	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6021	Manganese - Acid Soluble	10/09/2020	13:30	0.0207	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6021	Manganese - Acid Soluble	10/09/2020	13:45	0.0164	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6021	Manganese - Acid Soluble	10/09/2020	14:00	0.0169	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6024	Nickel - Acid Soluble	10/09/2020	13:00	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6024	Nickel - Acid Soluble	10/09/2020	13:15	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6024	Nickel - Acid Soluble	10/09/2020	13:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6024	Nickel - Acid Soluble	10/09/2020	13:45	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6024	Nickel - Acid Soluble	10/09/2020	14:00	<0.0005	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6038	Zinc - Acid Soluble	10/09/2020	13:00	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6038	Zinc - Acid Soluble	10/09/2020	13:15	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6038	Zinc - Acid Soluble	10/09/2020	13:30	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6038	Zinc - Acid Soluble	10/09/2020	13:45	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6038	Zinc - Acid Soluble	10/09/2020	14:00	<0.002	g/m³	
Edinburgh St Waikouaiti	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	P1859	Sample Filtration	10/09/2020	13:00	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	P1859	Sample Filtration	10/09/2020	13:15	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	P1859	Sample Filtration	10/09/2020	13:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	P1859	Sample Filtration	10/09/2020	13:45	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	P1859	Sample Filtration	10/09/2020	14:00	Completed		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	10/09/2020	11:55	54	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	10/09/2020	12:05	51	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	10/09/2020	12:30	51	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	10/09/2020	12:40	51	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	10/09/2020	11:25	50	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	10/09/2020	11:35	52	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	10/09/2020	11:55	14.1	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	10/09/2020	12:05	13.8	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	10/09/2020	12:30	13.9	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	10/09/2020	12:40	14	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	10/09/2020	11:25	13.9	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	10/09/2020	11:35	13.9	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	10/09/2020	11:55	14.8	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	10/09/2020	12:05	14.3	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	10/09/2020	12:30	14.4	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	10/09/2020	12:40	14.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	10/09/2020	11:25	14.7	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	10/09/2020	11:35	14.6	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	10/09/2020	11:55	10.6	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	10/09/2020	12:05	12.2	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	10/09/2020	12:30	12	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	10/09/2020	12:40	12.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	10/09/2020	11:25	11.4	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	10/09/2020	11:35	11.4	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	10/09/2020	11:55	0.002	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	10/09/2020	12:05	0.005	g/m³	

	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	10/09/2020	12:30	0.004	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	10/09/2020	12:40	0.004	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	10/09/2020	11:25	0.003	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	10/09/2020	11:35	0.009	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	10/09/2020	11:55	13.9	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	10/09/2020	12:05	14.8	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	10/09/2020	12:30	15.4	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	10/09/2020	12:40	15	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	10/09/2020	11:25	15.1	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	10/09/2020	11:35	15	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	10/09/2020	11:55	1.35	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	10/09/2020	12:05	0.0333	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	10/09/2020	12:30	0.035	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	10/09/2020	12:40	0.005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	10/09/2020	11:25	0.0261	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	10/09/2020	11:35	0.0371	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	10/09/2020	11:55	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	10/09/2020	12:05	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	10/09/2020	12:30	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	10/09/2020	12:40	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	10/09/2020	11:25	0.06	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	10/09/2020	11:35	0.24	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	10/09/2020	11:55	<0.0005	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	10/09/2020	12:05	0.0006	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	10/09/2020	12:30	0.0042	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	10/09/2020	12:40	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	10/09/2020	11:25	0.0014	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	10/09/2020	11:35	0.0023	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	10/09/2020	11:55	6.34	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	10/09/2020	12:05	6.58	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	10/09/2020	12:30	6.22	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	10/09/2020	12:40	6.43	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	10/09/2020	11:25	6.3	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	10/09/2020	11:35	6.1	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	10/09/2020	11:55	0.0013	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	10/09/2020	12:05	0.0124	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	10/09/2020	12:30	0.001	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	10/09/2020	12:40	0.002	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	10/09/2020	11:25	0.002	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	10/09/2020	11:35	0.009	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	10/09/2020	11:55	0.0006	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	10/09/2020	12:05	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	10/09/2020	12:30	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	10/09/2020	12:40	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	10/09/2020	11:25	<0.0005	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	10/09/2020	11:35	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	10/09/2020	11:55	0.021	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	10/09/2020	12:05	0.002	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	10/09/2020	12:30	0.087	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	10/09/2020	12:40	0.003	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	10/09/2020	11:25	0.073	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	10/09/2020	11:35	0.03	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	10/09/2020	11:55	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	10/09/2020	12:05	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	10/09/2020	12:30	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	10/09/2020	12:40	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	10/09/2020	11:25	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	10/09/2020	11:35	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	10/09/2020	11:55	7.1		
	TAB Waikouaiti	D-0001F	pH - Field	10/09/2020	12:05	7.1		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	10/09/2020	12:30	7.1		
	Karitane Bowls	D-0001F	pH - Field	10/09/2020	12:40	7		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	10/09/2020	11:25	7		
	Waikouaiti Golf Club	D-0001F	pH - Field	10/09/2020	11:35	7.2		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	10/09/2020	11:55	7.3	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	10/09/2020	12:05	9.9	g O2/m³	

	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	10/09/2020	12:30	10.6	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	10/09/2020	12:40	10	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	10/09/2020	11:25	9.1	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	10/09/2020	11:35	9.3	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	10/09/2020	11:55	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	10/09/2020	12:05	0.8	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	10/09/2020	12:30	0.15	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	10/09/2020	12:40	0.82	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	10/09/2020	11:25	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	10/09/2020	11:35	0.23	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	10/09/2020	11:55	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	10/09/2020	12:05	0.9	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	10/09/2020	12:30	0.7	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	10/09/2020	12:40	0.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	10/09/2020	11:25	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	10/09/2020	11:35	0.4	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	10/09/2020	11:55	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	10/09/2020	11:55	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	10/09/2020	11:55	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	10/09/2020	12:05	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	10/09/2020	12:30	Completed		
	Karitane Bowls	P1859	Sample Filtration	10/09/2020	12:40	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	10/09/2020	11:25	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	10/09/2020	11:35	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	602	Chloride - Add P1859 Filtration	14/09/2020	10:10	14.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	602	Chloride - Add P1859 Filtration	14/09/2020	10:20	15.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	602	Chloride - Add P1859 Filtration	14/09/2020	10:30	15.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	602	Chloride - Add P1859 Filtration	14/09/2020	10:40	15.4	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	602	Chloride - Add P1859 Filtration	14/09/2020	10:50	15.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	607	Sulphate - Add P1859 Filtration	14/09/2020	10:10	11.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	607	Sulphate - Add P1859 Filtration	14/09/2020	10:20	12.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	607	Sulphate - Add P1859 Filtration	14/09/2020	10:30	12.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	607	Sulphate - Add P1859 Filtration	14/09/2020	10:40	12.7	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	607	Sulphate - Add P1859 Filtration	14/09/2020	10:50	12.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6001	Aluminium - Acid Soluble	14/09/2020	10:10	0.018	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6001	Aluminium - Acid Soluble	14/09/2020	10:20	0.014	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6001	Aluminium - Acid Soluble	14/09/2020	10:30	0.015	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6001	Aluminium - Acid Soluble	14/09/2020	10:40	0.014	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6001	Aluminium - Acid Soluble	14/09/2020	10:50	0.011	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6010	Calcium - Acid Soluble	14/09/2020	10:10	16.8	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6010	Calcium - Acid Soluble	14/09/2020	10:20	16.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6010	Calcium - Acid Soluble	14/09/2020	10:30	15.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6010	Calcium - Acid Soluble	14/09/2020	10:40	16.5	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6010	Calcium - Acid Soluble	14/09/2020	10:50	16.7	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6013	Copper - Acid Soluble	14/09/2020	10:10	0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6013	Copper - Acid Soluble	14/09/2020	10:20	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6013	Copper - Acid Soluble	14/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6013	Copper - Acid Soluble	14/09/2020	10:40	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6013	Copper - Acid Soluble	14/09/2020	10:50	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6017	Iron - Acid Soluble	14/09/2020	10:10	0.47	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6017	Iron - Acid Soluble	14/09/2020	10:20	0.63	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6017	Iron - Acid Soluble	14/09/2020	10:30	0.56	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6017	Iron - Acid Soluble	14/09/2020	10:40	0.88	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6017	Iron - Acid Soluble	14/09/2020	10:50	0.32	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6018	Lead - Acid Soluble	14/09/2020	10:10	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6018	Lead - Acid Soluble	14/09/2020	10:20	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6018	Lead - Acid Soluble	14/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6018	Lead - Acid Soluble	14/09/2020	10:40	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6018	Lead - Acid Soluble	14/09/2020	10:50	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6020	Magnesium - Acid Soluble	14/09/2020	10:10	6.83	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6020	Magnesium - Acid Soluble	14/09/2020	10:20	6.73	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6020	Magnesium - Acid Soluble	14/09/2020	10:30	6.36	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6020	Magnesium - Acid Soluble	14/09/2020	10:40	6.72	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6020	Magnesium - Acid Soluble	14/09/2020	10:50	6.86	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6021	Manganese - Acid Soluble	14/09/2020	10:10	0.01	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6021	Manganese - Acid Soluble	14/09/2020	10:20	0.018	g/m³	

	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6021	Manganese - Acid Soluble	14/09/2020	10:30	0.015	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6021	Manganese - Acid Soluble	14/09/2020	10:40	0.018	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6021	Manganese - Acid Soluble	14/09/2020	10:50	0.013	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6024	Nickel - Acid Soluble	14/09/2020	10:10	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6024	Nickel - Acid Soluble	14/09/2020	10:20	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6024	Nickel - Acid Soluble	14/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6024	Nickel - Acid Soluble	14/09/2020	10:40	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6024	Nickel - Acid Soluble	14/09/2020	10:50	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6038	Zinc - Acid Soluble	14/09/2020	10:10	0.003	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6038	Zinc - Acid Soluble	14/09/2020	10:20	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6038	Zinc - Acid Soluble	14/09/2020	10:30	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6038	Zinc - Acid Soluble	14/09/2020	10:40	0.018	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6038	Zinc - Acid Soluble	14/09/2020	10:50	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	9402	ICP-MS - 2 Elements	14/09/2020	10:10	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	9402	ICP-MS - 2 Elements	14/09/2020	10:20	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	9402	ICP-MS - 2 Elements	14/09/2020	10:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	9402	ICP-MS - 2 Elements	14/09/2020	10:40	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	9402	ICP-MS - 2 Elements	14/09/2020	10:50	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	P1859	Sample Filtration	14/09/2020	10:10	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	P1859	Sample Filtration	14/09/2020	10:20	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	P1859	Sample Filtration	14/09/2020	10:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	P1859	Sample Filtration	14/09/2020	10:40	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	P1859	Sample Filtration	14/09/2020	10:50	Completed		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	14/09/2020	08:00	52	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	14/09/2020	08:10	51	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	14/09/2020	08:55	50	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	14/09/2020	09:05	51	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	14/09/2020	08:25	52	g CaCO3/m³	
Sample Discoloured	Waikouaiti Golf Club	52	Alkalinity - Total	14/09/2020	08:35	53	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	14/09/2020	08:00	14.1	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	14/09/2020	08:10	14.1	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	14/09/2020	08:55	14	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	14/09/2020	09:05	14.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	14/09/2020	08:25	14.4	g/m³	
Sample Discoloured	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	14/09/2020	08:35	14.8	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	14/09/2020	08:00	15.2	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	14/09/2020	08:10	15.4	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	14/09/2020	08:55	14.9	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	14/09/2020	09:05	15.5	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	14/09/2020	08:25	15	g/m³	
Sample Discoloured	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	14/09/2020	08:35	15.1	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	14/09/2020	08:00	12.4	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	14/09/2020	08:10	12.8	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	14/09/2020	08:55	12.5	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	14/09/2020	09:05	12.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	14/09/2020	08:25	12.3	g/m³	
Sample Discoloured	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	14/09/2020	08:35	12.5	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	14/09/2020	08:00	0.003	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	14/09/2020	08:10	0.005	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	14/09/2020	08:55	0.005	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	14/09/2020	09:05	0.006	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	14/09/2020	08:25	0.005	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	14/09/2020	08:35	0.012	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	14/09/2020	08:00	16.3	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	14/09/2020	08:10	16.1	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	14/09/2020	08:55	16.2	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	14/09/2020	09:05	16.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	14/09/2020	08:25	16.5	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	14/09/2020	08:35	17.7	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	14/09/2020	08:00	1.33	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	14/09/2020	08:10	0.042	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	14/09/2020	08:55	0.017	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	14/09/2020	09:05	0.007	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	14/09/2020	08:25	0.016	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6013	Copper - Acid Soluble	14/09/2020	08:35	0.051	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	14/09/2020	08:00	<0.01	g/m³	

	TAB Waikouaiti	6017	Iron - Acid Soluble	14/09/2020	08:10	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	14/09/2020	08:55	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	14/09/2020	09:05	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	14/09/2020	08:25	0.05	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6017	Iron - Acid Soluble	14/09/2020	08:35	0.28	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	14/09/2020	08:00	0.0008	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	14/09/2020	08:10	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	14/09/2020	08:55	0.0018	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	14/09/2020	09:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	14/09/2020	08:25	0.0009	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6018	Lead - Acid Soluble	14/09/2020	08:35	0.0036	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	14/09/2020	08:00	7.32	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	14/09/2020	08:10	7.29	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	14/09/2020	08:55	7.03	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	14/09/2020	09:05	6.86	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	14/09/2020	08:25	6.56	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	14/09/2020	08:35	7	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	14/09/2020	08:00	0.002	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	14/09/2020	08:10	0.0019	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	14/09/2020	08:55	0.0007	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	14/09/2020	09:05	0.0012	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	14/09/2020	08:25	0.0015	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	14/09/2020	08:35	0.0086	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	14/09/2020	08:00	0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	14/09/2020	08:10	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	14/09/2020	08:55	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	14/09/2020	09:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	14/09/2020	08:25	<0.0005	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	14/09/2020	08:35	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	14/09/2020	08:00	0.058	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	14/09/2020	08:10	<0.002	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	14/09/2020	08:55	0.054	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	14/09/2020	09:05	0.006	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	14/09/2020	08:25	0.042	g/m³	
Sample Discoloured	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	14/09/2020	08:35	0.051	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	14/09/2020	08:00	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	14/09/2020	08:10	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	14/09/2020	08:55	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	14/09/2020	09:05	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	14/09/2020	08:25	Completed		
Sample Discoloured	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	14/09/2020	08:35	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	14/09/2020	08:00	6.6		
	TAB Waikouaiti	D-0001F	pH - Field	14/09/2020	08:10	6.6		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	14/09/2020	08:55	6.4		
	Karitane Bowls	D-0001F	pH - Field	14/09/2020	09:05	6.5		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	14/09/2020	08:25	6.6		
Sample Discoloured	Waikouaiti Golf Club	D-0001F	pH - Field	14/09/2020	08:35	6.7		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	14/09/2020	08:00	10.7	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	14/09/2020	08:10	10.4	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	14/09/2020	08:55	11.8	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	14/09/2020	09:05	11.6	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	14/09/2020	08:25	11.4	g O2/m³	
Sample Discoloured	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	14/09/2020	08:35	12.1	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	14/09/2020	08:00	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	14/09/2020	08:10	0.74	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	14/09/2020	08:55	0.06	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	14/09/2020	09:05	0.82	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	14/09/2020	08:25	0.09	g/m³	
Sample Discoloured	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	14/09/2020	08:35	0.31	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	14/09/2020	08:00	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	14/09/2020	08:10	0.9	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	14/09/2020	08:55	0.1	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	14/09/2020	09:05	0.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	14/09/2020	08:25	0.2	g/m³	
Sample Discoloured	Waikouaiti Golf Club	D-0066H	Total Chlorine	14/09/2020	08:35	0.3	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	14/09/2020	08:00	Completed		

	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	14/09/2020	08:00	Completed			
Sample Discoloured	Waikouaiti Golf Club	O1420	Sampler Observation	14/09/2020	08:35	Sample	discoloured		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	14/09/2020	08:00	Completed			
	TAB Waikouaiti	P1859	Sample Filtration	14/09/2020	08:10	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	14/09/2020	08:55	Completed			
	Karitane Bowls	P1859	Sample Filtration	14/09/2020	09:05	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	14/09/2020	08:25	Completed			
Sample Discoloured	Waikouaiti Golf Club	P1859	Sample Filtration	14/09/2020	08:35	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	61	Chloride	14/09/2020	10:35	13	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	61	Chloride	14/09/2020	10:35:00	12	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	61	Chloride	14/09/2020	10:00	14	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	61	Chloride	14/09/2020	10:20	15	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	14/09/2020	10:35	0.11	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	601	Fluoride - Add P1859 Filtration	14/09/2020	10:00	0.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	14/09/2020	10:20	0.11	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	14/09/2020	10:35	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	605	Nitrate - Nitrogen - Add P1859 Filtration	14/09/2020	10:00	0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	14/09/2020	10:20	0.56	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	14/09/2020	10:35	12.8	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	14/09/2020	10:00	12.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	14/09/2020	10:20	17	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	704	Bromide - Ultra Trace	14/09/2020	10:35	0.023	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	704	Bromide - Ultra Trace	14/09/2020	10:00	0.02	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	704	Bromide - Ultra Trace	14/09/2020	10:20	<0.005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	14/09/2020	10:00	0.006	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	14/09/2020	10:20	0.006	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6002	Antimony - Acid Soluble	14/09/2020	10:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	14/09/2020	10:20	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	14/09/2020	10:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	14/09/2020	10:20	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6004	Barium - Acid Soluble	14/09/2020	10:00	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	14/09/2020	10:20	0.011	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6007	Boron - Acid Soluble	14/09/2020	10:00	<0.03	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	14/09/2020	10:20	<0.03	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	14/09/2020	10:00	<0.0002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	14/09/2020	10:20	<0.0002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	14/09/2020	10:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	14/09/2020	10:20	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	14/09/2020	10:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	14/09/2020	10:20	0.0013	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	14/09/2020	10:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	14/09/2020	10:20	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	14/09/2020	10:00	0.0035	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	14/09/2020	10:20	0.0034	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	14/09/2020	10:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	14/09/2020	10:20	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	14/09/2020	10:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	14/09/2020	10:20	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	14/09/2020	10:00	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	14/09/2020	10:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	14/09/2020	10:35	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6702	Antimony - Dissolved	14/09/2020	10:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	14/09/2020	10:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6704	Barium - Dissolved	14/09/2020	10:35	0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6707	Boron - Dissolved	14/09/2020	10:35	<0.03	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	14/09/2020	10:35	<0.0002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	14/09/2020	10:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	14/09/2020	10:35	0.0011	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	14/09/2020	10:35	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	14/09/2020	10:35	0.0018	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	14/09/2020	10:35	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	14/09/2020	10:35	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	14/09/2020	10:35	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9405	ICP-MS - 5 Elements	14/09/2020	10:35	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9405	ICP-MS - 5 Elements	14/09/2020	10:00	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9405	ICP-MS - 5 Elements	14/09/2020	10:20	Completed			

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	14/09/2020	10:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	14/09/2020	10:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	14/09/2020	10:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	14/09/2020	10:20	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	18/09/2020	09:20	0.73	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	18/09/2020	09:20	0.8	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	18/09/2020	09:20	0.07	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	18/09/2020	09:20	6.6	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	18/09/2020	09:20	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	18/09/2020	09:20	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Sludge Pond 3 Discharge	1	pH	21/09/2020	08:25	8		(1 - 14)
	Waikouaiti WTP - Consent Discharge	1	pH	21/09/2020	08:40	8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Downstream	1	pH	21/09/2020	09:15	7.7		(1 - 14)
	Waikouaiti WTP - Sludge Pond 3 Discharge	2	Suspended Solids - Total	21/09/2020	08:25	<5	g/m³	
	Waikouaiti WTP - Consent Discharge	2	Suspended Solids - Total	21/09/2020	08:40	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	2	Suspended Solids - Total	21/09/2020	09:15	<5	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	84	Turbidity	21/09/2020	08:25	1.01	NTU	
	Waikouaiti WTP - Consent Discharge	84	Turbidity	21/09/2020	08:40	0.95	NTU	
	Waikouaiti WTP - Waikouaiti River ? Downstream	84	Turbidity	21/09/2020	09:15	0.74	NTU	
	Waikouaiti WTP - Sludge Pond 3 Discharge	6001	Aluminium - Acid Soluble	21/09/2020	08:25	0.291	g/m³	
	Waikouaiti WTP - Consent Discharge	6001	Aluminium - Acid Soluble	21/09/2020	08:40	0.544	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	6001	Aluminium - Acid Soluble	21/09/2020	09:15	0.04	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	9401	ICP-MS - 1 Element	21/09/2020	08:25	Completed		
	Waikouaiti WTP - Consent Discharge	9401	ICP-MS - 1 Element	21/09/2020	08:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Downstream	9401	ICP-MS - 1 Element	21/09/2020	09:15	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0053F	Temperature - Field	21/09/2020	08:25	9.7	Deg C	
	Waikouaiti WTP - Consent Discharge	D-0053F	Temperature - Field	21/09/2020	08:40	10	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0053F	Temperature - Field	21/09/2020	09:15	8.9	Deg C	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-0058H	Free Available Chlorine	21/09/2020	08:25	<0.05	g/m³	
	Waikouaiti WTP - Consent Discharge	D-0058H	Free Available Chlorine	21/09/2020	08:40	<0.05	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-0058H	Free Available Chlorine	21/09/2020	09:15	<0.05	g/m³	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-1202	Sampling / Inspection 30 Mins	21/09/2020	08:25	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-1205	Sampling / Inspection 2 hours	21/09/2020	08:25	Completed		
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	21/09/2020	08:25	3	cfu/100ml (3 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0102	Faecal Coliforms by MF - Environmental Water	21/09/2020	08:40	5	cfu/100ml (5 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0102	Faecal Coliforms by MF - Environmental Water	21/09/2020	09:15	25	cfu/100ml (25 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0107	Enterococci - Environmental water	21/09/2020	08:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0107	Enterococci - Environmental water	21/09/2020	08:40	1	cfu/100mL (1 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0107	Enterococci - Environmental water	21/09/2020	09:15	6	cfu/100mL (6 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	21/09/2020	08:25	170	MPN/100ml (166.4 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	21/09/2020	08:40	96	MPN/100ml (96 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	21/09/2020	09:15	93	MPN/100ml (93.2 x 1)	
	Waikouaiti WTP - Sludge Pond 3 Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	21/09/2020	08:25	4	MPN/100mL (4.1 x 1)	
	Waikouaiti WTP - Consent Discharge	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	21/09/2020	08:40	2	MPN/100mL (2 x 1)	
	Waikouaiti WTP - Waikouaiti River ? Downstream	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	21/09/2020	09:15	18	MPN/100mL (17.5 x 1)	
Unable to sample due to livestock in paddock	Waikouaiti WTP - Discharge to Tributary ? Upstream	O1420	Sampler Observation	21/09/2020	00:00:00	Unable	to sample due to livestock in paddock	
Unable to sample due to livestock in paddock	Waikouaiti WTP - Discharge to Tributary ? Downstream	O1420	Sampler Observation	21/09/2020	00:00:00	Unable	to sample due to livestock in paddock	
Unable to sample due to livestock in paddock	Waikouaiti WTP - Waikouaiti River ? Upstream	O1420	Sampler Observation	21/09/2020	00:00:00	Unable	to sample due to livestock in paddock	
	Waikouaiti Pre Treatment	D-0084	Turbidity	25/09/2020	10:45	0.59	NTU	
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	25/09/2020	10:45	Completed		
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	25/09/2020	10:45	23	MPN/100mL (23.1 x 1)	
	Karitane Bowls	D-0058H	Free Available Chlorine	25/09/2020	08:50	0.68	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	25/09/2020	08:50	0.8	g/m³	
	Karitane Bowls	D-0084	Turbidity	25/09/2020	08:50	0.09	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	25/09/2020	08:50	8.7	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	25/09/2020	08:50	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	25/09/2020	08:50	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	25/09/2020	11:10	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	25/09/2020	10:45	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	25/09/2020	10:30	7.7		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	25/09/2020	11:10	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	25/09/2020	10:45	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	25/09/2020	10:30	<6	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	40	Total Non-Purgeable Organic Carbon	25/09/2020	11:10	1.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	40	Total Non-Purgeable Organic Carbon	25/09/2020	10:45	1.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	40	Total Non-Purgeable Organic Carbon	25/09/2020	10:30	1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	50	Total Solids - % units	25/09/2020	11:10	<0.1	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	50	Total Solids - % units	25/09/2020	10:45	<0.1	%	
	Waikouaiti WTP - Post Treated Water Reservoir	50	Total Solids - % units	25/09/2020	10:30	<0.1	%	
	Catchment - Waikouaiti River - Pump Station Intake	51	Volatile Solids - % units	25/09/2020	11:10	<1	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	51	Volatile Solids - % units	25/09/2020	10:45	<1	%	
	Waikouaiti WTP - Post Treated Water Reservoir	51	Volatile Solids - % units	25/09/2020	10:30	<1	%	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	25/09/2020	11:10	60	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	25/09/2020	10:45	63	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	25/09/2020	10:30	56	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	73	Bicarbonate by Calculation - requires tests 1 & 52	25/09/2020	11:10	60	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	73	Bicarbonate by Calculation - requires tests 1 & 52	25/09/2020	10:45	62	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	73	Bicarbonate by Calculation - requires tests 1 & 52	25/09/2020	10:30	56	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	74	Carbonate by Calculation - requires tests 1, 52, 73	25/09/2020	11:10	<1	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	74	Carbonate by Calculation - requires tests 1, 52, 73	25/09/2020	10:45	<1	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	74	Carbonate by Calculation - requires tests 1, 52, 73	25/09/2020	10:30	<1	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	76	Free CO2 by Calculation - requires tests 1, 52 & 73	25/09/2020	11:10	2	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	76	Free CO2 by Calculation - requires tests 1, 52 & 73	25/09/2020	10:45	2	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	76	Free CO2 by Calculation - requires tests 1, 52 & 73	25/09/2020	10:30	2	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	25/09/2020	11:10	55	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	25/09/2020	10:45	57	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	25/09/2020	10:30	52	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	84	Turbidity	25/09/2020	11:10	0.54	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	84	Turbidity	25/09/2020	10:45	0.59	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	84	Turbidity	25/09/2020	10:30	0.07	NTU	
	Catchment - Waikouaiti River - Pump Station Intake	123	Total Dissolved Solids - Calc by conductivity meter	25/09/2020	11:10	94	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	123	Total Dissolved Solids - Calc by conductivity meter	25/09/2020	10:45	94	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	123	Total Dissolved Solids - Calc by conductivity meter	25/09/2020	10:30	94	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	440	Dissolved (NP) Organic Carbon	25/09/2020	11:10	1.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	440	Dissolved (NP) Organic Carbon	25/09/2020	10:45	1.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	440	Dissolved (NP) Organic Carbon	25/09/2020	10:30	1.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	601	Fluoride - Add P1859 Filtration	25/09/2020	11:10	0.11	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	25/09/2020	10:45	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	25/09/2020	10:30	0.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	25/09/2020	11:10	11.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	25/09/2020	10:45	11.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	25/09/2020	10:30	13.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	603	Nitrite - Nitrogen - Add P1859 Filtration	25/09/2020	11:10	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	603	Nitrite - Nitrogen - Add P1859 Filtration	25/09/2020	10:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	603	Nitrite - Nitrogen - Add P1859 Filtration	25/09/2020	10:30	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	604	Bromide - Add P1859 Filtration	25/09/2020	11:10	<0.02	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	604	Bromide - Add P1859 Filtration	25/09/2020	10:45	<0.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	604	Bromide - Add P1859 Filtration	25/09/2020	10:30	<0.02	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	605	Nitrate - Nitrogen - Add P1859 Filtration	25/09/2020	11:10	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	25/09/2020	10:45	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	25/09/2020	10:30	0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	25/09/2020	11:10	12.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	25/09/2020	10:45	13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	25/09/2020	10:30	13.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	755	Absorbance at 254 nm	25/09/2020	11:10	0.06		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	755	Absorbance at 254 nm	25/09/2020	10:45	0.05		
	Waikouaiti WTP - Post Treated Water Reservoir	755	Absorbance at 254 nm	25/09/2020	10:30	0.01		
	Catchment - Waikouaiti River - Pump Station Intake	0755B	Absorbance at 254 nm - after filtering	25/09/2020	11:10	0.05		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0755B	Absorbance at 254 nm - after filtering	25/09/2020	10:45	0.05		
	Waikouaiti WTP - Post Treated Water Reservoir	0755B	Absorbance at 254 nm - after filtering	25/09/2020	10:30	0.01		
	Catchment - Waikouaiti River - Pump Station Intake	0755C	Transmittance	25/09/2020	11:10	87.7	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0755C	Transmittance	25/09/2020	10:45	88.5	%	
	Waikouaiti WTP - Post Treated Water Reservoir	0755C	Transmittance	25/09/2020	10:30	97.3	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1628	Phosphorus - Acid Soluble by OES	25/09/2020	10:30	<0.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1643	Silica by OES	25/09/2020	10:30	2.72	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1778B	Phosphate - Total	25/09/2020	11:10	<0.025	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1778B	Phosphate - Total	25/09/2020	10:45	<0.025	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1793	Silica - Total	25/09/2020	11:10	2.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1793	Silica - Total	25/09/2020	10:45	2.63	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	2078	Total Dissolved Phosphorus - Add P1859 Filtration	25/09/2020	11:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2078	Total Dissolved Phosphorus - Add P1859 Filtration	25/09/2020	10:45	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2078	Total Dissolved Phosphorus - Add P1859 Filtration	25/09/2020	10:30	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	25/09/2020	11:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	25/09/2020	10:45	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	25/09/2020	10:30	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	4000a	Total Algae Count - cells	25/09/2020	11:10	48	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000a	Total Algae Count - cells	25/09/2020	10:45	21	Cells per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4000a	Total Algae Count - cells	25/09/2020	10:30	<1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4000b	Total Algae Count - units	25/09/2020	11:10	34	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000b	Total Algae Count - units	25/09/2020	10:45	21	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4000b	Total Algae Count - units	25/09/2020	10:30	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4100a	Green Algae using cells	25/09/2020	11:10	<1	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4100a	Green Algae using cells	25/09/2020	10:45	<1	Cells per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4100a	Green Algae using cells	25/09/2020	10:30	<1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4100b	Green Algae using units	25/09/2020	11:10	<1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4100b	Green Algae using units	25/09/2020	10:45	<1	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4100b	Green Algae using units	25/09/2020	10:30	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4300a	Chrysophyta using cells	25/09/2020	11:10	34	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4300a	Chrysophyta using cells	25/09/2020	10:45	21	Cells per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4300a	Chrysophyta using cells	25/09/2020	10:30	<1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4300b	Chrysophyta using units	25/09/2020	11:10	34	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4300b	Chrysophyta using units	25/09/2020	10:45	21	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4300b	Chrysophyta using units	25/09/2020	10:30	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4309a	Cocconeis cells	25/09/2020	11:10	2	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309a	Cocconeis cells	25/09/2020	10:45	2	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4309b	Cocconeis units	25/09/2020	11:10	2	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309b	Cocconeis units	25/09/2020	10:45	2	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4315a	Cymbella cells	25/09/2020	11:10	2	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4315a	Cymbella cells	25/09/2020	10:45	2	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4315b	Cymbella units	25/09/2020	11:10	2	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4315b	Cymbella units	25/09/2020	10:45	2	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4324a	Epithemia cells	25/09/2020	11:10	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4324b	Epithemia units	25/09/2020	11:10	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4330a	Frustulia cells	25/09/2020	11:10	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4330b	Frustulia units	25/09/2020	11:10	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4332a	Gomphoneis cells	25/09/2020	11:10	2	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4332a	Gomphoneis cells	25/09/2020	10:45	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4332b	Gomphoneis units	25/09/2020	11:10	2	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4332b	Gomphoneis units	25/09/2020	10:45	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4345a	Navicula cells	25/09/2020	11:10	3	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4345b	Navicula units	25/09/2020	11:10	3	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4348a	Nitzschia cells	25/09/2020	11:10	20	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348a	Nitzschia cells	25/09/2020	10:45	15	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4348b	Nitzschia units	25/09/2020	11:10	20	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348b	Nitzschia units	25/09/2020	10:45	15	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4354a	Rhoicosphenia cells	25/09/2020	11:10	2	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4354a	Rhoicosphenia cells	25/09/2020	10:45	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4354b	Rhoicosphenia units	25/09/2020	11:10	2	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4354b	Rhoicosphenia units	25/09/2020	10:45	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4500a	Cyanophyta using cells	25/09/2020	11:10	14	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4500a	Cyanophyta using cells	25/09/2020	10:45	<1	Cells per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4500a	Cyanophyta using cells	25/09/2020	10:30	<1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4500b	Cyanophyta using units	25/09/2020	11:10	<1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4500b	Cyanophyta using units	25/09/2020	10:45	<1	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4500b	Cyanophyta using units	25/09/2020	10:30	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4518a	Phormidium cells	25/09/2020	11:10	14	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4518b	Phormidium units	25/09/2020	11:10	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4700a	Other Algae using cells	25/09/2020	11:10	<1	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4700a	Other Algae using cells	25/09/2020	10:45	<1	Cells per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4700a	Other Algae using cells	25/09/2020	10:30	<1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4700b	Other Algae using units	25/09/2020	11:10	<1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4700b	Other Algae using units	25/09/2020	10:45	<1	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	4700b	Other Algae using units	25/09/2020	10:30	<1	Units per mL	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	25/09/2020	10:30	0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	25/09/2020	10:30	<0.001	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	25/09/2020	10:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	25/09/2020	10:30	0.011	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	25/09/2020	10:30	<0.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	25/09/2020	10:30	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	25/09/2020	10:30	18.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	25/09/2020	10:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	25/09/2020	10:30	0.0007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	25/09/2020	10:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	25/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	25/09/2020	10:30	7.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	25/09/2020	10:30	0.0012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	25/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	25/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	25/09/2020	10:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	25/09/2020	10:30	9.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	25/09/2020	11:10	0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	25/09/2020	10:45	0.007	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	25/09/2020	11:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6602	Antimony - Total	25/09/2020	10:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	25/09/2020	11:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	25/09/2020	10:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	25/09/2020	11:10	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6604	Barium - Total	25/09/2020	10:45	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	25/09/2020	11:10	<0.05	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6607	Boron - Total	25/09/2020	10:45	<0.05	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	25/09/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	25/09/2020	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	25/09/2020	11:10	19.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	25/09/2020	10:45	18.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	25/09/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	25/09/2020	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	25/09/2020	11:10	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	25/09/2020	10:45	0.004	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	25/09/2020	11:10	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	25/09/2020	10:45	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	25/09/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	25/09/2020	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	25/09/2020	11:10	7.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	25/09/2020	10:45	7.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	25/09/2020	11:10	0.017	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	25/09/2020	10:45	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	25/09/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	25/09/2020	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	25/09/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	25/09/2020	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	25/09/2020	11:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	25/09/2020	10:45	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6631	Sodium - Total	25/09/2020	11:10	9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6631	Sodium - Total	25/09/2020	10:45	8.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	25/09/2020	11:10	12.4	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	25/09/2020	10:45	12.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	25/09/2020	10:30	11.6	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	25/09/2020	11:10	9.6	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	25/09/2020	10:45	9.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	25/09/2020	10:30	11.6	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1201	Sampling / Inspection 15 Mins	25/09/2020	10:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	D-1201	Sampling / Inspection 15 Mins	25/09/2020	10:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	25/09/2020	11:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-M0102	Faecal Coliforms by MF - Environmental Water	25/09/2020	11:10	40	cfu/100ml (40 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	25/09/2020	10:45	60	cfu/100ml (60 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0107	Enterococci - Environmental water	25/09/2020	11:10	<4	cfu/100mL (<4 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	25/09/2020	10:45	8	cfu/100mL (8 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	25/09/2020	11:10	200	MPN/100ml (195.6 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	25/09/2020	10:45	240	MPN/100ml (238.2 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	25/09/2020	11:10	38	MPN/100mL (38.3 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	25/09/2020	10:45	29	MPN/100mL (28.8 x 1)	

	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	25/09/2020	10:30	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	25/09/2020	10:30	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	25/09/2020	10:30	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	25/09/2020	10:30	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855B	Aqueous Total Metal Digestion for OES tests	25/09/2020	11:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855B	Aqueous Total Metal Digestion for OES tests	25/09/2020	10:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	25/09/2020	11:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	25/09/2020	10:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	25/09/2020	10:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	602	Chloride - Add P1859 Filtration	25/09/2020	10:30	14	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	602	Chloride - Add P1859 Filtration	25/09/2020	10:45	14.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	602	Chloride - Add P1859 Filtration	25/09/2020	11:00	13.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	602	Chloride - Add P1859 Filtration	25/09/2020	11:15	13.9	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	602	Chloride - Add P1859 Filtration	25/09/2020	11:30	14.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	607	Sulphate - Add P1859 Filtration	25/09/2020	10:30	13	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	607	Sulphate - Add P1859 Filtration	25/09/2020	10:45	13.4	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	607	Sulphate - Add P1859 Filtration	25/09/2020	11:00	13.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	607	Sulphate - Add P1859 Filtration	25/09/2020	11:15	13.1	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	607	Sulphate - Add P1859 Filtration	25/09/2020	11:30	13.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6001	Aluminium - Acid Soluble	25/09/2020	10:30	0.007	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6001	Aluminium - Acid Soluble	25/09/2020	10:45	0.011	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6001	Aluminium - Acid Soluble	25/09/2020	11:00	0.013	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6001	Aluminium - Acid Soluble	25/09/2020	11:15	0.011	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6001	Aluminium - Acid Soluble	25/09/2020	11:30	0.007	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6010	Calcium - Acid Soluble	25/09/2020	10:30	16	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6010	Calcium - Acid Soluble	25/09/2020	10:45	17.6	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6010	Calcium - Acid Soluble	25/09/2020	11:00	16.2	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6010	Calcium - Acid Soluble	25/09/2020	11:15	16.4	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6010	Calcium - Acid Soluble	25/09/2020	11:30	18.3	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6013	Copper - Acid Soluble	25/09/2020	10:30	0.0007	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6013	Copper - Acid Soluble	25/09/2020	10:45	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6013	Copper - Acid Soluble	25/09/2020	11:00	0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6013	Copper - Acid Soluble	25/09/2020	11:15	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6013	Copper - Acid Soluble	25/09/2020	11:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6017	Iron - Acid Soluble	25/09/2020	10:30	0.34	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6017	Iron - Acid Soluble	25/09/2020	10:45	0.46	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6017	Iron - Acid Soluble	25/09/2020	11:00	0.54	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6017	Iron - Acid Soluble	25/09/2020	11:15	0.49	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6017	Iron - Acid Soluble	25/09/2020	11:30	0.12	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6018	Lead - Acid Soluble	25/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6018	Lead - Acid Soluble	25/09/2020	10:45	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6018	Lead - Acid Soluble	25/09/2020	11:00	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6018	Lead - Acid Soluble	25/09/2020	11:15	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6018	Lead - Acid Soluble	25/09/2020	11:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6020	Magnesium - Acid Soluble	25/09/2020	10:30	7.28	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6020	Magnesium - Acid Soluble	25/09/2020	10:45	6.46	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6020	Magnesium - Acid Soluble	25/09/2020	11:00	7.37	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6020	Magnesium - Acid Soluble	25/09/2020	11:15	6.38	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6020	Magnesium - Acid Soluble	25/09/2020	11:30	6.51	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6021	Manganese - Acid Soluble	25/09/2020	10:30	0.0183	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6021	Manganese - Acid Soluble	25/09/2020	10:45	0.0196	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6021	Manganese - Acid Soluble	25/09/2020	11:00	0.0263	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6021	Manganese - Acid Soluble	25/09/2020	11:15	0.0211	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6021	Manganese - Acid Soluble	25/09/2020	11:30	0.0118	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6024	Nickel - Acid Soluble	25/09/2020	10:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6024	Nickel - Acid Soluble	25/09/2020	10:45	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6024	Nickel - Acid Soluble	25/09/2020	11:00	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6024	Nickel - Acid Soluble	25/09/2020	11:15	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6024	Nickel - Acid Soluble	25/09/2020	11:30	<0.0005	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	6038	Zinc - Acid Soluble	25/09/2020	10:30	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	6038	Zinc - Acid Soluble	25/09/2020	10:45	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	6038	Zinc - Acid Soluble	25/09/2020	11:00	0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	6038	Zinc - Acid Soluble	25/09/2020	11:15	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	6038	Zinc - Acid Soluble	25/09/2020	11:30	<0.002	g/m³	
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	9402	ICP-MS - 2 Elements	25/09/2020	10:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	9402	ICP-MS - 2 Elements	25/09/2020	10:45	Completed		

	Waikouaiti DZ ? Golf Club Metals Investigation 1C	9402	ICP-MS - 2 Elements	25/09/2020	11:00	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	9402	ICP-MS - 2 Elements	25/09/2020	11:15	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	9402	ICP-MS - 2 Elements	25/09/2020	11:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1A ? First Flush	P1859	Sample Filtration	25/09/2020	10:30	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1B	P1859	Sample Filtration	25/09/2020	10:45	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1C	P1859	Sample Filtration	25/09/2020	11:00	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1D	P1859	Sample Filtration	25/09/2020	11:15	Completed		
	Waikouaiti DZ ? Golf Club Metals Investigation 1E	P1859	Sample Filtration	25/09/2020	11:30	Completed		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	25/09/2020	09:10	53	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	25/09/2020	09:20	51	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	25/09/2020	08:40	51	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	25/09/2020	08:50	53	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	25/09/2020	09:35	53	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	25/09/2020	09:45	54	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	25/09/2020	09:10	14.7	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	25/09/2020	09:20	14.7	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	25/09/2020	08:40	14.5	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	25/09/2020	08:50	14.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	25/09/2020	09:35	14.7	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	25/09/2020	09:45	14.7	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	25/09/2020	09:10	13.8	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	25/09/2020	09:20	13.7	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	25/09/2020	08:40	13.8	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	25/09/2020	08:50	13.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	25/09/2020	09:35	13.9	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	25/09/2020	09:45	13.8	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	25/09/2020	09:10	12	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	25/09/2020	09:20	12.2	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	25/09/2020	08:40	12.3	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	25/09/2020	08:50	13.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	25/09/2020	09:35	12.9	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	25/09/2020	09:45	12.9	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	25/09/2020	09:10	0.004	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	25/09/2020	09:20	0.004	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	25/09/2020	08:40	0.005	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	25/09/2020	08:50	0.005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	25/09/2020	09:35	0.004	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	25/09/2020	09:45	0.018	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	25/09/2020	09:10	16.8	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	25/09/2020	09:20	15.6	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	25/09/2020	08:40	17.6	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	25/09/2020	08:50	16.6	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	25/09/2020	09:35	18.3	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	25/09/2020	09:45	16.1	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	25/09/2020	09:10	1.59	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	25/09/2020	09:20	0.0355	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	25/09/2020	08:40	0.0217	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	25/09/2020	08:50	0.0056	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	25/09/2020	09:35	0.0138	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	25/09/2020	09:45	0.0529	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	25/09/2020	09:10	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	25/09/2020	09:20	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	25/09/2020	08:40	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	25/09/2020	08:50	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	25/09/2020	09:35	0.09	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	25/09/2020	09:45	0.59	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	25/09/2020	09:10	0.0013	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	25/09/2020	09:20	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	25/09/2020	08:40	0.0038	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	25/09/2020	08:50	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	25/09/2020	09:35	0.0018	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	25/09/2020	09:45	0.0041	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	25/09/2020	09:10	6.42	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	25/09/2020	09:20	7.29	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	25/09/2020	08:40	6.29	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	25/09/2020	08:50	6.62	g/m³	

	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	25/09/2020	09:35	6.2	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	25/09/2020	09:45	6.44	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	25/09/2020	09:10	0.0008	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	25/09/2020	09:20	0.0014	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	25/09/2020	08:40	0.0006	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	25/09/2020	08:50	0.001	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	25/09/2020	09:35	0.0022	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	25/09/2020	09:45	0.0185	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	25/09/2020	09:10	0.0006	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	25/09/2020	09:20	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	25/09/2020	08:40	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	25/09/2020	08:50	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	25/09/2020	09:35	<0.0005	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	25/09/2020	09:45	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	25/09/2020	09:10	0.04	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	25/09/2020	09:20	0.002	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	25/09/2020	08:40	0.108	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	25/09/2020	08:50	0.004	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	25/09/2020	09:35	0.141	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	25/09/2020	09:45	0.052	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	25/09/2020	09:10	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	25/09/2020	09:20	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	25/09/2020	08:40	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	25/09/2020	08:50	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	25/09/2020	09:35	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	25/09/2020	09:45	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	25/09/2020	09:10	6.8		
	TAB Waikouaiti	D-0001F	pH - Field	25/09/2020	09:20	6.9		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	25/09/2020	08:40	6.8		
	Karitane Bowls	D-0001F	pH - Field	25/09/2020	08:50	6.8		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	25/09/2020	09:35	6.6		
	Waikouaiti Golf Club	D-0001F	pH - Field	25/09/2020	09:45	6.2		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	25/09/2020	09:10	7.2	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	25/09/2020	09:20	8.6	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	25/09/2020	08:40	9.8	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	25/09/2020	08:50	9.2	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	25/09/2020	09:35	8.7	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	25/09/2020	09:45	9.1	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	25/09/2020	09:10	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	25/09/2020	09:20	0.67	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	25/09/2020	08:40	<0.05	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	25/09/2020	08:50	0.68	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	25/09/2020	09:35	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	25/09/2020	09:45	0.23	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	25/09/2020	09:10	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	25/09/2020	09:20	0.8	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	25/09/2020	08:40	0.1	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	25/09/2020	08:50	0.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	25/09/2020	09:35	<0.05	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	25/09/2020	09:45	0.3	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	25/09/2020	09:10	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	25/09/2020	09:10	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	25/09/2020	09:10	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	25/09/2020	09:20	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	25/09/2020	08:40	Completed		
	Karitane Bowls	P1859	Sample Filtration	25/09/2020	08:50	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	25/09/2020	09:35	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	25/09/2020	09:45	Completed		

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	01/10/2020	09:50	0.77	g/m³	(.2 - 5)	
	TAB Waikouaiti	D-0066H	Total Chlorine	01/10/2020	09:50	0.9	g/m³		
	TAB Waikouaiti	D-0084	Turbidity	01/10/2020	09:50	0.08	NTU		
	TAB Waikouaiti	D-1310	Temperature on arrival	01/10/2020	09:50	7.3	Deg C		
	TAB Waikouaiti	D-M0411	E. coli by Colilert MPN 51 Wells - Drinking Water	01/10/2020	09:50	<1	MPN/100mL	(0 - 0)	
	TAB Waikouaiti	D-M0412	Total Coliforms by Colilert MPN -51 Wells -Drinking Water	01/10/2020	09:50	<1	MPN/100ml	(0 - 0)	
	Karitane Bowls	D-0058H	Free Available Chlorine	08/10/2020	17:30	0.79	g/m³	(.2 - 5)	
	Karitane Bowls	D-0066H	Total Chlorine	08/10/2020	17:30	0.9	g/m³		
	Karitane Bowls	D-0084	Turbidity	08/10/2020	17:30	0.08	NTU		
	Karitane Bowls	D-1310	Temperature on arrival	08/10/2020	17:30	6.4	Deg C		
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	08/10/2020	17:30	<1	MPN/100mL	(0 - 0)	
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	08/10/2020	17:30	<1	MPN/100ml	(0 - 0)	
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	09/10/2020	14:25	57	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	09/10/2020	14:30	56	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	09/10/2020	14:46	55	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	09/10/2020	14:56	56	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	09/10/2020	13:50	54	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	09/10/2020	14:10	56	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	09/10/2020	14:25	15.7	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	09/10/2020	14:30	16	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	09/10/2020	14:46	15.9	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	09/10/2020	14:56	16	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	09/10/2020	13:50	15.6	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	09/10/2020	14:10	15.8	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	09/10/2020	14:25	13.8	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	09/10/2020	14:30	13.7	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	09/10/2020	14:46	13.8	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	09/10/2020	14:56	13.7	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	09/10/2020	13:50	13.9	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	09/10/2020	14:10	13.8	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	09/10/2020	14:25	12.7	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	09/10/2020	14:30	13	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	09/10/2020	14:46	13.2	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	09/10/2020	14:56	12.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	09/10/2020	13:50	13.4	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	09/10/2020	14:10	13.4	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	09/10/2020	14:25	0.004	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	09/10/2020	14:30	0.006	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	09/10/2020	14:46	0.005	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	09/10/2020	14:56	0.006	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	09/10/2020	13:50	0.007	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	09/10/2020	14:10	0.041	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	09/10/2020	14:25	16.9	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	09/10/2020	14:30	16.8	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	09/10/2020	14:46	17.9	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	09/10/2020	14:56	17.3	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	09/10/2020	13:50	17.8	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	09/10/2020	14:10	16.8	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	09/10/2020	14:25	1.22	g/m³		
	TAB Waikouaiti	6013	Copper - Acid Soluble	09/10/2020	14:30	0.0704	g/m³		
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	09/10/2020	14:46	0.028	g/m³		
	Karitane Bowls	6013	Copper - Acid Soluble	09/10/2020	14:56	0.011	g/m³		
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	09/10/2020	13:50	0.0363	g/m³		
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	09/10/2020	14:10	0.0942	g/m³		
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	09/10/2020	14:25	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	09/10/2020	14:30	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	09/10/2020	14:46	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	09/10/2020	14:56	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	09/10/2020	13:50	0.18	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	09/10/2020	14:10	1.06	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	09/10/2020	14:25	0.001	g/m³		

	TAB Waikouaiti	6018	Lead - Acid Soluble	09/10/2020	14:30	0.0006	g/m³		
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	09/10/2020	14:46	0.0017	g/m³		
	Karitane Bowls	6018	Lead - Acid Soluble	09/10/2020	14:56	0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	09/10/2020	13:50	0.0015	g/m³		
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	09/10/2020	14:10	0.0121	g/m³		
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	09/10/2020	14:25	7.66	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	09/10/2020	14:30	7.38	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	09/10/2020	14:46	7.37	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	09/10/2020	14:56	7.19	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	09/10/2020	13:50	7.06	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	09/10/2020	14:10	6.61	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	09/10/2020	14:25	0.0011	g/m³		
	TAB Waikouaiti	6021	Manganese - Acid Soluble	09/10/2020	14:30	0.0012	g/m³		
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	09/10/2020	14:46	<0.0005	g/m³		
	Karitane Bowls	6021	Manganese - Acid Soluble	09/10/2020	14:56	0.0011	g/m³		
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	09/10/2020	13:50	0.0046	g/m³		
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	09/10/2020	14:10	0.0339	g/m³		
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	09/10/2020	14:25	<0.0005	g/m³		
	TAB Waikouaiti	6024	Nickel - Acid Soluble	09/10/2020	14:30	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	09/10/2020	14:46	<0.0005	g/m³		
	Karitane Bowls	6024	Nickel - Acid Soluble	09/10/2020	14:56	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	09/10/2020	13:50	0.0006	g/m³		
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	09/10/2020	14:10	0.0007	g/m³		
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	09/10/2020	14:25	0.037	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	09/10/2020	14:30	0.017	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	09/10/2020	14:46	0.037	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	09/10/2020	14:56	0.009	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	09/10/2020	13:50	0.071	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	09/10/2020	14:10	0.04	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	09/10/2020	14:25	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	09/10/2020	14:30	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	09/10/2020	14:46	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	09/10/2020	14:56	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	09/10/2020	13:50	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	09/10/2020	14:10	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	09/10/2020	14:25	7.4			
	TAB Waikouaiti	D-0001F	pH - Field	09/10/2020	14:30	7.3			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	09/10/2020	14:46	7.3			
	Karitane Bowls	D-0001F	pH - Field	09/10/2020	14:56	7.3			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	09/10/2020	13:50	7.3			
	Waikouaiti Golf Club	D-0001F	pH - Field	09/10/2020	14:10	7.4			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	09/10/2020	14:25	6.9	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	09/10/2020	14:30	7.5	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	09/10/2020	14:46	7.4	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	09/10/2020	14:56	7.6	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	09/10/2020	13:50	7.9	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	09/10/2020	14:10	7.4	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	09/10/2020	14:25	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	09/10/2020	14:30	0.62	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	09/10/2020	14:46	0.57	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	09/10/2020	14:56	0.66	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	09/10/2020	13:50	0.08	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	09/10/2020	14:10	0.13	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	09/10/2020	14:25	<0.05	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	09/10/2020	14:30	0.7	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	09/10/2020	14:46	0.6	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	09/10/2020	14:56	0.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	09/10/2020	13:50	0.1	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	09/10/2020	14:10	0.2	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	09/10/2020	14:25	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	09/10/2020	14:25	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	09/10/2020	14:25	Completed			

	TAB Waikouaiti	P1859	Sample Filtration	09/10/2020	14:30	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	09/10/2020	14:46	Completed			
	Karitane Bowls	P1859	Sample Filtration	09/10/2020	14:56	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	09/10/2020	13:50	Completed			
	Waikouaiti Golf Club	P1859	Sample Filtration	09/10/2020	14:10	Completed			
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	16/10/2020	10:05	61	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	16/10/2020	10:15	64	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	16/10/2020	10:35	61	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	16/10/2020	10:45	64	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	16/10/2020	09:40	60	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	16/10/2020	09:55	60	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	16/10/2020	10:05	15.4	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	16/10/2020	10:15	16	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	16/10/2020	10:35	16.1	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	16/10/2020	10:45	16.2	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	16/10/2020	09:40	15.8	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	16/10/2020	09:55	15.6	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	16/10/2020	10:05	14.2	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	16/10/2020	10:15	14.3	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	16/10/2020	10:35	14.2	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	16/10/2020	10:45	14.1	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	16/10/2020	09:40	14.2	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	16/10/2020	09:55	14.1	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	16/10/2020	10:05	12.7	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	16/10/2020	10:15	12.6	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	16/10/2020	10:35	12.2	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	16/10/2020	10:45	12.7	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	16/10/2020	09:40	12.6	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	16/10/2020	09:55	12.6	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	16/10/2020	10:05	0.004	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	16/10/2020	10:15	0.008	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	16/10/2020	10:35	0.007	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	16/10/2020	10:45	0.009	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	16/10/2020	09:40	0.006	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	16/10/2020	09:55	0.02	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	16/10/2020	10:05	17.6	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	16/10/2020	10:15	17	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	16/10/2020	10:35	18.6	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	16/10/2020	10:45	17.7	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	16/10/2020	09:40	18.6	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	16/10/2020	09:55	18.7	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	16/10/2020	10:05	1.37	g/m³		
	TAB Waikouaiti	6013	Copper - Acid Soluble	16/10/2020	10:15	0.0393	g/m³		
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	16/10/2020	10:35	0.0287	g/m³		
	Karitane Bowls	6013	Copper - Acid Soluble	16/10/2020	10:45	0.0059	g/m³		
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	16/10/2020	09:40	0.0138	g/m³		
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	16/10/2020	09:55	0.0488	g/m³		
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	16/10/2020	10:05	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	16/10/2020	10:15	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	16/10/2020	10:35	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	16/10/2020	10:45	0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	16/10/2020	09:40	0.12	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	16/10/2020	09:55	0.5	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	16/10/2020	10:05	<0.0005	g/m³		
	TAB Waikouaiti	6018	Lead - Acid Soluble	16/10/2020	10:15	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	16/10/2020	10:35	0.0028	g/m³		
	Karitane Bowls	6018	Lead - Acid Soluble	16/10/2020	10:45	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	16/10/2020	09:40	0.0008	g/m³		
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	16/10/2020	09:55	0.0039	g/m³		
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	16/10/2020	10:05	8.61	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	16/10/2020	10:15	8.65	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	16/10/2020	10:35	8.32	g/m³		

	Karitane Bowls	6020	Magnesium - Acid Soluble	16/10/2020	10:45	8.6	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	16/10/2020	09:40	8.39	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	16/10/2020	09:55	8.51	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	16/10/2020	10:05	0.0006	g/m³		
	TAB Waikouaiti	6021	Manganese - Acid Soluble	16/10/2020	10:15	0.001	g/m³		
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	16/10/2020	10:35	0.0005	g/m³		
	Karitane Bowls	6021	Manganese - Acid Soluble	16/10/2020	10:45	0.001	g/m³		
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	16/10/2020	09:40	0.0025	g/m³		
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	16/10/2020	09:55	0.0176	g/m³		
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	16/10/2020	10:05	0.0007	g/m³		
	TAB Waikouaiti	6024	Nickel - Acid Soluble	16/10/2020	10:15	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	16/10/2020	10:35	<0.0005	g/m³		
	Karitane Bowls	6024	Nickel - Acid Soluble	16/10/2020	10:45	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	16/10/2020	09:40	<0.0005	g/m³		
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	16/10/2020	09:55	<0.0005	g/m³		
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	16/10/2020	10:05	0.04	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	16/10/2020	10:15	0.004	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	16/10/2020	10:35	0.048	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	16/10/2020	10:45	0.003	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	16/10/2020	09:40	0.087	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	16/10/2020	09:55	0.033	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	16/10/2020	10:05	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	16/10/2020	10:15	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	16/10/2020	10:35	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	16/10/2020	10:45	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	16/10/2020	09:40	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	16/10/2020	09:55	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	16/10/2020	10:05	7.2			
	TAB Waikouaiti	D-0001F	pH - Field	16/10/2020	10:15	7.6			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	16/10/2020	10:35	7.5			
	Karitane Bowls	D-0001F	pH - Field	16/10/2020	10:45	7.5			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	16/10/2020	09:40	7.5			
	Waikouaiti Golf Club	D-0001F	pH - Field	16/10/2020	09:55	7.6			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	16/10/2020	10:05	12.9	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	16/10/2020	10:15	8.6	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	16/10/2020	10:35	8.2	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	16/10/2020	10:45	8.3	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	16/10/2020	09:40	10.3	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	16/10/2020	09:55	8.4	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	16/10/2020	10:05	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	16/10/2020	10:15	0.66	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	16/10/2020	10:35	0.47	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	16/10/2020	10:45	0.63	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	16/10/2020	09:40	<0.05	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	16/10/2020	09:55	0.1	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	16/10/2020	10:05	0.1	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	16/10/2020	10:15	0.8	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	16/10/2020	10:35	0.6	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	16/10/2020	10:45	0.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	16/10/2020	09:40	<0.05	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	16/10/2020	09:55	0.2	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	16/10/2020	10:05	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	16/10/2020	10:05	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	16/10/2020	10:05	Completed			
	TAB Waikouaiti	P1859	Sample Filtration	16/10/2020	10:15	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	16/10/2020	10:35	Completed			
	Karitane Bowls	P1859	Sample Filtration	16/10/2020	10:45	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	16/10/2020	09:40	Completed			
	Waikouaiti Golf Club	P1859	Sample Filtration	16/10/2020	09:55	Completed			
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	21/10/2020	13:40	68	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	21/10/2020	13:50	65	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	21/10/2020	13:20	65	g CaCO3/m³		

	Karitane Bowls	52	Alkalinity - Total	21/10/2020	13:25	66	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	21/10/2020	14:10	65	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	21/10/2020	14:18	66	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	21/10/2020	13:40	16.2	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	21/10/2020	13:50	16.7	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	21/10/2020	13:20	16.5	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	21/10/2020	13:25	16.6	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	21/10/2020	14:10	16.5	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	21/10/2020	14:18	16.4	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	21/10/2020	13:40	14.2	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	21/10/2020	13:50	14.7	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	21/10/2020	13:20	14.5	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	21/10/2020	13:25	14	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	21/10/2020	14:10	14	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	21/10/2020	14:18	14.1	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	21/10/2020	13:40	12.3	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	21/10/2020	13:50	11.3	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	21/10/2020	13:20	12.3	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	21/10/2020	13:25	11.2	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	21/10/2020	14:10	11.6	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	21/10/2020	14:18	11.8	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	21/10/2020	13:40	0.004	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	21/10/2020	13:50	0.007	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	21/10/2020	13:20	0.01	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	21/10/2020	13:25	0.008	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	21/10/2020	14:10	0.007	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	21/10/2020	14:18	0.007	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	21/10/2020	13:40	15	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	21/10/2020	13:50	15.5	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	21/10/2020	13:20	15.9	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	21/10/2020	13:25	15.9	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	21/10/2020	14:10	16.5	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	21/10/2020	14:18	16.5	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	21/10/2020	13:40	1.24	g/m³		
	TAB Waikouaiti	6013	Copper - Acid Soluble	21/10/2020	13:50	0.0503	g/m³		
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	21/10/2020	13:20	0.04	g/m³		
	Karitane Bowls	6013	Copper - Acid Soluble	21/10/2020	13:25	0.0064	g/m³		
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	21/10/2020	14:10	0.0125	g/m³		
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	21/10/2020	14:18	0.0188	g/m³		
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	21/10/2020	13:40	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	21/10/2020	13:50	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	21/10/2020	13:20	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	21/10/2020	13:25	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	21/10/2020	14:10	0.04	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	21/10/2020	14:18	0.04	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	21/10/2020	13:40	0.0005	g/m³		
	TAB Waikouaiti	6018	Lead - Acid Soluble	21/10/2020	13:50	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	21/10/2020	13:20	0.0081	g/m³		
	Karitane Bowls	6018	Lead - Acid Soluble	21/10/2020	13:25	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	21/10/2020	14:10	<0.0005	g/m³		
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	21/10/2020	14:18	0.0008	g/m³		
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	21/10/2020	13:40	8.14	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	21/10/2020	13:50	7.41	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	21/10/2020	13:20	7.15	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	21/10/2020	13:25	6.97	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	21/10/2020	14:10	7.12	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	21/10/2020	14:18	7.13	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	21/10/2020	13:40	0.0007	g/m³		
	TAB Waikouaiti	6021	Manganese - Acid Soluble	21/10/2020	13:50	0.0008	g/m³		
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	21/10/2020	13:20	<0.0005	g/m³		
	Karitane Bowls	6021	Manganese - Acid Soluble	21/10/2020	13:25	0.0006	g/m³		
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	21/10/2020	14:10	0.0013	g/m³		

	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	21/10/2020	14:18	0.0009	g/m³		
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	21/10/2020	13:40	<0.0005	g/m³		
	TAB Waikouaiti	6024	Nickel - Acid Soluble	21/10/2020	13:50	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	21/10/2020	13:20	<0.0005	g/m³		
	Karitane Bowls	6024	Nickel - Acid Soluble	21/10/2020	13:25	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	21/10/2020	14:10	<0.0005	g/m³		
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	21/10/2020	14:18	<0.0005	g/m³		
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	21/10/2020	13:40	0.037	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	21/10/2020	13:50	0.003	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	21/10/2020	13:20	0.175	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	21/10/2020	13:25	0.005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	21/10/2020	14:10	0.038	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	21/10/2020	14:18	0.021	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	21/10/2020	13:40	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	21/10/2020	13:50	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	21/10/2020	13:20	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	21/10/2020	13:25	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	21/10/2020	14:10	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	21/10/2020	14:18	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	21/10/2020	13:40	7.4			
	TAB Waikouaiti	D-0001F	pH - Field	21/10/2020	13:50	7.8			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	21/10/2020	13:20	7.4			
	Karitane Bowls	D-0001F	pH - Field	21/10/2020	13:25	7.4			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	21/10/2020	14:10	7.6			
	Waikouaiti Golf Club	D-0001F	pH - Field	21/10/2020	14:18	7.8			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	21/10/2020	13:40	6.9	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	21/10/2020	13:50	7.9	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	21/10/2020	13:20	7.8	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	21/10/2020	13:25	9.1	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	21/10/2020	14:10	9.1	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	21/10/2020	14:18	9.4	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	21/10/2020	13:40	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	21/10/2020	13:50	0.66	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	21/10/2020	13:20	0.35	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	21/10/2020	13:25	0.71	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	21/10/2020	14:10	0.15	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	21/10/2020	14:18	0.17	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	21/10/2020	13:40	<0.05	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	21/10/2020	13:50	0.7	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	21/10/2020	13:20	0.4	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	21/10/2020	13:25	0.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	21/10/2020	14:10	0.2	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	21/10/2020	14:18	0.2	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	21/10/2020	13:40	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	21/10/2020	13:40	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	21/10/2020	13:40	Completed			
	TAB Waikouaiti	P1859	Sample Filtration	21/10/2020	13:50	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	21/10/2020	13:20	Completed			
	Karitane Bowls	P1859	Sample Filtration	21/10/2020	13:25	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	21/10/2020	14:10	Completed			
	Waikouaiti Golf Club	P1859	Sample Filtration	21/10/2020	14:18	Completed			
	Waikouaiti Pre Treatment	D-0084	Turbidity	21/10/2020	10:30	0.09	NTU		
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	21/10/2020	10:30	Completed			
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	21/10/2020	10:30	<1	MPN/100mL (<1 x 1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	61	Chloride	30/10/2020	12:45	10	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	61	Chloride	30/10/2020	13:00	11	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	61	Chloride	30/10/2020	13:00:00	12	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	61	Chloride	30/10/2020	12:40	13	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	30/10/2020	12:45	0.12	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	601	Fluoride - Add P1859 Filtration	30/10/2020	13:00	0.11	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	30/10/2020	12:40	0.12	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	30/10/2020	12:45	0.19	g/m³		

	Waikouaiti WTP - Containerised Plant Filtrate	605	Nitrate - Nitrogen - Add P1859 Filtration	30/10/2020	13:00	0.02	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	30/10/2020	12:40	0.02	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	30/10/2020	12:45	14.5	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	30/10/2020	13:00	14.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	30/10/2020	12:40	12.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	704	Bromide - Ultra Trace	30/10/2020	12:45	0.024	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	704	Bromide - Ultra Trace	30/10/2020	13:00	0.025	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	704	Bromide - Ultra Trace	30/10/2020	12:40	<0.005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	30/10/2020	13:00	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	30/10/2020	12:40	0.007	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6002	Antimony - Acid Soluble	30/10/2020	13:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	30/10/2020	12:40	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	30/10/2020	13:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	30/10/2020	12:40	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6004	Barium - Acid Soluble	30/10/2020	13:00	0.013	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	30/10/2020	12:40	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6007	Boron - Acid Soluble	30/10/2020	13:00	<0.03	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	30/10/2020	12:40	<0.03	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	30/10/2020	13:00	<0.0002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	30/10/2020	12:40	<0.0002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	30/10/2020	13:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	30/10/2020	12:40	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	30/10/2020	13:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	30/10/2020	12:40	0.0008	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	30/10/2020	13:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	30/10/2020	12:40	0.0006	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	30/10/2020	13:00	0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	30/10/2020	12:40	0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	30/10/2020	13:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	30/10/2020	12:40	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	30/10/2020	13:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	30/10/2020	12:40	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	30/10/2020	13:00	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	30/10/2020	12:40	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	30/10/2020	12:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6702	Antimony - Dissolved	30/10/2020	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	30/10/2020	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6704	Barium - Dissolved	30/10/2020	12:45	0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6707	Boron - Dissolved	30/10/2020	12:45	<0.03	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	30/10/2020	12:45	<0.0002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	30/10/2020	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	30/10/2020	12:45	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	30/10/2020	12:45	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	30/10/2020	12:45	0.0011	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	30/10/2020	12:45	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	30/10/2020	12:45	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	30/10/2020	12:45	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV001	Aldrin and Dieldrin	30/10/2020	12:45	<0.00003	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV001	Aldrin and Dieldrin	30/10/2020	13:00	<0.00003	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV001	Aldrin and Dieldrin	30/10/2020	12:40	<0.00003	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV007	DDT and Isomers	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV007	DDT and Isomers	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV007	DDT and Isomers	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV020	Cyanazine	30/10/2020	12:45	<0.0007	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV020	Cyanazine	30/10/2020	13:00	<0.0007	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV020	Cyanazine	30/10/2020	12:40	<0.0007	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV027	Oryzalin	30/10/2020	12:45	<0.010	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV027	Oryzalin	30/10/2020	13:00	<0.010	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV027	Oryzalin	30/10/2020	12:40	<0.010	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV033	Terbacil	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV033	Terbacil	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV033	Terbacil	30/10/2020	12:40	<0.001	mg/L		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV036	Azinphos Methyl	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV036	Azinphos Methyl	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV036	Azinphos Methyl	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV040	Aldicarb	30/10/2020	12:45	<0.006	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV040	Aldicarb	30/10/2020	13:00	<0.006	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV040	Aldicarb	30/10/2020	12:40	<0.006	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV042	Chlorotoluron	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV042	Chlorotoluron	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV042	Chlorotoluron	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV043	Diuron	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV043	Diuron	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV043	Diuron	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV044	Isoproturon	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV044	Isoproturon	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV044	Isoproturon	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV045	Primisulfuron-methyl	30/10/2020	12:45	<0.100	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV045	Primisulfuron-methyl	30/10/2020	13:00	<0.100	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV045	Primisulfuron-methyl	30/10/2020	12:40	<0.100	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	LS-SV046	Thiabendazole	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	LS-SV046	Thiabendazole	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV046	Thiabendazole	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	30/10/2020	12:45	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	30/10/2020	13:00	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	30/10/2020	12:40	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-003	a-chlordane	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-003	a-chlordane	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-003	a-chlordane	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-010	Endrin	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-010	Endrin	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-010	Endrin	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-017	Lindane (g-BHC)	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-017	Lindane (g-BHC)	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-017	Lindane (g-BHC)	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-018	Methoxychlor	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-018	Methoxychlor	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-018	Methoxychlor	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-022	Procymidone	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-022	Procymidone	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-022	Procymidone	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-025	Alachlor	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-025	Alachlor	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-025	Alachlor	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-027	Atrazine	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-027	Atrazine	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-027	Atrazine	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-028	Bromacil	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-028	Bromacil	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-028	Bromacil	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-029	Carbofuran	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-029	Carbofuran	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-029	Carbofuran	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-032	Metalaxyl-M	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-032	Metalaxyl-M	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-032	Metalaxyl-M	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-033	Metolachlor	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-033	Metolachlor	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-033	Metolachlor	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-034	Metribuzin	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-034	Metribuzin	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-034	Metribuzin	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-035	Molinate	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-035	Molinate	30/10/2020	13:00	<0.0001	mg/L		

	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-035	Molinate	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-037	Oxadiazon	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-037	Oxadiazon	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-037	Oxadiazon	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-038	Pendimethalin	30/10/2020	12:45	<0.002	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-038	Pendimethalin	30/10/2020	13:00	<0.002	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-038	Pendimethalin	30/10/2020	12:40	<0.002	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-039	Propazine	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-039	Propazine	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-039	Propazine	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-040	Pyriproxyfen	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-040	Pyriproxyfen	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-040	Pyriproxyfen	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-041	Simazine	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-041	Simazine	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-041	Simazine	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-042	Terbuthylazine	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-042	Terbuthylazine	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-042	Terbuthylazine	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-043	Trifluralin	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-043	Trifluralin	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-043	Trifluralin	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-044	Hexazinone	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-044	Hexazinone	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-044	Hexazinone	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-045	Chlorpyrifos	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-045	Chlorpyrifos	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-045	Chlorpyrifos	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-047	Dimethoate	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-047	Dimethoate	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-047	Dimethoate	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-048	Pirimiphos methyl	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-048	Pirimiphos methyl	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-048	Pirimiphos methyl	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-053	Benzo(a)pyrene	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-053	Benzo(a)pyrene	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-053	Benzo(a)pyrene	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	SVOC-073	Bis(2-ethylhexyl)phthalate	30/10/2020	12:45	<0.0010	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	SVOC-073	Bis(2-ethylhexyl)phthalate	30/10/2020	13:00	<0.0010	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-073	Bis(2-ethylhexyl)phthalate	30/10/2020	12:40	<0.0010	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-003	Benzene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-003	Benzene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-003	Benzene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-010	o-Xylene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-010	o-Xylene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-010	o-Xylene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-014	Styrene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-014	Styrene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-014	Styrene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-016	Toluene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-016	Toluene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-016	Toluene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-017	Total p,m Xylene, Ethylbenzene	30/10/2020	12:45	<0.0015	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-017	Total p,m Xylene, Ethylbenzene	30/10/2020	13:00	<0.0015	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-017	Total p,m Xylene, Ethylbenzene	30/10/2020	12:40	<0.0015	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-026	1,2-Dibromo-3-chloropropane	30/10/2020	12:45	<0.001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-026	1,2-Dibromo-3-chloropropane	30/10/2020	13:00	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-026	1,2-Dibromo-3-chloropropane	30/10/2020	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-027	1,2-Dibromoethane	30/10/2020	12:45	<0.0002	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-027	1,2-Dibromoethane	30/10/2020	13:00	<0.0002	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-027	1,2-Dibromoethane	30/10/2020	12:40	<0.0002	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-028	1,2-Dichloroethane	30/10/2020	12:45	<0.0005	mg/L		

	Waikouaiti WTP - Containerised Plant Filtrate	VOC-028	1,2-Dichloroethane	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-028	1,2-Dichloroethane	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-029	1,2-Dichloropropane	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-029	1,2-Dichloropropane	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-029	1,2-Dichloropropane	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-035	Carbon tetrachloride	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-035	Carbon tetrachloride	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-035	Carbon tetrachloride	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-038	cis-1,2-Dichloroethene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-038	cis-1,2-Dichloroethene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-038	cis-1,2-Dichloroethene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-039	cis-1,3-Dichloropropene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-039	cis-1,3-Dichloropropene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-039	cis-1,3-Dichloropropene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-042	Dichloromethane	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-042	Dichloromethane	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-042	Dichloromethane	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-043	Hexachlorobutadiene	30/10/2020	12:45	<0.0002	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-043	Hexachlorobutadiene	30/10/2020	13:00	<0.0002	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-043	Hexachlorobutadiene	30/10/2020	12:40	<0.0002	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-044	Tetrachloroethene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-044	Tetrachloroethene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-044	Tetrachloroethene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-045	trans-1,2-Dichloroethene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-045	trans-1,2-Dichloroethene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-045	trans-1,2-Dichloroethene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-046	trans-1,3-Dichloropropene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-046	trans-1,3-Dichloropropene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-046	trans-1,3-Dichloropropene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-047	Trichloroethene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-047	Trichloroethene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-047	Trichloroethene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-049	Vinyl Chloride	30/10/2020	12:45	<0.0003	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-049	Vinyl Chloride	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-049	Vinyl Chloride	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-052	1,2-Dichlorobenzene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-052	1,2-Dichlorobenzene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-052	1,2-Dichlorobenzene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-054	1,4-Dichlorobenzene	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-054	1,4-Dichlorobenzene	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-054	1,4-Dichlorobenzene	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-062	Bromodichloromethane	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-062	Bromodichloromethane	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-062	Bromodichloromethane	30/10/2020	12:40	0.0059	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-067	Epichlorohydrin	30/10/2020	12:45	<0.0001	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-067	Epichlorohydrin	30/10/2020	13:00	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-067	Epichlorohydrin	30/10/2020	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	VOC-068	1,4-Dioxane	30/10/2020	12:45	<0.04	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	VOC-068	1,4-Dioxane	30/10/2020	13:00	<0.04	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-068	1,4-Dioxane	30/10/2020	12:40	<0.04	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH001	2,4-D in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH001	2,4-D in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH001	2,4-D in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH004	2,4-DB in water	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH004	2,4-DB in water	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH004	2,4-DB in water	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH007	2,4,5-T in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH007	2,4,5-T in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH007	2,4,5-T in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH010	Acifluorfen in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH010	Acifluorfen in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH010	Acifluorfen in water	30/10/2020	12:40	<0.0005	mg/L		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH013	Bentazone in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH013	Bentazone in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH013	Bentazone in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH016	Bromoxynil in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH016	Bromoxynil in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH016	Bromoxynil in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH019	Dicamba in water	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH019	Dicamba in water	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH019	Dicamba in water	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH022	Dichlorprop in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH022	Dichlorprop in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH022	Dichlorprop in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH025	Dinoseb in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH025	Dinoseb in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH025	Dinoseb in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH028	Fenoprop in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH028	Fenoprop in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH028	Fenoprop in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH031	MCPA in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH031	MCPA in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH031	MCPA in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH034	MCPB in water	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH034	MCPB in water	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH034	MCPB in water	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH037	Mecoprop in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH037	Mecoprop in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH037	Mecoprop in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH040	Pentachlorophenol in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH040	Pentachlorophenol in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH040	Pentachlorophenol in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH043	Picloram in water	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH043	Picloram in water	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH043	Picloram in water	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-AH046	Triclopyr in water	30/10/2020	12:45	<0.0005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-AH046	Triclopyr in water	30/10/2020	13:00	<0.0005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-AH046	Triclopyr in water	30/10/2020	12:40	<0.0005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP001	Dichlorvos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP001	Dichlorvos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP001	Dichlorvos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP002	3,4,5-Trimethacarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP002	3,4,5-Trimethacarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP002	3,4,5-Trimethacarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP003	Acephate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP003	Acephate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP003	Acephate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP004	Dichlobenil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP004	Dichlobenil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP004	Dichlobenil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP005	Biphenyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP005	Biphenyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP005	Biphenyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP006	Mevinphos-1 and 2	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP006	Mevinphos-1 and 2	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP006	Mevinphos-1 and 2	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP007	Dioxacarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP007	Dioxacarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP007	Dioxacarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP008	Pebulate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP008	Pebulate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP008	Pebulate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP009	Etridiazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP009	Etridiazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP009	Etridiazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP010	Nitrapyrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP010	Nitrapyrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP010	Nitrapyrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP011	Methacrifos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP011	Methacrifos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP011	Methacrifos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP012	THPI	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP012	THPI	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP012	THPI	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP013	Chloroneb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP013	Chloroneb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP013	Chloroneb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP014	Phthalimide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP014	Phthalimide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP014	Phthalimide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP015	2-Phenylphenol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP015	2-Phenylphenol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP015	2-Phenylphenol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP016	Flonicamid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP016	Flonicamid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP016	Flonicamid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP017	Tecnazene	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP017	Tecnazene	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP017	Tecnazene	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP018	Propachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP018	Propachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP018	Propachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP019	2-4-D-Methylester	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP019	2-4-D-Methylester	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP019	2-4-D-Methylester	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP020	Diphenylamine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP020	Diphenylamine	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP020	Diphenylamine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP021	Trifluralin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP021	Trifluralin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP021	Trifluralin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP022	Chlorpropham	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP022	Chlorpropham	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP022	Chlorpropham	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP023	Benfluralin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP023	Benfluralin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP023	Benfluralin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP025	Desethylatrazine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP025	Desethylatrazine	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP025	Desethylatrazine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP026	2,6-Dichlorobenzamide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP026	2,6-Dichlorobenzamide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP026	2,6-Dichlorobenzamide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP027	Desethylterbuthylazine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP027	Desethylterbuthylazine	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP027	Desethylterbuthylazine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP028	Atrazine-desisopropyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP028	Atrazine-desisopropyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP028	Atrazine-desisopropyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP029	Monocrotophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP029	Monocrotophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP029	Monocrotophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP030	Phorate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP030	Phorate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP030	Phorate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP031	alpha-BHC	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP031	alpha-BHC	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP031	alpha-BHC	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP032	Hexachlorobenzene	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP032	Hexachlorobenzene	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP032	Hexachlorobenzene	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP033	Ethoxyquin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP033	Ethoxyquin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP033	Ethoxyquin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP034	Pentachloroanisole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP034	Pentachloroanisole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP034	Pentachloroanisole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP035	Dichloran	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP035	Dichloran	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP035	Dichloran	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP036	Simazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP036	Simazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP036	Simazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP037	Atrazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP037	Atrazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP037	Atrazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP038	Propazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP038	Propazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP038	Propazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP039	Profluralin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP039	Profluralin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP039	Profluralin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP040	Clomazone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP040	Clomazone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP040	Clomazone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP041	beta-BHC	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP041	beta-BHC	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP041	beta-BHC	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP042	Propentamphos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP042	Propentamphos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP042	Propentamphos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP044	Terbuthylazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP044	Terbuthylazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP044	Terbuthylazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP045	Quintozene	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP045	Quintozene	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP045	Quintozene	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP046	Terbufos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP046	Terbufos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP046	Terbufos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP047	Cyanophos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP047	Cyanophos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP047	Cyanophos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP048	Diazinon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP048	Diazinon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP048	Diazinon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP049	Fluchloralin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP049	Fluchloralin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP049	Fluchloralin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP050	Propyzamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP050	Propyzamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP050	Propyzamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP051	Fonofos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP051	Fonofos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP051	Fonofos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP052	Pyrimethanil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP052	Pyrimethanil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP052	Pyrimethanil	30/10/2020	12:40	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP053	Terfluthrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP053	Terfluthrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP053	Terfluthrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP055	Secbumenton	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP055	Secbumenton	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP055	Secbumenton	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP056	Dinoseb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP056	Dinoseb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP056	Dinoseb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP057	Paraoxon-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP057	Paraoxon-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP057	Paraoxon-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP058	Terbacil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP058	Terbacil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP058	Terbacil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP059	Etrimfos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP059	Etrimfos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP059	Etrimfos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP060	Phosmet	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP060	Phosmet	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP060	Phosmet	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP061	Tri-allate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP061	Tri-allate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP061	Tri-allate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP062	delta-BHC	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP062	delta-BHC	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP062	delta-BHC	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP063	Iprobenfos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP063	Iprobenfos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP063	Iprobenfos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP064	Fenfluthrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP064	Fenfluthrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP064	Fenfluthrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP065	epsilon-HCH	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP065	epsilon-HCH	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP065	epsilon-HCH	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP066	gamma-BHC (Lindane)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP066	gamma-BHC (Lindane)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP066	gamma-BHC (Lindane)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP067	Monalide	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP067	Monalide	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP067	Monalide	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP068	Formothion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP068	Formothion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP068	Formothion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP069	Bromocyclen	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP069	Bromocyclen	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP069	Bromocyclen	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP070	Fenazox	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP070	Fenazox	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP070	Fenazox	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP071	Phosphamidon-1 and 2	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP071	Phosphamidon-1 and 2	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP071	Phosphamidon-1 and 2	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP072	Pentachloroaniline	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP072	Pentachloroaniline	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP072	Pentachloroaniline	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP073	Desmetryn	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP073	Desmetryn	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP073	Desmetryn	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP074	Cyprazine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP074	Cyprazine	30/10/2020	13:00	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP074	Cyprazine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP075	Terbucarb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP075	Terbucarb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP075	Terbucarb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP076	Propanil	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP076	Propanil	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP076	Propanil	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP078	Malaoxon	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP078	Malaoxon	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP078	Malaoxon	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP079	Acetochlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP079	Acetochlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP079	Acetochlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP080	Metribuzin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP080	Metribuzin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP080	Metribuzin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP081	Chlorpyrifos-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP081	Chlorpyrifos-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP081	Chlorpyrifos-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP082	Vinclozolin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP082	Vinclozolin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP082	Vinclozolin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP083	Transfluthrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP083	Transfluthrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP083	Transfluthrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP084	Alachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP084	Alachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP084	Alachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP085	Parathion-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP085	Parathion-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP085	Parathion-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP086	Metalaxyl (Mefenoxam)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP086	Metalaxyl (Mefenoxam)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP086	Metalaxyl (Mefenoxam)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP087	Ametryn	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP087	Ametryn	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP087	Ametryn	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP088	Prometryn	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP088	Prometryn	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP088	Prometryn	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP089	Fenchlorphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP089	Fenchlorphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP089	Fenchlorphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP090	Tridiphane	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP090	Tridiphane	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP090	Tridiphane	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP091	Heptachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP091	Heptachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP091	Heptachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP092	Pirimiphos-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP092	Pirimiphos-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP092	Pirimiphos-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP093	Trinexapac-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP093	Trinexapac-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP093	Trinexapac-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP094	Terbutryn	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP094	Terbutryn	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP094	Terbutryn	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP095	1-Naphthaleneacetic acid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP095	1-Naphthaleneacetic acid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP095	1-Naphthaleneacetic acid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP096	Fenitrothion	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP096	Fenitrothion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP096	Fenitrothion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP097	Ethofumesate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP097	Ethofumesate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP097	Ethofumesate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP098	2,4'-Dichlorobenzophenone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP098	2,4'-Dichlorobenzophenone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP098	2,4'-Dichlorobenzophenone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP100	Bromacil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP100	Bromacil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP100	Bromacil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP101	Pentanochlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP101	Pentanochlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP101	Pentanochlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP102	Malathion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP102	Malathion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP102	Malathion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP103	Dichlofluanid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP103	Dichlofluanid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP103	Dichlofluanid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP104	Dipropetryn	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP104	Dipropetryn	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP104	Dipropetryn	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP105	Metolachlor (S-Metolachlor)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP105	Metolachlor (S-Metolachlor)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP105	Metolachlor (S-Metolachlor)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP106	Chlorpyrifos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP106	Chlorpyrifos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP106	Chlorpyrifos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP107	Fenthion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP107	Fenthion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP107	Fenthion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP108	Cyanazine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP108	Cyanazine	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP108	Cyanazine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP110	Chlorthal-dimethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP110	Chlorthal-dimethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP110	Chlorthal-dimethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP111	Anthraquinone	30/10/2020	12:45	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP111	Anthraquinone	30/10/2020	13:00	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP111	Anthraquinone	30/10/2020	12:40	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP112	Parathion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP112	Parathion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP112	Parathion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP113	Aldrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP113	Aldrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP113	Aldrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP114	Triadimefon	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP114	Triadimefon	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP114	Triadimefon	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP115	Isocarbophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP115	Isocarbophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP115	Isocarbophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP116	Nitrothal-isopropyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP116	Nitrothal-isopropyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP116	Nitrothal-isopropyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP117	4,4'-Dichlorobenzophenone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP117	4,4'-Dichlorobenzophenone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP117	4,4'-Dichlorobenzophenone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP118	Triphenylmethane	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP118	Triphenylmethane	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP118	Triphenylmethane	30/10/2020	12:40	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP119	Chlorthion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP119	Chlorthion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP119	Chlorthion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP120	Trichlornate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP120	Trichlornate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP120	Trichlornate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP121	Pirimophos-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP121	Pirimophos-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP121	Pirimophos-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP122	Fenson	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP122	Fenson	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP122	Fenson	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP123	Bromophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP123	Bromophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP123	Bromophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP124	Isofenphos-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP124	Isofenphos-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP124	Isofenphos-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP125	Cyprodinil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP125	Cyprodinil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP125	Cyprodinil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP126	Metazachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP126	Metazachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP126	Metazachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP127	Isodrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP127	Isodrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP127	Isodrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP128	Fipronil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP128	Fipronil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP128	Fipronil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP129	Allethrin-1,2	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP129	Allethrin-1,2	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP129	Allethrin-1,2	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP130	Isofenphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP130	Isofenphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP130	Isofenphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP131	(EZ)-Pyrifenox	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP131	(EZ)-Pyrifenox	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP131	(EZ)-Pyrifenox	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP132	Mercarbam	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP132	Mercarbam	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP132	Mercarbam	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP133	(EZ)-Chlorfenvinphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP133	(EZ)-Chlorfenvinphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP133	(EZ)-Chlorfenvinphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP134	Tolylfluanid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP134	Tolylfluanid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP134	Tolylfluanid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP135	Heptachlor-endo-epoxide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP135	Heptachlor-endo-epoxide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP135	Heptachlor-endo-epoxide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP136	Heptachlor-exo-epoxide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP136	Heptachlor-exo-epoxide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP136	Heptachlor-exo-epoxide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP137	Allethrin-3,4 (Bioallethrin)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP137	Allethrin-3,4 (Bioallethrin)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP137	Allethrin-3,4 (Bioallethrin)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP138	Phenthoate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP138	Phenthoate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP138	Phenthoate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP139	Quinalphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP139	Quinalphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP139	Quinalphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP140	Triadimenol-1	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP140	Triadimenol-1	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP140	Triadimenol-1	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP141	Captan	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP141	Captan	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP141	Captan	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP142	Procymidone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP142	Procymidone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP142	Procymidone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP143	Triflumizole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP143	Triflumizole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP143	Triflumizole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP144	Folpet	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP144	Folpet	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP144	Folpet	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP145	Triadimenol-2	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP145	Triadimenol-2	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP145	Triadimenol-2	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP146	Haloxyfop-methyl ester	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP146	Haloxyfop-methyl ester	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP146	Haloxyfop-methyl ester	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP147	Flurenol-butyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP147	Flurenol-butyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP147	Flurenol-butyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP148	Bromophos-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP148	Bromophos-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP148	Bromophos-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP149	trans-Chlordane	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP149	trans-Chlordane	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP149	trans-Chlordane	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP150	Flumetralin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP150	Flumetralin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP150	Flumetralin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP151	o,p'-DDE	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP151	o,p'-DDE	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP151	o,p'-DDE	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP152	Tetrachlorvinphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP152	Tetrachlorvinphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP152	Tetrachlorvinphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP153	Butachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP153	Butachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP153	Butachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP154	Paclobutrazol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP154	Paclobutrazol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP154	Paclobutrazol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP155	Picoxystrobin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP155	Picoxystrobin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP155	Picoxystrobin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP156	cis-Chlordane (alpha)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP156	cis-Chlordane (alpha)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP156	cis-Chlordane (alpha)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP157	alpha-Endosulfan	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP157	alpha-Endosulfan	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP157	alpha-Endosulfan	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP158	Fluazolate	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP158	Fluazolate	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP158	Fluazolate	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP159	Flutriafol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP159	Flutriafol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP159	Flutriafol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP160	Flutolanil	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP160	Flutolanil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP160	Flutolanil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP161	Napropamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP161	Napropamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP161	Napropamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP162	Jodfenphos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP162	Jodfenphos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP162	Jodfenphos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP163	Chlorfenson	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP163	Chlorfenson	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP163	Chlorfenson	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP164	Imazalil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP164	Imazalil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP164	Imazalil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP165	Fludioxonil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP165	Fludioxonil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP165	Fludioxonil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP166	Prothiofos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP166	Prothiofos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP166	Prothiofos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP167	Isoprothiolane	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP167	Isoprothiolane	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP167	Isoprothiolane	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP168	Fipronil Sulfone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP168	Fipronil Sulfone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP168	Fipronil Sulfone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP169	Profenofos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP169	Profenofos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP169	Profenofos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP170	Oxadiazon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP170	Oxadiazon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP170	Oxadiazon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP171	p,p'-DDE	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP171	p,p'-DDE	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP171	p,p'-DDE	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP172	Uniconazole (Uniconazole-P)	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP172	Uniconazole (Uniconazole-P)	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP172	Uniconazole (Uniconazole-P)	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP173	Flamprop-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP173	Flamprop-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP173	Flamprop-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP174	Oxyfluorfen	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP174	Oxyfluorfen	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP174	Oxyfluorfen	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP175	Myclobutanil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP175	Myclobutanil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP175	Myclobutanil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP176	Dieldrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP176	Dieldrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP176	Dieldrin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP177	o,p'-DDD	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP177	o,p'-DDD	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP177	o,p'-DDD	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP178	p,p'-DDD	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP178	p,p'-DDD	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP178	p,p'-DDD	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP179	Methoprotryn	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP179	Methoprotryn	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP179	Methoprotryn	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP180	Diclobutrazol	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP180	Diclobutrazol	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP180	Diclobutrazol	30/10/2020	12:40	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP181	Azaconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP181	Azaconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP181	Azaconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP182	Cyflufenamid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP182	Cyflufenamid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP182	Cyflufenamid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP183	Chlorfenapyr	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP183	Chlorfenapyr	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP183	Chlorfenapyr	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP184	Isoxathion	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP184	Isoxathion	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP184	Isoxathion	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP185	4,4'-Bromobenzophenone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP185	4,4'-Bromobenzophenone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP185	4,4'-Bromobenzophenone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP186	Carpropamid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP186	Carpropamid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP186	Carpropamid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP187	Perthan	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP187	Perthan	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP187	Perthan	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP188	Nitrofen	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP188	Nitrofen	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP188	Nitrofen	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP189	Fluazifop-P-butyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP189	Fluazifop-P-butyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP189	Fluazifop-P-butyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP190	Endrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP190	Endrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP190	Endrin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP191	Chlorobenzilate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP191	Chlorobenzilate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP191	Chlorobenzilate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP192	Chloropropylate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP192	Chloropropylate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP192	Chloropropylate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP193	Etaconazole I and II	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP193	Etaconazole I and II	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP193	Etaconazole I and II	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP194	beta-Endosulfan	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP194	beta-Endosulfan	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP194	beta-Endosulfan	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP195	Ethion	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP195	Ethion	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP195	Ethion	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP196	Aclonifen	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP196	Aclonifen	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP196	Aclonifen	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP197	o,p'-DDT	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP197	o,p'-DDT	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP197	o,p'-DDT	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP198	Mepronil	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP198	Mepronil	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP198	Mepronil	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP199	Tetrasul	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP199	Tetrasul	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP199	Tetrasul	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP200	Triazophos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP200	Triazophos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP200	Triazophos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP201	Ofurace	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP201	Ofurace	30/10/2020	13:00	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP201	Ofurace	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP202	Famphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP202	Famphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP202	Famphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP203	Isoxadifen-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP203	Isoxadifen-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP203	Isoxadifen-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP204	Benalaxyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP204	Benalaxyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP204	Benalaxyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP205	Carbophenothion-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP205	Carbophenothion-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP205	Carbophenothion-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP206	Trifloxystrobin	30/10/2020	12:45	<0.001	mg/L	(- .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP206	Trifloxystrobin	30/10/2020	13:00	<0.001	mg/L	(- .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP206	Trifloxystrobin	30/10/2020	12:40	<0.001	mg/L	(- .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP207	Norflurazon	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP207	Norflurazon	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP207	Norflurazon	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP208	Edifenphos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP208	Edifenphos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP208	Edifenphos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP209	Endosulfan sulfate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP209	Endosulfan sulfate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP209	Endosulfan sulfate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP210	Clodinafop-propargyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP210	Clodinafop-propargyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP210	Clodinafop-propargyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP211	p,p'-DDT	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP211	p,p'-DDT	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP211	p,p'-DDT	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP212	Lenacil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP212	Lenacil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP212	Lenacil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP213	Hexazinone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP213	Hexazinone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP213	Hexazinone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP214	Fluotrimazol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP214	Fluotrimazol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP214	Fluotrimazol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP215	Diflufenican	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP215	Diflufenican	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP215	Diflufenican	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP216	Nitralin	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP216	Nitralin	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP216	Nitralin	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP217	Menfenpyr-diethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP217	Menfenpyr-diethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP217	Menfenpyr-diethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP218	Spiromesifen	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP218	Spiromesifen	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP218	Spiromesifen	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP220	Pyridaphenthion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP220	Pyridaphenthion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP220	Pyridaphenthion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP221	Iprodione	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP221	Iprodione	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP221	Iprodione	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP222	Tetramethrin-1	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP222	Tetramethrin-1	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP222	Tetramethrin-1	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP223	Bifenthrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP223	Bifenthrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP223	Bifenthrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP224	o,p-Dicofol	30/10/2020	12:45	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP224	o,p-Dicofol	30/10/2020	13:00	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP224	o,p-Dicofol	30/10/2020	12:40	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP225	Bromopropylate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP225	Bromopropylate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP225	Bromopropylate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP226	Picolinafen	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP226	Picolinafen	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP226	Picolinafen	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP227	Fenoxycarb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP227	Fenoxycarb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP227	Fenoxycarb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP228	Methoxychlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP228	Methoxychlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP228	Methoxychlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP229	Etoxazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP229	Etoxazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP229	Etoxazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP230	Fenpropathrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP230	Fenpropathrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP230	Fenpropathrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP231	Fenamidone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP231	Fenamidone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP231	Fenamidone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP232	Tebufenpyrad	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP232	Tebufenpyrad	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP232	Tebufenpyrad	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP233	Bifenox	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP233	Bifenox	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP233	Bifenox	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP234	p,p-Dicofol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP234	p,p-Dicofol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP234	p,p-Dicofol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP235	cis-metaconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP235	cis-metaconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP235	cis-metaconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP236	Bromuconazole-2	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP236	Bromuconazole-2	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP236	Bromuconazole-2	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP237	Tetradifon	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP237	Tetradifon	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP237	Tetradifon	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP238	Phosalone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP238	Phosalone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP238	Phosalone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP239	Leptophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP239	Leptophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP239	Leptophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP240	Triticonazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP240	Triticonazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP240	Triticonazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP241	lambda-Cyhalothrin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP241	lambda-Cyhalothrin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP241	lambda-Cyhalothrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP242	Mirex	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP242	Mirex	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP242	Mirex	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP243	Pyrazophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP243	Pyrazophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP243	Pyrazophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP244	Metrafenone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP244	Metrafenone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP244	Metrafenone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP245	Azinphos-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP245	Azinphos-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP245	Azinphos-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP246	Piperonyl butoxide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP246	Piperonyl butoxide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP246	Piperonyl butoxide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP247	Spirodiclofen	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP247	Spirodiclofen	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP247	Spirodiclofen	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP248	Permethrin-1	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP248	Permethrin-1	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP248	Permethrin-1	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP249	Fluquinconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP249	Fluquinconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP249	Fluquinconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP250	Butafenacil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP250	Butafenacil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP250	Butafenacil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP251	Cyfluthrin-1,2,3,4	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP251	Cyfluthrin-1,2,3,4	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP251	Cyfluthrin-1,2,3,4	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP252	Boscalid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP252	Boscalid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP252	Boscalid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP253	Cypermethrin-1	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP253	Cypermethrin-1	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP253	Cypermethrin-1	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP254	Flucythrinate-1	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP254	Flucythrinate-1	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP254	Flucythrinate-1	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP255	Quizalofop-ethyl (Quizalofop-P-ethyl)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP255	Quizalofop-ethyl (Quizalofop-P-ethyl)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP255	Quizalofop-ethyl (Quizalofop-P-ethyl)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP256	Pyridalyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP256	Pyridalyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP256	Pyridalyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP257	Flumioxazin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP257	Flumioxazin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP257	Flumioxazin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP258	Fenvalerate-1	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP258	Fenvalerate-1	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP258	Fenvalerate-1	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP259	tau-Fluvalinate-2	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP259	tau-Fluvalinate-2	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP259	tau-Fluvalinate-2	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP260	Deltamethrin-1 (Tralomethrin deg.-1)	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP260	Deltamethrin-1 (Tralomethrin deg.-1)	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP260	Deltamethrin-1 (Tralomethrin deg.-1)	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP261	Azoxystrobin	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP261	Azoxystrobin	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP261	Azoxystrobin	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP262	Propiconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP262	Propiconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP262	Propiconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP265	Acibenzolar-s-methyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP265	Acibenzolar-s-methyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP265	Acibenzolar-s-methyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP266	Acrinathrin	30/10/2020	12:45	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP266	Acrinathrin	30/10/2020	13:00	<0.003	mg/L	(- .003)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP266	Acrinathrin	30/10/2020	12:40	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP267	Benoxacor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP267	Benoxacor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP267	Benoxacor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP269	Bitertanol-1 and 2	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP269	Bitertanol-1 and 2	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP269	Bitertanol-1 and 2	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP270	Cadusafos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP270	Cadusafos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP270	Cadusafos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP271	Carboxin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP271	Carboxin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP271	Carboxin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP275	Chlorantraniliprole	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP275	Chlorantraniliprole	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP275	Chlorantraniliprole	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP276	Chlorfluazuron	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP276	Chlorfluazuron	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP276	Chlorfluazuron	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP277	Chloridazon	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP277	Chloridazon	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP277	Chloridazon	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP279	Cyazofamid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP279	Cyazofamid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP279	Cyazofamid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP280	Cyproconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP280	Cyproconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP280	Cyproconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP281	Dichlorprop-p (2,4-DP)	30/10/2020	12:45	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP281	Dichlorprop-p (2,4-DP)	30/10/2020	13:00	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP281	Dichlorprop-p (2,4-DP)	30/10/2020	12:40	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP282	Difenoconazole-1	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP282	Difenoconazole-1	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP282	Difenoconazole-1	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP283	Difenoconazole-2	30/10/2020	12:45	<0.005	mg/L	(- .005)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP283	Difenoconazole-2	30/10/2020	13:00	<0.005	mg/L	(- .005)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP283	Difenoconazole-2	30/10/2020	12:40	<0.005	mg/L	(- .005)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP284	Diflubenzuron	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP284	Diflubenzuron	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP284	Diflubenzuron	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP285	Disulfoton	30/10/2020	12:45	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP285	Disulfoton	30/10/2020	13:00	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP285	Disulfoton	30/10/2020	12:40	<0.003	mg/L	(- .003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP286	EPN	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP286	EPN	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP286	EPN	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP287	Ethoprophos	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP287	Ethoprophos	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP287	Ethoprophos	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP288	Fenarimol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP288	Fenarimol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP288	Fenarimol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP289	Fenoxaprop-ethyl (Fenoxaprop-P-ethyl)	30/10/2020	12:45	<0.011	mg/L	(- .011)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP289	Fenoxaprop-ethyl (Fenoxaprop-P-ethyl)	30/10/2020	13:00	<0.011	mg/L	(- .011)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP289	Fenoxaprop-ethyl (Fenoxaprop-P-ethyl)	30/10/2020	12:40	<0.011	mg/L	(- .011)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP290	Fenpiclonil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP290	Fenpiclonil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP290	Fenpiclonil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP291	Fenpropidin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP291	Fenpropidin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP291	Fenpropidin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP292	Fensulfothion	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP292	Fensulfothion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP292	Fensulfothion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP293	Fluazinam	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP293	Fluazinam	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP293	Fluazinam	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP294	Formetanate	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP294	Formetanate	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP294	Formetanate	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP295	Furalaxyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP295	Furalaxyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP295	Furalaxyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP296	Halfenprox	30/10/2020	12:45	<0.006	mg/L	(- .006)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP296	Halfenprox	30/10/2020	13:00	<0.006	mg/L	(- .006)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP296	Halfenprox	30/10/2020	12:40	<0.006	mg/L	(- .006)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP297	Hexaconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP297	Hexaconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP297	Hexaconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP298	Hexythiazox	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP298	Hexythiazox	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP298	Hexythiazox	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP299	Imazapyr	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP299	Imazapyr	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP299	Imazapyr	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP301	Mandipropamid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP301	Mandipropamid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP301	Mandipropamid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP302	Methidathion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP302	Methidathion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP302	Methidathion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP304	Omethoate	30/10/2020	12:45	<0.009	mg/L	(- .009)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP304	Omethoate	30/10/2020	13:00	<0.009	mg/L	(- .009)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP304	Omethoate	30/10/2020	12:40	<0.009	mg/L	(- .009)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP305	Oxadixyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP305	Oxadixyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP305	Oxadixyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP306	Oxamyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP306	Oxamyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP306	Oxamyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP307	Penconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP307	Penconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP307	Penconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP308	Pencycuron	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP308	Pencycuron	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP308	Pencycuron	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP309	Propamocarb	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP309	Propamocarb	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP309	Propamocarb	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP311	Quinoxyfen	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP311	Quinoxyfen	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP311	Quinoxyfen	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP312	Spirotetramat-cis-keto-hydroxy	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP312	Spirotetramat-cis-keto-hydroxy	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP312	Spirotetramat-cis-keto-hydroxy	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP313	Spiroxamine	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP313	Spiroxamine	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP313	Spiroxamine	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP314	Tebufenozide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP314	Tebufenozide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP314	Tebufenozide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP315	Tepraloxydim	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP315	Tepraloxydim	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP315	Tepraloxydim	30/10/2020	12:40	<0.002	mg/L	(- .002)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP316	Thiacloprid	30/10/2020	12:45	Not	Recovered		
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP316	Thiacloprid	30/10/2020	13:00	Not	Recovered		
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP316	Thiacloprid	30/10/2020	12:40	Not	Recovered		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-GCP317	Thiobencarb	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-GCP317	Thiobencarb	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-GCP317	Thiobencarb	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP001	Azaconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP001	Azaconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP001	Azaconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP002	Atrazine-desisopropyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP002	Atrazine-desisopropyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP002	Atrazine-desisopropyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP003	Dimoxysrobin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP003	Dimoxysrobin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP003	Dimoxysrobin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP004	Fenamidone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP004	Fenamidone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP004	Fenamidone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP005	Hexazinone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP005	Hexazinone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP005	Hexazinone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP006	Lenacil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP006	Lenacil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP006	Lenacil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP007	Ofurace	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP007	Ofurace	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP007	Ofurace	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP008	Paclobutrazol	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP008	Paclobutrazol	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP008	Paclobutrazol	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP009	Phosphamidon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP009	Phosphamidon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP009	Phosphamidon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP010	Terbutylazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP010	Terbutylazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP010	Terbutylazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP011	Fenamiphos	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP011	Fenamiphos	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP011	Fenamiphos	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP012	Fenamiphos-sulfone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP012	Fenamiphos-sulfone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP012	Fenamiphos-sulfone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP013	Phorate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP013	Phorate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP013	Phorate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP014	Phorat-sulfone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP014	Phorat-sulfone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP014	Phorat-sulfone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP015	Climbazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP015	Climbazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP015	Climbazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP016	Coumaphos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP016	Coumaphos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP016	Coumaphos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP017	Crimidine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP017	Crimidine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP017	Crimidine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP018	Cyanofenphos	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP018	Cyanofenphos	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP018	Cyanofenphos	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP019	Cyphenothrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP019	Cyphenothrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP019	Cyphenothrin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP020	Dichlofenthion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP020	Dichlofenthion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP020	Dichlofenthion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP021	Dicrotophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP021	Dicrotophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP021	Dicrotophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP022	Dimethachlor	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP022	Dimethachlor	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP022	Dimethachlor	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP023	EPTC	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP023	EPTC	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP023	EPTC	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP024	Fensulfothion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP024	Fensulfothion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP024	Fensulfothion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP025	Isazofos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP025	Isazofos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP025	Isazofos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP026	Phenthoate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP026	Phenthoate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP026	Phenthoate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP027	Spinosad	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP027	Spinosad	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP027	Spinosad	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP028	Acephate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP028	Acephate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP028	Acephate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP029	Aldicarb-sulfone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP029	Aldicarb-sulfone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP029	Aldicarb-sulfone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP030	Azoxystrobin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP030	Azoxystrobin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP030	Azoxystrobin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP031	Boscalid	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP031	Boscalid	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP031	Boscalid	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP032	Bromuconazole-trans	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP032	Bromuconazole-trans	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP032	Bromuconazole-trans	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP033	Buprofezin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP033	Buprofezin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP033	Buprofezin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP034	Butocarboxim-sulfoxide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP034	Butocarboxim-sulfoxide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP034	Butocarboxim-sulfoxide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP035	Carbofuran	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP035	Carbofuran	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP035	Carbofuran	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP036	BYI08330 mono-hydroxy	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP036	BYI08330 mono-hydroxy	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP036	BYI08330 mono-hydroxy	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP037	Carbendazim	30/10/2020	12:45	<0.001	mg/L	(.001 - .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP037	Carbendazim	30/10/2020	13:00	<0.001	mg/L	(.001 - .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP037	Carbendazim	30/10/2020	12:40	<0.001	mg/L	(.001 - .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP038	Chlorpyrifos-ethyl	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP038	Chlorpyrifos-ethyl	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP038	Chlorpyrifos-ethyl	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP039	Cymoxanil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP039	Cymoxanil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP039	Cymoxanil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP040	Cyprodinil	30/10/2020	12:45	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP040	Cyprodinil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP040	Cyprodinil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP041	Diethofencarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP041	Diethofencarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP041	Diethofencarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP042	Dimethoate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP042	Dimethoate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP042	Dimethoate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP043	Dimethomorph	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP043	Dimethomorph	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP043	Dimethomorph	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP044	Diniconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP044	Diniconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP044	Diniconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP045	Diphenamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP045	Diphenamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP045	Diphenamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP046	Epoxiconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP046	Epoxiconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP046	Epoxiconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP047	Ethiofencarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP047	Ethiofencarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP047	Ethiofencarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP048	Fenbuconazol	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP048	Fenbuconazol	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP048	Fenbuconazol	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP049	Fenpyroximate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP049	Fenpyroximate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP049	Fenpyroximate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP050	Fluazifop-P-butyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP050	Fluazifop-P-butyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP050	Fluazifop-P-butyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP051	Flufenoxuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP051	Flufenoxuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP051	Flufenoxuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP052	Iprodione	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP052	Iprodione	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP052	Iprodione	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP053	Iprovalicarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP053	Iprovalicarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP053	Iprovalicarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP054	Isoprocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP054	Isoprocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP054	Isoprocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP055	Vamidothion-sulfoxide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP055	Vamidothion-sulfoxide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP055	Vamidothion-sulfoxide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP056	Isoprothiolane	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP056	Isoprothiolane	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP056	Isoprothiolane	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP057	Propoxur	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP057	Propoxur	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP057	Propoxur	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP058	Imidacloprid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP058	Imidacloprid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP058	Imidacloprid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP059	Pirimicarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP059	Pirimicarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP059	Pirimicarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP060	Methomyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP060	Methomyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP060	Methomyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP061	Isoproturon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP061	Isoproturon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP061	Isoproturon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP062	Pendimethalin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP062	Pendimethalin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP062	Pendimethalin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP063	Fluopicolide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP063	Fluopicolide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP063	Fluopicolide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP064	Rotenone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP064	Rotenone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP064	Rotenone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP065	Fluthiacet-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP065	Fluthiacet-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP065	Fluthiacet-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP066	Pyridaben	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP066	Pyridaben	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP066	Pyridaben	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP067	Isoxaflutole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP067	Isoxaflutole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP067	Isoxaflutole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP068	Methiocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP068	Methiocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP068	Methiocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP069	Trifloxystrobin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP069	Trifloxystrobin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP069	Trifloxystrobin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP070	Mepanipyrim	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP070	Mepanipyrim	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP070	Mepanipyrim	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP071	Pyraclostrobin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP071	Pyraclostrobin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP071	Pyraclostrobin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP072	Resmethrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP072	Resmethrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP072	Resmethrin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP073	2-Hydroxy-propoxycarbazone	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP073	2-Hydroxy-propoxycarbazone	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP073	2-Hydroxy-propoxycarbazone	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP074	Trinexapac-ethyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP074	Trinexapac-ethyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP074	Trinexapac-ethyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP075	Vamidothion	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP075	Vamidothion	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP075	Vamidothion	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP076	Vamidothion-sulfone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP076	Vamidothion-sulfone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP076	Vamidothion-sulfone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP077	Amdro	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP077	Amdro	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP077	Amdro	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP078	Cyantraniliprole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP078	Cyantraniliprole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP078	Cyantraniliprole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP079	Fenazox	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP079	Fenazox	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP079	Fenazox	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP080	Flupyradifurone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP080	Flupyradifurone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP080	Flupyradifurone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP081	Alanycarb	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP081	Alanycarb	30/10/2020	13:00	<0.002	mg/L	(-.002)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP081	Alanycarb	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP082	Aminocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP082	Aminocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP082	Aminocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP083	Atrazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP083	Atrazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP083	Atrazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP084	Benthiavalicarb-isopropyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP084	Benthiavalicarb-isopropyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP084	Benthiavalicarb-isopropyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP085	Butylate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP085	Butylate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP085	Butylate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP086	BYI08330 enol-glucoside	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP086	BYI08330 enol-glucoside	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP086	BYI08330 enol-glucoside	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP087	Chlorbromuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP087	Chlorbromuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP087	Chlorbromuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP088	Difenoxuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP088	Difenoxuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP088	Difenoxuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP089	Dimefuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP089	Dimefuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP089	Dimefuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP090	Dimethipin	30/10/2020	12:45	<0.003	mg/L	(-.003)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP090	Dimethipin	30/10/2020	13:00	<0.003	mg/L	(-.003)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP090	Dimethipin	30/10/2020	12:40	<0.003	mg/L	(-.003)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP091	Etobenzanid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP091	Etobenzanid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP091	Etobenzanid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP092	Fuberidazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP092	Fuberidazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP092	Fuberidazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP093	Malaoxon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP093	Malaoxon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP093	Malaoxon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP094	Metribuzin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP094	Metribuzin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP094	Metribuzin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP095	Paraoxon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP095	Paraoxon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP095	Paraoxon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP096	Paraoxon-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP096	Paraoxon-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP096	Paraoxon-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP097	Phenothrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP097	Phenothrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP097	Phenothrin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP098	Prohexadione	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP098	Prohexadione	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP098	Prohexadione	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP099	Terbufos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP099	Terbufos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP099	Terbufos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP100	Terbufos-sulfone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP100	Terbufos-sulfone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP100	Terbufos-sulfone	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP101	Cyflumetofen	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP101	Cyflumetofen	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP101	Cyflumetofen	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP102	Benzyldimethyldodecyl ammonium chloride (BAC-12)	30/10/2020	12:45	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP102	Benzyldimethyldodecyl ammonium chloride (BAC-12)	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP102	Benzyldimethyldodecyl ammonium chloride (BAC-12)	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP103	Benzyldimethylhexadecyl ammonium chloride (BAC-16)	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP103	Benzyldimethylhexadecyl ammonium chloride (BAC-16)	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP103	Benzyldimethylhexadecyl ammonium chloride (BAC-16)	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP104	Dimethyldioctyl ammonium bromide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP104	Dimethyldioctyl ammonium bromide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP104	Dimethyldioctyl ammonium bromide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP105	BTS 27271	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP105	BTS 27271	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP105	BTS 27271	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP106	Clomeprop	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP106	Clomeprop	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP106	Clomeprop	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP107	Pyrifluquinazon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP107	Pyrifluquinazon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP107	Pyrifluquinazon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP108	Spinetoram	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP108	Spinetoram	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP108	Spinetoram	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP109	Fluopyram (AE C656948)	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP109	Fluopyram (AE C656948)	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP109	Fluopyram (AE C656948)	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP110	Profenofos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP110	Profenofos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP110	Profenofos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP111	Prometon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP111	Prometon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP111	Prometon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP112	Simetryn	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP112	Simetryn	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP112	Simetryn	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP113	Sulfotep	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP113	Sulfotep	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP113	Sulfotep	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP114	Terbumeton	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP114	Terbumeton	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP114	Terbumeton	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP115	Triazophos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP115	Triazophos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP115	Triazophos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP116	Fenamiphos-sulfoxide	30/10/2020	12:45	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP116	Fenamiphos-sulfoxide	30/10/2020	13:00	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP116	Fenamiphos-sulfoxide	30/10/2020	12:40	<0.002	mg/L	(-.002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP118	Amisulbrom	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP118	Amisulbrom	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP118	Amisulbrom	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP119	Benfuresate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP119	Benfuresate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP119	Benfuresate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP120	Bensulide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP120	Bensulide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP120	Bensulide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP121	Carpropamid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP121	Carpropamid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP121	Carpropamid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP122	Dimetilan	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP122	Dimetilan	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP122	Dimetilan	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP123	Flurtamone	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP123	Flurtamone	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP123	Flurtamone	30/10/2020	12:40	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP124	Orysastrobin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP124	Orysastrobin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP124	Orysastrobin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP125	Oxfendazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP125	Oxfendazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP125	Oxfendazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP126	Oxycarboxine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP126	Oxycarboxine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP126	Oxycarboxine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP127	Penoxsulam	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP127	Penoxsulam	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP127	Penoxsulam	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP128	Pyroxsulam	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP128	Pyroxsulam	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP128	Pyroxsulam	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP129	Sulprofos-sulphoxide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP129	Sulprofos-sulphoxide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP129	Sulprofos-sulphoxide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP130	Penthiopyrad	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP130	Penthiopyrad	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP130	Penthiopyrad	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP131	Isouron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP131	Isouron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP131	Isouron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP132	Dazomet	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP132	Dazomet	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP132	Dazomet	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP133	Etoxazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP133	Etoxazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP133	Etoxazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP134	Aldicarb-sulfoxide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP134	Aldicarb-sulfoxide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP134	Aldicarb-sulfoxide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP135	Azinphos-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP135	Azinphos-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP135	Azinphos-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP136	cis-Bromuconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP136	cis-Bromuconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP136	cis-Bromuconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP137	Carbaryl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP137	Carbaryl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP137	Carbaryl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP138	Clethodim	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP138	Clethodim	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP138	Clethodim	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP139	Clofentezine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP139	Clofentezine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP139	Clofentezine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP140	Cycloxydim	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP140	Cycloxydim	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP140	Cycloxydim	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP141	Demeton-S-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP141	Demeton-S-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP141	Demeton-S-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP142	Dimepiperate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP142	Dimepiperate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP142	Dimepiperate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP143	Dioxacarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP143	Dioxacarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP143	Dioxacarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP144	Ethofenprox	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP144	Ethofenprox	30/10/2020	13:00	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP144	Ethofenprox	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP145	Fenpropimorph	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP145	Fenpropimorph	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP145	Fenpropimorph	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP146	Fenpyrazamine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP146	Fenpyrazamine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP146	Fenpyrazamine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP147	Flufenacet	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP147	Flufenacet	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP147	Flufenacet	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP148	Pethoxamid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP148	Pethoxamid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP148	Pethoxamid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP149	Picaridin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP149	Picaridin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP149	Picaridin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP150	Pinoxaden	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP150	Pinoxaden	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP150	Pinoxaden	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP151	Triflumuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP151	Triflumuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP151	Triflumuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP152	Carbetamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP152	Carbetamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP152	Carbetamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP153	Nicosulfuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP153	Nicosulfuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP153	Nicosulfuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP154	Triasulfuron	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP154	Triasulfuron	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP154	Triasulfuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP155	Benzyldimethylstearyl ammonium chloride (BAC-18)	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP155	Benzyldimethylstearyl ammonium chloride (BAC-18)	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP155	Benzyldimethylstearyl ammonium chloride (BAC-18)	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP156	Chromafenozide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP156	Chromafenozide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP156	Chromafenozide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP157	Bioresmethrin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP157	Bioresmethrin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP157	Bioresmethrin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP158	Cinidon-ethyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP158	Cinidon-ethyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP158	Cinidon-ethyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP159	Dinotefuran	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP159	Dinotefuran	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP159	Dinotefuran	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP160	Diphenylamine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP160	Diphenylamine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP160	Diphenylamine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP161	Fenazaquin	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP161	Fenazaquin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP161	Fenazaquin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP162	Fenobucarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP162	Fenobucarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP162	Fenobucarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP163	Flusilazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP163	Flusilazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP163	Flusilazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP164	Flurathiocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP164	Flurathiocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP164	Flurathiocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP165	Imidacloprid-olefin	30/10/2020	12:45	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP165	Imidacloprid-olefin	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP165	Imidacloprid-olefin	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP166	Kresoxim-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP166	Kresoxim-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP166	Kresoxim-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP167	Metalaxyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP167	Metalaxyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP167	Metalaxyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP168	Oxamyl-oxime	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP168	Oxamyl-oxime	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP168	Oxamyl-oxime	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP169	Phoxim	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP169	Phoxim	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP169	Phoxim	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP170	Propham	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP170	Propham	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP170	Propham	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP171	Prosulfocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP171	Prosulfocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP171	Prosulfocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP172	Pyrimidifen	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP172	Pyrimidifen	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP172	Pyrimidifen	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP173	Pyriproxyfen	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP173	Pyriproxyfen	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP173	Pyriproxyfen	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP174	Simazine	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP174	Simazine	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP174	Simazine	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP175	Simeconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP175	Simeconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP175	Simeconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP176	Tebuconazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP176	Tebuconazole	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP176	Tebuconazole	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP177	Tolfenpyrad	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP177	Tolfenpyrad	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP177	Tolfenpyrad	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP178	Triadimenol	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP178	Triadimenol	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP178	Triadimenol	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP179	3,4,5-Trimethacarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP179	3,4,5-Trimethacarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP179	3,4,5-Trimethacarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP180	Alachlor	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP180	Alachlor	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP180	Alachlor	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP181	Bupirimate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP181	Bupirimate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP181	Bupirimate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP182	Dementon-S-methyl-sulfon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP182	Dementon-S-methyl-sulfon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP182	Dementon-S-methyl-sulfon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP183	Desmethyl-pirimicarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP183	Desmethyl-pirimicarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP183	Desmethyl-pirimicarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP184	Diazinon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP184	Diazinon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP184	Diazinon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP185	Diflufenican	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP185	Diflufenican	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP185	Diflufenican	30/10/2020	12:40	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP186	Fosthiazate	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP186	Fosthiazate	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP186	Fosthiazate	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP187	Indoxacarb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP187	Indoxacarb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP187	Indoxacarb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP188	Linuron	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP188	Linuron	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP188	Linuron	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP189	Malathion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP189	Malathion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP189	Malathion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP190	Methamidophos	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP190	Methamidophos	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP190	Methamidophos	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP191	Fluxapyroxad	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP191	Fluxapyroxad	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP191	Fluxapyroxad	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP192	Clothianidin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP192	Clothianidin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP192	Clothianidin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP193	Carbosulfan	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP193	Carbosulfan	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP193	Carbosulfan	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP194	Mesotrione	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP194	Mesotrione	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP194	Mesotrione	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP195	3-Hydroxycarbofuran	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP195	3-Hydroxycarbofuran	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP195	3-Hydroxycarbofuran	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP196	Aldicarb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP196	Aldicarb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP196	Aldicarb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP197	Emamectin benzoate	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP197	Emamectin benzoate	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP197	Emamectin benzoate	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP198	Ethiofencarb-sulfon	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP198	Ethiofencarb-sulfon	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP198	Ethiofencarb-sulfon	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP199	Phenmedipham	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP199	Phenmedipham	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP199	Phenmedipham	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP200	Thiofanox-sulfone	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP200	Thiofanox-sulfone	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP200	Thiofanox-sulfone	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP201	Ametoctradin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP201	Ametoctradin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP201	Ametoctradin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP202	Benodanil	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP202	Benodanil	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP202	Benodanil	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP203	Fenthion	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP203	Fenthion	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP203	Fenthion	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP205	Fluoxastrobin	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP205	Fluoxastrobin	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP205	Fluoxastrobin	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP206	Flutriafol	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP206	Flutriafol	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP206	Flutriafol	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP207	Methabenzthiazuron	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP207	Methabenzthiazuron	30/10/2020	13:00	<0.001	mg/L	(- .001)	

	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP207	Methabenzthiazuron	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP208	Metolcarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP208	Metolcarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP208	Metolcarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP209	Prochloraz	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP209	Prochloraz	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP209	Prochloraz	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP210	Promecarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP210	Promecarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP210	Promecarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP211	Pyrimethanil	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP211	Pyrimethanil	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP211	Pyrimethanil	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP212	Tebufenpyrad	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP212	Tebufenpyrad	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP212	Tebufenpyrad	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP213	Tolclofos-methyl	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP213	Tolclofos-methyl	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP213	Tolclofos-methyl	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP214	Tridemorph	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP214	Tridemorph	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP214	Tridemorph	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP215	Cyazofamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP215	Cyazofamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP215	Cyazofamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP216	Salflufenacil hydrochlorid	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP216	Salflufenacil hydrochlorid	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP216	Salflufenacil hydrochlorid	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP217	Bendiocarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP217	Bendiocarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP217	Bendiocarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP218	XMC	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP218	XMC	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP218	XMC	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP219	Isofenphos	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP219	Isofenphos	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP219	Isofenphos	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP220	Ethion	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP220	Ethion	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP220	Ethion	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP221	Zoxamide	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP221	Zoxamide	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP221	Zoxamide	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP222	Pebulate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP222	Pebulate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP222	Pebulate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP223	Metosulam	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP223	Metosulam	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP223	Metosulam	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP224	Ethychlozate	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP224	Ethychlozate	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP224	Ethychlozate	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP225	Neburon	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP225	Neburon	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP225	Neburon	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP226	Propaquizafop	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP226	Propaquizafop	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP226	Propaquizafop	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP227	Thiodicarb	30/10/2020	12:45	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP227	Thiodicarb	30/10/2020	13:00	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP227	Thiodicarb	30/10/2020	12:40	<0.001	mg/L	(-.001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP228	Tricyclazole	30/10/2020	12:45	<0.001	mg/L	(-.001)	

	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP228	Tricyclazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP228	Tricyclazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP229	Pyrazoxyfen	30/10/2020	12:45	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP229	Pyrazoxyfen	30/10/2020	13:00	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP229	Pyrazoxyfen	30/10/2020	12:40	<0.002	mg/L	(- .002)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP230	Terbucarb	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP230	Terbucarb	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP230	Terbucarb	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP231	Thiofanox	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP231	Thiofanox	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP231	Thiofanox	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP232	Thiamethoxam	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP232	Thiamethoxam	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP232	Thiamethoxam	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP233	Thiofanox-sulfoxide	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP233	Thiofanox-sulfoxide	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP233	Thiofanox-sulfoxide	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP234	Benzethonium chloride	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP234	Benzethonium chloride	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP234	Benzethonium chloride	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-LCP235	Tetraconazole	30/10/2020	12:45	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Containerised Plant Filtrate	W-LCP235	Tetraconazole	30/10/2020	13:00	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Post Treated Water Reservoir	W-LCP235	Tetraconazole	30/10/2020	12:40	<0.001	mg/L	(- .001)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn01	2,3,4,6-Tetrachlorophenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn01	2,3,4,6-Tetrachlorophenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn01	2,3,4,6-Tetrachlorophenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn02	Total of 2,4,5 & 2,4,6 -Trichlorophenol	30/10/2020	12:45	<0.02	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn02	Total of 2,4,5 & 2,4,6 -Trichlorophenol	30/10/2020	13:00	<0.02	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn02	Total of 2,4,5 & 2,4,6 -Trichlorophenol	30/10/2020	12:40	<0.02	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn04	2,4-Dichlorophenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn04	2,4-Dichlorophenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn04	2,4-Dichlorophenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn06	2,6-Dichlorophenol	30/10/2020	12:45	<0.02	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn06	2,6-Dichlorophenol	30/10/2020	13:00	<0.02	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn06	2,6-Dichlorophenol	30/10/2020	12:40	<0.02	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn07	2-Chlorophenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn07	2-Chlorophenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn07	2-Chlorophenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn09	3,4,5-Trichlorophenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn09	3,4,5-Trichlorophenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn09	3,4,5-Trichlorophenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn10	4-Chloro-3-cresol or 4-Chloro-3-methylphenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn10	4-Chloro-3-cresol or 4-Chloro-3-methylphenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn10	4-Chloro-3-cresol or 4-Chloro-3-methylphenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn15	Pentachlorophenol	30/10/2020	12:45	<0.005	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn15	Pentachlorophenol	30/10/2020	13:00	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn15	Pentachlorophenol	30/10/2020	12:40	<0.005	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-Phn16	Phenol	30/10/2020	12:45	<0.01	mg/L		
	Waikouaiti WTP - Containerised Plant Filtrate	W-Phn16	Phenol	30/10/2020	13:00	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-Phn16	Phenol	30/10/2020	12:40	<0.01	mg/L		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	30/10/2020	11:10	61	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	30/10/2020	11:20	60	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	30/10/2020	10:40	60	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	30/10/2020	10:50	59	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	30/10/2020	11:30	62	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	30/10/2020	11:40	63	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	11:10	15.8	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	30/10/2020	11:20	15.2	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	10:40	16.1	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	30/10/2020	10:50	15.6	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	11:30	16	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	30/10/2020	11:40	15.7	g/m³		

	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	11:10	13.9	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	30/10/2020	11:20	13.8	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	10:40	14.2	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	30/10/2020	10:50	14	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	11:30	14.2	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	30/10/2020	11:40	13.9	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	11:10	11.8	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	30/10/2020	11:20	12.2	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	10:40	12.2	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	30/10/2020	10:50	12.3	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	11:30	11.5	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	30/10/2020	11:40	11.3	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	11:10	0.01	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	30/10/2020	11:20	0.007	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	10:40	0.013	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	30/10/2020	10:50	0.008	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	11:30	0.008	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	30/10/2020	11:40	0.07	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	11:10	17.4	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	30/10/2020	11:20	16.9	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	10:40	18.1	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	30/10/2020	10:50	16.9	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	11:30	17.9	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	30/10/2020	11:40	17.6	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	11:10	0.0184	g/m³		
	TAB Waikouaiti	6013	Copper - Acid Soluble	30/10/2020	11:20	0.0007	g/m³		
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	10:40	0.0347	g/m³		
	Karitane Bowls	6013	Copper - Acid Soluble	30/10/2020	10:50	0.0009	g/m³		
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	11:30	0.0238	g/m³		
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	30/10/2020	11:40	0.0132	g/m³		
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	11:10	0.03	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	30/10/2020	11:20	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	10:40	0.04	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	30/10/2020	10:50	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	11:30	0.14	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	30/10/2020	11:40	0.02	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	11:10	0.0083	g/m³		
	TAB Waikouaiti	6018	Lead - Acid Soluble	30/10/2020	11:20	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	10:40	0.0172	g/m³		
	Karitane Bowls	6018	Lead - Acid Soluble	30/10/2020	10:50	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	11:30	0.0034	g/m³		
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	30/10/2020	11:40	0.0006	g/m³		
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	11:10	7.77	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	30/10/2020	11:20	7.85	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	10:40	7.5	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	30/10/2020	10:50	7.32	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	11:30	7.42	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	30/10/2020	11:40	7.57	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	11:10	0.0117	g/m³		
	TAB Waikouaiti	6021	Manganese - Acid Soluble	30/10/2020	11:20	0.0006	g/m³		
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	10:40	0.0078	g/m³		
	Karitane Bowls	6021	Manganese - Acid Soluble	30/10/2020	10:50	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	11:30	0.0049	g/m³		
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	30/10/2020	11:40	0.0008	g/m³		
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	11:10	0.0042	g/m³		
	TAB Waikouaiti	6024	Nickel - Acid Soluble	30/10/2020	11:20	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	10:40	0.0043	g/m³		
	Karitane Bowls	6024	Nickel - Acid Soluble	30/10/2020	10:50	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	11:30	0.0007	g/m³		
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	30/10/2020	11:40	<0.0005	g/m³		
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	11:10	0.08	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	30/10/2020	11:20	<0.002	g/m³		

	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	10:40	0.112	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	30/10/2020	10:50	0.002	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	11:30	0.154	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	30/10/2020	11:40	0.016	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	11:10	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	30/10/2020	11:20	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	10:40	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	30/10/2020	10:50	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	11:30	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	30/10/2020	11:40	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	30/10/2020	11:10	7.5			
	TAB Waikouaiti	D-0001F	pH - Field	30/10/2020	11:20	7.6			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	30/10/2020	10:40	7.3			
	Karitane Bowls	D-0001F	pH - Field	30/10/2020	10:50	7.5			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	30/10/2020	11:30	7.8			
	Waikouaiti Golf Club	D-0001F	pH - Field	30/10/2020	11:40	7.8			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	11:10	8.9	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	30/10/2020	11:20	7.8	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	10:40	8.7	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	30/10/2020	10:50	7.6	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	11:30	7.4	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	30/10/2020	11:40	8.7	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	11:10	0.13	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	30/10/2020	11:20	0.61	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	10:40	0.17	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	30/10/2020	10:50	0.59	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	11:30	0.14	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	30/10/2020	11:40	0.14	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	30/10/2020	11:10	0.5	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	30/10/2020	11:20	0.8	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	30/10/2020	10:40	0.3	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	30/10/2020	10:50	0.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	30/10/2020	11:30	0.2	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	30/10/2020	11:40	0.3	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	30/10/2020	11:10	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	30/10/2020	11:10	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	30/10/2020	11:10	Completed			
	TAB Waikouaiti	P1859	Sample Filtration	30/10/2020	11:20	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	30/10/2020	10:40	Completed			
	Karitane Bowls	P1859	Sample Filtration	30/10/2020	10:50	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	30/10/2020	11:30	Completed			
	Waikouaiti Golf Club	P1859	Sample Filtration	30/10/2020	11:40	Completed			
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	30/10/2020	00:00:00				
	TAB Waikouaiti	52	Alkalinity - Total	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	30/10/2020	00:00:00				
	Karitane Bowls	52	Alkalinity - Total	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	30/10/2020	00:00:00				
	Waikouaiti Golf Club	52	Alkalinity - Total	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	Karitane Bowls	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				

	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	TAB Waikouaiti	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	Karitane Bowls	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			

	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	30/10/2020	00:00:00	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	30/10/2020	00:00:00				
	TAB Waikouaiti	D-0001F	pH - Field	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	30/10/2020	00:00:00				
	Karitane Bowls	D-0001F	pH - Field	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	30/10/2020	00:00:00				
	Waikouaiti Golf Club	D-0001F	pH - Field	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	TAB Waikouaiti	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	Karitane Bowls	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	TAB Waikouaiti	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	Karitane Bowls	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	Waikouaiti Golf Club	D-0066H	Total Chlorine	30/10/2020	00:00:00				
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	30/10/2020	00:00:00	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	30/10/2020	00:00:00	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	30/10/2020	00:00:00				
	TAB Waikouaiti	P1859	Sample Filtration	30/10/2020	00:00:00				
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	30/10/2020	00:00:00				
	Karitane Bowls	P1859	Sample Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	30/10/2020	00:00:00				
	Waikouaiti Golf Club	P1859	Sample Filtration	30/10/2020	00:00:00				
	Karitane Bowls	D-0058H	Free Available Chlorine	30/10/2020	10:50	0.59	g/m^3	(.2 - 5)	
	Karitane Bowls	D-0066H	Total Chlorine	30/10/2020	10:50	0.8	g/m^3		
	Karitane Bowls	D-0084	Turbidity	30/10/2020	10:50	0.09	NTU		
	Karitane Bowls	D-1310	Temperature on arrival	30/10/2020	10:50	7.7	Deg C		
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	30/10/2020	10:50	<1	MPN/100mL	(0 - 0)	
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	30/10/2020	10:50	<1	MPN/100ml	(0 - 0)	

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti Pumping Main	1	pH	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	52	Alkalinity - Total	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	P1859	Sample Filtration	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	Prob1	Problem Sample - INITIAL VALIDATION HERE:	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH031	MCPA in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH034	MCPB in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH043	Picloram in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	02/11/2020	00:00:00			
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	02/11/2020	00:00:00			
	TAB Waikouaiti	D-0058H	Free Available Chlorine	05/11/2020	11:50	0.42	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	05/11/2020	11:50	0.6	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	05/11/2020	11:50	0.2	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	05/11/2020	11:50	8.8	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	05/11/2020	11:50	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	05/11/2020	11:50	<1	MPN/100ml	(0 - 0)
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	05/11/2020	11:40	56	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	05/11/2020	11:50	57	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	05/11/2020	11:45	58	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	05/11/2020	11:55	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	05/11/2020	11:15	59	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	05/11/2020	11:25	59	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	05/11/2020	11:40	15.3	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	05/11/2020	11:50	15.2	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	05/11/2020	11:45	15.6	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	05/11/2020	11:55	15.5	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	05/11/2020	11:15	15.6	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	05/11/2020	11:25	15.6	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	05/11/2020	11:40	13.7	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	05/11/2020	11:50	13.6	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	05/11/2020	11:45	14	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	05/11/2020	11:55	13.6	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	05/11/2020	11:15	13.8	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	05/11/2020	11:25	14.9	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	05/11/2020	11:40	14.3	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	05/11/2020	11:50	15.3	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	05/11/2020	11:45	14.4	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	05/11/2020	11:55	14.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	05/11/2020	11:15	13.3	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	05/11/2020	11:25	14.1	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	05/11/2020	11:40	0.01	g/m³	

	TAB Waikouaiti	6001	Aluminium - Acid Soluble	05/11/2020	11:50	0.011	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	05/11/2020	11:45	0.014	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	05/11/2020	11:55	0.011	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	05/11/2020	11:15	0.009	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	05/11/2020	11:25	0.009	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	05/11/2020	11:40	16.1	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	05/11/2020	11:50	16	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	05/11/2020	11:45	16.7	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	05/11/2020	11:55	16.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	05/11/2020	11:15	17.2	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	05/11/2020	11:25	17.2	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	05/11/2020	11:40	0.0062	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	05/11/2020	11:50	0.0009	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	05/11/2020	11:45	0.01	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	05/11/2020	11:55	0.0007	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	05/11/2020	11:15	0.014	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	05/11/2020	11:25	0.011	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	05/11/2020	11:40	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	05/11/2020	11:50	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	05/11/2020	11:45	0.02	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	05/11/2020	11:55	0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	05/11/2020	11:15	0.04	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	05/11/2020	11:25	0.05	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	05/11/2020	11:40	0.0025	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	05/11/2020	11:50	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	05/11/2020	11:45	0.0049	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	05/11/2020	11:55	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	05/11/2020	11:15	0.0009	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	05/11/2020	11:25	0.0007	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	05/11/2020	11:40	8.38	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	05/11/2020	11:50	8.31	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	05/11/2020	11:45	7.52	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	05/11/2020	11:55	7.54	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	05/11/2020	11:15	7.28	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	05/11/2020	11:25	7.31	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	05/11/2020	11:40	0.001	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	05/11/2020	11:50	0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	05/11/2020	11:45	0.009	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	05/11/2020	11:55	0.0009	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	05/11/2020	11:15	0.0014	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	05/11/2020	11:25	0.0013	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	05/11/2020	11:40	0.0006	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	05/11/2020	11:50	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	05/11/2020	11:45	0.0018	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	05/11/2020	11:55	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	05/11/2020	11:15	<0.0005	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	05/11/2020	11:25	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	05/11/2020	11:40	0.037	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	05/11/2020	11:50	0.004	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	05/11/2020	11:45	0.043	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	05/11/2020	11:55	0.003	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	05/11/2020	11:15	0.045	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	05/11/2020	11:25	0.016	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	05/11/2020	11:40	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	05/11/2020	11:50	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	05/11/2020	11:45	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	05/11/2020	11:55	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	05/11/2020	11:15	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	05/11/2020	11:25	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	05/11/2020	11:40	6.6		
	TAB Waikouaiti	D-0001F	pH - Field	05/11/2020	11:50	6.6		

	Karitane Bowls - Pre-flush	D-0001F	pH - Field	05/11/2020	11:45	6.8		
	Karitane Bowls	D-0001F	pH - Field	05/11/2020	11:55	6.8		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	05/11/2020	11:15	6.8		
	Waikouaiti Golf Club	D-0001F	pH - Field	05/11/2020	11:25	5.7		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:40	6.5	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:50	6.8	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:45	7	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:55	6.8	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:15	6.9	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	05/11/2020	11:25	6.9	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	05/11/2020	11:40	0.29	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	05/11/2020	11:50	0.42	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	05/11/2020	11:45	0.46	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	05/11/2020	11:55	0.49	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	05/11/2020	11:15	0.09	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	05/11/2020	11:25	0.06	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	05/11/2020	11:40	0.5	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	05/11/2020	11:50	0.6	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	05/11/2020	11:45	0.6	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	05/11/2020	11:55	0.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	05/11/2020	11:15	0.2	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	05/11/2020	11:25	0.2	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	05/11/2020	11:40	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	05/11/2020	11:40	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	05/11/2020	11:40	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	05/11/2020	11:50	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	05/11/2020	11:45	Completed		
	Karitane Bowls	P1859	Sample Filtration	05/11/2020	11:55	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	05/11/2020	11:15	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	05/11/2020	11:25	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	61	Chloride	05/11/2020	10:30	10	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	61	Chloride	05/11/2020	10:20	11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	61	Chloride	05/11/2020	10:25	12	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	05/11/2020	10:30	0.12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	601	Fluoride - Add P1859 Filtration	05/11/2020	10:20	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	05/11/2020	10:25	0.11	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	05/11/2020	10:30	0.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	605	Nitrate - Nitrogen - Add P1859 Filtration	05/11/2020	10:20	0.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	05/11/2020	10:25	0.02	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	05/11/2020	10:30	18.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	05/11/2020	10:20	18.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	05/11/2020	10:25	16	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	704	Bromide - Ultra Trace	05/11/2020	10:30	0.029	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	704	Bromide - Ultra Trace	05/11/2020	10:20	0.027	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	704	Bromide - Ultra Trace	05/11/2020	10:25	0.006	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	05/11/2020	10:20	0.008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	05/11/2020	10:25	0.013	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6002	Antimony - Acid Soluble	05/11/2020	10:20	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	05/11/2020	10:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	05/11/2020	10:20	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	05/11/2020	10:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6004	Barium - Acid Soluble	05/11/2020	10:20	0.011	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	05/11/2020	10:25	0.011	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6007	Boron - Acid Soluble	05/11/2020	10:20	<0.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	05/11/2020	10:25	<0.03	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	05/11/2020	10:20	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	05/11/2020	10:25	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	05/11/2020	10:20	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	05/11/2020	10:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	05/11/2020	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	05/11/2020	10:25	0.0008	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	05/11/2020	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	05/11/2020	10:25	0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	05/11/2020	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	05/11/2020	10:25	0.0007	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	05/11/2020	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	05/11/2020	10:25	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	05/11/2020	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	05/11/2020	10:25	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	05/11/2020	10:20	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	05/11/2020	10:25	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	05/11/2020	10:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6702	Antimony - Dissolved	05/11/2020	10:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	05/11/2020	10:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6704	Barium - Dissolved	05/11/2020	10:30	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6707	Boron - Dissolved	05/11/2020	10:30	<0.03	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	05/11/2020	10:30	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	05/11/2020	10:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	05/11/2020	10:30	0.0018	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	05/11/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	05/11/2020	10:30	0.0017	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	05/11/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	05/11/2020	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	05/11/2020	10:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	05/11/2020	10:30	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	05/11/2020	10:20	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	05/11/2020	10:25	Completed		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	12/11/2020	14:30	67	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	12/11/2020	14:40	58	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	12/11/2020	14:55	59	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	12/11/2020	15:05	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	12/11/2020	13:45	60	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	12/11/2020	13:55	60	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	12/11/2020	14:30	17.9	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	12/11/2020	14:40	15.9	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	12/11/2020	14:55	16.4	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	12/11/2020	15:05	16.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	12/11/2020	13:45	16.4	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	12/11/2020	13:55	16.4	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	12/11/2020	14:30	14.9	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	12/11/2020	14:40	14.3	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	12/11/2020	14:55	14.6	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	12/11/2020	15:05	14.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	12/11/2020	13:45	14.3	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	12/11/2020	13:55	14.2	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	12/11/2020	14:30	11.4	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	12/11/2020	14:40	20.4	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	12/11/2020	14:55	20.9	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	12/11/2020	15:05	20.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	12/11/2020	13:45	18.8	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	12/11/2020	13:55	18.6	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	12/11/2020	14:30	0.005	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	12/11/2020	14:40	0.009	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	12/11/2020	14:55	0.02	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	12/11/2020	15:05	0.011	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	12/11/2020	13:45	0.009	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	12/11/2020	13:55	0.01	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	12/11/2020	14:30	17.4	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	12/11/2020	14:40	16.3	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	12/11/2020	14:55	17.2	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	12/11/2020	15:05	18.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	12/11/2020	13:45	18.4	g/m³	

	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	12/11/2020	13:55	18.8	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	12/11/2020	14:30	1.28	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	12/11/2020	14:40	0.057	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	12/11/2020	14:55	0.0462	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	12/11/2020	15:05	0.0042	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	12/11/2020	13:45	0.0086	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	12/11/2020	13:55	0.0082	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	12/11/2020	14:30	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	12/11/2020	14:40	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	12/11/2020	14:55	0.02	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	12/11/2020	15:05	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	12/11/2020	13:45	0.14	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	12/11/2020	13:55	0.04	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	12/11/2020	14:30	0.0021	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	12/11/2020	14:40	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	12/11/2020	14:55	0.0093	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	12/11/2020	15:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	12/11/2020	13:45	0.0021	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	12/11/2020	13:55	0.0009	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	12/11/2020	14:30	8.17	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	12/11/2020	14:40	8.49	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	12/11/2020	14:55	7.3	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	12/11/2020	15:05	7.42	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	12/11/2020	13:45	7.03	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	12/11/2020	13:55	7.06	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	12/11/2020	14:30	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	12/11/2020	14:40	0.0029	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	12/11/2020	14:55	0.014	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	12/11/2020	15:05	0.0013	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	12/11/2020	13:45	0.002	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	12/11/2020	13:55	0.0016	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	12/11/2020	14:30	0.0007	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	12/11/2020	14:40	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	12/11/2020	14:55	0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	12/11/2020	15:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	12/11/2020	13:45	<0.0005	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	12/11/2020	13:55	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	12/11/2020	14:30	0.086	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	12/11/2020	14:40	0.006	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	12/11/2020	14:55	0.117	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	12/11/2020	15:05	0.003	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	12/11/2020	13:45	0.13	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	12/11/2020	13:55	0.011	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	12/11/2020	14:30	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	12/11/2020	14:40	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	12/11/2020	14:55	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	12/11/2020	15:05	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	12/11/2020	13:45	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	12/11/2020	13:55	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	12/11/2020	14:30	6.7		
	TAB Waikouaiti	D-0001F	pH - Field	12/11/2020	14:40	7		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	12/11/2020	14:55	7		
	Karitane Bowls	D-0001F	pH - Field	12/11/2020	15:05	7		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	12/11/2020	13:45	7.4		
	Waikouaiti Golf Club	D-0001F	pH - Field	12/11/2020	13:55	7.4		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/11/2020	14:30	6.8	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	12/11/2020	14:40	8.7	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/11/2020	14:55	8.2	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	12/11/2020	15:05	7.8	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/11/2020	13:45	7	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	12/11/2020	13:55	6.9	g O2/m³	

	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	12/11/2020	14:30	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	12/11/2020	14:40	0.65	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	12/11/2020	14:55	0.42	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	12/11/2020	15:05	0.66	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	12/11/2020	13:45	0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	12/11/2020	13:55	0.08	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	12/11/2020	14:30	0.1	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	12/11/2020	14:40	0.8	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	12/11/2020	14:55	0.5	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	12/11/2020	15:05	0.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	12/11/2020	13:45	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	12/11/2020	13:55	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	12/11/2020	14:30	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	12/11/2020	14:30	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	12/11/2020	14:30	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	12/11/2020	14:40	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	12/11/2020	14:55	Completed		
	Karitane Bowls	P1859	Sample Filtration	12/11/2020	15:05	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	12/11/2020	13:45	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	12/11/2020	13:55	Completed		
	Waikouaiti Pumping Main	D-1204	Sampling / Inspection 60 Mins	12/11/2020	14:00	Completed		
	Waikouaiti Pumping Main	W-TO001	Geosmin by SPME	12/11/2020	14:00	4.3	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	12/11/2020	13:35	3.6	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	12/11/2020	13:25	3.2	ng/L	
	Waikouaiti Pumping Main	W-TO002	2-Methylisoborneol by SPME	12/11/2020	14:00	7.9	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	12/11/2020	13:35	7.2	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	12/11/2020	13:25	6.2	ng/L	
	Waikouaiti Pumping Main	W-TO003	2,4,6-Trichloroanisole by SPME	12/11/2020	14:00	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	12/11/2020	13:35	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	12/11/2020	13:25	<1	ng/L	
	Waikouaiti Pre Treatment	D-0084	Turbidity	17/11/2020	11:30	0.89	NTU	
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	17/11/2020	11:30	Completed		
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	17/11/2020	11:30	29	MPN/100mL (28.8 x 1)	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	17/11/2020	11:10	0.53	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	17/11/2020	11:10	0.7	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	17/11/2020	11:10	0.07	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	17/11/2020	11:10	5.9	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	17/11/2020	11:10	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	17/11/2020	11:10	<1	MPN/100ml	(0 - 0)
	Waikouaiti Pumping Main	1	pH	20/11/2020	12:00	7.6		(1 - 14)
	Waikouaiti Pumping Main	52	Alkalinity - Total	20/11/2020	12:00	63	g CaCO3/m³	
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	20/11/2020	12:00	19.1	mS/m (190.7 x .1)	
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	20/11/2020	12:00	0.32	g/m³	
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	20/11/2020	12:00	127	g/m³	
	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	20/11/2020	12:00	17.1	g/m³	
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	20/11/2020	12:00	7.86	g/m³	
	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	20/11/2020	12:00	75	g CaCO3/m³	
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	20/11/2020	12:00	43	g CaCO3/m³	
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	20/11/2020	12:00	<0.005	g/m³	
	Waikouaiti Pumping Main	P1859	Sample Filtration	20/11/2020	12:00	Completed		
	Waikouaiti Pumping Main	Prob1	Problem Sample - INITIAL VALIDATION HERE:	20/11/2020	12:00	Problem	resolved and closed.	
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	20/11/2020	12:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	20/11/2020	12:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	20/11/2020	12:00	<0.0005	mg/L	

	Waikouaiti Pumping Main	W-AH031	MCPA in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH034	MCPB in water	20/11/2020	12:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH043	Picloram in water	20/11/2020	12:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	20/11/2020	12:00	<0.0005	mg/L	
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	20/11/2020	11:55	56	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	20/11/2020	12:05	56	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	20/11/2020	11:00	56	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	20/11/2020	11:10	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	20/11/2020	11:35	57	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	20/11/2020	11:45	58	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	20/11/2020	11:55	15.2	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	20/11/2020	12:05	15.1	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	20/11/2020	11:00	15.3	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	20/11/2020	11:10	15.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	20/11/2020	11:35	15.3	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	20/11/2020	11:45	15.1	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	20/11/2020	11:55	13.7	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	20/11/2020	12:05	13.3	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	20/11/2020	11:00	13.4	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	20/11/2020	11:10	13.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	20/11/2020	11:35	13.6	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	20/11/2020	11:45	13.3	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	20/11/2020	11:55	17.7	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	20/11/2020	12:05	13.2	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	20/11/2020	11:00	13.8	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	20/11/2020	11:10	13.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	20/11/2020	11:35	16	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	20/11/2020	11:45	15.7	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	20/11/2020	11:55	0.005	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	20/11/2020	12:05	0.009	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	20/11/2020	11:00	0.01	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	20/11/2020	11:10	0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	20/11/2020	11:35	0.009	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	20/11/2020	11:45	0.01	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	20/11/2020	11:55	16	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	20/11/2020	12:05	16.3	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	20/11/2020	11:00	16.3	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	20/11/2020	11:10	16.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	20/11/2020	11:35	17.3	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	20/11/2020	11:45	17.5	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	20/11/2020	11:55	1.24	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	20/11/2020	12:05	0.072	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	20/11/2020	11:00	0.0363	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	20/11/2020	11:10	0.0075	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	20/11/2020	11:35	0.0162	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	20/11/2020	11:45	0.0116	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	20/11/2020	11:55	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	20/11/2020	12:05	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	20/11/2020	11:00	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	20/11/2020	11:10	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	20/11/2020	11:35	0.03	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	20/11/2020	11:45	0.03	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	20/11/2020	11:55	0.0015	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	20/11/2020	12:05	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	20/11/2020	11:00	0.0061	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	20/11/2020	11:10	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	20/11/2020	11:35	0.0013	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	20/11/2020	11:45	0.001	g/m³	

	Waikouaiti TAB - Pre-flush		6020	Magnesium - Acid Soluble	20/11/2020	11:55	8.79	g/m³	
	TAB Waikouaiti		6020	Magnesium - Acid Soluble	20/11/2020	12:05	8.21	g/m³	
	Karitane Bowls - Pre-flush		6020	Magnesium - Acid Soluble	20/11/2020	11:00	7.82	g/m³	
	Karitane Bowls		6020	Magnesium - Acid Soluble	20/11/2020	11:10	8.14	g/m³	
	Waikouaiti Golf Club - Pre-flush		6020	Magnesium - Acid Soluble	20/11/2020	11:35	7.87	g/m³	
	Waikouaiti Golf Club		6020	Magnesium - Acid Soluble	20/11/2020	11:45	8.04	g/m³	
	Waikouaiti TAB - Pre-flush		6021	Manganese - Acid Soluble	20/11/2020	11:55	0.0027	g/m³	
	TAB Waikouaiti		6021	Manganese - Acid Soluble	20/11/2020	12:05	0.001	g/m³	
	Karitane Bowls - Pre-flush		6021	Manganese - Acid Soluble	20/11/2020	11:00	0.001	g/m³	
	Karitane Bowls		6021	Manganese - Acid Soluble	20/11/2020	11:10	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush		6021	Manganese - Acid Soluble	20/11/2020	11:35	0.0018	g/m³	
	Waikouaiti Golf Club		6021	Manganese - Acid Soluble	20/11/2020	11:45	0.0014	g/m³	
	Waikouaiti TAB - Pre-flush		6024	Nickel - Acid Soluble	20/11/2020	11:55	<0.0005	g/m³	
	TAB Waikouaiti		6024	Nickel - Acid Soluble	20/11/2020	12:05	<0.0005	g/m³	
	Karitane Bowls - Pre-flush		6024	Nickel - Acid Soluble	20/11/2020	11:00	<0.0005	g/m³	
	Karitane Bowls		6024	Nickel - Acid Soluble	20/11/2020	11:10	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush		6024	Nickel - Acid Soluble	20/11/2020	11:35	0.0006	g/m³	
	Waikouaiti Golf Club		6024	Nickel - Acid Soluble	20/11/2020	11:45	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush		6038	Zinc - Acid Soluble	20/11/2020	11:55	0.06	g/m³	
	TAB Waikouaiti		6038	Zinc - Acid Soluble	20/11/2020	12:05	0.006	g/m³	
	Karitane Bowls - Pre-flush		6038	Zinc - Acid Soluble	20/11/2020	11:00	0.123	g/m³	
	Karitane Bowls		6038	Zinc - Acid Soluble	20/11/2020	11:10	0.007	g/m³	
	Waikouaiti Golf Club - Pre-flush		6038	Zinc - Acid Soluble	20/11/2020	11:35	0.041	g/m³	
	Waikouaiti Golf Club		6038	Zinc - Acid Soluble	20/11/2020	11:45	0.237	g/m³	
	Waikouaiti TAB - Pre-flush		9402	ICP-MS - 2 Elements	20/11/2020	11:55	Completed		
	TAB Waikouaiti		9402	ICP-MS - 2 Elements	20/11/2020	12:05	Completed		
	Karitane Bowls - Pre-flush		9402	ICP-MS - 2 Elements	20/11/2020	11:00	Completed		
	Karitane Bowls		9402	ICP-MS - 2 Elements	20/11/2020	11:10	Completed		
	Waikouaiti Golf Club - Pre-flush		9402	ICP-MS - 2 Elements	20/11/2020	11:35	Completed		
	Waikouaiti Golf Club		9402	ICP-MS - 2 Elements	20/11/2020	11:45	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F		pH - Field	20/11/2020	11:55	7		
	TAB Waikouaiti	D-0001F		pH - Field	20/11/2020	12:05	7		
	Karitane Bowls - Pre-flush	D-0001F		pH - Field	20/11/2020	11:00	7.1		
	Karitane Bowls	D-0001F		pH - Field	20/11/2020	11:10	7		
	Waikouaiti Golf Club - Pre-flush	D-0001F		pH - Field	20/11/2020	11:35	7.2		
	Waikouaiti Golf Club	D-0001F		pH - Field	20/11/2020	11:45	7.3		
	Waikouaiti TAB - Pre-flush	D-0056F		Dissolved Oxygen - Field	20/11/2020	11:55	6.7	g O2/m³	
	TAB Waikouaiti	D-0056F		Dissolved Oxygen - Field	20/11/2020	12:05	6.8	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F		Dissolved Oxygen - Field	20/11/2020	11:00	7.1	g O2/m³	
	Karitane Bowls	D-0056F		Dissolved Oxygen - Field	20/11/2020	11:10	8.4	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F		Dissolved Oxygen - Field	20/11/2020	11:35	6.8	g O2/m³	
	Waikouaiti Golf Club	D-0056F		Dissolved Oxygen - Field	20/11/2020	11:45	6.9	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H		Free Available Chlorine	20/11/2020	11:55	<0.05	g/m³	
	TAB Waikouaiti	D-0058H		Free Available Chlorine	20/11/2020	12:05	0.62	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H		Free Available Chlorine	20/11/2020	11:00	0.41	g/m³	
	Karitane Bowls	D-0058H		Free Available Chlorine	20/11/2020	11:10	0.34	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H		Free Available Chlorine	20/11/2020	11:35	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H		Free Available Chlorine	20/11/2020	11:45	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H		Total Chlorine	20/11/2020	11:55	<0.05	g/m³	
	TAB Waikouaiti	D-0066H		Total Chlorine	20/11/2020	12:05	0.7	g/m³	
	Karitane Bowls - Pre-flush	D-0066H		Total Chlorine	20/11/2020	11:00	0.5	g/m³	
	Karitane Bowls	D-0066H		Total Chlorine	20/11/2020	11:10	0.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H		Total Chlorine	20/11/2020	11:35	0.2	g/m³	
	Waikouaiti Golf Club	D-0066H		Total Chlorine	20/11/2020	11:45	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202		Sampling / Inspection 30 Mins	20/11/2020	11:55	Completed		
	Waikouaiti TAB - Pre-flush	D-1205		Sampling / Inspection 2 hours	20/11/2020	11:55	Completed		
	Waikouaiti TAB - Pre-flush	P1859		Sample Filtration	20/11/2020	11:55	Completed		
	TAB Waikouaiti	P1859		Sample Filtration	20/11/2020	12:05	Completed		
	Karitane Bowls - Pre-flush	P1859		Sample Filtration	20/11/2020	11:00	Completed		
	Karitane Bowls	P1859		Sample Filtration	20/11/2020	11:10	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859		Sample Filtration	20/11/2020	11:35	Completed		

	Waikouaiti Golf Club	P1859	Sample Filtration	20/11/2020	11:45	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	25/11/2020	12:25	0.62	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	25/11/2020	12:25	0.6	g/m³	
	Karitane Bowls	D-0084	Turbidity	25/11/2020	12:25	0.1	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	25/11/2020	12:25	7.5	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	25/11/2020	12:25	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	25/11/2020	12:25	<1	MPN/100ml	(0 - 0)
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	27/11/2020	11:05	56	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	27/11/2020	11:15	59	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	27/11/2020	10:40	60	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	27/11/2020	10:50	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	27/11/2020	11:30	58	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	27/11/2020	11:40	57	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	27/11/2020	11:05	15.7	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	27/11/2020	11:15	16.4	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	27/11/2020	10:40	16.5	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	27/11/2020	10:50	16.6	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	27/11/2020	11:30	16.2	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	27/11/2020	11:40	16.1	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	27/11/2020	11:05	13.8	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	27/11/2020	11:15	14.2	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	27/11/2020	10:40	13.9	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	27/11/2020	10:50	14.1	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	27/11/2020	11:30	15.5	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	27/11/2020	11:40	13.7	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	27/11/2020	11:05	13.1	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	27/11/2020	11:15	11	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	27/11/2020	10:40	10.9	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	27/11/2020	10:50	11.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	27/11/2020	11:30	14.1	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	27/11/2020	11:40	11.7	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	27/11/2020	11:05	0.006	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	27/11/2020	11:15	0.01	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	27/11/2020	10:40	0.026	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	27/11/2020	10:50	0.012	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	27/11/2020	11:30	0.01	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	27/11/2020	11:40	0.009	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	27/11/2020	11:05	15.2	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	27/11/2020	11:15	14.9	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	27/11/2020	10:40	15.9	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	27/11/2020	10:50	16.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	27/11/2020	11:30	16.4	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	27/11/2020	11:40	16.3	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	27/11/2020	11:05	1.31	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	27/11/2020	11:15	0.0437	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	27/11/2020	10:40	0.0291	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	27/11/2020	10:50	0.008	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	27/11/2020	11:30	0.0325	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	27/11/2020	11:40	0.0119	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	27/11/2020	11:05	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	27/11/2020	11:15	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	27/11/2020	10:40	0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	27/11/2020	10:50	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	27/11/2020	11:30	0.08	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	27/11/2020	11:40	0.02	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	27/11/2020	11:05	0.0017	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	27/11/2020	11:15	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	27/11/2020	10:40	0.0046	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	27/11/2020	10:50	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	27/11/2020	11:30	0.0033	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	27/11/2020	11:40	0.0007	g/m³	

	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	27/11/2020	11:05	7.92	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	27/11/2020	11:15	7.92	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	27/11/2020	10:40	7.71	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	27/11/2020	10:50	7.71	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	27/11/2020	11:30	7.46	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	27/11/2020	11:40	7.46	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	27/11/2020	11:05	0.0014	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	27/11/2020	11:15	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	27/11/2020	10:40	0.0157	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	27/11/2020	10:50	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	27/11/2020	11:30	0.0023	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	27/11/2020	11:40	0.0012	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	27/11/2020	11:05	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	27/11/2020	11:15	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	27/11/2020	10:40	0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	27/11/2020	10:50	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	27/11/2020	11:30	0.0009	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	27/11/2020	11:40	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	27/11/2020	11:05	0.048	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	27/11/2020	11:15	0.008	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	27/11/2020	10:40	0.084	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	27/11/2020	10:50	0.015	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	27/11/2020	11:30	0.091	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	27/11/2020	11:40	0.02	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	27/11/2020	11:05	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	27/11/2020	11:15	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	27/11/2020	10:40	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	27/11/2020	10:50	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	27/11/2020	11:30	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	27/11/2020	11:40	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	27/11/2020	11:05	6.9		
	TAB Waikouaiti	D-0001F	pH - Field	27/11/2020	11:15	7		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	27/11/2020	10:40	6.4		
	Karitane Bowls	D-0001F	pH - Field	27/11/2020	10:50	6.8		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	27/11/2020	11:30	7.3		
	Waikouaiti Golf Club	D-0001F	pH - Field	27/11/2020	11:40	7.4		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	27/11/2020	11:05	7.3	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	27/11/2020	11:15	8.4	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	27/11/2020	10:40	8.1	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	27/11/2020	10:50	8.2	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	27/11/2020	11:30	6.8	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	27/11/2020	11:40	7.3	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	27/11/2020	11:05	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	27/11/2020	11:15	0.6	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	27/11/2020	10:40	0.39	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	27/11/2020	10:50	0.52	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	27/11/2020	11:30	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	27/11/2020	11:40	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	27/11/2020	11:05	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	27/11/2020	11:15	0.6	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	27/11/2020	10:40	0.5	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	27/11/2020	10:50	0.6	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	27/11/2020	11:30	<0.05	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	27/11/2020	11:40	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	27/11/2020	11:05	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	27/11/2020	11:05	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	27/11/2020	11:05	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	27/11/2020	11:15	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	27/11/2020	10:40	Completed		
	Karitane Bowls	P1859	Sample Filtration	27/11/2020	10:50	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	27/11/2020	11:30	Completed		

	Waikouaiti Golf Club	P1859	Sample Filtration	27/11/2020	11:40	Completed		
	Waikouaiti Pumping Main	D-1204	Sampling / Inspection 60 Mins	27/11/2020	12:00	Completed		
	Waikouaiti Pumping Main	W-TO001	Geosmin by SPME	27/11/2020	12:00	5.9	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	27/11/2020	12:20	6	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	27/11/2020	12:15	5.7	ng/L	
	Waikouaiti Pumping Main	W-TO002	2-Methylisoborneol by SPME	27/11/2020	12:00	6.5	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	27/11/2020	12:20	6.8	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	27/11/2020	12:15	7.6	ng/L	
	Waikouaiti Pumping Main	W-TO003	2,4,6-Trichloroanisole by SPME	27/11/2020	12:00	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	27/11/2020	12:20	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	27/11/2020	12:15	<1	ng/L	

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti Pumping Main	D-1204	Sampling / Inspection 60 Mins	04/12/2020	10:40	Completed		
	Waikouaiti Pumping Main	W-TO001	Geosmin by SPME	04/12/2020	10:40	6.6	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	04/12/2020	10:30	6.7	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	04/12/2020	10:25	7	ng/L	
	Waikouaiti Pumping Main	W-TO002	2-Methylisoborneol by SPME	04/12/2020	10:40	4.8	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	04/12/2020	10:30	6.8	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	04/12/2020	10:25	6.9	ng/L	
	Waikouaiti Pumping Main	W-TO003	2,4,6-Trichloroanisole by SPME	04/12/2020	10:40	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	04/12/2020	10:30	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	04/12/2020	10:25	<1	ng/L	
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	04/12/2020	10:55	58	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	04/12/2020	11:05	56	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	04/12/2020	11:55	57	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	04/12/2020	12:05	59	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	04/12/2020	11:25	60	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	04/12/2020	11:35	58	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	04/12/2020	10:55	16	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	04/12/2020	11:05	15.4	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	04/12/2020	11:55	15.7	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	04/12/2020	12:05	15.5	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	04/12/2020	11:25	16	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	04/12/2020	11:35	15.9	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	04/12/2020	10:55	14.3	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	04/12/2020	11:05	14.1	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	04/12/2020	11:55	14.2	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	04/12/2020	12:05	14.1	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	04/12/2020	11:25	14.4	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	04/12/2020	11:35	14.3	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	04/12/2020	10:55	10.7	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	04/12/2020	11:05	11.2	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	04/12/2020	11:55	10.8	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	04/12/2020	12:05	11.1	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	04/12/2020	11:25	10.9	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	04/12/2020	11:35	10.9	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	04/12/2020	10:55	0.006	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	04/12/2020	11:05	0.01	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	04/12/2020	11:55	0.014	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	04/12/2020	12:05	0.012	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	04/12/2020	11:25	0.019	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	04/12/2020	11:35	0.012	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	04/12/2020	10:55	17.3	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	04/12/2020	11:05	16.5	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	04/12/2020	11:55	17.4	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	04/12/2020	12:05	17.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	04/12/2020	11:25	18.6	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	04/12/2020	11:35	18.4	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	04/12/2020	10:55	0.096	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	04/12/2020	11:05	0.0568	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	04/12/2020	11:55	0.0393	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	04/12/2020	12:05	0.0046	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	04/12/2020	11:25	0.0461	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	04/12/2020	11:35	0.0187	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	04/12/2020	10:55	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	04/12/2020	11:05	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	04/12/2020	11:55	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	04/12/2020	12:05	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	04/12/2020	11:25	0.2	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	04/12/2020	11:35	0.05	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	04/12/2020	10:55	0.0012	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	04/12/2020	11:05	0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	04/12/2020	11:55	0.0053	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	04/12/2020	12:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	04/12/2020	11:25	0.0081	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	04/12/2020	11:35	0.0025	g/m³	

	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	04/12/2020	10:55	7.96	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	04/12/2020	11:05	7.89	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	04/12/2020	11:55	7.78	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	04/12/2020	12:05	7.72	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	04/12/2020	11:25	7.76	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	04/12/2020	11:35	7.7	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	04/12/2020	10:55	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	04/12/2020	11:05	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	04/12/2020	11:55	0.0026	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	04/12/2020	12:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	04/12/2020	11:25	0.0062	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	04/12/2020	11:35	0.0012	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	04/12/2020	10:55	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	04/12/2020	11:05	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	04/12/2020	11:55	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	04/12/2020	12:05	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	04/12/2020	11:25	0.0008	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	04/12/2020	11:35	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	04/12/2020	10:55	0.061	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	04/12/2020	11:05	0.01	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	04/12/2020	11:55	0.102	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	04/12/2020	12:05	0.004	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	04/12/2020	11:25	0.105	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	04/12/2020	11:35	0.051	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	04/12/2020	10:55	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	04/12/2020	11:05	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	04/12/2020	11:55	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	04/12/2020	12:05	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	04/12/2020	11:25	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	04/12/2020	11:35	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	04/12/2020	10:55	6.7		
	TAB Waikouaiti	D-0001F	pH - Field	04/12/2020	11:05	6.8		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	04/12/2020	11:55	7.1		
	Karitane Bowls	D-0001F	pH - Field	04/12/2020	12:05	7.2		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	04/12/2020	11:25	7.1		
	Waikouaiti Golf Club	D-0001F	pH - Field	04/12/2020	11:35	7.2		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	04/12/2020	10:55	6.4	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	04/12/2020	11:05	7.8	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	04/12/2020	11:55	8.3	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	04/12/2020	12:05	8.2	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	04/12/2020	11:25	8.3	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	04/12/2020	11:35	7.2	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	04/12/2020	10:55	0.06	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	04/12/2020	11:05	0.75	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	04/12/2020	11:55	0.5	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	04/12/2020	12:05	0.67	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	04/12/2020	11:25	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	04/12/2020	11:35	0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	04/12/2020	10:55	0.1	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	04/12/2020	11:05	0.9	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	04/12/2020	11:55	0.6	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	04/12/2020	12:05	0.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	04/12/2020	11:25	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	04/12/2020	11:35	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	04/12/2020	10:55	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	04/12/2020	10:55	Completed		
	Waikouaiti Golf Club - Pre-flush	O1420	Sampler Observation	04/12/2020	11:25	No	water at usual tap, smaple taken around corner at alternate tap	
	Waikouaiti Golf Club	O1420	Sampler Observation	04/12/2020	11:35	No	water at usual tap, smaple taken around corner at alternate tap	
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	04/12/2020	10:55	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	04/12/2020	11:05	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	04/12/2020	11:55	Completed		
	Karitane Bowls	P1859	Sample Filtration	04/12/2020	12:05	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	04/12/2020	11:25	Completed		

	Waikouaiti Golf Club	P1859	Sample Filtration	04/12/2020	11:35	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	04/12/2020	12:05	0.67	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	04/12/2020	12:05	0.9	g/m³	
	Karitane Bowls	D-0084	Turbidity	04/12/2020	12:05	0.63	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	04/12/2020	12:05	6.8	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/12/2020	12:05	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/12/2020	12:05	<1	MPN/100ml	(0 - 0)
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	08/12/2020	14:46	59	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	08/12/2020	14:51	57	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	08/12/2020	12:55	57	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	08/12/2020	13:00	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	08/12/2020	14:22	59	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	08/12/2020	14:27	60	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	08/12/2020	14:46	15.7	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	08/12/2020	14:51	15.1	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	08/12/2020	12:55	15.3	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	08/12/2020	13:00	15.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	08/12/2020	14:22	15.2	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	08/12/2020	14:27	15.4	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	08/12/2020	14:46	14.3	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	08/12/2020	14:51	13.5	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	08/12/2020	12:55	13.9	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	08/12/2020	13:00	13.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	08/12/2020	14:22	13.9	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	08/12/2020	14:27	14	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	08/12/2020	14:46	11.1	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	08/12/2020	14:51	11	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	08/12/2020	12:55	11.5	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	08/12/2020	13:00	11.3	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	08/12/2020	14:22	11.4	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	08/12/2020	14:27	11.6	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	08/12/2020	14:46	0.004	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	08/12/2020	14:51	0.01	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	08/12/2020	12:55	0.012	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	08/12/2020	13:00	0.02	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	08/12/2020	14:22	0.017	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	08/12/2020	14:27	0.052	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	08/12/2020	14:46	16.5	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	08/12/2020	14:51	16.1	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	08/12/2020	12:55	16.9	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	08/12/2020	13:00	16.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	08/12/2020	14:22	17.3	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	08/12/2020	14:27	17.7	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	08/12/2020	14:46	0.91	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	08/12/2020	14:51	0.0625	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	08/12/2020	12:55	0.0168	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	08/12/2020	13:00	0.048	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	08/12/2020	14:22	0.121	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	08/12/2020	14:27	1.51	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	08/12/2020	14:46	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	08/12/2020	14:51	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	08/12/2020	12:55	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	08/12/2020	13:00	0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	08/12/2020	14:22	0.08	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	08/12/2020	14:27	0.54	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	08/12/2020	14:46	0.0009	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	08/12/2020	14:51	0.0007	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	08/12/2020	12:55	0.0024	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	08/12/2020	13:00	0.072	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	08/12/2020	14:22	0.0168	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	08/12/2020	14:27	0.394	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	08/12/2020	14:46	8.26	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	08/12/2020	14:51	8.13	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	08/12/2020	12:55	7.86	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	08/12/2020	13:00	7.81	g/m³	

	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	08/12/2020	14:22	7.74	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	08/12/2020	14:27	7.66	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	08/12/2020	14:46	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	08/12/2020	14:51	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	08/12/2020	12:55	0.0017	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	08/12/2020	13:00	0.0032	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	08/12/2020	14:22	0.0021	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	08/12/2020	14:27	0.0086	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	08/12/2020	14:46	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	08/12/2020	14:51	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	08/12/2020	12:55	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	08/12/2020	13:00	0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	08/12/2020	14:22	0.001	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	08/12/2020	14:27	0.009	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	08/12/2020	14:46	0.029	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	08/12/2020	14:51	0.019	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	08/12/2020	12:55	0.034	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	08/12/2020	13:00	0.139	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	08/12/2020	14:22	0.203	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	08/12/2020	14:27	1.31	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	08/12/2020	14:46	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	08/12/2020	14:51	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	08/12/2020	12:55	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	08/12/2020	13:00	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	08/12/2020	14:22	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	08/12/2020	14:27	Completed		
	Waikouaiti TAB - Pre-flush	D-0001	pH	08/12/2020	14:46	7.7		
	TAB Waikouaiti	D-0001	pH	08/12/2020	14:51	7.8		
	Karitane Bowls - Pre-flush	D-0001	pH	08/12/2020	12:55	7.8		
	Karitane Bowls	D-0001	pH	08/12/2020	13:00	7.9		
	Waikouaiti Golf Club - Pre-flush	D-0001	pH	08/12/2020	14:22	7.9		
	Waikouaiti Golf Club	D-0001	pH	08/12/2020	14:27	8		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	08/12/2020	14:46	5.7	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	08/12/2020	14:51	7	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	08/12/2020	12:55	7.1	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	08/12/2020	13:00	7	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	08/12/2020	14:22	5.6	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	08/12/2020	14:27	6.7	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	08/12/2020	14:46	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	08/12/2020	14:51	0.74	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	08/12/2020	12:55	0.47	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	08/12/2020	13:00	0.62	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	08/12/2020	14:22	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	08/12/2020	14:27	0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	08/12/2020	14:46	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	08/12/2020	14:51	0.9	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	08/12/2020	12:55	0.6	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	08/12/2020	13:00	0.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	08/12/2020	14:22	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	08/12/2020	14:27	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	08/12/2020	14:46	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	08/12/2020	14:46	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	08/12/2020	14:46	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	08/12/2020	14:51	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	08/12/2020	12:55	Completed		
	Karitane Bowls	P1859	Sample Filtration	08/12/2020	13:00	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	08/12/2020	14:22	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	08/12/2020	14:27	Completed		
	Waikouaiti Pumping Main	1	pH	08/12/2020	11:50	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	08/12/2020	11:15	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	08/12/2020	11:10	7.7		(1 - 14)
	Waikouaiti Pumping Main	2	Suspended Solids - Total	08/12/2020	11:50	<5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	08/12/2020	11:15	<5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	08/12/2020	11:10	<5	g/m³	
	Waikouaiti Pumping Main	0040B	Total Organic Carbon by TOC analyser	08/12/2020	11:50	2.6	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0040B	Total Organic Carbon by TOC analyser	08/12/2020	11:15	2.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0040B	Total Organic Carbon by TOC analyser	08/12/2020	11:10	1.3	g/m³	
	Waikouaiti Pumping Main	49	Total Solids - g/m3 units	08/12/2020	11:50	124	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	49	Total Solids - g/m3 units	08/12/2020	11:15	120	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	49	Total Solids - g/m3 units	08/12/2020	11:10	142	g/m³	
	Waikouaiti Pumping Main	52	Alkalinity - Total	08/12/2020	11:50	63	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	08/12/2020	11:15	62	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	08/12/2020	11:10	61	g CaCO3/m³	
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	08/12/2020	11:50	18.5	mS/m (185.3 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	55	Conductivity at 25°C - mS/m unit	08/12/2020	11:15	18.4	mS/m (184.2 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	08/12/2020	11:10	19.4	mS/m (194.1 x .1)	
	Waikouaiti Pumping Main	73	Bicarbonate by Calculation - requires tests 1 & 52	08/12/2020	11:50	63	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	73	Bicarbonate by Calculation - requires tests 1 & 52	08/12/2020	11:15	62	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	73	Bicarbonate by Calculation - requires tests 1 & 52	08/12/2020	11:10	61	g CaCO3/m³	
	Waikouaiti Pumping Main	74	Carbonate by Calculation - requires tests 1, 52, 73	08/12/2020	11:50	<1	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	74	Carbonate by Calculation - requires tests 1, 52, 73	08/12/2020	11:15	<1	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	74	Carbonate by Calculation - requires tests 1, 52, 73	08/12/2020	11:10	<1	g CaCO3/m³	
	Waikouaiti Pumping Main	76	Free CO2 by Calculation - requires tests 1, 52 & 73	08/12/2020	11:50	2	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	76	Free CO2 by Calculation - requires tests 1, 52 & 73	08/12/2020	11:15	2	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	76	Free CO2 by Calculation - requires tests 1, 52 & 73	08/12/2020	11:10	2	g CO2/m³	
	Waikouaiti Pumping Main	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	08/12/2020	11:50	57	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	08/12/2020	11:15	57	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	08/12/2020	11:10	56	g CO2/m³	
	Waikouaiti Pumping Main	84	Turbidity	08/12/2020	11:50	1.49	NTU	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	84	Turbidity	08/12/2020	11:15	0.82	NTU	
	Waikouaiti WTP - Post Treated Water Reservoir	84	Turbidity	08/12/2020	11:10	0.18	NTU	
	Waikouaiti Pumping Main	123	Total Dissolved Solids - Calc by conductivity meter	08/12/2020	11:50	91	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	123	Total Dissolved Solids - Calc by conductivity meter	08/12/2020	11:15	90	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	123	Total Dissolved Solids - Calc by conductivity meter	08/12/2020	11:10	95	g/m³	
	Waikouaiti Pumping Main	0440B	Dissolved Organic Carbon	08/12/2020	11:50	2.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440B	Dissolved Organic Carbon	08/12/2020	11:15	1.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440B	Dissolved Organic Carbon	08/12/2020	11:10	1.1	g/m³	
	Waikouaiti Pumping Main	601	Fluoride - Add P1859 Filtration	08/12/2020	11:50	0.12	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	08/12/2020	11:10	0.11	g/m³	
	Waikouaiti Pumping Main	602	Chloride - Add P1859 Filtration	08/12/2020	11:50	10.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	08/12/2020	11:10	13.4	g/m³	
	Waikouaiti Pumping Main	603	Nitrite - Nitrogen - Add P1859 Filtration	08/12/2020	11:50	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	603	Nitrite - Nitrogen - Add P1859 Filtration	08/12/2020	11:10	<0.01	g/m³	
	Waikouaiti Pumping Main	604	Bromide - Add P1859 Filtration	08/12/2020	11:50	0.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	604	Bromide - Add P1859 Filtration	08/12/2020	11:10	<0.02	g/m³	
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	08/12/2020	11:50	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	08/12/2020	11:10	0.02	g/m³	
	Waikouaiti Pumping Main	607	Sulphate - Add P1859 Filtration	08/12/2020	11:50	9.99	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	08/12/2020	11:10	11.1	g/m³	
	Waikouaiti Pumping Main	725	Cyanide by Discrete Analyser	08/12/2020	11:50	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	725	Cyanide by Discrete Analyser	08/12/2020	11:15	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	725	Cyanide by Discrete Analyser	08/12/2020	11:10	<0.005	g/m³	
	Waikouaiti Pumping Main	1250	Transmissivity @ 253.7nm	08/12/2020	11:50	85.4	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	08/12/2020	11:15	86.1	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	08/12/2020	11:10	97.6	%	
	Waikouaiti Pumping Main	1643	Silica by OES	08/12/2020	11:50	1.95	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1643	Silica by OES	08/12/2020	11:10	2.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	08/12/2020	11:10	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	08/12/2020	11:10	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	08/12/2020	11:10	<0.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	08/12/2020	11:10	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	08/12/2020	11:10	15.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	08/12/2020	11:10	0.0006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	08/12/2020	11:10	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	08/12/2020	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	08/12/2020	11:10	8.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	08/12/2020	11:10	0.0005	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	08/12/2020	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	08/12/2020	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	08/12/2020	11:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	08/12/2020	11:10	11.2	g/m³	
	Waikouaiti Pumping Main	6601	Aluminium - Total	08/12/2020	11:50	0.018	g/m³	
	Waikouaiti Pumping Main	6602	Antimony - Total	08/12/2020	11:50	<0.002	g/m³	
	Waikouaiti Pumping Main	6603	Arsenic - Total	08/12/2020	11:50	<0.002	g/m³	
	Waikouaiti Pumping Main	6604	Barium - Total	08/12/2020	11:50	0.012	g/m³	
	Waikouaiti Pumping Main	6607	Boron - Total	08/12/2020	11:50	<0.05	g/m³	
	Waikouaiti Pumping Main	6608	Cadmium - Total	08/12/2020	11:50	<0.001	g/m³	
	Waikouaiti Pumping Main	6610	Calcium - Total	08/12/2020	11:50	15.6	g/m³	
	Waikouaiti Pumping Main	6611	Chromium - Total	08/12/2020	11:50	<0.001	g/m³	
	Waikouaiti Pumping Main	6613	Copper - Total	08/12/2020	11:50	<0.002	g/m³	
	Waikouaiti Pumping Main	6617	Iron - Total	08/12/2020	11:50	0.3	g/m³	
	Waikouaiti Pumping Main	6618	Lead - Total	08/12/2020	11:50	<0.001	g/m³	
	Waikouaiti Pumping Main	6620	Magnesium - Total	08/12/2020	11:50	7.6	g/m³	
	Waikouaiti Pumping Main	6621	Manganese - Total	08/12/2020	11:50	0.027	g/m³	
	Waikouaiti Pumping Main	6622	Mercury - Total	08/12/2020	11:50	<0.001	g/m³	
	Waikouaiti Pumping Main	6624	Nickel - Total	08/12/2020	11:50	<0.001	g/m³	
	Waikouaiti Pumping Main	6628	Selenium - Total	08/12/2020	11:50	<0.005	g/m³	
	Waikouaiti Pumping Main	6631	Sodium - Total	08/12/2020	11:50	10.7	g/m³	
	Waikouaiti Pumping Main	D-0053F	Temperature - Field	08/12/2020	11:50	15.9	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	08/12/2020	11:15	16.9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	08/12/2020	11:10	16.3	Deg C	
	Waikouaiti Pumping Main	D-0056F	Dissolved Oxygen - Field	08/12/2020	11:50	9.4	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	08/12/2020	11:15	5.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	08/12/2020	11:10	7.2	g O2/m³	
	Waikouaiti Pumping Main	D-1201	Sampling / Inspection 15 Mins	08/12/2020	11:50	Completed		
	Waikouaiti Pumping Main	D-1204	Sampling / Inspection 60 Mins	08/12/2020	11:50	Completed		
	Waikouaiti Pumping Main	D-M0102	Faecal Coliforms by MF - Environmental Water	08/12/2020	11:50	39	cfu/100ml (39 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	08/12/2020	11:15	17	cfu/100ml (17 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0102	Faecal Coliforms by MF - Environmental Water	08/12/2020	11:10	<1	cfu/100ml (<1 x 1)	
	Waikouaiti Pumping Main	D-M0107	Enterococci - Environmental water	08/12/2020	11:50	8	cfu/100mL (8 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	08/12/2020	11:15	1	cfu/100mL (1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	08/12/2020	11:10	<1	cfu/100mL (<1 x 1)	
	Waikouaiti Pumping Main	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/12/2020	11:50	730	MPN/100ml (727 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/12/2020	11:15	980	MPN/100ml (980.4 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	08/12/2020	11:10	<1	MPN/100ml (<1 x 1)	
	Waikouaiti Pumping Main	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/12/2020	11:50	58	MPN/100mL (57.6 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/12/2020	11:15	19	MPN/100mL (18.7 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	08/12/2020	11:10	<1	MPN/100mL (<1 x 1)	
	Waikouaiti Pumping Main	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/12/2020	11:50	Completed		
	Waikouaiti Pumping Main	P1859	Sample Filtration	08/12/2020	11:50	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	08/12/2020	11:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	08/12/2020	11:10	0.12	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	08/12/2020	11:10	10.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	603	Nitrite - Nitrogen - Add P1859 Filtration	08/12/2020	11:10	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	604	Bromide - Add P1859 Filtration	08/12/2020	11:10	0.03	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	08/12/2020	11:10	0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	08/12/2020	11:10	10.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1643	Silica by OES	08/12/2020	11:10	2.1	g/m³	
	Waikouaiti Pumping Main	4000a	Total Algae Count - cells	08/12/2020	11:50	23	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000a	Total Algae Count - cells	08/12/2020	11:10	9	Cells per mL	
	Waikouaiti Pumping Main	4000b	Total Algae Count - units	08/12/2020	11:50	14	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000b	Total Algae Count - units	08/12/2020	11:10	9	Units per mL	
	Waikouaiti Pumping Main	4100a	Green Algae using cells	08/12/2020	11:50	2	Cells per mL	
	Waikouaiti Pumping Main	4100b	Green Algae using units	08/12/2020	11:50	<1	Units per mL	
	Waikouaiti Pumping Main	4139a	Mougeotia cells	08/12/2020	11:50	2	Cells per mL	
	Waikouaiti Pumping Main	4139b	Mougeotia units	08/12/2020	11:50	<1	Units per mL	
	Waikouaiti Pumping Main	4300a	Chrysophyta using cells	08/12/2020	11:50	13	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4300a	Chrysophyta using cells	08/12/2020	11:10	9	Cells per mL	
	Waikouaiti Pumping Main	4300b	Chrysophyta using units	08/12/2020	11:50	13	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4300b	Chrysophyta using units	08/12/2020	11:10	9	Units per mL	
	Waikouaiti Pumping Main	4309a	Cocconeis cells	08/12/2020	11:50	6	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309a	Cocconeis cells	08/12/2020	11:10	5	Cells per mL	

	Waikouaiti Pumping Main	4309b	Cocconeis units	08/12/2020	11:50	6	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309b	Cocconeis units	08/12/2020	11:10	5	Units per mL	
	Waikouaiti Pumping Main	4315a	Cymbella cells	08/12/2020	11:50	1	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4315a	Cymbella cells	08/12/2020	11:10	1	Cells per mL	
	Waikouaiti Pumping Main	4315b	Cymbella units	08/12/2020	11:50	1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4315b	Cymbella units	08/12/2020	11:10	1	Units per mL	
	Waikouaiti Pumping Main	4333a	Gomphonema cells	08/12/2020	11:50	1	Cells per mL	
	Waikouaiti Pumping Main	4333b	Gomphonema units	08/12/2020	11:50	1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4345a	Navicula cells	08/12/2020	11:10	1	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4345b	Navicula units	08/12/2020	11:10	1	Units per mL	
	Waikouaiti Pumping Main	4348a	Nitzschia cells	08/12/2020	11:50	5	Cells per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348a	Nitzschia cells	08/12/2020	11:10	2	Cells per mL	
	Waikouaiti Pumping Main	4348b	Nitzschia units	08/12/2020	11:50	5	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348b	Nitzschia units	08/12/2020	11:10	2	Units per mL	
	Waikouaiti Pumping Main	4500a	Cyanophyta using cells	08/12/2020	11:50	8	Cells per mL	
	Waikouaiti Pumping Main	4500b	Cyanophyta using units	08/12/2020	11:50	<1	Units per mL	
	Waikouaiti Pumping Main	4518a	Phormidium cells	08/12/2020	11:50	8	Cells per mL	
	Waikouaiti Pumping Main	4518b	Phormidium units	08/12/2020	11:50	<1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	08/12/2020	11:10	0.008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6602	Antimony - Total	08/12/2020	11:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	08/12/2020	11:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6604	Barium - Total	08/12/2020	11:10	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6607	Boron - Total	08/12/2020	11:10	<0.05	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	08/12/2020	11:10	15.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	08/12/2020	11:10	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	08/12/2020	11:10	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	08/12/2020	11:10	0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	08/12/2020	11:10	7.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	08/12/2020	11:10	0.013	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	08/12/2020	11:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	08/12/2020	11:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6631	Sodium - Total	08/12/2020	11:10	9.8	g/m³	
	Waikouaiti Pumping Main	LS-SV001	Aldrin and Dieldrin	08/12/2020	11:50	<0.00003	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV001	Aldrin and Dieldrin	08/12/2020	11:15	<0.00003	mg/L	
	Waikouaiti Pumping Main	LS-SV007	DDT and Isomers	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV007	DDT and Isomers	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV020	Cyanazine	08/12/2020	11:50	<0.0007	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV020	Cyanazine	08/12/2020	11:15	<0.0007	mg/L	
	Waikouaiti Pumping Main	LS-SV027	Oryzalin	08/12/2020	11:50	<0.010	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV027	Oryzalin	08/12/2020	11:15	<0.010	mg/L	
	Waikouaiti Pumping Main	LS-SV033	Terbacil	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV033	Terbacil	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV036	Azinphos Methyl	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV036	Azinphos Methyl	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV040	Aldicarb	08/12/2020	11:50	<0.006	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV040	Aldicarb	08/12/2020	11:15	<0.006	mg/L	
	Waikouaiti Pumping Main	LS-SV042	Chlorotoluron	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV042	Chlorotoluron	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV043	Diuron	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV043	Diuron	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV044	Isoproturon	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV044	Isoproturon	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti Pumping Main	LS-SV045	Primisulfuron-methyl	08/12/2020	11:50	<0.01	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV045	Primisulfuron-methyl	08/12/2020	11:15	<0.01	mg/L	
	Waikouaiti Pumping Main	LS-SV046	Thiabendazole	08/12/2020	11:50	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV046	Thiabendazole	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/12/2020	11:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	08/12/2020	11:10	Completed		
	Waikouaiti Pumping Main	P1871	Subcontracted Report	08/12/2020	11:50	Attached		
	Waikouaiti WTP - Post Treated Water Reservoir	P1871	Subcontracted Report	08/12/2020	11:15	Attached		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-003	a-chlordane	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-010	Endrin	08/12/2020	11:15	<0.0001	mg/L	

	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-017	Lindane (g-BHC)	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-018	Methoxychlor	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-022	Procymidone	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-025	Alachlor	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-027	Atrazine	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-028	Bromacil	08/12/2020	11:15	<0.005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-029	Carbofuran	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-032	Metalaxyl-M	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-033	Metolachlor	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-034	Metribuzin	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-035	Molinate	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-037	Oxadiazon	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-038	Pendimethalin	08/12/2020	11:15	<0.002	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-039	Propazine	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-040	Pyriproxyfen	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-041	Simazine	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-042	Terbuthylazine	08/12/2020	11:15	<0.0010	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-043	Trifluralin	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-044	Hexazinone	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-045	Chlorpyrifos	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-047	Dimethoate	08/12/2020	11:15	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-048	Pirimiphos methyl	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-053	Benzo(a)pyrene	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti Pumping Main	SVOC-073	Bis(2-ethylhexyl)phthalate	08/12/2020	11:50	<0.0020	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-073	Bis(2-ethylhexyl)phthalate	08/12/2020	11:15	<0.0020	mg/L	
	Waikouaiti Pumping Main	VOC-067	Epichlorohydrin	08/12/2020	11:50	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-067	Epichlorohydrin	08/12/2020	11:15	<0.0001	mg/L	
	Waikouaiti Pumping Main	VOC-068	1,4-Dioxane	08/12/2020	11:50	<0.04	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-068	1,4-Dioxane	08/12/2020	11:15	<0.04	mg/L	
	Waikouaiti Pumping Main	1004c	Temperature on arrival	08/12/2020	11:50	18.4	Deg C	(0 - 20)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1004c	Temperature on arrival	08/12/2020	11:10	18.6	Deg C	(0 - 20)
	Waikouaiti WTP - Post Treated Water Reservoir	1004c	Temperature on arrival	08/12/2020	00:10	19.8	Deg C	(0 - 20)
	Waikouaiti Pumping Main	M0201	Giardia - confirmed per 10L	08/12/2020	11:50	<0.5	cysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0201	Giardia - confirmed per 10L	08/12/2020	11:10	<0.5	cysts/10L	
	Waikouaiti Pumping Main	M0202	Giardia - Presumptive per 10L	08/12/2020	11:50	<0.5	cysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0202	Giardia - Presumptive per 10L	08/12/2020	11:10	<0.5	cysts/10L	
	Waikouaiti Pumping Main	M0203	Giardia Recovery - %	08/12/2020	11:50	55	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0203	Giardia Recovery - %	08/12/2020	11:10	50	%	
	Waikouaiti WTP - Post Treated Water Reservoir	M0203	Giardia Recovery - %	08/12/2020	00:10	58	%	
	Waikouaiti WTP - Post Treated Water Reservoir	M0205	Giardia - confirmed per 100L	08/12/2020	00:10	<0.1	cysts/100L	
	Waikouaiti Pumping Main	M0208	Cryptosporidium - confirmed per 10L	08/12/2020	11:50	<0.5	oocysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0208	Cryptosporidium - confirmed per 10L	08/12/2020	11:10	<0.5	oocysts/10L	
	Waikouaiti Pumping Main	M0209	Cryptosporidium - presumptive per 10L	08/12/2020	11:50	<0.5	oocysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0209	Cryptosporidium - presumptive per 10L	08/12/2020	11:10	<0.5	oocysts/10L	
	Waikouaiti Pumping Main	M0210	Crypto Recovery - %	08/12/2020	11:50	58	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0210	Crypto Recovery - %	08/12/2020	11:10	53	%	
	Waikouaiti WTP - Post Treated Water Reservoir	M0210	Crypto Recovery - %	08/12/2020	00:10	58	%	
	Waikouaiti WTP - Post Treated Water Reservoir	M0212	Cryptosporidium - confirmed per 100L	08/12/2020	00:10	<0.1	oocysts/100L	
	Waikouaiti TAB - Pre-flush	1	pH	18/12/2020	10:50	7.9		(1 - 14)
	TAB Waikouaiti	1	pH	18/12/2020	11:00	7.9		(1 - 14)
	Karitane Bowls - Pre-flush	1	pH	18/12/2020	10:25	7.9		(1 - 14)
	Karitane Bowls	1	pH	18/12/2020	10:35	7.9		(1 - 14)
	Waikouaiti Golf Club - Pre-flush	1	pH	18/12/2020	11:10	8		(1 - 14)
	Waikouaiti Golf Club	1	pH	18/12/2020	11:20	7.9		(1 - 14)
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	18/12/2020	10:50	61	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	18/12/2020	11:00	58	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	18/12/2020	10:25	59	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	18/12/2020	10:35	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	18/12/2020	11:10	59	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	18/12/2020	11:20	58	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	18/12/2020	10:50	16.7	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	18/12/2020	11:00	16.7	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	18/12/2020	10:25	16.8	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	18/12/2020	10:35	16.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	18/12/2020	11:10	16.8	g/m³	

	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	18/12/2020	11:20	16.8	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	18/12/2020	10:50	14	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	18/12/2020	11:00	13.8	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	18/12/2020	10:25	13.8	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	18/12/2020	10:35	13.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	18/12/2020	11:10	13.9	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	18/12/2020	11:20	13.9	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	18/12/2020	10:50	10.9	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	18/12/2020	11:00	10.5	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	18/12/2020	10:25	10.6	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	18/12/2020	10:35	10.5	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	18/12/2020	11:10	10.5	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	18/12/2020	11:20	10.4	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	18/12/2020	10:50	0.005	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	18/12/2020	11:00	0.011	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	18/12/2020	10:25	<0.002	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	18/12/2020	10:35	0.012	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	18/12/2020	11:10	0.011	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	18/12/2020	11:20	0.02	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	18/12/2020	10:50	15.5	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	18/12/2020	11:00	15.4	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	18/12/2020	10:25	15.9	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	18/12/2020	10:35	16	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	18/12/2020	11:10	16.9	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	18/12/2020	11:20	16.7	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	18/12/2020	10:50	1.47	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	18/12/2020	11:00	0.058	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	18/12/2020	10:25	0.0273	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	18/12/2020	10:35	0.0049	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	18/12/2020	11:10	0.0352	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	18/12/2020	11:20	0.06	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	18/12/2020	10:50	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	18/12/2020	11:00	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	18/12/2020	10:25	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	18/12/2020	10:35	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	18/12/2020	11:10	0.17	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	18/12/2020	11:20	0.2	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	18/12/2020	10:50	0.0009	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	18/12/2020	11:00	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	18/12/2020	10:25	0.0029	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	18/12/2020	10:35	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	18/12/2020	11:10	0.004	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	18/12/2020	11:20	0.0085	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	18/12/2020	10:50	6.78	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	18/12/2020	11:00	6.73	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	18/12/2020	10:25	6.35	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	18/12/2020	10:35	6.29	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	18/12/2020	11:10	6.16	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	18/12/2020	11:20	6.07	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	18/12/2020	10:50	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	18/12/2020	11:00	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	18/12/2020	10:25	<0.0005	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	18/12/2020	10:35	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	18/12/2020	11:10	0.0055	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	18/12/2020	11:20	0.0033	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	18/12/2020	10:50	0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	18/12/2020	11:00	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	18/12/2020	10:25	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	18/12/2020	10:35	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	18/12/2020	11:10	0.0006	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	18/12/2020	11:20	0.0006	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	18/12/2020	10:50	0.053	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	18/12/2020	11:00	0.004	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	18/12/2020	10:25	0.072	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	18/12/2020	10:35	0.004	g/m³	

	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	18/12/2020	11:10	0.074	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	18/12/2020	11:20	0.262	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	18/12/2020	10:50	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	18/12/2020	11:00	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	18/12/2020	10:25	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	18/12/2020	10:35	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	18/12/2020	11:10	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	18/12/2020	11:20	Completed		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	18/12/2020	10:50	7.2	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	18/12/2020	11:00	7.8	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	18/12/2020	10:25	7.2	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	18/12/2020	10:35	8	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	18/12/2020	11:10	6.1	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	18/12/2020	11:20	6.3	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	18/12/2020	10:50	0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	18/12/2020	11:00	0.39	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	18/12/2020	10:25	0.48	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	18/12/2020	10:35	0.57	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	18/12/2020	11:10	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	18/12/2020	11:20	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	18/12/2020	10:50	0.2	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	18/12/2020	11:00	0.6	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	18/12/2020	10:25	0.6	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	18/12/2020	10:35	0.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	18/12/2020	11:10	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	18/12/2020	11:20	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	18/12/2020	10:50	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	18/12/2020	10:50	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	18/12/2020	10:50	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	18/12/2020	11:00	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	18/12/2020	10:25	Completed		
	Karitane Bowls	P1859	Sample Filtration	18/12/2020	10:35	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	18/12/2020	11:10	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	18/12/2020	11:20	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	18/12/2020	11:00	0.39	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	18/12/2020	11:00	0.6	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	18/12/2020	11:00	0.07	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	18/12/2020	11:00	6	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	18/12/2020	11:00	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	18/12/2020	11:00	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	18/12/2020	12:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	18/12/2020	12:05	3.4	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	18/12/2020	11:55	3.8	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	18/12/2020	11:50	4.3	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	18/12/2020	12:05	2.3	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	18/12/2020	11:55	2.6	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	18/12/2020	11:50	2.8	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	12:05	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	11:55	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	11:50	<1	ng/L	
	Catchment - Waikouaiti Confluence	W-TO001	Geosmin by SPME	18/12/2020	11:30	6.1	ng/L	
	Catchment - Waikouaiti North Branch	W-TO001	Geosmin by SPME	18/12/2020	12:00	7.3	ng/L	
	Catchment - Waikouaiti South Branch	W-TO001	Geosmin by SPME	18/12/2020	12:30	3.5	ng/L	
	Catchment - Waikouaiti Confluence	W-TO002	2-Methylisoborneol by SPME	18/12/2020	11:30	3.4	ng/L	
	Catchment - Waikouaiti North Branch	W-TO002	2-Methylisoborneol by SPME	18/12/2020	12:00	4.7	ng/L	
	Catchment - Waikouaiti South Branch	W-TO002	2-Methylisoborneol by SPME	18/12/2020	12:30	2.8	ng/L	
	Catchment - Waikouaiti Confluence	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	11:30	<1	ng/L	
	Catchment - Waikouaiti North Branch	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	12:00	<1	ng/L	
	Catchment - Waikouaiti South Branch	W-TO003	2,4,6-Trichloroanisole by SPME	18/12/2020	12:30	<1	ng/L	
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	22/12/2020	13:40	60	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	22/12/2020	13:45	60	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	22/12/2020	14:20	59	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	22/12/2020	14:25	61	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	22/12/2020	13:12	61	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	22/12/2020	13:17	60	g CaCO3/m³	

	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	22/12/2020	13:40	16.5	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	22/12/2020	13:45	17.1	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	22/12/2020	14:20	16.5	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	22/12/2020	14:25	17.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	22/12/2020	13:12	17.1	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	22/12/2020	13:17	17	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	22/12/2020	13:40	14.2	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	22/12/2020	13:45	14.5	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	22/12/2020	14:20	14.3	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	22/12/2020	14:25	14.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	22/12/2020	13:12	14.1	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	22/12/2020	13:17	14.1	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	22/12/2020	13:40	10.5	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	22/12/2020	13:45	9.95	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	22/12/2020	14:20	10.7	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	22/12/2020	14:25	9.72	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	22/12/2020	13:12	10.1	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	22/12/2020	13:17	10.2	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	22/12/2020	13:40	0.006	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	22/12/2020	13:45	0.01	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	22/12/2020	14:20	0.014	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	22/12/2020	14:25	0.013	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	22/12/2020	13:12	0.014	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	22/12/2020	13:17	0.016	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	22/12/2020	13:40	16.2	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	22/12/2020	13:45	16.9	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	22/12/2020	14:20	17.1	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	22/12/2020	14:25	17.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	22/12/2020	13:12	18.4	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	22/12/2020	13:17	18.1	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	22/12/2020	13:40	1.01	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	22/12/2020	13:45	0.063	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	22/12/2020	14:20	0.019	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	22/12/2020	14:25	0.0056	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	22/12/2020	13:12	0.384	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	22/12/2020	13:17	0.039	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	22/12/2020	13:40	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	22/12/2020	13:45	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	22/12/2020	14:20	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	22/12/2020	14:25	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	22/12/2020	13:12	0.02	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	22/12/2020	13:17	0.02	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	22/12/2020	13:40	0.0022	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	22/12/2020	13:45	0.0009	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	22/12/2020	14:20	0.0077	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	22/12/2020	14:25	0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	22/12/2020	13:12	0.0009	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	22/12/2020	13:17	0.0009	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	22/12/2020	13:40	8.18	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	22/12/2020	13:45	8.39	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	22/12/2020	14:20	8.04	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	22/12/2020	14:25	8.25	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	22/12/2020	13:12	7.95	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	22/12/2020	13:17	7.83	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	22/12/2020	13:40	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	22/12/2020	13:45	0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	22/12/2020	14:20	<0.0005	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	22/12/2020	14:25	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	22/12/2020	13:12	0.001	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	22/12/2020	13:17	0.0012	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	22/12/2020	13:40	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	22/12/2020	13:45	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	22/12/2020	14:20	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	22/12/2020	14:25	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	22/12/2020	13:12	<0.0005	g/m³	

	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	22/12/2020	13:17	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	22/12/2020	13:40	0.028	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	22/12/2020	13:45	0.01	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	22/12/2020	14:20	0.042	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	22/12/2020	14:25	0.005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	22/12/2020	13:12	0.052	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	22/12/2020	13:17	0.018	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	22/12/2020	13:40	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	22/12/2020	13:45	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	22/12/2020	14:20	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	22/12/2020	14:25	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	22/12/2020	13:12	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	22/12/2020	13:17	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	22/12/2020	13:40	7.9		
	TAB Waikouaiti	D-0001F	pH - Field	22/12/2020	13:45	7.9		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	22/12/2020	14:20	8.2		
	Karitane Bowls	D-0001F	pH - Field	22/12/2020	14:25	8.1		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	22/12/2020	13:12	8.1		
	Waikouaiti Golf Club	D-0001F	pH - Field	22/12/2020	13:17	8.3		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	22/12/2020	13:40	6	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	22/12/2020	13:45	6.2	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	22/12/2020	14:20	7.3	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	22/12/2020	14:25	7.5	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	22/12/2020	13:12	6.4	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	22/12/2020	13:17	6.5	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	22/12/2020	13:40	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	22/12/2020	13:45	0.5	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	22/12/2020	14:20	0.16	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	22/12/2020	14:25	0.57	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	22/12/2020	13:12	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	22/12/2020	13:17	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	22/12/2020	13:40	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	22/12/2020	13:45	0.6	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	22/12/2020	14:20	0.3	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	22/12/2020	14:25	0.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	22/12/2020	13:12	0.1	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	22/12/2020	13:17	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	22/12/2020	13:40	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	22/12/2020	13:40	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	22/12/2020	13:40	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	22/12/2020	13:45	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	22/12/2020	14:20	Completed		
	Karitane Bowls	P1859	Sample Filtration	22/12/2020	14:25	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	22/12/2020	13:12	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	22/12/2020	13:17	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	22/12/2020	12:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	22/12/2020	12:25	7	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	22/12/2020	12:15	4.5	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	22/12/2020	12:12	4.4	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	22/12/2020	12:25	7.3	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	22/12/2020	12:15	4.4	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	22/12/2020	12:12	6.1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	22/12/2020	12:25	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	22/12/2020	12:15	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	22/12/2020	12:12	<1	ng/L	
	Waikouaiti Pre Treatment	D-0084	Turbidity	25/12/2020	00:00:00			
	Waikouaiti Pre Treatment	D-1201	Sampling / Inspection 15 Mins	25/12/2020	00:00:00	Completed		
	Waikouaiti Pre Treatment	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	25/12/2020	00:00:00			
	Karitane Bowls	D-0058H	Free Available Chlorine	25/12/2020	08:50	0.68	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	25/12/2020	08:50	0.9	g/m³	
	Karitane Bowls	D-0084	Turbidity	25/12/2020	08:50	0.1	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	25/12/2020	08:50	9.4	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	25/12/2020	08:50	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	25/12/2020	08:50	<1	MPN/100ml	(0 - 0)
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	31/12/2020	10:10	57	g CaCO3/m³	

	TAB Waikouaiti	52	Alkalinity - Total	31/12/2020	10:20	48	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	31/12/2020	09:45	57	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	31/12/2020	09:55	48	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	31/12/2020	10:30	49	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	31/12/2020	10:40	56	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	31/12/2020	10:10	16.4	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	31/12/2020	10:20	13.8	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	31/12/2020	09:45	16.4	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	31/12/2020	09:55	14.2	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	31/12/2020	10:30	16.9	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	31/12/2020	10:40	16.2	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	31/12/2020	10:10	14.8	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	31/12/2020	10:20	14.2	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	31/12/2020	09:45	14.7	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	31/12/2020	09:55	14.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	31/12/2020	10:30	14.4	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	31/12/2020	10:40	14.7	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	31/12/2020	10:10	10.9	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	31/12/2020	10:20	15	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	31/12/2020	09:45	10.8	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	31/12/2020	09:55	14.9	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	31/12/2020	10:30	11.1	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	31/12/2020	10:40	11.6	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	31/12/2020	10:10	0.005	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	31/12/2020	10:20	0.011	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	31/12/2020	09:45	0.011	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	31/12/2020	09:55	0.012	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	31/12/2020	10:30	0.013	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	31/12/2020	10:40	0.016	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	31/12/2020	10:10	16.9	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	31/12/2020	10:20	15.1	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	31/12/2020	09:45	17.2	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	31/12/2020	09:55	16.1	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	31/12/2020	10:30	17.7	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	31/12/2020	10:40	17.1	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	31/12/2020	10:10	1.17	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	31/12/2020	10:20	0.0568	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	31/12/2020	09:45	0.0326	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	31/12/2020	09:55	0.0087	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	31/12/2020	10:30	0.047	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	31/12/2020	10:40	0.0414	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	31/12/2020	10:10	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	31/12/2020	10:20	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	31/12/2020	09:45	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	31/12/2020	09:55	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	31/12/2020	10:30	2.99	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	31/12/2020	10:40	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	31/12/2020	10:10	0.0007	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	31/12/2020	10:20	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	31/12/2020	09:45	0.0042	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	31/12/2020	09:55	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	31/12/2020	10:30	0.0266	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	31/12/2020	10:40	0.0055	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	31/12/2020	10:10	7.57	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	31/12/2020	10:20	7.2	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	31/12/2020	09:45	7.35	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	31/12/2020	09:55	6.96	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	31/12/2020	10:30	7.11	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	31/12/2020	10:40	7.1	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	31/12/2020	10:10	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	31/12/2020	10:20	0.0007	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	31/12/2020	09:45	<0.0005	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	31/12/2020	09:55	0.0006	g/m³	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	31/12/2020	10:30	0.0492	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	31/12/2020	10:40	0.0016	g/m³	

	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	31/12/2020	10:10	<0.0005	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	31/12/2020	10:20	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	31/12/2020	09:45	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	31/12/2020	09:55	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	31/12/2020	10:30	0.0012	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	31/12/2020	10:40	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	31/12/2020	10:10	0.029	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	31/12/2020	10:20	<0.002	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	31/12/2020	09:45	0.185	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	31/12/2020	09:55	0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	31/12/2020	10:30	0.197	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	31/12/2020	10:40	0.194	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	31/12/2020	10:10	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	31/12/2020	10:20	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	31/12/2020	09:45	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	31/12/2020	09:55	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	31/12/2020	10:30	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	31/12/2020	10:40	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	31/12/2020	10:10	7.6		
	TAB Waikouaiti	D-0001F	pH - Field	31/12/2020	10:20	7.6		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	31/12/2020	09:45	7.9		
	Karitane Bowls	D-0001F	pH - Field	31/12/2020	09:55	7.9		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	31/12/2020	10:30	7.6		
	Waikouaiti Golf Club	D-0001F	pH - Field	31/12/2020	10:40	7.8		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	31/12/2020	10:10	5.8	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	31/12/2020	10:20	6.7	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	31/12/2020	09:45	6.5	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	31/12/2020	09:55	7.5	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	31/12/2020	10:30	5.6	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	31/12/2020	10:40	6.3	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	31/12/2020	10:10	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	31/12/2020	10:20	0.47	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	31/12/2020	09:45	0.35	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	31/12/2020	09:55	0.49	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	31/12/2020	10:30	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	31/12/2020	10:40	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	31/12/2020	10:10	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	31/12/2020	10:20	0.5	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	31/12/2020	09:45	0.5	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	31/12/2020	09:55	0.5	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	31/12/2020	10:30	<0.05	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	31/12/2020	10:40	0.1	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	31/12/2020	10:10	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	31/12/2020	10:10	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	31/12/2020	10:10	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	31/12/2020	10:20	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	31/12/2020	09:45	Completed		
	Karitane Bowls	P1859	Sample Filtration	31/12/2020	09:55	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	31/12/2020	10:30	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	31/12/2020	10:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	31/12/2020	11:55	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	31/12/2020	11:55	5.8	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	31/12/2020	11:45	5.4	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	31/12/2020	11:40	5.3	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	31/12/2020	11:55	4.6	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	31/12/2020	11:45	4.3	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	31/12/2020	11:40	3.9	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	31/12/2020	11:55	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	31/12/2020	11:45	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	31/12/2020	11:40	<1	ng/L	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	31/12/2020	10:20	0.47	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	31/12/2020	10:20	0.5	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	31/12/2020	10:20	0.08	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	31/12/2020	10:20	8.9	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	31/12/2020	10:20	<1	MPN/100mL	(0 - 0)

	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	31/12/2020	10:20	<1	MPN/100ml	(0 - 0)

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range	
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	07/01/2021	11:00	53	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	07/01/2021	11:10	35	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	07/01/2021	10:35	54	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	07/01/2021	10:45	37	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	07/01/2021	11:20	56	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	07/01/2021	11:30	48	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	07/01/2021	11:00	14	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	07/01/2021	11:10	8.9	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	07/01/2021	10:35	13.9	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	07/01/2021	10:45	9.1	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	07/01/2021	11:20	14.6	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	07/01/2021	11:30	13.5	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	07/01/2021	11:00	14.4	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	07/01/2021	11:10	15	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	07/01/2021	10:35	14.4	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	07/01/2021	10:45	15.2	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	07/01/2021	11:20	14.4	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	07/01/2021	11:30	14.5	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	07/01/2021	11:00	14.4	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	07/01/2021	11:10	13.8	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	07/01/2021	10:35	15.8	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	07/01/2021	10:45	13.9	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	07/01/2021	11:20	14.2	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	07/01/2021	11:30	15.2	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	07/01/2021	11:00	0.007	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	07/01/2021	11:10	0.009	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	07/01/2021	10:35	0.006	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	07/01/2021	10:45	0.012	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	07/01/2021	11:20	0.018	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	07/01/2021	11:30	0.067	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	07/01/2021	11:00	16.2	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	07/01/2021	11:10	11.1	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	07/01/2021	10:35	16.4	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	07/01/2021	10:45	12	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	07/01/2021	11:20	18	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	07/01/2021	11:30	17.4	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	07/01/2021	11:00	1.07	g/m³		
	TAB Waikouaiti	6013	Copper - Acid Soluble	07/01/2021	11:10	0.0368	g/m³		
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	07/01/2021	10:35	0.0602	g/m³		
	Karitane Bowls	6013	Copper - Acid Soluble	07/01/2021	10:45	0.0084	g/m³		
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	07/01/2021	11:20	0.0299	g/m³		
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	07/01/2021	11:30	0.124	g/m³		
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	07/01/2021	11:00	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	07/01/2021	11:10	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	07/01/2021	10:35	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	07/01/2021	10:45	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	07/01/2021	11:20	0.21	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	07/01/2021	11:30	1.12	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	07/01/2021	11:00	0.0013	g/m³		
	TAB Waikouaiti	6018	Lead - Acid Soluble	07/01/2021	11:10	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	07/01/2021	10:35	0.0087	g/m³		
	Karitane Bowls	6018	Lead - Acid Soluble	07/01/2021	10:45	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	07/01/2021	11:20	0.0036	g/m³		
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	07/01/2021	11:30	0.0178	g/m³		
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	07/01/2021	11:00	7.77	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	07/01/2021	11:10	5.72	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	07/01/2021	10:35	7.4	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	07/01/2021	10:45	5.54	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	07/01/2021	11:20	7.16	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	07/01/2021	11:30	7.03	g/m³		

	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	07/01/2021	11:00	0.0006	g/m³		
	TAB Waikouaiti	6021	Manganese - Acid Soluble	07/01/2021	11:10	0.001	g/m³		
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	07/01/2021	10:35	0.0006	g/m³		
	Karitane Bowls	6021	Manganese - Acid Soluble	07/01/2021	10:45	0.001	g/m³		
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	07/01/2021	11:20	0.0024	g/m³		
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	07/01/2021	11:30	0.0267	g/m³		
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	07/01/2021	11:00	0.0005	g/m³		
	TAB Waikouaiti	6024	Nickel - Acid Soluble	07/01/2021	11:10	<0.0005	g/m³		
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	07/01/2021	10:35	0.0009	g/m³		
	Karitane Bowls	6024	Nickel - Acid Soluble	07/01/2021	10:45	<0.0005	g/m³		
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	07/01/2021	11:20	0.001	g/m³		
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	07/01/2021	11:30	0.0009	g/m³		
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	07/01/2021	11:00	0.036	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	07/01/2021	11:10	0.004	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	07/01/2021	10:35	0.207	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	07/01/2021	10:45	0.008	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	07/01/2021	11:20	0.151	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	07/01/2021	11:30	0.072	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	07/01/2021	11:00	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	07/01/2021	11:10	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	07/01/2021	10:35	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	07/01/2021	10:45	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	07/01/2021	11:20	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	07/01/2021	11:30	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	07/01/2021	11:00	7.7			
	TAB Waikouaiti	D-0001F	pH - Field	07/01/2021	11:10	7.7			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	07/01/2021	10:35	7.6			
	Karitane Bowls	D-0001F	pH - Field	07/01/2021	10:45	7.8			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	07/01/2021	11:20	8.1			
	Waikouaiti Golf Club	D-0001F	pH - Field	07/01/2021	11:30	8.2			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	07/01/2021	11:00	5.7	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	07/01/2021	11:10	6.4	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	07/01/2021	10:35	5.6	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	07/01/2021	10:45	6.3	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	07/01/2021	11:20	6	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	07/01/2021	11:30	6.1	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	07/01/2021	11:00	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	07/01/2021	11:10	0.5	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	07/01/2021	10:35	<0.05	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	07/01/2021	10:45	0.37	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	07/01/2021	11:20	0.07	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	07/01/2021	11:30	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	07/01/2021	11:00	0.1	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	07/01/2021	11:10	0.7	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	07/01/2021	10:35	0.1	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	07/01/2021	10:45	0.6	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	07/01/2021	11:20	0.1	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	07/01/2021	11:30	0.1	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	07/01/2021	11:00	Completed			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	07/01/2021	11:00	Completed			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	07/01/2021	11:00	Completed			
	TAB Waikouaiti	P1859	Sample Filtration	07/01/2021	11:10	Completed			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	07/01/2021	10:35	Completed			
	Karitane Bowls	P1859	Sample Filtration	07/01/2021	10:45	Completed			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	07/01/2021	11:20	Completed			
	Waikouaiti Golf Club	P1859	Sample Filtration	07/01/2021	11:30	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	07/01/2021	13:10	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	07/01/2021	13:10	3.3	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	07/01/2021	12:45	3.2	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	07/01/2021	12:40	3.9	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	07/01/2021	13:10	2.1	ng/L		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	07/01/2021	12:45	2.9	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	07/01/2021	12:40	2.5	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	07/01/2021	13:10	<1	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	07/01/2021	12:45	<1	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	07/01/2021	12:40	<1	ng/L		
	Karitane Bowls	D-0058H	Free Available Chlorine	07/01/2021	10:45	0.37	g/m³	(.2 - 5)	
	Karitane Bowls	D-0066H	Total Chlorine	07/01/2021	10:45	0.6	g/m³		
	Karitane Bowls	D-0084	Turbidity	07/01/2021	10:45	0.07	NTU		
	Karitane Bowls	D-1310	Temperature on arrival	07/01/2021	10:45	8.6	Deg C		
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	07/01/2021	10:45	<1	MPN/100mL	(0 - 0)	
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	07/01/2021	10:45	<1	MPN/100ml	(0 - 0)	
	Waikouaiti Pumping Main	1	pH	07/01/2021	12:45	7.4		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	07/01/2021	13:10	7.3		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	07/01/2021	12:40	7.4		(1 - 14)	
	Waikouaiti Pumping Main	2	Suspended Solids - Total	07/01/2021	12:45	14	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	07/01/2021	13:10	10	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	07/01/2021	12:40	<5	g/m³		
	Waikouaiti Pumping Main	0040B	Total Organic Carbon by TOC analyser	07/01/2021	12:45	8.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0040B	Total Organic Carbon by TOC analyser	07/01/2021	13:10	9.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0040B	Total Organic Carbon by TOC analyser	07/01/2021	12:40	3.6	g/m³		
	Waikouaiti Pumping Main	49	Total Solids - g/m3 units	07/01/2021	12:45	123	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	49	Total Solids - g/m3 units	07/01/2021	13:10	122	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	49	Total Solids - g/m3 units	07/01/2021	12:40	174	g/m³		
	Waikouaiti Pumping Main	52	Alkalinity - Total	07/01/2021	12:45	21	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	07/01/2021	13:10	20	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	07/01/2021	12:40	31	g CaCO3/m³		
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	07/01/2021	12:45	12.2	mS/m (121.7 x .1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	55	Conductivity at 25°C - mS/m unit	07/01/2021	13:10	11.4	mS/m (114.3 x .1)		
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	07/01/2021	12:40	15.6	mS/m (156.2 x .1)		
	Waikouaiti Pumping Main	73	Bicarbonate by Calculation - requires tests 1 & 52	07/01/2021	12:45	21	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	73	Bicarbonate by Calculation - requires tests 1 & 52	07/01/2021	13:10	20	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	73	Bicarbonate by Calculation - requires tests 1 & 52	07/01/2021	12:40	31	g CaCO3/m³		
	Waikouaiti Pumping Main	74	Carbonate by Calculation - requires tests 1, 52, 73	07/01/2021	12:45	<1	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	74	Carbonate by Calculation - requires tests 1, 52, 73	07/01/2021	13:10	<1	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	74	Carbonate by Calculation - requires tests 1, 52, 73	07/01/2021	12:40	<1	g CaCO3/m³		
	Waikouaiti Pumping Main	76	Free CO2 by Calculation - requires tests 1, 52 & 73	07/01/2021	12:45	2	g CO2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	76	Free CO2 by Calculation - requires tests 1, 52 & 73	07/01/2021	13:10	2	g CO2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	76	Free CO2 by Calculation - requires tests 1, 52 & 73	07/01/2021	12:40	2	g CO2/m³		
	Waikouaiti Pumping Main	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	07/01/2021	12:45	20	g CO2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	07/01/2021	13:10	20	g CO2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	07/01/2021	12:40	30	g CO2/m³		
	Waikouaiti Pumping Main	84	Turbidity	07/01/2021	12:45	6.65	NTU		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	84	Turbidity	07/01/2021	13:10	7.52	NTU		
	Waikouaiti WTP - Post Treated Water Reservoir	84	Turbidity	07/01/2021	12:40	0.11	NTU		
	Waikouaiti Pumping Main	123	Total Dissolved Solids - Calc by conductivity meter	07/01/2021	12:45	60	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	123	Total Dissolved Solids - Calc by conductivity meter	07/01/2021	13:10	56	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	123	Total Dissolved Solids - Calc by conductivity meter	07/01/2021	12:40	76	g/m³		
	Waikouaiti Pumping Main	0440B	Dissolved Organic Carbon	07/01/2021	12:45	7.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440B	Dissolved Organic Carbon	07/01/2021	13:10	8.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440B	Dissolved Organic Carbon	07/01/2021	12:40	3.5	g/m³		
	Waikouaiti Pumping Main	601	Fluoride - Add P1859 Filtration	07/01/2021	12:45	0.09	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	07/01/2021	12:40	0.08	g/m³		
	Waikouaiti Pumping Main	602	Chloride - Add P1859 Filtration	07/01/2021	12:45	10.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	07/01/2021	12:40	15.1	g/m³		
	Waikouaiti Pumping Main	603	Nitrite - Nitrogen - Add P1859 Filtration	07/01/2021	12:45	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	603	Nitrite - Nitrogen - Add P1859 Filtration	07/01/2021	12:40	<0.01	g/m³		
	Waikouaiti Pumping Main	604	Bromide - Add P1859 Filtration	07/01/2021	12:45	0.03	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	604	Bromide - Add P1859 Filtration	07/01/2021	12:40	<0.02	g/m³		
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	07/01/2021	12:45	0.49	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	07/01/2021	12:40	0.3	g/m³		
	Waikouaiti Pumping Main	607	Sulphate - Add P1859 Filtration	07/01/2021	12:45	12.8	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	07/01/2021	12:40	13.5	g/m³		
	Waikouaiti Pumping Main	725	Cyanide by Discrete Analyser	07/01/2021	12:45	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	725	Cyanide by Discrete Analyser	07/01/2021	13:10	<0.005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	725	Cyanide by Discrete Analyser	07/01/2021	12:40	<0.005	g/m³		
	Waikouaiti Pumping Main	1250	Transmissivity @ 253.7nm	07/01/2021	12:45	50.1	%		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	07/01/2021	13:10	44	%		
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	07/01/2021	12:40	89.7	%		
	Waikouaiti Pumping Main	1643	Silica by OES	07/01/2021	12:45	8.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1643	Silica by OES	07/01/2021	12:40	4.31	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	07/01/2021	12:40	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	07/01/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	07/01/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	07/01/2021	12:40	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	07/01/2021	12:40	<0.03	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	07/01/2021	12:40	<0.0002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	07/01/2021	12:40	10.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	07/01/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	07/01/2021	12:40	0.0008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	07/01/2021	12:40	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	07/01/2021	12:40	0.0006	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	07/01/2021	12:40	5.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	07/01/2021	12:40	0.0025	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	07/01/2021	12:40	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	07/01/2021	12:40	0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	07/01/2021	12:40	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	07/01/2021	12:40	12.2	g/m³		
	Waikouaiti Pumping Main	6601	Aluminium - Total	07/01/2021	12:45	0.324	g/m³		
	Waikouaiti Pumping Main	6602	Antimony - Total	07/01/2021	12:45	<0.002	g/m³		
	Waikouaiti Pumping Main	6603	Arsenic - Total	07/01/2021	12:45	0.002	g/m³		
	Waikouaiti Pumping Main	6604	Barium - Total	07/01/2021	12:45	0.015	g/m³		
	Waikouaiti Pumping Main	6607	Boron - Total	07/01/2021	12:45	<0.05	g/m³		
	Waikouaiti Pumping Main	6608	Cadmium - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti Pumping Main	6610	Calcium - Total	07/01/2021	12:45	8	g/m³		
	Waikouaiti Pumping Main	6611	Chromium - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti Pumping Main	6613	Copper - Total	07/01/2021	12:45	<0.002	g/m³		
	Waikouaiti Pumping Main	6617	Iron - Total	07/01/2021	12:45	0.5	g/m³		
	Waikouaiti Pumping Main	6618	Lead - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti Pumping Main	6620	Magnesium - Total	07/01/2021	12:45	3.8	g/m³		
	Waikouaiti Pumping Main	6621	Manganese - Total	07/01/2021	12:45	0.027	g/m³		
	Waikouaiti Pumping Main	6622	Mercury - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti Pumping Main	6624	Nickel - Total	07/01/2021	12:45	0.001	g/m³		
	Waikouaiti Pumping Main	6628	Selenium - Total	07/01/2021	12:45	<0.005	g/m³		
	Waikouaiti Pumping Main	6631	Sodium - Total	07/01/2021	12:45	8.6	g/m³		
	Waikouaiti Pumping Main	D-0053F	Temperature - Field	07/01/2021	12:45	17.4	Deg C		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	07/01/2021	13:10	16.8	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	07/01/2021	12:40	18.2	Deg C		
	Waikouaiti Pumping Main	D-0056F	Dissolved Oxygen - Field	07/01/2021	12:45	8.2	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	07/01/2021	13:10	7.4	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	07/01/2021	12:40	6.8	g O2/m³		
	Waikouaiti Pumping Main	D-1201	Sampling / Inspection 15 Mins	07/01/2021	12:45	Completed			
	Waikouaiti Pumping Main	D-1204	Sampling / Inspection 60 Mins	07/01/2021	12:45	Completed			
	Waikouaiti Pumping Main	D-M0102	Faecal Coliforms by MF - Environmental Water	07/01/2021	12:45	82	cfu/100ml (82 x 1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	07/01/2021	13:10	55	cfu/100ml (55 x 1)		
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0102	Faecal Coliforms by MF - Environmental Water	07/01/2021	12:40	<1	cfu/100ml (<1 x 1)		
	Waikouaiti Pumping Main	D-M0107	Enterococci - Environmental water	07/01/2021	12:45	12	cfu/100mL (12 x 1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	07/01/2021	13:10	11	cfu/100mL (11 x 1)		
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	07/01/2021	12:40	<1	cfu/100mL (<1 x 1)		
	Waikouaiti Pumping Main	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/01/2021	12:45	830	MPN/100ml (829.7 x 1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/01/2021	13:10	1,000	MPN/100ml (1011.2 x 1)		
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	07/01/2021	12:40	<1	MPN/100ml (<1 x 1)		
	Waikouaiti Pumping Main	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/01/2021	12:45	130	MPN/100mL (125.9 x 1)		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/01/2021	13:10	120	MPN/100mL (119.1 x 1)		
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	07/01/2021	12:40	<1	MPN/100mL (<1 x 1)		
	Waikouaiti Pumping Main	P1855	Aqueous Total Metal Digestion for ICPMS codes	07/01/2021	12:45	Completed			
	Waikouaiti Pumping Main	P1859	Sample Filtration	07/01/2021	12:45	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	07/01/2021	12:40	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	601	Fluoride - Add P1859 Filtration	07/01/2021	12:45	0.09	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	07/01/2021	12:45	10.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	603	Nitrite - Nitrogen - Add P1859 Filtration	07/01/2021	12:45	<0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	604	Bromide - Add P1859 Filtration	07/01/2021	12:45	0.03	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	605	Nitrate - Nitrogen - Add P1859 Filtration	07/01/2021	12:45	0.49	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	07/01/2021	12:45	12.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1643	Silica by OES	07/01/2021	12:45	7.12	g/m³		
	Waikouaiti Pumping Main	4000a	Total Algae Count - cells	07/01/2021	13:10	14	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000a	Total Algae Count - cells	07/01/2021	12:45	25	Cells per mL		
	Waikouaiti Pumping Main	4000b	Total Algae Count - units	07/01/2021	13:10	14	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4000b	Total Algae Count - units	07/01/2021	12:45	13	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4100a	Green Algae using cells	07/01/2021	12:45	5	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4100b	Green Algae using units	07/01/2021	12:45	1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4154a	Scenedesmus cells	07/01/2021	12:45	5	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4154b	Scenedesmus units	07/01/2021	12:45	1	Units per mL		
	Waikouaiti Pumping Main	4300a	Chrysophyta using cells	07/01/2021	13:10	12	Cells per mL		
	Waikouaiti Pumping Main	4300b	Chrysophyta using units	07/01/2021	13:10	12	Units per mL		
	Waikouaiti Pumping Main	4309a	Cocconeis cells	07/01/2021	13:10	1	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309a	Cocconeis cells	07/01/2021	12:45	1	Cells per mL		
	Waikouaiti Pumping Main	4309b	Cocconeis units	07/01/2021	13:10	1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4309b	Cocconeis units	07/01/2021	12:45	1	Units per mL		
	Waikouaiti Pumping Main	4315a	Cymbella cells	07/01/2021	13:10	1	Cells per mL		
	Waikouaiti Pumping Main	4315b	Cymbella units	07/01/2021	13:10	1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4324a	Epithemia cells	07/01/2021	12:45	1	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4324b	Epithemia units	07/01/2021	12:45	1	Units per mL		
	Waikouaiti Pumping Main	4345a	Navicula cells	07/01/2021	13:10	1	Cells per mL		
	Waikouaiti Pumping Main	4345b	Navicula units	07/01/2021	13:10	1	Units per mL		
	Waikouaiti Pumping Main	4348a	Nitzschia cells	07/01/2021	13:10	9	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348a	Nitzschia cells	07/01/2021	12:45	9	Cells per mL		
	Waikouaiti Pumping Main	4348b	Nitzschia units	07/01/2021	13:10	9	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4348b	Nitzschia units	07/01/2021	12:45	9	Units per mL		
	Waikouaiti Pumping Main	4500a	Cyanophyta using cells	07/01/2021	13:10	<1	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4500a	Cyanophyta using cells	07/01/2021	12:45	9	Cells per mL		
	Waikouaiti Pumping Main	4500b	Cyanophyta using units	07/01/2021	13:10	<1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4500b	Cyanophyta using units	07/01/2021	12:45	<1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4518a	Phormidium cells	07/01/2021	12:45	4	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4518b	Phormidium units	07/01/2021	12:45	<1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4521a	Pseudanabaena cells	07/01/2021	12:45	5	Cells per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	4521b	Pseudanabaena units	07/01/2021	12:45	<1	Units per mL		
	Waikouaiti Pumping Main	4700a	Other Algae using cells	07/01/2021	13:10	1	Cells per mL		
	Waikouaiti Pumping Main	4700b	Other Algae using units	07/01/2021	13:10	1	Units per mL		
	Waikouaiti Pumping Main	4705a	Euglena cells	07/01/2021	13:10	1	Cells per mL		
	Waikouaiti Pumping Main	4705b	Euglena units	07/01/2021	13:10	1	Units per mL		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	07/01/2021	12:45	0.387	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6602	Antimony - Total	07/01/2021	12:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	07/01/2021	12:45	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6604	Barium - Total	07/01/2021	12:45	0.014	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6607	Boron - Total	07/01/2021	12:45	<0.05	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	07/01/2021	12:45	3.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	07/01/2021	12:45	0.004	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	07/01/2021	12:45	0.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	07/01/2021	12:45	3.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	07/01/2021	12:45	0.022	g/m³		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	07/01/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	07/01/2021	12:45	0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	07/01/2021	12:45	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6631	Sodium - Total	07/01/2021	12:45	8.3	g/m³		
	Waikouaiti Pumping Main	LS-SV001	Aldrin and Dieldrin	07/01/2021	13:10	<0.00003	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV001	Aldrin and Dieldrin	07/01/2021	12:40	<0.00003	mg/L		
	Waikouaiti Pumping Main	LS-SV007	DDT and Isomers	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV007	DDT and Isomers	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV020	Cyanazine	07/01/2021	13:10	<0.0007	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV020	Cyanazine	07/01/2021	12:40	<0.0007	mg/L		
	Waikouaiti Pumping Main	LS-SV027	Oryzalin	07/01/2021	13:10	<0.010	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV027	Oryzalin	07/01/2021	12:40	<0.010	mg/L		
	Waikouaiti Pumping Main	LS-SV033	Terbacil	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV033	Terbacil	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV036	Azinphos Methyl	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV036	Azinphos Methyl	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV040	Aldicarb	07/01/2021	13:10	<0.006	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV040	Aldicarb	07/01/2021	12:40	<0.006	mg/L		
	Waikouaiti Pumping Main	LS-SV042	Chlorotoluron	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV042	Chlorotoluron	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV043	Diuron	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV043	Diuron	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV044	Isoproturon	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV044	Isoproturon	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti Pumping Main	LS-SV045	Primisulfuron-methyl	07/01/2021	13:10	<0.01	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV045	Primisulfuron-methyl	07/01/2021	12:40	<0.01	mg/L		
	Waikouaiti Pumping Main	LS-SV046	Thiabendazole	07/01/2021	13:10	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV046	Thiabendazole	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	07/01/2021	12:45	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	07/01/2021	12:45	Completed			
	Waikouaiti Pumping Main	P1871	Subcontracted Report	07/01/2021	13:10	Attached			
	Waikouaiti WTP - Post Treated Water Reservoir	P1871	Subcontracted Report	07/01/2021	12:40	Attached			
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-003	a-chlordane	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-010	Endrin	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-017	Lindane (g-BHC)	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-018	Methoxychlor	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-022	Procymidone	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-025	Alachlor	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-027	Atrazine	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-028	Bromacil	07/01/2021	12:40	<0.005	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-029	Carbofuran	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-032	Metalaxyl-M	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-033	Metolachlor	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-034	Metribuzin	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-035	Molinate	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-037	Oxadiazon	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-038	Pendimethalin	07/01/2021	12:40	<0.002	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-039	Propazine	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-040	Pyriproxyfen	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-041	Simazine	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-042	Terbuthylazine	07/01/2021	12:40	<0.0010	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-043	Trifluralin	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-044	Hexazinone	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-045	Chlorpyrifos	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-047	Dimethoate	07/01/2021	12:40	<0.001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-048	Pirimiphos methyl	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-053	Benzo(a)pyrene	07/01/2021	12:40	<0.0001	mg/L		
	Waikouaiti Pumping Main	SVOC-073	Bis(2-ethylhexyl)phthalate	07/01/2021	13:10	<0.0020	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-073	Bis(2-ethylhexyl)phthalate	07/01/2021	12:40	<0.0020	mg/L		
	Waikouaiti Pumping Main	VOC-067	Epichlorohydrin	07/01/2021	13:10	<0.0001	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-067	Epichlorohydrin	07/01/2021	12:40	<0.0001	mg/L		

	Waikouaiti Pumping Main	VOC-068	1,4-Dioxane	07/01/2021	13:10	<0.04	mg/L		
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-068	1,4-Dioxane	07/01/2021	12:40	<0.04	mg/L		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	12/01/2021	12:25	39	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	12/01/2021	12:35	33	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	12/01/2021	12:05	30	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	12/01/2021	12:15	32	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	12/01/2021	12:50	37	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	12/01/2021	13:00	35	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	12/01/2021	12:25	9.6	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	12/01/2021	12:35	8.5	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	12/01/2021	12:05	9	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	12/01/2021	12:15	8.5	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	12/01/2021	12:50	9.5	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	12/01/2021	13:00	9.5	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	12/01/2021	12:25	15.8	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	12/01/2021	12:35	17.1	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	12/01/2021	12:05	15.9	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	12/01/2021	12:15	17.1	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	12/01/2021	12:50	16.2	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	12/01/2021	13:00	16.3	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	12/01/2021	12:25	13.8	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	12/01/2021	12:35	17.8	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	12/01/2021	12:05	14.3	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	12/01/2021	12:15	17.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	12/01/2021	12:50	15	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	12/01/2021	13:00	15.1	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	12/01/2021	12:25	0.005	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	12/01/2021	12:35	0.01	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	12/01/2021	12:05	0.009	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	12/01/2021	12:15	0.011	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	12/01/2021	12:50	0.01	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	12/01/2021	13:00	0.029	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	12/01/2021	12:25	11.9	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	12/01/2021	12:35	11.5	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	12/01/2021	12:05	11.9	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	12/01/2021	12:15	12.3	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	12/01/2021	12:50	13.2	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	12/01/2021	13:00	12.9	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	12/01/2021	12:25	0.971	g/m³	(2 - 2)	
	TAB Waikouaiti	6013	Copper - Acid Soluble	12/01/2021	12:35	0.0339	g/m³	(2 - 2)	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	12/01/2021	12:05	0.0366	g/m³	(2 - 2)	
	Karitane Bowls	6013	Copper - Acid Soluble	12/01/2021	12:15	0.0083	g/m³	(2 - 2)	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	12/01/2021	12:50	0.0142	g/m³	(2 - 2)	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	12/01/2021	13:00	0.0448	g/m³	(2 - 2)	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	12/01/2021	12:25	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	12/01/2021	12:35	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	12/01/2021	12:05	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	12/01/2021	12:15	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	12/01/2021	12:50	0.09	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	12/01/2021	13:00	0.43	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	12/01/2021	12:25	0.0011	g/m³	(.005 - .01)	
	TAB Waikouaiti	6018	Lead - Acid Soluble	12/01/2021	12:35	<0.0005	g/m³	(.005 - .01)	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	12/01/2021	12:05	0.0051	g/m³	(.005 - .01)	
	Karitane Bowls	6018	Lead - Acid Soluble	12/01/2021	12:15	0.0005	g/m³	(.005 - .01)	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	12/01/2021	12:50	0.0016	g/m³	(.005 - .01)	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	12/01/2021	13:00	0.0064	g/m³	(.005 - .01)	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	12/01/2021	12:25	5.7	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	12/01/2021	12:35	5.72	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	12/01/2021	12:05	5.41	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	12/01/2021	12:15	5.5	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	12/01/2021	12:50	5.35	g/m³		

	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	12/01/2021	13:00	5.37	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	12/01/2021	12:25	0.0007	g/m³	(.4 - .4)	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	12/01/2021	12:35	0.0037	g/m³	(.4 - .4)	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	12/01/2021	12:05	0.0015	g/m³	(.4 - .4)	
	Karitane Bowls	6021	Manganese - Acid Soluble	12/01/2021	12:15	0.0028	g/m³	(.4 - .4)	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	12/01/2021	12:50	0.0033	g/m³	(.4 - .4)	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	12/01/2021	13:00	0.0128	g/m³	(.4 - .4)	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	12/01/2021	12:25	0.0006	g/m³	(.08 - .08)	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	12/01/2021	12:35	<0.0005	g/m³	(.08 - .08)	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	12/01/2021	12:05	0.0005	g/m³	(.08 - .08)	
	Karitane Bowls	6024	Nickel - Acid Soluble	12/01/2021	12:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	12/01/2021	12:50	0.0006	g/m³	(.08 - .08)	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	12/01/2021	13:00	0.0006	g/m³	(.08 - .08)	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	12/01/2021	12:25	0.057	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	12/01/2021	12:35	0.002	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	12/01/2021	12:05	0.122	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	12/01/2021	12:15	0.008	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	12/01/2021	12:50	0.12	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	12/01/2021	13:00	0.027	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	12/01/2021	12:25	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	12/01/2021	12:35	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	12/01/2021	12:05	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	12/01/2021	12:15	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	12/01/2021	12:50	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	12/01/2021	13:00	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	12/01/2021	12:25	7.6			
	TAB Waikouaiti	D-0001F	pH - Field	12/01/2021	12:35	7.6			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	12/01/2021	12:05	7.7			
	Karitane Bowls	D-0001F	pH - Field	12/01/2021	12:15	7.6			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	12/01/2021	12:50	7.9			
	Waikouaiti Golf Club	D-0001F	pH - Field	12/01/2021	13:00	7.9			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/01/2021	12:25	5.7	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	12/01/2021	12:35	6.4	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/01/2021	12:05	6.4	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	12/01/2021	12:15	6.9	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	12/01/2021	12:50	5.7	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	12/01/2021	13:00	6	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	12/01/2021	12:25	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	12/01/2021	12:35	0.46	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	12/01/2021	12:05	<0.05	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	12/01/2021	12:15	0.54	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	12/01/2021	12:50	<0.05	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	12/01/2021	13:00	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	12/01/2021	12:25	<0.05	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	12/01/2021	12:35	0.6	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	12/01/2021	12:05	0.2	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	12/01/2021	12:15	0.7	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	12/01/2021	12:50	0.1	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	12/01/2021	13:00	0.1	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	12/01/2021	12:25	Complete			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	12/01/2021	12:25	Complete			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	12/01/2021	12:25	Complete			
	TAB Waikouaiti	P1859	Sample Filtration	12/01/2021	12:35	Complete			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	12/01/2021	12:05	Complete			
	Karitane Bowls	P1859	Sample Filtration	12/01/2021	12:15	Complete			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	12/01/2021	12:50	Complete			
	Waikouaiti Golf Club	P1859	Sample Filtration	12/01/2021	13:00	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	12/01/2021	13:40	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	12/01/2021	13:40	2.6	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	12/01/2021	13:30	2.5	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	12/01/2021	13:25	2.9	ng/L		

	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	12/01/2021	13:40	1.7	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	12/01/2021	13:30	1.3	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	12/01/2021	13:25	<1	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	12/01/2021	13:40	<1	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	12/01/2021	13:30	<1	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	12/01/2021	13:25	<1	ng/L		
	Catchment - Waikouaiti Confluence	SC002	Nodularin/Microcystin - Bloom water - NOD_MIC_BL	14/01/2021	10:22	attached			
	Catchment - Waikouaiti Confluence	SC003	Anatoxins in Bloom or drinking water - ANATOX_CYN	14/01/2021	10:22	attached			
	Catchment - Waikouaiti Confluence	SC004	Saxitoxin - L_JELL_CYA	14/01/2021	10:22	attached			
	Catchment - Waikouaiti North Branch	SC039	Cyanobacteria - FW_CC_CYA Preserved	14/01/2021	14:13	attached			
	Catchment - Waikouaiti South Branch	SC039	Cyanobacteria - FW_CC_CYA Preserved	14/01/2021	12:30	attached			
	Catchment - Waikouaiti North Branch	SC039a	Cyanobacteria - FW_CC_CYA Unpreserved	14/01/2021	14:13	attached			
	Catchment - Waikouaiti South Branch	SC039a	Cyanobacteria - FW_CC_CYA Unpreserved	14/01/2021	12:30	attached			
	Catchment - Waikouaiti Confluence	W-TO001	Geosmin by SPME	14/01/2021	10:22	4.2	ng/L		
	Catchment - Waikouaiti North Branch	W-TO001	Geosmin by SPME	14/01/2021	14:13	4.9	ng/L		
	Catchment - Waikouaiti South Branch	W-TO001	Geosmin by SPME	14/01/2021	12:30	2.4	ng/L		
	Catchment - Waikouaiti Confluence	W-TO002	2-Methylisoborneol by SPME	14/01/2021	10:22	1.8	ng/L		
	Catchment - Waikouaiti North Branch	W-TO002	2-Methylisoborneol by SPME	14/01/2021	14:13	1.9	ng/L		
	Catchment - Waikouaiti South Branch	W-TO002	2-Methylisoborneol by SPME	14/01/2021	12:30	2.1	ng/L		
	Catchment - Waikouaiti Confluence	W-TO003	2,4,6-Trichloroanisole by SPME	14/01/2021	10:22	<1	ng/L		
	Catchment - Waikouaiti North Branch	W-TO003	2,4,6-Trichloroanisole by SPME	14/01/2021	14:13	<1	ng/L		
	Catchment - Waikouaiti South Branch	W-TO003	2,4,6-Trichloroanisole by SPME	14/01/2021	12:30	<1	ng/L		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	20/01/2021	11:50	37	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	20/01/2021	11:55	43	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	20/01/2021	11:30	43	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	20/01/2021	11:35	43	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	20/01/2021	12:05	40	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	20/01/2021	12:10	42	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	20/01/2021	11:50	10.6	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	20/01/2021	11:55	11.9	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	20/01/2021	11:30	11.9	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	20/01/2021	11:35	12	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	20/01/2021	12:05	11.1	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	20/01/2021	12:10	11.2	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	20/01/2021	11:50	17	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	20/01/2021	11:55	16.8	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	20/01/2021	11:30	16.4	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	20/01/2021	11:35	16.3	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	20/01/2021	12:05	16.7	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	20/01/2021	12:10	16.7	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	20/01/2021	11:50	16	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	20/01/2021	11:55	17.2	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	20/01/2021	11:30	16.8	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	20/01/2021	11:35	16.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	20/01/2021	12:05	17.1	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	20/01/2021	12:10	17	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	20/01/2021	11:50	0.004	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	20/01/2021	11:55	0.009	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	20/01/2021	11:30	0.008	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	20/01/2021	11:35	0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	20/01/2021	12:05	0.007	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	20/01/2021	12:10	0.043	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	20/01/2021	11:50	11.7	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	20/01/2021	11:55	15.3	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	20/01/2021	11:30	14.8	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	20/01/2021	11:35	15.4	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	20/01/2021	12:05	14.6	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	20/01/2021	12:10	15.4	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	20/01/2021	11:50	1.08	g/m³	(2 - 2)	
	TAB Waikouaiti	6013	Copper - Acid Soluble	20/01/2021	11:55	0.0611	g/m³	(2 - 2)	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	20/01/2021	11:30	0.0306	g/m³	(2 - 2)	

	Karitane Bowls	6013	Copper - Acid Soluble	20/01/2021	11:35	0.0058	g/m³	(2 - 2)	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	20/01/2021	12:05	0.0185	g/m³	(2 - 2)	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	20/01/2021	12:10	0.0373	g/m³	(2 - 2)	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	20/01/2021	11:50	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	20/01/2021	11:55	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	20/01/2021	11:30	<0.01	g/m³		
	Karitane Bowls	6017	Iron - Acid Soluble	20/01/2021	11:35	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	20/01/2021	12:05	0.1	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	20/01/2021	12:10	1.35	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	20/01/2021	11:50	0.0021	g/m³	(.005 - .01)	
	TAB Waikouaiti	6018	Lead - Acid Soluble	20/01/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	20/01/2021	11:30	0.0035	g/m³	(.005 - .01)	
	Karitane Bowls	6018	Lead - Acid Soluble	20/01/2021	11:35	0.0005	g/m³	(.005 - .01)	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	20/01/2021	12:05	0.0017	g/m³	(.005 - .01)	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	20/01/2021	12:10	0.0057	g/m³	(.005 - .01)	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	20/01/2021	11:50	4.92	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	20/01/2021	11:55	6.04	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	20/01/2021	11:30	5.85	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	20/01/2021	11:35	6.08	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	20/01/2021	12:05	5.27	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	20/01/2021	12:10	5.14	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	20/01/2021	11:50	0.002	g/m³	(.4 - .4)	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	20/01/2021	11:55	0.003	g/m³	(.4 - .4)	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	20/01/2021	11:30	0.0021	g/m³	(.4 - .4)	
	Karitane Bowls	6021	Manganese - Acid Soluble	20/01/2021	11:35	0.0052	g/m³	(.4 - .4)	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	20/01/2021	12:05	0.0033	g/m³	(.4 - .4)	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	20/01/2021	12:10	0.028	g/m³	(.4 - .4)	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	20/01/2021	11:50	0.0008	g/m³	(.08 - .08)	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	20/01/2021	11:55	0.0005	g/m³	(.08 - .08)	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	20/01/2021	11:30	0.0006	g/m³	(.08 - .08)	
	Karitane Bowls	6024	Nickel - Acid Soluble	20/01/2021	11:35	0.0005	g/m³	(.08 - .08)	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	20/01/2021	12:05	0.0006	g/m³	(.08 - .08)	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	20/01/2021	12:10	0.0009	g/m³	(.08 - .08)	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	20/01/2021	11:50	0.046	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	20/01/2021	11:55	0.002	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	20/01/2021	11:30	0.053	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	20/01/2021	11:35	0.007	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	20/01/2021	12:05	0.016	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	20/01/2021	12:10	0.041	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	20/01/2021	11:50	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	20/01/2021	11:55	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	20/01/2021	11:30	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	20/01/2021	11:35	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	20/01/2021	12:05	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	20/01/2021	12:10	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	20/01/2021	11:50	7.6			
	TAB Waikouaiti	D-0001F	pH - Field	20/01/2021	11:55	7.5			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	20/01/2021	11:30	7.6			
	Karitane Bowls	D-0001F	pH - Field	20/01/2021	11:35	7.6			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	20/01/2021	12:05	7.7			
	Waikouaiti Golf Club	D-0001F	pH - Field	20/01/2021	12:10	7.7			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	20/01/2021	11:50	5.5	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	20/01/2021	11:55	6.5	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	20/01/2021	11:30	6.5	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	20/01/2021	11:35	6.6	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	20/01/2021	12:05	6.4	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	20/01/2021	12:10	6.6	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	20/01/2021	11:50	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	20/01/2021	11:55	0.84	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	20/01/2021	11:30	<0.05	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	20/01/2021	11:35	0.71	g/m³	(.2 - 5)	

	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	20/01/2021	12:05	<0.05	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	20/01/2021	12:10	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	20/01/2021	11:50	<0.05	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	20/01/2021	11:55	0.9	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	20/01/2021	11:30	<0.05	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	20/01/2021	11:35	1	g/m³		
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	20/01/2021	12:05	<0.05	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	20/01/2021	12:10	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	20/01/2021	11:50	Complete			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	20/01/2021	11:50	Complete			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	20/01/2021	11:50	Complete			
	TAB Waikouaiti	P1859	Sample Filtration	20/01/2021	11:55	Complete			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	20/01/2021	11:30	Complete			
	Karitane Bowls	P1859	Sample Filtration	20/01/2021	11:35	Complete			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	20/01/2021	12:05	Complete			
	Waikouaiti Golf Club	P1859	Sample Filtration	20/01/2021	12:10	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	20/01/2021	12:50	0.008	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	20/01/2021	12:45	0.009	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	20/01/2021	12:40	5.93	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	20/01/2021	12:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	20/01/2021	12:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	20/01/2021	12:40	0.003	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	20/01/2021	12:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	20/01/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	20/01/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	20/01/2021	12:50	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	20/01/2021	12:45	<0.0005	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6012	Cobalt - Acid Soluble	20/01/2021	12:40	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	20/01/2021	12:50	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	20/01/2021	12:45	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	20/01/2021	12:40	0.0016	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	20/01/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	20/01/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	20/01/2021	12:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	20/01/2021	12:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	20/01/2021	12:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	20/01/2021	12:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	20/01/2021	12:50	0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	20/01/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	20/01/2021	12:40	0.0012	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	20/01/2021	12:50	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	20/01/2021	12:45	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6028	Selenium - Acid Soluble	20/01/2021	12:40	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	20/01/2021	12:55	0.482	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	20/01/2021	13:00	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	20/01/2021	13:00	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	20/01/2021	12:55	0.004	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	20/01/2021	13:00	0.013	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	20/01/2021	13:00	<0.05	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	20/01/2021	13:00	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	20/01/2021	12:55	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	20/01/2021	13:00	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	20/01/2021	12:55	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	20/01/2021	13:00	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	20/01/2021	12:55	0.365	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	20/01/2021	13:00	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	20/01/2021	12:55	0.05	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	20/01/2021	13:00	0.022	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	20/01/2021	13:00	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	20/01/2021	12:55	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	20/01/2021	13:00	0.001	g/m³		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	20/01/2021	12:55	0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	20/01/2021	13:00	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	20/01/2021	12:55	<0.005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	20/01/2021	13:00	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	20/01/2021	13:00	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	20/01/2021	13:00	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	20/01/2021	12:55	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	20/01/2021	13:00	4.7	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	20/01/2021	12:55	4.5	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	20/01/2021	12:50	3.6	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	20/01/2021	13:00	1.4	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	20/01/2021	12:55	1.1	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	20/01/2021	12:50	<1	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	20/01/2021	13:00	<1	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	20/01/2021	12:55	<1	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	20/01/2021	12:50	<1	ng/L		
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	28/01/2021	13:00	49	g CaCO3/m³		
	TAB Waikouaiti	52	Alkalinity - Total	28/01/2021	13:10	51	g CaCO3/m³		
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	28/01/2021	12:40	51	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	28/01/2021	12:50	52	g CaCO3/m³		
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	28/01/2021	13:25	50	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	28/01/2021	13:35	51	g CaCO3/m³		
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	28/01/2021	13:00	13.4	g/m³		
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	28/01/2021	13:10	14.3	g/m³		
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	28/01/2021	12:40	14.3	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	28/01/2021	12:50	14.6	g/m³		
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	28/01/2021	13:25	13.9	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	28/01/2021	13:35	14.1	g/m³		
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	28/01/2021	13:00	16.8	g/m³		
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	28/01/2021	13:10	15.7	g/m³		
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	28/01/2021	12:40	16.1	g/m³		
	Karitane Bowls	602	Chloride - Add P1859 Filtration	28/01/2021	12:50	15.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	28/01/2021	13:25	16.1	g/m³		
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	28/01/2021	13:35	16.1	g/m³		
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	28/01/2021	13:00	25.3	g/m³		
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	28/01/2021	13:10	40	g/m³		
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	28/01/2021	12:40	37.2	g/m³		
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	28/01/2021	12:50	39.8	g/m³		
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	28/01/2021	13:25	34.2	g/m³		
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	28/01/2021	13:35	35.5	g/m³		
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	28/01/2021	13:00	0.005	g/m³		
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	28/01/2021	13:10	0.01	g/m³		
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	28/01/2021	12:40	0.009	g/m³		
	Karitane Bowls	6001	Aluminium - Acid Soluble	28/01/2021	12:50	0.013	g/m³		
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	28/01/2021	13:25	0.008	g/m³		
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	28/01/2021	13:35	0.008	g/m³		
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	28/01/2021	13:00	15.4	g/m³		
	TAB Waikouaiti	6010	Calcium - Acid Soluble	28/01/2021	13:10	17.5	g/m³		
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	28/01/2021	12:40	18.9	g/m³		
	Karitane Bowls	6010	Calcium - Acid Soluble	28/01/2021	12:50	19.2	g/m³		
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	28/01/2021	13:25	18.3	g/m³		
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	28/01/2021	13:35	20.2	g/m³		
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	28/01/2021	13:00	1.24	g/m³	(2 - 2)	
	TAB Waikouaiti	6013	Copper - Acid Soluble	28/01/2021	13:10	0.0367	g/m³	(2 - 2)	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	28/01/2021	12:40	0.043	g/m³	(2 - 2)	
	Karitane Bowls	6013	Copper - Acid Soluble	28/01/2021	12:50	0.0047	g/m³	(2 - 2)	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	28/01/2021	13:25	0.0096	g/m³	(2 - 2)	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	28/01/2021	13:35	0.0063	g/m³	(2 - 2)	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	28/01/2021	13:00	<0.01	g/m³		
	TAB Waikouaiti	6017	Iron - Acid Soluble	28/01/2021	13:10	<0.01	g/m³		
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	28/01/2021	12:40	<0.01	g/m³		

	Karitane Bowls	6017	Iron - Acid Soluble	28/01/2021	12:50	<0.01	g/m³		
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	28/01/2021	13:25	0.05	g/m³		
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	28/01/2021	13:35	0.04	g/m³		
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	28/01/2021	13:00	0.0012	g/m³	(.005 - .01)	
	TAB Waikouaiti	6018	Lead - Acid Soluble	28/01/2021	13:10	<0.0005	g/m³	(.005 - .01)	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	28/01/2021	12:40	0.0095	g/m³	(.005 - .01)	
	Karitane Bowls	6018	Lead - Acid Soluble	28/01/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	28/01/2021	13:25	0.0013	g/m³	(.005 - .01)	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	28/01/2021	13:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	28/01/2021	13:00	9.64	g/m³		
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	28/01/2021	13:10	13.1	g/m³		
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	28/01/2021	12:40	11.5	g/m³		
	Karitane Bowls	6020	Magnesium - Acid Soluble	28/01/2021	12:50	12.3	g/m³		
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	28/01/2021	13:25	10.1	g/m³		
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	28/01/2021	13:35	10.4	g/m³		
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	28/01/2021	13:00	0.0026	g/m³	(.4 - .4)	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	28/01/2021	13:10	<0.0005	g/m³	(.4 - .4)	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	28/01/2021	12:40	<0.0005	g/m³	(.4 - .4)	
	Karitane Bowls	6021	Manganese - Acid Soluble	28/01/2021	12:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	28/01/2021	13:25	0.0017	g/m³	(.4 - .4)	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	28/01/2021	13:35	0.0017	g/m³	(.4 - .4)	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	28/01/2021	13:00	0.0007	g/m³	(.08 - .08)	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	28/01/2021	13:10	0.0005	g/m³	(.08 - .08)	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	28/01/2021	12:40	0.0007	g/m³	(.08 - .08)	
	Karitane Bowls	6024	Nickel - Acid Soluble	28/01/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	28/01/2021	13:25	0.0007	g/m³	(.08 - .08)	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	28/01/2021	13:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	28/01/2021	13:00	0.039	g/m³		
	TAB Waikouaiti	6038	Zinc - Acid Soluble	28/01/2021	13:10	0.012	g/m³		
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	28/01/2021	12:40	0.172	g/m³		
	Karitane Bowls	6038	Zinc - Acid Soluble	28/01/2021	12:50	0.007	g/m³		
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	28/01/2021	13:25	0.031	g/m³		
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	28/01/2021	13:35	0.011	g/m³		
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	28/01/2021	13:00	Completed			
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	28/01/2021	13:10	Completed			
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	28/01/2021	12:40	Completed			
	Karitane Bowls	9402	ICP-MS - 2 Elements	28/01/2021	12:50	Completed			
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	28/01/2021	13:25	Completed			
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	28/01/2021	13:35	Completed			
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	28/01/2021	13:00	7.3			
	TAB Waikouaiti	D-0001F	pH - Field	28/01/2021	13:10	7.4			
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	28/01/2021	12:40	7.8			
	Karitane Bowls	D-0001F	pH - Field	28/01/2021	12:50	7.6			
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	28/01/2021	13:25	7.7			
	Waikouaiti Golf Club	D-0001F	pH - Field	28/01/2021	13:35	7.7			
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	28/01/2021	13:00	5.2	g O2/m³		
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	28/01/2021	13:10	6.2	g O2/m³		
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	28/01/2021	12:40	6.4	g O2/m³		
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	28/01/2021	12:50	6.5	g O2/m³		
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	28/01/2021	13:25	6.2	g O2/m³		
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	28/01/2021	13:35	6.4	g O2/m³		
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	28/01/2021	13:00	<0.05	g/m³		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	28/01/2021	13:10	0.55	g/m³	(.2 - 5)	
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	28/01/2021	12:40	0.26	g/m³		
	Karitane Bowls	D-0058H	Free Available Chlorine	28/01/2021	12:50	0.53	g/m³	(.2 - 5)	
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	28/01/2021	13:25	0.05	g/m³		
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	28/01/2021	13:35	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	28/01/2021	13:00	<0.05	g/m³		
	TAB Waikouaiti	D-0066H	Total Chlorine	28/01/2021	13:10	0.7	g/m³		
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	28/01/2021	12:40	0.4	g/m³		
	Karitane Bowls	D-0066H	Total Chlorine	28/01/2021	12:50	0.7	g/m³		

	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	28/01/2021	13:25	0.1	g/m³		
	Waikouaiti Golf Club	D-0066H	Total Chlorine	28/01/2021	13:35	<0.05	g/m³		
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	28/01/2021	13:00	Complete			
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	28/01/2021	13:00	Complete			
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	28/01/2021	13:00	Complete			
	TAB Waikouaiti	P1859	Sample Filtration	28/01/2021	13:10	Complete			
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	28/01/2021	12:40	Complete			
	Karitane Bowls	P1859	Sample Filtration	28/01/2021	12:50	Complete			
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	28/01/2021	13:25	Complete			
	Waikouaiti Golf Club	P1859	Sample Filtration	28/01/2021	13:35	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	28/01/2021	14:10	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	28/01/2021	14:15	0.009	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	28/01/2021	14:20	299	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	28/01/2021	14:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	28/01/2021	14:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	28/01/2021	14:20	0.02	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	28/01/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	28/01/2021	14:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	28/01/2021	14:20	0.0005	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	28/01/2021	14:10	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	28/01/2021	14:15	<0.0005	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6012	Cobalt - Acid Soluble	28/01/2021	14:20	0.0106	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	28/01/2021	14:10	0.001	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	28/01/2021	14:15	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	28/01/2021	14:20	0.172	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	28/01/2021	14:10	0.0009	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	28/01/2021	14:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	28/01/2021	14:20	0.0302	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	28/01/2021	14:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	28/01/2021	14:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	28/01/2021	14:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	28/01/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	28/01/2021	14:15	0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	28/01/2021	14:20	1.99	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	28/01/2021	14:10	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	28/01/2021	14:15	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6028	Selenium - Acid Soluble	28/01/2021	14:20	<0.002	g/m³	(.01 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	28/01/2021	14:05	0.017	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	28/01/2021	13:55	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	28/01/2021	13:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	28/01/2021	14:05	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	28/01/2021	13:55	0.015	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	28/01/2021	13:55	<0.05	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	28/01/2021	13:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	28/01/2021	14:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	28/01/2021	13:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	28/01/2021	14:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	28/01/2021	13:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	28/01/2021	14:05	0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	28/01/2021	13:55	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	28/01/2021	14:05	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	28/01/2021	13:55	0.022	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	28/01/2021	13:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	28/01/2021	14:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	28/01/2021	13:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	28/01/2021	14:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	28/01/2021	13:55	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	28/01/2021	14:05	<0.005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	28/01/2021	13:55	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	28/01/2021	13:55	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	28/01/2021	13:55	Complete			

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	28/01/2021	14:05	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	W-TO0001	Geosmin by SPME	28/01/2021	13:55	4	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO0001	Geosmin by SPME	28/01/2021	14:05	4.4	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO0001	Geosmin by SPME	28/01/2021	14:10	4.7	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO0002	2-Methylisoborneol by SPME	28/01/2021	13:55	5.2	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO0002	2-Methylisoborneol by SPME	28/01/2021	14:05	5.5	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO0002	2-Methylisoborneol by SPME	28/01/2021	14:10	2.8	ng/L		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO0003	2,4,6-Trichloroanisole by SPME	28/01/2021	13:55	<1	ng/L		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO0003	2,4,6-Trichloroanisole by SPME	28/01/2021	14:05	<1	ng/L		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO0003	2,4,6-Trichloroanisole by SPME	28/01/2021	14:10	<1	ng/L		
	Karitane Bowls	D-0058H	Free Available Chlorine	29/01/2021	15:40	0.86	g/m^3	(.2 - 5)	
	Karitane Bowls	D-0066H	Total Chlorine	29/01/2021	15:40	1	g/m^3		
	Karitane Bowls	D-0084	Turbidity	29/01/2021	15:40	0.2	NTU		
	Karitane Bowls	D-1310	Temperature on arrival	29/01/2021	15:40	9.9	Deg C		
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/01/2021	15:40	<1	MPN/100mL	(0 - 0)	
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/01/2021	15:40	<1	MPN/100ml	(0 - 0)	

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti TAB - Pre-flush	52	Alkalinity - Total	01/02/2021	13:38	54	g CaCO3/m³	
	TAB Waikouaiti	52	Alkalinity - Total	01/02/2021	13:44	58	g CaCO3/m³	
	Karitane Bowls - Pre-flush	52	Alkalinity - Total	01/02/2021	13:15	56	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	01/02/2021	13:20	58	g CaCO3/m³	
	Waikouaiti Golf Club - Pre-flush	52	Alkalinity - Total	01/02/2021	14:00	58	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	01/02/2021	14:05	57	g CaCO3/m³	
	Waikouaiti TAB - Pre-flush	0440D	Dissolved Inorganic Carbon	01/02/2021	13:38	14.9	g/m³	
	TAB Waikouaiti	0440D	Dissolved Inorganic Carbon	01/02/2021	13:44	16.5	g/m³	
	Karitane Bowls - Pre-flush	0440D	Dissolved Inorganic Carbon	01/02/2021	13:15	15.9	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	01/02/2021	13:20	16.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	0440D	Dissolved Inorganic Carbon	01/02/2021	14:00	16.2	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	01/02/2021	14:05	16.4	g/m³	
	Waikouaiti TAB - Pre-flush	602	Chloride - Add P1859 Filtration	01/02/2021	13:38	16.1	g/m³	
	TAB Waikouaiti	602	Chloride - Add P1859 Filtration	01/02/2021	13:44	15.8	g/m³	
	Karitane Bowls - Pre-flush	602	Chloride - Add P1859 Filtration	01/02/2021	13:15	16.3	g/m³	
	Karitane Bowls	602	Chloride - Add P1859 Filtration	01/02/2021	13:20	15.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	602	Chloride - Add P1859 Filtration	01/02/2021	14:00	16	g/m³	
	Waikouaiti Golf Club	602	Chloride - Add P1859 Filtration	01/02/2021	14:05	15.9	g/m³	
	Waikouaiti TAB - Pre-flush	607	Sulphate - Add P1859 Filtration	01/02/2021	13:38	39.6	g/m³	
	TAB Waikouaiti	607	Sulphate - Add P1859 Filtration	01/02/2021	13:44	42.8	g/m³	
	Karitane Bowls - Pre-flush	607	Sulphate - Add P1859 Filtration	01/02/2021	13:15	43.4	g/m³	
	Karitane Bowls	607	Sulphate - Add P1859 Filtration	01/02/2021	13:20	42.7	g/m³	
	Waikouaiti Golf Club - Pre-flush	607	Sulphate - Add P1859 Filtration	01/02/2021	14:00	41.9	g/m³	
	Waikouaiti Golf Club	607	Sulphate - Add P1859 Filtration	01/02/2021	14:05	42.8	g/m³	
	Waikouaiti TAB - Pre-flush	6001	Aluminium - Acid Soluble	01/02/2021	13:38	0.004	g/m³	
	TAB Waikouaiti	6001	Aluminium - Acid Soluble	01/02/2021	13:44	0.012	g/m³	
	Karitane Bowls - Pre-flush	6001	Aluminium - Acid Soluble	01/02/2021	13:15	0.014	g/m³	
	Karitane Bowls	6001	Aluminium - Acid Soluble	01/02/2021	13:20	0.013	g/m³	
	Waikouaiti Golf Club - Pre-flush	6001	Aluminium - Acid Soluble	01/02/2021	14:00	0.01	g/m³	
	Waikouaiti Golf Club	6001	Aluminium - Acid Soluble	01/02/2021	14:05	0.022	g/m³	
	Waikouaiti TAB - Pre-flush	6010	Calcium - Acid Soluble	01/02/2021	13:38	19.6	g/m³	
	TAB Waikouaiti	6010	Calcium - Acid Soluble	01/02/2021	13:44	21.5	g/m³	
	Karitane Bowls - Pre-flush	6010	Calcium - Acid Soluble	01/02/2021	13:15	23	g/m³	
	Karitane Bowls	6010	Calcium - Acid Soluble	01/02/2021	13:20	22.8	g/m³	
	Waikouaiti Golf Club - Pre-flush	6010	Calcium - Acid Soluble	01/02/2021	14:00	22.9	g/m³	
	Waikouaiti Golf Club	6010	Calcium - Acid Soluble	01/02/2021	14:05	23.2	g/m³	
	Waikouaiti TAB - Pre-flush	6013	Copper - Acid Soluble	01/02/2021	13:38	1.14	g/m³	
	TAB Waikouaiti	6013	Copper - Acid Soluble	01/02/2021	13:44	0.0647	g/m³	
	Karitane Bowls - Pre-flush	6013	Copper - Acid Soluble	01/02/2021	13:15	0.0235	g/m³	
	Karitane Bowls	6013	Copper - Acid Soluble	01/02/2021	13:20	0.0058	g/m³	
	Waikouaiti Golf Club - Pre-flush	6013	Copper - Acid Soluble	01/02/2021	14:00	0.0296	g/m³	
	Waikouaiti Golf Club	6013	Copper - Acid Soluble	01/02/2021	14:05	0.026	g/m³	
	Waikouaiti TAB - Pre-flush	6017	Iron - Acid Soluble	01/02/2021	13:38	<0.01	g/m³	
	TAB Waikouaiti	6017	Iron - Acid Soluble	01/02/2021	13:44	<0.01	g/m³	
	Karitane Bowls - Pre-flush	6017	Iron - Acid Soluble	01/02/2021	13:15	<0.01	g/m³	
	Karitane Bowls	6017	Iron - Acid Soluble	01/02/2021	13:20	<0.01	g/m³	
	Waikouaiti Golf Club - Pre-flush	6017	Iron - Acid Soluble	01/02/2021	14:00	0.05	g/m³	
	Waikouaiti Golf Club	6017	Iron - Acid Soluble	01/02/2021	14:05	0.36	g/m³	
	Waikouaiti TAB - Pre-flush	6018	Lead - Acid Soluble	01/02/2021	13:38	0.0016	g/m³	
	TAB Waikouaiti	6018	Lead - Acid Soluble	01/02/2021	13:44	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6018	Lead - Acid Soluble	01/02/2021	13:15	0.0027	g/m³	
	Karitane Bowls	6018	Lead - Acid Soluble	01/02/2021	13:20	0.0008	g/m³	
	Waikouaiti Golf Club - Pre-flush	6018	Lead - Acid Soluble	01/02/2021	14:00	0.0037	g/m³	
	Waikouaiti Golf Club	6018	Lead - Acid Soluble	01/02/2021	14:05	0.0044	g/m³	
	Waikouaiti TAB - Pre-flush	6020	Magnesium - Acid Soluble	01/02/2021	13:38	12.7	g/m³	
	TAB Waikouaiti	6020	Magnesium - Acid Soluble	01/02/2021	13:44	13.7	g/m³	
	Karitane Bowls - Pre-flush	6020	Magnesium - Acid Soluble	01/02/2021	13:15	12.9	g/m³	
	Karitane Bowls	6020	Magnesium - Acid Soluble	01/02/2021	13:20	13.4	g/m³	
	Waikouaiti Golf Club - Pre-flush	6020	Magnesium - Acid Soluble	01/02/2021	14:00	12.5	g/m³	
	Waikouaiti Golf Club	6020	Magnesium - Acid Soluble	01/02/2021	14:05	12.7	g/m³	
	Waikouaiti TAB - Pre-flush	6021	Manganese - Acid Soluble	01/02/2021	13:38	<0.0005	g/m³	
	TAB Waikouaiti	6021	Manganese - Acid Soluble	01/02/2021	13:44	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6021	Manganese - Acid Soluble	01/02/2021	13:15	0.0009	g/m³	
	Karitane Bowls	6021	Manganese - Acid Soluble	01/02/2021	13:20	<0.0005	g/m³	

	Waikouaiti Golf Club - Pre-flush	6021	Manganese - Acid Soluble	01/02/2021	14:00	0.002	g/m³	
	Waikouaiti Golf Club	6021	Manganese - Acid Soluble	01/02/2021	14:05	0.0096	g/m³	
	Waikouaiti TAB - Pre-flush	6024	Nickel - Acid Soluble	01/02/2021	13:38	0.0008	g/m³	
	TAB Waikouaiti	6024	Nickel - Acid Soluble	01/02/2021	13:44	<0.0005	g/m³	
	Karitane Bowls - Pre-flush	6024	Nickel - Acid Soluble	01/02/2021	13:15	<0.0005	g/m³	
	Karitane Bowls	6024	Nickel - Acid Soluble	01/02/2021	13:20	<0.0005	g/m³	
	Waikouaiti Golf Club - Pre-flush	6024	Nickel - Acid Soluble	01/02/2021	14:00	0.0006	g/m³	
	Waikouaiti Golf Club	6024	Nickel - Acid Soluble	01/02/2021	14:05	<0.0005	g/m³	
	Waikouaiti TAB - Pre-flush	6038	Zinc - Acid Soluble	01/02/2021	13:38	0.124	g/m³	
	TAB Waikouaiti	6038	Zinc - Acid Soluble	01/02/2021	13:44	<0.002	g/m³	
	Karitane Bowls - Pre-flush	6038	Zinc - Acid Soluble	01/02/2021	13:15	0.039	g/m³	
	Karitane Bowls	6038	Zinc - Acid Soluble	01/02/2021	13:20	0.014	g/m³	
	Waikouaiti Golf Club - Pre-flush	6038	Zinc - Acid Soluble	01/02/2021	14:00	0.041	g/m³	
	Waikouaiti Golf Club	6038	Zinc - Acid Soluble	01/02/2021	14:05	0.028	g/m³	
	Waikouaiti TAB - Pre-flush	9402	ICP-MS - 2 Elements	01/02/2021	13:38	Completed		
	TAB Waikouaiti	9402	ICP-MS - 2 Elements	01/02/2021	13:44	Completed		
	Karitane Bowls - Pre-flush	9402	ICP-MS - 2 Elements	01/02/2021	13:15	Completed		
	Karitane Bowls	9402	ICP-MS - 2 Elements	01/02/2021	13:20	Completed		
	Waikouaiti Golf Club - Pre-flush	9402	ICP-MS - 2 Elements	01/02/2021	14:00	Completed		
	Waikouaiti Golf Club	9402	ICP-MS - 2 Elements	01/02/2021	14:05	Completed		
	Waikouaiti TAB - Pre-flush	D-0001F	pH - Field	01/02/2021	13:38	7.4		
	TAB Waikouaiti	D-0001F	pH - Field	01/02/2021	13:44	7.8		
	Karitane Bowls - Pre-flush	D-0001F	pH - Field	01/02/2021	13:15	7.6		
	Karitane Bowls	D-0001F	pH - Field	01/02/2021	13:20	8.1		
	Waikouaiti Golf Club - Pre-flush	D-0001F	pH - Field	01/02/2021	14:00	7.8		
	Waikouaiti Golf Club	D-0001F	pH - Field	01/02/2021	14:05	7.8		
	Waikouaiti TAB - Pre-flush	D-0056F	Dissolved Oxygen - Field	01/02/2021	13:38	5.2	g O2/m³	
	TAB Waikouaiti	D-0056F	Dissolved Oxygen - Field	01/02/2021	13:44	7.9	g O2/m³	
	Karitane Bowls - Pre-flush	D-0056F	Dissolved Oxygen - Field	01/02/2021	13:15	5.8	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	01/02/2021	13:20	8.9	g O2/m³	
	Waikouaiti Golf Club - Pre-flush	D-0056F	Dissolved Oxygen - Field	01/02/2021	14:00	6.6	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	01/02/2021	14:05	7.5	g O2/m³	
	Waikouaiti TAB - Pre-flush	D-0058H	Free Available Chlorine	01/02/2021	13:38	<0.05	g/m³	
	TAB Waikouaiti	D-0058H	Free Available Chlorine	01/02/2021	13:44	0.49	g/m³	(.2 - 5)
	Karitane Bowls - Pre-flush	D-0058H	Free Available Chlorine	01/02/2021	13:15	<0.05	g/m³	
	Karitane Bowls	D-0058H	Free Available Chlorine	01/02/2021	13:20	0.49	g/m³	(.2 - 5)
	Waikouaiti Golf Club - Pre-flush	D-0058H	Free Available Chlorine	01/02/2021	14:00	<0.05	g/m³	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	01/02/2021	14:05	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-0066H	Total Chlorine	01/02/2021	13:38	<0.05	g/m³	
	TAB Waikouaiti	D-0066H	Total Chlorine	01/02/2021	13:44	0.8	g/m³	
	Karitane Bowls - Pre-flush	D-0066H	Total Chlorine	01/02/2021	13:15	<0.05	g/m³	
	Karitane Bowls	D-0066H	Total Chlorine	01/02/2021	13:20	0.6	g/m³	
	Waikouaiti Golf Club - Pre-flush	D-0066H	Total Chlorine	01/02/2021	14:00	<0.05	g/m³	
	Waikouaiti Golf Club	D-0066H	Total Chlorine	01/02/2021	14:05	<0.05	g/m³	
	Waikouaiti TAB - Pre-flush	D-1202	Sampling / Inspection 30 Mins	01/02/2021	13:38	Completed		
	Waikouaiti TAB - Pre-flush	D-1205	Sampling / Inspection 2 hours	01/02/2021	13:38	Completed		
	Waikouaiti TAB - Pre-flush	P1859	Sample Filtration	01/02/2021	13:38	Completed		
	TAB Waikouaiti	P1859	Sample Filtration	01/02/2021	13:44	Completed		
	Karitane Bowls - Pre-flush	P1859	Sample Filtration	01/02/2021	13:15	Completed		
	Karitane Bowls	P1859	Sample Filtration	01/02/2021	13:20	Completed		
	Waikouaiti Golf Club - Pre-flush	P1859	Sample Filtration	01/02/2021	14:00	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	01/02/2021	14:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	01/02/2021	12:45	0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	01/02/2021	12:40	0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	01/02/2021	12:43	0.983	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	01/02/2021	12:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	01/02/2021	12:40	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	01/02/2021	12:43	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	01/02/2021	12:45	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	01/02/2021	12:40	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	01/02/2021	12:43	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	01/02/2021	12:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	01/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6012	Cobalt - Acid Soluble	01/02/2021	12:43	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	01/02/2021	12:45	<0.0005	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	01/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	01/02/2021	12:43	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	01/02/2021	12:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	01/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	01/02/2021	12:43	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	01/02/2021	12:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	01/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	01/02/2021	12:43	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	01/02/2021	12:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	01/02/2021	12:40	0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	01/02/2021	12:43	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	01/02/2021	12:45	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	01/02/2021	12:40	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6028	Selenium - Acid Soluble	01/02/2021	12:43	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	01/02/2021	12:50	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	01/02/2021	12:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	01/02/2021	12:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	01/02/2021	12:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	01/02/2021	12:15	0.018	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	01/02/2021	12:15	<0.05	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	01/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	01/02/2021	12:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	01/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	01/02/2021	12:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	01/02/2021	12:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	01/02/2021	12:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	01/02/2021	12:15	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	01/02/2021	12:50	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	01/02/2021	12:15	0.023	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	01/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	01/02/2021	12:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	01/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	01/02/2021	12:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	01/02/2021	12:15	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	01/02/2021	12:50	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	01/02/2021	12:15	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	01/02/2021	12:15	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/02/2021	12:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/02/2021	12:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	01/02/2021	12:15	3.4	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	01/02/2021	12:50	2.4	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	01/02/2021	12:45	2.9	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	01/02/2021	12:15	3.9	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	01/02/2021	12:50	3.3	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	01/02/2021	12:45	3.8	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	01/02/2021	12:15	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	01/02/2021	12:50	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	01/02/2021	12:45	<1	ng/L	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	04/02/2021	12:30	60	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	04/02/2021	12:40	61	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	04/02/2021	11:50	61	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	04/02/2021	11:58	61	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	04/02/2021	11:00	59	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	04/02/2021	11:08	61	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	04/02/2021	12:30	17.1	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	04/02/2021	12:40	17.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	04/02/2021	11:50	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	04/02/2021	11:58	16.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	04/02/2021	11:00	17.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	04/02/2021	11:08	17.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	04/02/2021	12:30	15.5	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	04/02/2021	12:40	15.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	04/02/2021	11:50	15.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	04/02/2021	11:58	15.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	04/02/2021	11:00	15.7	g/m³	

	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	04/02/2021	11:08	15.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	04/02/2021	12:30	41.5	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	04/02/2021	12:40	41.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	04/02/2021	11:50	41.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	04/02/2021	11:58	41.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	04/02/2021	11:00	41.5	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	04/02/2021	11:08	41.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	04/02/2021	12:30	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	04/02/2021	12:30	0.015	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	04/02/2021	12:40	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	04/02/2021	11:50	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	04/02/2021	11:58	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	04/02/2021	11:00	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	04/02/2021	11:08	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	04/02/2021	10:34	0.009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	04/02/2021	10:40	0.648	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	04/02/2021	10:32	0.013	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	04/02/2021	10:34	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	04/02/2021	10:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	04/02/2021	10:32	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	04/02/2021	12:30	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	04/02/2021	12:40	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	04/02/2021	11:50	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	04/02/2021	11:58	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	04/02/2021	11:00	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	04/02/2021	11:08	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	04/02/2021	10:34	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	04/02/2021	10:40	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	04/02/2021	10:32	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	04/02/2021	12:30	21.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	04/02/2021	12:40	21	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	04/02/2021	11:50	22.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	04/02/2021	11:58	22.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	04/02/2021	11:00	21.9	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	04/02/2021	11:08	22	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	04/02/2021	10:34	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6012	Cobalt - Acid Soluble	04/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	04/02/2021	10:32	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	04/02/2021	12:30	0.0021	g/m³	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	04/02/2021	12:40	0.0018	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	04/02/2021	11:50	0.0017	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	04/02/2021	11:58	0.0017	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	04/02/2021	11:00	0.0022	g/m³	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	04/02/2021	11:08	0.0018	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	04/02/2021	10:34	0.0014	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	04/02/2021	10:40	0.0016	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	04/02/2021	10:32	0.0015	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	04/02/2021	12:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	04/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	04/02/2021	11:50	0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	04/02/2021	11:58	0.05	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	04/02/2021	11:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	04/02/2021	11:08	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	04/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	04/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	04/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	04/02/2021	11:58	0.0006	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	04/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	04/02/2021	11:08	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	04/02/2021	10:34	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	04/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	04/02/2021	10:32	0.0009	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	04/02/2021	12:30	14.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	04/02/2021	12:40	14.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	04/02/2021	11:50	12.8	g/m³	

	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	04/02/2021	11:58	12.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	04/02/2021	11:00	13.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	04/02/2021	11:08	13.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	04/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	04/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	04/02/2021	11:50	0.0011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	04/02/2021	11:58	0.0012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	04/02/2021	11:00	0.0008	g/m³	
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	04/02/2021	11:08	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	04/02/2021	10:34	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	04/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	04/02/2021	10:32	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	04/02/2021	12:30	0.0008	g/m³	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	04/02/2021	12:40	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	04/02/2021	11:50	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	04/02/2021	11:58	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	04/02/2021	11:00	0.0033	g/m³	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	04/02/2021	11:08	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	04/02/2021	10:34	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	04/02/2021	10:40	0.0006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	04/02/2021	10:32	0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	04/02/2021	10:34	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6028	Selenium - Acid Soluble	04/02/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	04/02/2021	10:32	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	04/02/2021	12:30	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	04/02/2021	12:40	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	04/02/2021	11:50	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	04/02/2021	11:58	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	04/02/2021	11:00	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	04/02/2021	11:08	0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	04/02/2021	10:20	0.018	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	04/02/2021	10:30	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	04/02/2021	10:20	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	04/02/2021	10:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	04/02/2021	10:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	04/02/2021	10:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	04/02/2021	10:20	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	04/02/2021	10:30	0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	04/02/2021	10:20	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	04/02/2021	10:30	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	04/02/2021	10:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	04/02/2021	10:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	04/02/2021	10:20	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	04/02/2021	10:30	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	04/02/2021	12:30	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	04/02/2021	12:40	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	04/02/2021	11:50	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	04/02/2021	11:58	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	04/02/2021	11:00	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	04/02/2021	11:08	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	04/02/2021	10:20	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	04/02/2021	10:30	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	04/02/2021	10:34	0.009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	04/02/2021	10:40	0.14	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	04/02/2021	10:32	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	04/02/2021	10:30	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	04/02/2021	10:34	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	04/02/2021	10:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	04/02/2021	10:32	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	04/02/2021	12:30	<0.0002	g/m³	

	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	04/02/2021	12:40	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	04/02/2021	11:50	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	04/02/2021	11:58	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	04/02/2021	11:00	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	04/02/2021	11:08	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	04/02/2021	10:20	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	04/02/2021	10:30	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	04/02/2021	10:34	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	04/02/2021	10:40	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	04/02/2021	10:32	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	04/02/2021	12:30	20.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	04/02/2021	12:40	20.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	04/02/2021	11:50	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	04/02/2021	11:58	22.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	04/02/2021	11:00	21.7	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	04/02/2021	11:08	21.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	04/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	04/02/2021	10:30	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	04/02/2021	10:34	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6711	Chromium - Dissolved	04/02/2021	10:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	04/02/2021	10:32	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	04/02/2021	12:30	0.0016	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	04/02/2021	12:40	0.0011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	04/02/2021	11:50	0.0014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	04/02/2021	11:58	0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	04/02/2021	11:00	0.0014	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	04/02/2021	11:08	0.0019	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	04/02/2021	10:20	0.0014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	04/02/2021	10:30	0.0041	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	04/02/2021	10:34	0.0006	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	04/02/2021	10:40	0.0006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	04/02/2021	10:32	0.0015	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	04/02/2021	12:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	04/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	04/02/2021	11:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	04/02/2021	11:58	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	04/02/2021	11:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	04/02/2021	11:08	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	04/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	04/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	04/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	04/02/2021	11:58	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	04/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	04/02/2021	11:08	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	04/02/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	04/02/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	04/02/2021	10:34	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	04/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	04/02/2021	10:32	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	04/02/2021	12:30	13.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	04/02/2021	12:40	14.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	04/02/2021	11:50	12.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	04/02/2021	11:58	12.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	04/02/2021	11:00	13.7	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	04/02/2021	11:08	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	04/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	04/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	04/02/2021	11:50	0.0008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	04/02/2021	11:58	0.0007	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	04/02/2021	11:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	04/02/2021	11:08	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	04/02/2021	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	04/02/2021	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	04/02/2021	10:34	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	04/02/2021	10:40	<0.0005	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	04/02/2021	10:32	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	04/02/2021	12:30	0.0007	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	04/02/2021	12:40	0.0006	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	04/02/2021	11:50	0.0008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	04/02/2021	11:58	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	04/02/2021	11:00	0.0011	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	04/02/2021	11:08	0.0006	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	04/02/2021	10:20	0.0006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	04/02/2021	10:30	0.0006	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	04/02/2021	10:34	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	04/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	04/02/2021	10:32	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	04/02/2021	10:20	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	04/02/2021	10:30	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	04/02/2021	10:34	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6728	Selenium - Dissolved	04/02/2021	10:40	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	04/02/2021	10:32	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	04/02/2021	12:30	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	04/02/2021	12:40	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	04/02/2021	11:50	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	04/02/2021	11:58	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	04/02/2021	11:00	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	04/02/2021	11:08	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	04/02/2021	12:30	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	04/02/2021	12:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	04/02/2021	11:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	04/02/2021	11:58	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	04/02/2021	11:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	04/02/2021	11:08	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	04/02/2021	12:30	7.9		
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	04/02/2021	12:40	7.9		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	04/02/2021	11:50	8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	04/02/2021	11:58	7.5		
	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	04/02/2021	11:00	7.7		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	04/02/2021	11:08	7.8		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	04/02/2021	12:30	6.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	04/02/2021	12:40	6.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	04/02/2021	11:50	6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	04/02/2021	11:58	6.9	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	04/02/2021	11:00	5.7	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	04/02/2021	11:08	6.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	04/02/2021	12:30	0.4	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	04/02/2021	12:40	0.6	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	04/02/2021	11:50	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	04/02/2021	11:58	<0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	04/02/2021	11:00	0.3	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	04/02/2021	11:08	0.61	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	04/02/2021	12:30	0.9	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	04/02/2021	12:40	0.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	04/02/2021	11:50	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	04/02/2021	11:58	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	04/02/2021	11:00	0.3	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	04/02/2021	11:08	0.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	04/02/2021	12:30	Complete		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	04/02/2021	10:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	04/02/2021	10:20	Complete		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	04/02/2021	12:30	Complete		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/02/2021	10:20	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/02/2021	10:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	04/02/2021	12:30	Complete		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	04/02/2021	12:40	Complete		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	04/02/2021	11:50	Complete		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	04/02/2021	11:58	Complete		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	04/02/2021	11:00	Complete		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	04/02/2021	11:08	Complete		

	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	04/02/2021	10:20	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	04/02/2021	10:30	Complete		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	04/02/2021	10:34	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	04/02/2021	10:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	04/02/2021	10:32	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	04/02/2021	09:32	0.46	g/m^3	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	04/02/2021	09:32	0.5	g/m^3	
	TAB Waikouaiti	D-0084	Turbidity	04/02/2021	09:32	0.06	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	04/02/2021	09:32	8.6	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/02/2021	09:32	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/02/2021	09:32	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	05/02/2021	12:10	63	g CaCO3/m^3	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	05/02/2021	12:15	62	g CaCO3/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	05/02/2021	12:35	63	g CaCO3/m^3	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	05/02/2021	12:46	60	g CaCO3/m^3	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	05/02/2021	13:35	63	g CaCO3/m^3	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	05/02/2021	13:45	62	g CaCO3/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	05/02/2021	12:10	17.6	g/m^3	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	05/02/2021	12:15	17.6	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	05/02/2021	12:35	16.5	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	05/02/2021	12:46	16.6	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	05/02/2021	13:35	17.5	g/m^3	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	05/02/2021	13:45	17.5	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	05/02/2021	12:10	15.9	g/m^3	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	05/02/2021	12:15	15.7	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	05/02/2021	12:35	15.8	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	05/02/2021	12:46	15.8	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	05/02/2021	13:35	15.9	g/m^3	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	05/02/2021	13:45	15.9	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	05/02/2021	12:10	41.9	g/m^3	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	05/02/2021	12:15	41.5	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	05/02/2021	12:35	41.3	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	05/02/2021	12:46	41.2	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	05/02/2021	13:35	41.5	g/m^3	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	05/02/2021	13:45	41.5	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	05/02/2021	12:10	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	05/02/2021	12:10	0.014	g/m^3	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	05/02/2021	12:15	0.014	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	05/02/2021	12:35	0.015	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	05/02/2021	12:46	0.015	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	05/02/2021	13:35	0.015	g/m^3	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	05/02/2021	13:45	0.015	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	05/02/2021	14:20	0.009	g/m^3	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	05/02/2021	14:15	0.877	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	05/02/2021	14:05	0.012	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	05/02/2021	14:20	<0.001	g/m^3	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	05/02/2021	14:15	<0.001	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	05/02/2021	14:05	<0.001	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	05/02/2021	12:10	<0.0002	g/m^3	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	05/02/2021	12:15	<0.0002	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	05/02/2021	12:35	<0.0002	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	05/02/2021	12:46	<0.0002	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	05/02/2021	13:35	<0.0002	g/m^3	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	05/02/2021	13:45	<0.0002	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	05/02/2021	14:20	<0.0002	g/m^3	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	05/02/2021	14:15	<0.0002	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	05/02/2021	14:05	<0.0002	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	05/02/2021	12:10	22.1	g/m^3	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	05/02/2021	12:15	21.5	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	05/02/2021	12:35	22.2	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	05/02/2021	12:46	22.6	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	05/02/2021	13:35	22.3	g/m^3	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	05/02/2021	13:45	22.4	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	05/02/2021	14:20	<0.0005	g/m^3	
	Waikouaiti WTP - Supernatant Tube Settler	6012	Cobalt - Acid Soluble	05/02/2021	14:15	<0.0005	g/m^3	

	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	05/02/2021	14:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	05/02/2021	12:10	0.0018	g/m³	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	05/02/2021	12:15	0.0015	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	05/02/2021	12:35	0.0012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	05/02/2021	12:46	0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	05/02/2021	13:35	0.0013	g/m³	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	05/02/2021	13:45	0.0012	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	05/02/2021	14:20	0.0007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	05/02/2021	14:15	0.0012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	05/02/2021	14:05	0.0014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	05/02/2021	12:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	05/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	05/02/2021	12:35	0.06	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	05/02/2021	12:46	0.07	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	05/02/2021	13:35	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	05/02/2021	13:45	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	05/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	05/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	05/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	05/02/2021	12:46	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	05/02/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	05/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	05/02/2021	14:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	05/02/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	05/02/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	05/02/2021	12:10	14.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	05/02/2021	12:15	14.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	05/02/2021	12:35	13.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	05/02/2021	12:46	12.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	05/02/2021	13:35	13.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	05/02/2021	13:45	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	05/02/2021	12:10	0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	05/02/2021	12:15	0.0008	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	05/02/2021	12:35	0.0017	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	05/02/2021	12:46	0.0018	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	05/02/2021	13:35	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	05/02/2021	13:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	05/02/2021	14:20	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	05/02/2021	14:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	05/02/2021	14:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	05/02/2021	12:10	0.0007	g/m³	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	05/02/2021	12:15	0.0006	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	05/02/2021	12:35	0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	05/02/2021	12:46	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	05/02/2021	13:35	0.0006	g/m³	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	05/02/2021	13:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	05/02/2021	14:20	0.0011	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	05/02/2021	14:15	0.0008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	05/02/2021	14:05	0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	05/02/2021	14:20	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6028	Selenium - Acid Soluble	05/02/2021	14:15	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	05/02/2021	14:05	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	05/02/2021	12:10	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	05/02/2021	12:15	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	05/02/2021	12:35	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	05/02/2021	12:46	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	05/02/2021	13:35	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	05/02/2021	13:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	05/02/2021	14:25	0.014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	05/02/2021	14:10	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	05/02/2021	14:25	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	05/02/2021	14:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	05/02/2021	14:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	05/02/2021	14:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	05/02/2021	14:25	<0.001	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	05/02/2021	14:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	05/02/2021	14:25	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	05/02/2021	14:10	0.004	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	05/02/2021	14:25	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	05/02/2021	14:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	05/02/2021	14:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	05/02/2021	14:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	05/02/2021	14:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	05/02/2021	14:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	05/02/2021	14:25	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	05/02/2021	14:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	05/02/2021	12:10	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	05/02/2021	12:15	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	05/02/2021	12:35	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	05/02/2021	12:46	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	05/02/2021	13:35	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	05/02/2021	13:45	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	05/02/2021	14:25	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	05/02/2021	14:10	0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	05/02/2021	14:20	0.009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	05/02/2021	14:15	0.216	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	05/02/2021	14:05	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	05/02/2021	14:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	05/02/2021	14:10	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	05/02/2021	14:20	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	05/02/2021	14:15	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	05/02/2021	14:05	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	05/02/2021	12:10	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	05/02/2021	12:15	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	05/02/2021	12:35	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	05/02/2021	12:46	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	05/02/2021	13:35	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	05/02/2021	13:45	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	05/02/2021	14:25	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	05/02/2021	14:10	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	05/02/2021	14:20	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	05/02/2021	14:15	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	05/02/2021	14:05	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	05/02/2021	12:10	21.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	05/02/2021	12:15	21.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	05/02/2021	12:35	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	05/02/2021	12:46	22.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	05/02/2021	13:35	22.5	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	05/02/2021	13:45	22.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	05/02/2021	14:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	05/02/2021	14:10	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	05/02/2021	14:20	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6711	Chromium - Dissolved	05/02/2021	14:15	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	05/02/2021	14:05	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	05/02/2021	12:10	0.0019	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	05/02/2021	12:15	0.0012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	05/02/2021	12:35	0.0009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	05/02/2021	12:46	0.0009	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	05/02/2021	13:35	0.0013	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	05/02/2021	13:45	0.0012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	05/02/2021	14:25	0.0013	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	05/02/2021	14:10	0.0027	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	05/02/2021	14:20	0.0007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	05/02/2021	14:15	0.0008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	05/02/2021	14:05	0.0014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	05/02/2021	12:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	05/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	05/02/2021	12:35	0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	05/02/2021	12:46	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	05/02/2021	13:35	<0.01	g/m³	(.2 - .2)

	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	05/02/2021	13:45	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	05/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	05/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	05/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	05/02/2021	12:46	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	05/02/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	05/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	05/02/2021	14:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	05/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	05/02/2021	14:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	05/02/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	05/02/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	05/02/2021	12:10	14.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	05/02/2021	12:15	14.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	05/02/2021	12:35	12.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	05/02/2021	12:46	12.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	05/02/2021	13:35	13.6	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	05/02/2021	13:45	13.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	05/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	05/02/2021	12:15	0.0028	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	05/02/2021	12:35	0.0015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	05/02/2021	12:46	0.0013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	05/02/2021	13:35	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	05/02/2021	13:45	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	05/02/2021	14:25	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	05/02/2021	14:10	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	05/02/2021	14:20	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	05/02/2021	14:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	05/02/2021	14:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	05/02/2021	12:10	0.0008	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	05/02/2021	12:15	0.0006	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	05/02/2021	12:35	0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	05/02/2021	12:46	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	05/02/2021	13:35	0.0006	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	05/02/2021	13:45	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	05/02/2021	14:25	0.0006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	05/02/2021	14:10	0.0012	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	05/02/2021	14:20	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	05/02/2021	14:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	05/02/2021	14:05	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	05/02/2021	14:25	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	05/02/2021	14:10	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	05/02/2021	14:20	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6728	Selenium - Dissolved	05/02/2021	14:15	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	05/02/2021	14:05	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	05/02/2021	12:10	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	05/02/2021	12:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	05/02/2021	12:35	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	05/02/2021	12:46	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	05/02/2021	13:35	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	05/02/2021	13:45	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	05/02/2021	12:10	Complete		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	05/02/2021	12:15	Complete		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	05/02/2021	12:35	Complete		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	05/02/2021	12:46	Complete		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	05/02/2021	13:35	Complete		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	05/02/2021	13:45	Complete		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	05/02/2021	12:10	6	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	05/02/2021	12:15	7.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	05/02/2021	12:35	5.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	05/02/2021	12:46	6	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	05/02/2021	13:35	7.5	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	05/02/2021	13:45	6.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	05/02/2021	12:10	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	05/02/2021	12:15	0.48	g/m³	(.2 - 5)

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	05/02/2021	12:35	0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	05/02/2021	12:46	0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	05/02/2021	13:35	0.52	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	05/02/2021	13:45	0.4	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	05/02/2021	12:10	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	05/02/2021	12:15	0.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	05/02/2021	12:35	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	05/02/2021	12:46	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	05/02/2021	13:35	0.7	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	05/02/2021	13:45	0.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	05/02/2021	12:10	Complete		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	05/02/2021	14:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	05/02/2021	14:25	Complete		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	05/02/2021	12:10	Complete		
	Waikouaiti SS - 192 Main Rd - Preflush	O1420	Sampler Observation	05/02/2021	12:10	Complete		
	Waikouaiti SS - 192 Main Rd	O1420	Sampler Observation	05/02/2021	12:15	0.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	O1420	Sampler Observation	05/02/2021	12:35	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	O1420	Sampler Observation	05/02/2021	12:46	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	O1420	Sampler Observation	05/02/2021	13:35	0.7	g/m³	
	Karitane SS - 99 Stornoway St	O1420	Sampler Observation	05/02/2021	13:45	0.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	05/02/2021	14:25	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	05/02/2021	14:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	05/02/2021	12:10	Complete		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	05/02/2021	12:15	Complete		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	05/02/2021	12:35	Complete		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	05/02/2021	12:46	Complete		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	05/02/2021	13:35	Complete		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	05/02/2021	13:45	Complete		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	05/02/2021	14:25	Complete		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	05/02/2021	14:10	Complete		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	05/02/2021	14:20	Complete		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	05/02/2021	14:15	Complete		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	05/02/2021	14:05	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	06/02/2021	09:30	64	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	06/02/2021	09:40	62	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	06/02/2021	09:10	60	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	06/02/2021	09:20	60	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	06/02/2021	08:45	64	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	06/02/2021	08:55	63	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	06/02/2021	09:30	17.5	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	06/02/2021	09:40	17.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	06/02/2021	09:10	16.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	06/02/2021	09:20	16.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	06/02/2021	08:45	17.6	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	06/02/2021	08:55	17.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	06/02/2021	09:30	15.7	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	06/02/2021	09:40	15.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	06/02/2021	09:10	15.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	06/02/2021	09:20	15.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	06/02/2021	08:45	15.9	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	06/02/2021	08:55	15.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	06/02/2021	09:30	41.4	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	06/02/2021	09:40	41.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	06/02/2021	09:10	41.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	06/02/2021	09:20	41.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	06/02/2021	08:45	41.3	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	06/02/2021	08:55	41.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	06/02/2021	09:30	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	06/02/2021	09:30	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	06/02/2021	09:40	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	06/02/2021	09:10	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	06/02/2021	09:20	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	06/02/2021	08:45	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	06/02/2021	08:55	0.015	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	06/02/2021	09:30	0.009	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	06/02/2021	08:24	0.011	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	06/02/2021	09:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	06/02/2021	08:24	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	06/02/2021	09:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	06/02/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	06/02/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	06/02/2021	09:20	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	06/02/2021	08:45	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	06/02/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	06/02/2021	09:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	06/02/2021	08:24	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	06/02/2021	09:30	21	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	06/02/2021	09:40	21	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	06/02/2021	09:10	22.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	06/02/2021	09:20	22.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	06/02/2021	08:45	22.3	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	06/02/2021	08:55	22.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	06/02/2021	08:24	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	06/02/2021	09:30	0.0018	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	06/02/2021	09:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	06/02/2021	09:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	06/02/2021	09:20	<0.0005	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	06/02/2021	08:45	<0.0005	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	06/02/2021	08:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	06/02/2021	08:24	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	06/02/2021	09:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	06/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	06/02/2021	09:10	0.15	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	06/02/2021	09:20	0.06	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	06/02/2021	08:45	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	06/02/2021	08:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	06/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	06/02/2021	09:10	0.0009	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	06/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	06/02/2021	08:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	06/02/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	06/02/2021	08:24	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	06/02/2021	09:30	14.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	06/02/2021	09:40	14.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	06/02/2021	09:10	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	06/02/2021	09:20	12.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	06/02/2021	08:45	13.5	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	06/02/2021	08:55	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	06/02/2021	09:30	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	06/02/2021	09:40	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	06/02/2021	09:10	0.0031	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	06/02/2021	09:20	0.0015	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	06/02/2021	08:45	0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	06/02/2021	08:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	06/02/2021	08:24	<0.0005	g/m³	(.002 - .002)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	06/02/2021	09:30	0.0082	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	06/02/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	06/02/2021	09:10	0.0897	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	06/02/2021	09:20	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	06/02/2021	08:45	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	06/02/2021	08:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	06/02/2021	09:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	06/02/2021	08:24	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	06/02/2021	09:30	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	06/02/2021	08:24	<0.002	g/m³	(.01 - .01)

	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	06/02/2021	09:30	0.008	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	06/02/2021	09:40	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	06/02/2021	09:10	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	06/02/2021	09:20	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	06/02/2021	08:45	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	06/02/2021	08:55	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	06/02/2021	08:15	0.018	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	06/02/2021	08:25	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	06/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	06/02/2021	08:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	06/02/2021	08:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	06/02/2021	08:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	06/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	06/02/2021	08:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	06/02/2021	08:15	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	06/02/2021	08:25	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	06/02/2021	08:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	06/02/2021	08:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	06/02/2021	08:15	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	06/02/2021	08:25	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	06/02/2021	09:30	0.015	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	06/02/2021	09:40	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	06/02/2021	09:10	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	06/02/2021	09:20	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	06/02/2021	08:45	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	06/02/2021	08:55	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	06/02/2021	08:15	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	06/02/2021	08:25	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	06/02/2021	09:30	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	06/02/2021	08:24	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	06/02/2021	08:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	06/02/2021	09:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	06/02/2021	08:24	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	06/02/2021	09:30	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	06/02/2021	09:40	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	06/02/2021	09:10	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	06/02/2021	09:20	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	06/02/2021	08:45	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	06/02/2021	08:55	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	06/02/2021	08:15	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	06/02/2021	08:25	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	06/02/2021	09:30	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	06/02/2021	08:24	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	06/02/2021	09:30	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	06/02/2021	09:40	21.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	06/02/2021	09:10	22.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	06/02/2021	09:20	22.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	06/02/2021	08:45	22.5	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	06/02/2021	08:55	22.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	06/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	06/02/2021	08:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	06/02/2021	09:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	06/02/2021	08:24	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	06/02/2021	09:30	0.0021	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	06/02/2021	09:40	0.0011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	06/02/2021	09:10	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	06/02/2021	09:20	0.0006	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	06/02/2021	08:45	0.0013	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	06/02/2021	08:55	0.0011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	06/02/2021	08:15	0.0009	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	06/02/2021	08:25	0.0023	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	06/02/2021	09:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	06/02/2021	08:24	0.0008	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	06/02/2021	09:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	06/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	06/02/2021	09:10	0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	06/02/2021	09:20	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	06/02/2021	08:45	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	06/02/2021	08:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	06/02/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	06/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	06/02/2021	09:10	0.011	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	06/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	06/02/2021	08:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	06/02/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	06/02/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	06/02/2021	08:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	06/02/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	06/02/2021	08:24	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	06/02/2021	09:30	14.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	06/02/2021	09:40	15	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	06/02/2021	09:10	12.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	06/02/2021	09:20	12.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	06/02/2021	08:45	14.1	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	06/02/2021	08:55	14.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	06/02/2021	09:30	0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	06/02/2021	09:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	06/02/2021	09:10	0.0014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	06/02/2021	09:20	0.0013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	06/02/2021	08:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	06/02/2021	08:55	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	06/02/2021	08:15	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	06/02/2021	08:25	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	06/02/2021	09:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	06/02/2021	08:24	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	06/02/2021	09:30	0.0008	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	06/02/2021	09:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	06/02/2021	09:10	0.0043	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	06/02/2021	09:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	06/02/2021	08:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	06/02/2021	08:55	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	06/02/2021	08:15	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	06/02/2021	08:25	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	06/02/2021	09:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	06/02/2021	08:24	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	06/02/2021	08:15	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	06/02/2021	08:25	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	06/02/2021	09:30	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	06/02/2021	08:24	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	06/02/2021	09:30	0.009	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	06/02/2021	09:40	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	06/02/2021	09:10	0.256	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	06/02/2021	09:20	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	06/02/2021	08:45	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	06/02/2021	08:55	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	06/02/2021	09:30	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	06/02/2021	09:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	06/02/2021	09:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	06/02/2021	09:20	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	06/02/2021	08:45	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	06/02/2021	08:55	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	06/02/2021	09:30	7.6		
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	06/02/2021	09:40	7.7		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	06/02/2021	09:10	7.9		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	06/02/2021	09:20	7.9		

	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	06/02/2021	08:45	7.9		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	06/02/2021	08:55	7.9		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	06/02/2021	09:30	6.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	06/02/2021	09:40	6.3	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	06/02/2021	09:10	5.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	06/02/2021	09:20	5.9	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	06/02/2021	08:45	7.4	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	06/02/2021	08:55	8.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	06/02/2021	09:30	0.72	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	06/02/2021	09:40	0.69	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	06/02/2021	09:10	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	06/02/2021	09:20	<0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	06/02/2021	08:45	0.55	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	06/02/2021	08:55	0.62	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	06/02/2021	09:30	0.9	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	06/02/2021	09:40	0.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	06/02/2021	09:10	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	06/02/2021	09:20	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	06/02/2021	08:45	0.7	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	06/02/2021	08:55	0.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	06/02/2021	09:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	06/02/2021	08:15	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	06/02/2021	08:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	06/02/2021	09:30	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	06/02/2021	00:00:00	No	water, Tube settler dry	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	06/02/2021	08:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	06/02/2021	08:25	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	06/02/2021	09:30	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	06/02/2021	09:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	06/02/2021	09:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	06/02/2021	09:20	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	06/02/2021	08:45	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	06/02/2021	08:55	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	06/02/2021	08:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	06/02/2021	08:25	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	06/02/2021	09:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	06/02/2021	08:24	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	07/02/2021	13:05	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	07/02/2021	13:10	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	07/02/2021	13:30	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	07/02/2021	13:35	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	07/02/2021	12:45	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	07/02/2021	12:50	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	07/02/2021	13:05	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	07/02/2021	13:10	64	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	07/02/2021	13:30	63	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	07/02/2021	13:35	63	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	07/02/2021	12:45	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	07/02/2021	12:50	63	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	07/02/2021	13:05	18	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	07/02/2021	13:10	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	07/02/2021	13:30	16.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	07/02/2021	13:35	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	07/02/2021	12:45	17.9	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	07/02/2021	12:50	18	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	07/02/2021	13:05	15.7	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	07/02/2021	13:10	15.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	07/02/2021	13:30	15.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	07/02/2021	13:35	15.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	07/02/2021	12:45	16.2	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	07/02/2021	12:50	16.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	07/02/2021	13:05	41.1	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	07/02/2021	13:10	41.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	07/02/2021	13:30	41.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	07/02/2021	13:35	41.4	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	07/02/2021	12:45	41.7	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	07/02/2021	12:50	41.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	07/02/2021	13:05	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	07/02/2021	13:05	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	07/02/2021	13:10	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	07/02/2021	13:30	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	07/02/2021	13:35	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	07/02/2021	12:45	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	07/02/2021	12:50	0.015	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	07/02/2021	12:15	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	07/02/2021	12:10	0.008	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	07/02/2021	12:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	07/02/2021	12:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	07/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	07/02/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	07/02/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	07/02/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	07/02/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	07/02/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	07/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	07/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	07/02/2021	13:05	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	07/02/2021	13:10	21.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	07/02/2021	13:30	22.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	07/02/2021	13:35	22	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	07/02/2021	12:45	22.6	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	07/02/2021	12:50	22.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	07/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	07/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	07/02/2021	13:05	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	07/02/2021	13:10	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	07/02/2021	13:30	0.0201	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	07/02/2021	13:35	0.0136	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	07/02/2021	12:45	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	07/02/2021	12:50	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	07/02/2021	12:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	07/02/2021	12:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	07/02/2021	13:05	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	07/02/2021	13:10	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	07/02/2021	13:30	0.04	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	07/02/2021	13:35	0.03	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	07/02/2021	12:45	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	07/02/2021	12:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	07/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	07/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	07/02/2021	13:30	0.0011	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	07/02/2021	13:35	0.0011	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	07/02/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	07/02/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	07/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	07/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	07/02/2021	13:05	14.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	07/02/2021	13:10	14.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	07/02/2021	13:30	13.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	07/02/2021	13:35	12.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	07/02/2021	12:45	13.9	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	07/02/2021	12:50	14.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	07/02/2021	13:05	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	07/02/2021	13:10	0.0016	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	07/02/2021	13:30	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	07/02/2021	13:35	0.0009	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	07/02/2021	12:45	0.0006	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	07/02/2021	12:50	0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	07/02/2021	12:15	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	07/02/2021	12:10	<0.0005	g/m³	(.002 - .002)

	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	07/02/2021	13:05	<0.0005	g/m³	(.02 - .02)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	07/02/2021	13:10	<0.0005	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	07/02/2021	13:30	0.0006	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	07/02/2021	13:35	<0.0005	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	07/02/2021	12:45	<0.0005	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	07/02/2021	12:50	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	07/02/2021	12:15	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	07/02/2021	12:10	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	07/02/2021	12:15	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	07/02/2021	12:10	<0.002	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	07/02/2021	13:05	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	07/02/2021	13:10	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	07/02/2021	13:30	0.043	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	07/02/2021	13:35	0.038	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	07/02/2021	12:45	0.004	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	07/02/2021	12:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	07/02/2021	12:30	0.011	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	07/02/2021	12:25	0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	07/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	07/02/2021	12:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	07/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	07/02/2021	12:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	07/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	07/02/2021	12:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	07/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	07/02/2021	12:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	07/02/2021	12:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	07/02/2021	12:25	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	07/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	07/02/2021	12:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	07/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	07/02/2021	12:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	07/02/2021	12:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	07/02/2021	12:25	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	07/02/2021	13:05	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	07/02/2021	13:10	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	07/02/2021	13:30	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	07/02/2021	13:35	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	07/02/2021	12:45	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	07/02/2021	12:50	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	07/02/2021	12:30	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	07/02/2021	12:25	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	07/02/2021	12:15	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	07/02/2021	12:10	0.008	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	07/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	07/02/2021	12:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	07/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	07/02/2021	12:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	07/02/2021	13:05	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	07/02/2021	13:10	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	07/02/2021	13:30	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	07/02/2021	13:35	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	07/02/2021	12:45	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	07/02/2021	12:50	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	07/02/2021	12:30	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	07/02/2021	12:25	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	07/02/2021	12:15	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	07/02/2021	12:10	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	07/02/2021	13:05	22.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	07/02/2021	13:10	22.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	07/02/2021	13:30	22.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	07/02/2021	13:35	22.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	07/02/2021	12:45	23.3	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	07/02/2021	12:50	23.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	07/02/2021	12:30	<0.001	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	07/02/2021	12:25	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	07/02/2021	12:15	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	07/02/2021	12:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	07/02/2021	13:05	0.0012	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	07/02/2021	13:10	0.0009	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	07/02/2021	13:30	0.0164	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	07/02/2021	13:35	0.0132	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	07/02/2021	12:45	0.0007	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	07/02/2021	12:50	0.0006	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	07/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	07/02/2021	12:25	0.0024	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	07/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	07/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	07/02/2021	13:05	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	07/02/2021	13:10	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	07/02/2021	13:30	0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	07/02/2021	13:35	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	07/02/2021	12:45	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	07/02/2021	12:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	07/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	07/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	07/02/2021	13:30	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	07/02/2021	13:35	0.0006	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	07/02/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	07/02/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	07/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	07/02/2021	12:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	07/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	07/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	07/02/2021	13:05	14.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	07/02/2021	13:10	15.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	07/02/2021	13:30	13.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	07/02/2021	13:35	13.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	07/02/2021	12:45	14.4	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	07/02/2021	12:50	14.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	07/02/2021	13:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	07/02/2021	13:10	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	07/02/2021	13:30	0.0008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	07/02/2021	13:35	0.0009	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	07/02/2021	12:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	07/02/2021	12:50	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	07/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	07/02/2021	12:25	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	07/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	07/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	07/02/2021	13:05	0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	07/02/2021	13:10	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	07/02/2021	13:30	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	07/02/2021	13:35	0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	07/02/2021	12:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	07/02/2021	12:50	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	07/02/2021	12:30	0.0008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	07/02/2021	12:25	0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	07/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	07/02/2021	12:10	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	07/02/2021	12:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	07/02/2021	12:25	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	07/02/2021	12:15	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	07/02/2021	12:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	07/02/2021	13:05	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	07/02/2021	13:10	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	07/02/2021	13:30	0.042	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	07/02/2021	13:35	0.04	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	07/02/2021	12:45	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	07/02/2021	12:50	<0.002	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	07/02/2021	13:05	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	07/02/2021	13:10	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	07/02/2021	13:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	07/02/2021	13:35	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	07/02/2021	12:45	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	07/02/2021	12:50	Completed		
No Water	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	07/02/2021	12:20	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	07/02/2021	13:05	6.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	07/02/2021	13:10	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	07/02/2021	13:30	5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	07/02/2021	13:35	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	07/02/2021	12:45	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	07/02/2021	12:50	6.7	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	07/02/2021	13:05	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	07/02/2021	13:10	0.73	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	07/02/2021	13:30	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	07/02/2021	13:35	<0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	07/02/2021	12:45	<0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	07/02/2021	12:50	0.66	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	07/02/2021	13:05	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	07/02/2021	13:10	0.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	07/02/2021	13:30	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	07/02/2021	13:35	<0.05	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	07/02/2021	12:45	<0.05	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	07/02/2021	12:50	0.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	07/02/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	07/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	07/02/2021	12:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	07/02/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	07/02/2021	12:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	07/02/2021	12:25	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	07/02/2021	13:05	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	07/02/2021	13:10	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	07/02/2021	13:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	07/02/2021	13:35	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	07/02/2021	12:45	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	07/02/2021	12:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	07/02/2021	12:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	07/02/2021	12:25	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	07/02/2021	12:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	07/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	08/02/2021	10:35	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	08/02/2021	10:40	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	08/02/2021	10:50	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	08/02/2021	10:55	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	08/02/2021	10:20	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	08/02/2021	10:25	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	08/02/2021	10:35	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	08/02/2021	10:40	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	08/02/2021	10:50	64	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	08/02/2021	10:55	64	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	08/02/2021	10:20	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	08/02/2021	10:25	66	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	08/02/2021	10:35	17.9	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	08/02/2021	10:40	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	08/02/2021	10:50	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	08/02/2021	10:55	18	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	08/02/2021	10:20	18.1	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	08/02/2021	10:25	18.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	08/02/2021	10:35	16	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	08/02/2021	10:40	16	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	08/02/2021	10:50	16.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	08/02/2021	10:55	16.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	08/02/2021	10:20	16.1	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	08/02/2021	10:25	16.1	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	08/02/2021	10:35	40.8	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	08/02/2021	10:40	40.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	08/02/2021	10:50	40.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	08/02/2021	10:55	40.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	08/02/2021	10:20	40.7	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	08/02/2021	10:25	40.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	08/02/2021	10:35	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	08/02/2021	10:35	0.013	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	08/02/2021	10:40	0.013	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	08/02/2021	10:50	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	08/02/2021	10:55	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	08/02/2021	10:20	0.016	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	08/02/2021	10:25	0.015	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	08/02/2021	11:10	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	08/02/2021	11:15	0.009	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	08/02/2021	11:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	08/02/2021	11:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	08/02/2021	10:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	08/02/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	08/02/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	08/02/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	08/02/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	08/02/2021	10:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	08/02/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	08/02/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	08/02/2021	10:35	22.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	08/02/2021	10:40	21.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	08/02/2021	10:50	22	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	08/02/2021	10:55	22.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	08/02/2021	10:20	22.7	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	08/02/2021	10:25	22.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	08/02/2021	11:10	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	08/02/2021	11:15	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	08/02/2021	10:35	0.0014	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	08/02/2021	10:40	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	08/02/2021	10:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	08/02/2021	10:55	<0.0005	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	08/02/2021	10:20	0.0006	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	08/02/2021	10:25	0.0008	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	08/02/2021	11:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	08/02/2021	11:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	08/02/2021	10:35	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	08/02/2021	10:40	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	08/02/2021	10:50	0.07	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	08/02/2021	10:55	0.06	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	08/02/2021	10:20	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	08/02/2021	10:25	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	08/02/2021	10:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	08/02/2021	10:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	08/02/2021	10:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	08/02/2021	10:55	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	08/02/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	08/02/2021	10:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	08/02/2021	11:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	08/02/2021	11:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	08/02/2021	10:35	14.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	08/02/2021	10:40	14.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	08/02/2021	10:50	14.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	08/02/2021	10:55	14.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	08/02/2021	10:20	14.2	g/m³		
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	08/02/2021	10:25	14.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	08/02/2021	10:35	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	08/02/2021	10:40	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	08/02/2021	10:50	0.0017	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	08/02/2021	10:55	0.0026	g/m³	(.4 - .4)	

	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	08/02/2021	10:20	0.004	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	08/02/2021	10:25	0.004	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	08/02/2021	11:10	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	08/02/2021	11:15	<0.0005	g/m³	(.002 - .002)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	08/02/2021	10:35	0.0007	g/m³	(.02 - .02)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	08/02/2021	10:40	<0.0005	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	08/02/2021	10:50	<0.0005	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	08/02/2021	10:55	<0.0005	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	08/02/2021	10:20	<0.0005	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	08/02/2021	10:25	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	08/02/2021	11:10	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	08/02/2021	11:15	0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	08/02/2021	11:10	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	08/02/2021	11:15	<0.002	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	08/02/2021	10:35	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	08/02/2021	10:40	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	08/02/2021	10:50	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	08/02/2021	10:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	08/02/2021	10:20	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	08/02/2021	10:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	08/02/2021	11:30	0.019	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	08/02/2021	11:20	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	08/02/2021	11:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	08/02/2021	11:20	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	08/02/2021	11:20	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	08/02/2021	11:20	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	08/02/2021	11:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	08/02/2021	11:20	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	08/02/2021	11:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	08/02/2021	11:20	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	08/02/2021	11:20	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	08/02/2021	11:20	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	08/02/2021	11:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	08/02/2021	11:20	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	08/02/2021	10:35	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	08/02/2021	10:40	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	08/02/2021	10:50	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	08/02/2021	10:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	08/02/2021	10:20	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	08/02/2021	10:25	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	08/02/2021	11:30	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	08/02/2021	11:20	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	08/02/2021	11:10	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	08/02/2021	11:15	0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	08/02/2021	11:20	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	08/02/2021	11:10	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	08/02/2021	11:15	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	08/02/2021	10:35	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	08/02/2021	10:40	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	08/02/2021	10:50	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	08/02/2021	10:55	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	08/02/2021	10:20	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	08/02/2021	10:25	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	08/02/2021	11:30	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	08/02/2021	11:20	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	08/02/2021	11:10	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	08/02/2021	11:15	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	08/02/2021	10:35	23.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	08/02/2021	10:40	23.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	08/02/2021	10:50	22.9	g/m³	

	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	08/02/2021	10:55	22.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	08/02/2021	10:20	23.1	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	08/02/2021	10:25	23.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	08/02/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	08/02/2021	11:20	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	08/02/2021	11:10	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	08/02/2021	11:15	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	08/02/2021	10:35	0.0017	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	08/02/2021	10:40	0.0021	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	08/02/2021	10:50	0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	08/02/2021	10:55	0.0008	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	08/02/2021	10:20	0.0013	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	08/02/2021	10:25	0.0014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	08/02/2021	11:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	08/02/2021	11:20	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	08/02/2021	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	08/02/2021	11:15	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	08/02/2021	10:35	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	08/02/2021	10:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	08/02/2021	10:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	08/02/2021	10:55	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	08/02/2021	10:20	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	08/02/2021	10:25	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	08/02/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	08/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	08/02/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	08/02/2021	10:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	08/02/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	08/02/2021	10:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	08/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	08/02/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	08/02/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	08/02/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	08/02/2021	10:35	15.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	08/02/2021	10:40	15.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	08/02/2021	10:50	15.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	08/02/2021	10:55	14.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	08/02/2021	10:20	14.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	08/02/2021	10:25	14.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	08/02/2021	10:35	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	08/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	08/02/2021	10:50	0.0008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	08/02/2021	10:55	0.0006	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	08/02/2021	10:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	08/02/2021	10:25	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	08/02/2021	11:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	08/02/2021	11:20	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	08/02/2021	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	08/02/2021	11:15	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	08/02/2021	10:35	0.0006	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	08/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	08/02/2021	10:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	08/02/2021	10:55	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	08/02/2021	10:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	08/02/2021	10:25	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	08/02/2021	11:30	0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	08/02/2021	11:20	0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	08/02/2021	11:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	08/02/2021	11:15	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	08/02/2021	11:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	08/02/2021	11:20	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	08/02/2021	11:10	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	08/02/2021	11:15	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	08/02/2021	10:35	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	08/02/2021	10:40	0.002	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	08/02/2021	10:50	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	08/02/2021	10:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	08/02/2021	10:20	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	08/02/2021	10:25	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	08/02/2021	10:35	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	08/02/2021	10:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	08/02/2021	10:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	08/02/2021	10:55	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	08/02/2021	10:20	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	08/02/2021	10:25	Completed		
No Water	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	08/02/2021	11:10	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:35	7.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:40	6.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:50	5.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:55	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:20	6.6	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	08/02/2021	10:25	6.7	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	08/02/2021	10:35	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	08/02/2021	10:40	0.68	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	08/02/2021	10:50	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	08/02/2021	10:55	0.07	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	08/02/2021	10:20	<0.05	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	08/02/2021	10:25	0.79	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	08/02/2021	10:35	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	08/02/2021	10:40	1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	08/02/2021	10:50	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	08/02/2021	10:55	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	08/02/2021	10:20	<0.05	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	08/02/2021	10:25	0.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	08/02/2021	10:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	08/02/2021	11:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	08/02/2021	11:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	08/02/2021	10:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/02/2021	11:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/02/2021	11:20	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	08/02/2021	10:35	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	08/02/2021	10:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	08/02/2021	10:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	08/02/2021	10:55	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	08/02/2021	10:20	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	08/02/2021	10:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	08/02/2021	11:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	08/02/2021	11:20	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	08/02/2021	11:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	08/02/2021	11:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	09/02/2021	11:00	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	09/02/2021	11:05	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	09/02/2021	11:25	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	09/02/2021	11:30	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	09/02/2021	10:40	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	09/02/2021	10:45	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	09/02/2021	11:00	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	09/02/2021	11:05	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	09/02/2021	11:25	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	09/02/2021	11:30	67	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	09/02/2021	10:40	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	09/02/2021	10:45	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	09/02/2021	11:00	18.3	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	09/02/2021	11:05	18.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	09/02/2021	11:25	18.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	09/02/2021	11:30	18.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	09/02/2021	10:40	18.3	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	09/02/2021	10:45	18.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	09/02/2021	11:00	16.1	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	09/02/2021	11:05	16.1	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	09/02/2021	11:25	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	09/02/2021	11:30	16.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	09/02/2021	10:40	16.3	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	09/02/2021	10:45	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	09/02/2021	11:00	40.2	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	09/02/2021	11:05	40	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	09/02/2021	11:25	40.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	09/02/2021	11:30	40.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	09/02/2021	10:40	40.2	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	09/02/2021	10:45	40.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	09/02/2021	11:00	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	09/02/2021	11:00	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	09/02/2021	11:05	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	09/02/2021	11:25	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	09/02/2021	11:30	0.015	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	09/02/2021	10:40	0.019	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	09/02/2021	10:45	0.015	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	09/02/2021	10:05	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	09/02/2021	10:10	0.009	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	09/02/2021	10:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	09/02/2021	10:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	09/02/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	09/02/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	09/02/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	09/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	09/02/2021	10:40	0.0003	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	09/02/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	09/02/2021	10:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	09/02/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	09/02/2021	11:00	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	09/02/2021	11:05	21.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	09/02/2021	11:25	22.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	09/02/2021	11:30	23.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	09/02/2021	10:40	22.7	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	09/02/2021	10:45	22.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	09/02/2021	10:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	09/02/2021	10:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	09/02/2021	11:00	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	09/02/2021	11:05	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	09/02/2021	11:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	09/02/2021	11:30	<0.0005	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	09/02/2021	10:40	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	09/02/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	09/02/2021	10:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	09/02/2021	10:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	09/02/2021	11:00	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	09/02/2021	11:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	09/02/2021	11:25	0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	09/02/2021	11:30	0.08	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	09/02/2021	10:40	0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	09/02/2021	10:45	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	09/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	09/02/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	09/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	09/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	09/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	09/02/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	09/02/2021	10:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	09/02/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	09/02/2021	11:00	14.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	09/02/2021	11:05	14.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	09/02/2021	11:25	13.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	09/02/2021	11:30	13.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	09/02/2021	10:40	13.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	09/02/2021	10:45	14.2	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	09/02/2021	11:00	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	09/02/2021	11:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	09/02/2021	11:25	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	09/02/2021	11:30	0.0015	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	09/02/2021	10:40	0.0006	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	09/02/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	09/02/2021	10:05	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	09/02/2021	10:10	<0.0005	g/m³	(.002 - .002)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	09/02/2021	11:00	0.003	g/m³	(.02 - .02)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	09/02/2021	11:05	<0.0005	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	09/02/2021	11:25	0.0007	g/m³	(.02 - .02)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	09/02/2021	11:30	<0.0005	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	09/02/2021	10:40	0.0006	g/m³	(.02 - .02)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	09/02/2021	10:45	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	09/02/2021	10:05	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	09/02/2021	10:10	<0.0005	g/m³	(.02 - .02)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	09/02/2021	10:05	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	09/02/2021	10:10	<0.002	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	09/02/2021	11:00	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	09/02/2021	11:05	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	09/02/2021	11:25	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	09/02/2021	11:30	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	09/02/2021	10:40	0.011	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	09/02/2021	10:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	09/02/2021	10:20	0.015	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	09/02/2021	10:15	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	09/02/2021	10:20	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	09/02/2021	10:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	09/02/2021	10:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	09/02/2021	10:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	09/02/2021	10:20	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	09/02/2021	10:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	09/02/2021	10:20	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	09/02/2021	10:15	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	09/02/2021	10:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	09/02/2021	10:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	09/02/2021	10:20	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	09/02/2021	10:15	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	09/02/2021	11:00	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	09/02/2021	11:05	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	09/02/2021	11:25	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	09/02/2021	11:30	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	09/02/2021	10:40	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	09/02/2021	10:45	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	09/02/2021	10:20	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	09/02/2021	10:15	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	09/02/2021	10:05	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	09/02/2021	10:10	0.009	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	09/02/2021	10:15	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	09/02/2021	10:05	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	09/02/2021	10:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	09/02/2021	11:00	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	09/02/2021	11:05	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	09/02/2021	11:25	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	09/02/2021	11:30	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	09/02/2021	10:40	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	09/02/2021	10:45	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	09/02/2021	10:20	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	09/02/2021	10:15	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	09/02/2021	10:05	<0.0002	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	09/02/2021	10:10	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	09/02/2021	11:00	22.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	09/02/2021	11:05	22.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	09/02/2021	11:25	23.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	09/02/2021	11:30	23.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	09/02/2021	10:40	23.3	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	09/02/2021	10:45	23.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	09/02/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	09/02/2021	10:15	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	09/02/2021	10:05	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	09/02/2021	10:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	09/02/2021	11:00	0.0008	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	09/02/2021	11:05	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	09/02/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	09/02/2021	11:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	09/02/2021	10:40	0.0009	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	09/02/2021	10:45	0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	09/02/2021	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	09/02/2021	10:15	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	09/02/2021	10:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	09/02/2021	10:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	09/02/2021	11:00	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	09/02/2021	11:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	09/02/2021	11:25	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	09/02/2021	11:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	09/02/2021	10:40	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	09/02/2021	10:45	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	09/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	09/02/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	09/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	09/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	09/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	09/02/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	09/02/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	09/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	09/02/2021	10:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	09/02/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	09/02/2021	11:00	14.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	09/02/2021	11:05	15	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	09/02/2021	11:25	14.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	09/02/2021	11:30	14.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	09/02/2021	10:40	14.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	09/02/2021	10:45	14.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	09/02/2021	11:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	09/02/2021	11:05	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	09/02/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	09/02/2021	11:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	09/02/2021	10:40	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	09/02/2021	10:45	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	09/02/2021	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	09/02/2021	10:15	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	09/02/2021	10:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	09/02/2021	10:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	09/02/2021	11:00	0.0006	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	09/02/2021	11:05	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	09/02/2021	11:25	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	09/02/2021	11:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	09/02/2021	10:40	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	09/02/2021	10:45	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	09/02/2021	10:20	0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	09/02/2021	10:15	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	09/02/2021	10:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	09/02/2021	10:10	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	09/02/2021	10:20	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	09/02/2021	10:15	<0.005	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	09/02/2021	10:05	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	09/02/2021	10:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	09/02/2021	11:00	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	09/02/2021	11:05	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	09/02/2021	11:25	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	09/02/2021	11:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	09/02/2021	10:40	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	09/02/2021	10:45	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	09/02/2021	11:00	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	09/02/2021	11:05	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	09/02/2021	11:25	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	09/02/2021	11:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	09/02/2021	10:40	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	09/02/2021	10:45	Completed		
No Water	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	09/02/2021	10:05	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	09/02/2021	11:00	6	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	09/02/2021	11:05	6.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	09/02/2021	11:25	5.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	09/02/2021	11:30	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	09/02/2021	10:40	5.8	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	09/02/2021	10:45	6.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	09/02/2021	11:00	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	09/02/2021	11:05	0.77	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	09/02/2021	11:25	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	09/02/2021	11:30	<0.05	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	09/02/2021	10:40	0.07	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	09/02/2021	10:45	0.73	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	09/02/2021	11:00	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	09/02/2021	11:05	1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	09/02/2021	11:25	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	09/02/2021	11:30	<0.05	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	09/02/2021	10:40	0.1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	09/02/2021	10:45	0.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	09/02/2021	11:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	09/02/2021	10:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	09/02/2021	10:20	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	09/02/2021	11:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	09/02/2021	10:20	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	09/02/2021	10:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	09/02/2021	11:00	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	09/02/2021	11:05	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	09/02/2021	11:25	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	09/02/2021	11:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	09/02/2021	10:40	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	09/02/2021	10:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	09/02/2021	10:20	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	09/02/2021	10:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	09/02/2021	10:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	09/02/2021	10:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	10/02/2021	11:25	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	10/02/2021	11:35	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	10/02/2021	11:03	8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	10/02/2021	11:11	8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	10/02/2021	11:48	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	10/02/2021	11:57	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	10/02/2021	11:25	66	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	10/02/2021	11:35	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	10/02/2021	11:03	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	10/02/2021	11:11	67	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	10/02/2021	11:48	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	10/02/2021	11:57	66	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	10/02/2021	11:25	18.5	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	10/02/2021	11:35	18.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	10/02/2021	11:03	18.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	10/02/2021	11:11	18.2	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	10/02/2021	11:48	18.6	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	10/02/2021	11:57	18.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	10/02/2021	11:25	16.5	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	10/02/2021	11:35	16.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	10/02/2021	11:03	16.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	10/02/2021	11:11	16.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	10/02/2021	11:48	16.1	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	10/02/2021	11:57	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	10/02/2021	11:25	39.6	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	10/02/2021	11:35	39.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	10/02/2021	11:03	40.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	10/02/2021	11:11	40.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	10/02/2021	11:48	40	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	10/02/2021	11:57	39.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	10/02/2021	11:25	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	10/02/2021	11:25	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	10/02/2021	11:35	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	10/02/2021	11:03	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	10/02/2021	11:11	0.014	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	10/02/2021	11:48	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	10/02/2021	11:57	0.012	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	10/02/2021	12:20	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	10/02/2021	12:15	0.007	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	10/02/2021	12:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	10/02/2021	12:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	10/02/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	10/02/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	10/02/2021	11:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	10/02/2021	11:11	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	10/02/2021	11:48	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	10/02/2021	11:57	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	10/02/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	10/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	10/02/2021	11:25	22.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	10/02/2021	11:35	21.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	10/02/2021	11:03	23.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	10/02/2021	11:11	23.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	10/02/2021	11:48	22.7	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	10/02/2021	11:57	22.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6012	Cobalt - Acid Soluble	10/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6012	Cobalt - Acid Soluble	10/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	10/02/2021	11:25	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	10/02/2021	11:35	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	10/02/2021	11:03	0.0075	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	10/02/2021	11:11	<0.0005	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	10/02/2021	11:48	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	10/02/2021	11:57	0.0011	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	10/02/2021	12:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	10/02/2021	12:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	10/02/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	10/02/2021	11:35	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	10/02/2021	11:03	0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	10/02/2021	11:11	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	10/02/2021	11:48	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	10/02/2021	11:57	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	10/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	10/02/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	10/02/2021	11:03	0.004	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	10/02/2021	11:11	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	10/02/2021	11:48	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	10/02/2021	11:57	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	10/02/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	10/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	10/02/2021	11:25	13	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	10/02/2021	11:35	12.7	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	10/02/2021	11:03	12.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	10/02/2021	11:11	12.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	10/02/2021	11:48	12.4	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	10/02/2021	11:57	12.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	10/02/2021	11:25	0.0023	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	10/02/2021	11:35	0.0025	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	10/02/2021	11:03	0.0029	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	10/02/2021	11:11	0.0009	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	10/02/2021	11:48	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	10/02/2021	11:57	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	10/02/2021	12:20	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	10/02/2021	12:15	<0.0005	g/m³	(.002 - .002)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	10/02/2021	11:25	0.0043	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	10/02/2021	11:35	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	10/02/2021	11:03	0.023	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	10/02/2021	11:11	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	10/02/2021	11:48	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	10/02/2021	11:57	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	10/02/2021	12:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	10/02/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	10/02/2021	12:20	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	10/02/2021	12:15	<0.002	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	10/02/2021	11:25	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	10/02/2021	11:35	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	10/02/2021	11:03	0.175	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	10/02/2021	11:11	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	10/02/2021	11:48	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	10/02/2021	11:57	0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	10/02/2021	12:30	0.014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	10/02/2021	12:17	0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	10/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	10/02/2021	12:17	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	10/02/2021	12:17	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	10/02/2021	12:17	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	10/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	10/02/2021	12:17	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	10/02/2021	12:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	10/02/2021	12:17	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	10/02/2021	12:17	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	10/02/2021	12:17	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	10/02/2021	12:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	10/02/2021	12:17	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	10/02/2021	11:25	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	10/02/2021	11:35	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	10/02/2021	11:03	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	10/02/2021	11:11	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	10/02/2021	11:48	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	10/02/2021	11:57	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	10/02/2021	12:30	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	10/02/2021	12:17	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	10/02/2021	12:20	0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	10/02/2021	12:15	0.006	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	10/02/2021	12:17	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	10/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	10/02/2021	12:15	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	10/02/2021	11:25	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	10/02/2021	11:35	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	10/02/2021	11:03	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	10/02/2021	11:11	<0.0002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	10/02/2021	11:48	<0.0002	g/m³	

	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	10/02/2021	11:57	<0.0002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	10/02/2021	12:30	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	10/02/2021	12:17	<0.0002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	10/02/2021	12:20	<0.0002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	10/02/2021	12:15	<0.0002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	10/02/2021	11:25	23.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	10/02/2021	11:35	23.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	10/02/2021	11:03	24.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	10/02/2021	11:11	25.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	10/02/2021	11:48	24.3	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	10/02/2021	11:57	24.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	10/02/2021	12:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	10/02/2021	12:17	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	10/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	10/02/2021	12:15	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	10/02/2021	11:25	0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	10/02/2021	11:35	0.0012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	10/02/2021	11:03	0.0108	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	10/02/2021	11:11	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	10/02/2021	11:48	0.001	g/m³	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	10/02/2021	11:57	0.0014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	10/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	10/02/2021	12:17	0.0013	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	10/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	10/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	10/02/2021	11:25	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	10/02/2021	11:35	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	10/02/2021	11:03	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	10/02/2021	11:11	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	10/02/2021	11:48	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	10/02/2021	11:57	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	10/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	10/02/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	10/02/2021	11:03	0.009	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	10/02/2021	11:11	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	10/02/2021	11:48	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	10/02/2021	11:57	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	10/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	10/02/2021	12:17	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	10/02/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	10/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	10/02/2021	11:25	14.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	10/02/2021	11:35	14.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	10/02/2021	11:03	13.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	10/02/2021	11:11	13.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	10/02/2021	11:48	13.6	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	10/02/2021	11:57	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	10/02/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	10/02/2021	11:35	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	10/02/2021	11:03	0.0006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	10/02/2021	11:11	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	10/02/2021	11:48	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	10/02/2021	11:57	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	10/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	10/02/2021	12:17	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	10/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	10/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	10/02/2021	11:25	0.0007	g/m³	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	10/02/2021	11:35	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	10/02/2021	11:03	0.0012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	10/02/2021	11:11	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	10/02/2021	11:48	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	10/02/2021	11:57	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	10/02/2021	12:30	0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	10/02/2021	12:17	0.0006	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	10/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	10/02/2021	12:15	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	10/02/2021	12:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	10/02/2021	12:17	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	10/02/2021	12:20	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	10/02/2021	12:15	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	10/02/2021	11:25	0.002	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	10/02/2021	11:35	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	10/02/2021	11:03	0.232	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	10/02/2021	11:11	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	10/02/2021	11:48	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	10/02/2021	11:57	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	10/02/2021	11:25	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	10/02/2021	11:35	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	10/02/2021	11:03	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	10/02/2021	11:11	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	10/02/2021	11:48	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	10/02/2021	11:57	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:25	5.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:35	6.3	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:03	6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:11	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:48	6.5	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	10/02/2021	11:57	7.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	10/02/2021	11:25	0.58	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	10/02/2021	11:35	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	10/02/2021	11:03	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	10/02/2021	11:11	<0.05	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	10/02/2021	11:48	0.86	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	10/02/2021	11:57	0.87	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	10/02/2021	11:25	0.7	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	10/02/2021	11:35	1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	10/02/2021	11:03	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	10/02/2021	11:11	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	10/02/2021	11:48	1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	10/02/2021	11:57	1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	10/02/2021	11:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	10/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	10/02/2021	12:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	10/02/2021	11:25	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	10/02/2021	00:00:00	No	water	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	10/02/2021	12:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	10/02/2021	12:17	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	10/02/2021	11:25	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	10/02/2021	11:35	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	10/02/2021	11:03	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	10/02/2021	11:11	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	10/02/2021	11:48	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	10/02/2021	11:57	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	10/02/2021	12:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	10/02/2021	12:17	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	10/02/2021	12:20	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	10/02/2021	12:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	11/02/2021	13:32	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	11/02/2021	13:45	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	11/02/2021	13:05	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	11/02/2021	13:15	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	11/02/2021	14:00	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	11/02/2021	14:10	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	11/02/2021	13:32	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	11/02/2021	13:45	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	11/02/2021	13:05	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	11/02/2021	13:15	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	11/02/2021	14:00	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	11/02/2021	14:10	67	g CaCO3/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	11/02/2021	13:32	18.5	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	11/02/2021	13:45	18.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	11/02/2021	13:05	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	11/02/2021	13:15	18.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	11/02/2021	14:00	18.7	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	11/02/2021	14:10	18.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	11/02/2021	13:32	16.4	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	11/02/2021	13:45	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	11/02/2021	13:05	16.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	11/02/2021	13:15	16.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	11/02/2021	14:00	16.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	11/02/2021	14:10	16.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	11/02/2021	13:32	39.3	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	11/02/2021	13:45	39.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	11/02/2021	13:05	40.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	11/02/2021	13:15	40.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	11/02/2021	14:00	39.7	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	11/02/2021	14:10	39.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	11/02/2021	13:32	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	11/02/2021	13:32	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	11/02/2021	13:45	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	11/02/2021	13:05	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	11/02/2021	13:15	0.017	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	11/02/2021	14:00	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	11/02/2021	14:10	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	11/02/2021	00:00	0.012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	11/02/2021	14:35	0.011	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	11/02/2021	00:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	11/02/2021	14:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	11/02/2021	13:32	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	11/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	11/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	11/02/2021	13:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	11/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	11/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	11/02/2021	00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	11/02/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	11/02/2021	13:32	24.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	11/02/2021	13:45	23.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	11/02/2021	13:05	24.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	11/02/2021	13:15	23.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	11/02/2021	14:00	24.2	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	11/02/2021	14:10	24.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6011	Chromium - Acid Soluble	11/02/2021	00:00	<0.001	g/m³	(.05 - .05)
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	11/02/2021	14:35	<0.001	g/m³	(.05 - .05)
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	11/02/2021	13:32	0.0022	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	11/02/2021	13:45	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	11/02/2021	13:05	0.0108	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	11/02/2021	13:15	0.0006	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	11/02/2021	14:00	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	11/02/2021	14:10	0.0008	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	11/02/2021	00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	11/02/2021	14:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	11/02/2021	13:32	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	11/02/2021	13:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	11/02/2021	13:05	0.03	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	11/02/2021	13:15	0.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	11/02/2021	14:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	11/02/2021	14:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	11/02/2021	13:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	11/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	11/02/2021	13:05	0.0023	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	11/02/2021	13:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	11/02/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	11/02/2021	14:10	<0.0005	g/m³	(.005 - .01)

	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	11/02/2021	00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	11/02/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	11/02/2021	13:32	14	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	11/02/2021	13:45	13.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	11/02/2021	13:05	13.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	11/02/2021	13:15	13.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	11/02/2021	14:00	13.4	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	11/02/2021	14:10	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	11/02/2021	13:32	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	11/02/2021	13:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	11/02/2021	13:05	0.0016	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	11/02/2021	13:15	0.0033	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	11/02/2021	14:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	11/02/2021	14:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	11/02/2021	00:00	<0.0005	g/m³	(.002 - .002)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	11/02/2021	14:35	<0.0005	g/m³	(.002 - .002)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	11/02/2021	13:32	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	11/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	11/02/2021	13:05	0.0173	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	11/02/2021	13:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	11/02/2021	14:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	11/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	11/02/2021	00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	11/02/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6028	Selenium - Acid Soluble	11/02/2021	00:00	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	11/02/2021	14:35	<0.002	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	11/02/2021	13:32	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	11/02/2021	13:45	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	11/02/2021	13:05	0.28	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	11/02/2021	13:15	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	11/02/2021	14:00	0.004	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	11/02/2021	14:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	11/02/2021	14:45	0.012	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	11/02/2021	14:45	0.009	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	11/02/2021	14:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	11/02/2021	14:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	11/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6611	Chromium - Total	11/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	11/02/2021	14:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	11/02/2021	14:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	11/02/2021	14:45	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	11/02/2021	14:45	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	11/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	11/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	11/02/2021	14:45	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6628	Selenium - Total	11/02/2021	14:45	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	11/02/2021	13:32	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	11/02/2021	13:45	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	11/02/2021	13:05	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	11/02/2021	13:15	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	11/02/2021	14:00	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	11/02/2021	14:10	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	11/02/2021	14:45	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	11/02/2021	14:45	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	11/02/2021	00:00	0.012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	11/02/2021	14:35	0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	11/02/2021	00:00	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	11/02/2021	14:35	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	11/02/2021	13:32	<0.0002	g/m³	(.004 - .004)

	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	11/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	11/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	11/02/2021	13:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	11/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	11/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	11/02/2021	14:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	11/02/2021	14:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	11/02/2021	00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	11/02/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	11/02/2021	13:32	24.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	11/02/2021	13:45	23.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	11/02/2021	13:05	25.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	11/02/2021	13:15	24.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	11/02/2021	14:00	24.6	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	11/02/2021	14:10	24.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6711	Chromium - Dissolved	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6711	Chromium - Dissolved	11/02/2021	14:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6711	Chromium - Dissolved	11/02/2021	00:00	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6711	Chromium - Dissolved	11/02/2021	14:35	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	11/02/2021	13:32	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	11/02/2021	13:45	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	11/02/2021	13:05	0.0287	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	11/02/2021	13:15	0.0006	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	11/02/2021	14:00	0.0023	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	11/02/2021	14:10	0.0015	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	11/02/2021	14:45	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	11/02/2021	14:45	0.0018	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	11/02/2021	00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	11/02/2021	14:35	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	11/02/2021	13:32	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	11/02/2021	13:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	11/02/2021	13:05	0.02	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	11/02/2021	13:15	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	11/02/2021	14:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	11/02/2021	14:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	11/02/2021	13:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	11/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	11/02/2021	13:05	0.0094	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	11/02/2021	13:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	11/02/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	11/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	11/02/2021	14:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	11/02/2021	14:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	11/02/2021	00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	11/02/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	11/02/2021	13:32	14	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	11/02/2021	13:45	13.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	11/02/2021	13:05	13	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	11/02/2021	13:15	13.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	11/02/2021	14:00	13.4	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	11/02/2021	14:10	13.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	11/02/2021	13:32	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	11/02/2021	13:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	11/02/2021	13:05	0.0014	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	11/02/2021	13:15	0.0013	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	11/02/2021	14:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	11/02/2021	14:10	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	11/02/2021	14:45	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	11/02/2021	14:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	11/02/2021	00:00	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	11/02/2021	14:35	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	11/02/2021	13:32	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	11/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	11/02/2021	13:05	0.0015	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	11/02/2021	13:15	<0.0005	g/m³	(.08 - .08)

	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	11/02/2021	14:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	11/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	11/02/2021	14:45	0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	11/02/2021	14:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	11/02/2021	00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	11/02/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6728	Selenium - Dissolved	11/02/2021	14:45	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6728	Selenium - Dissolved	11/02/2021	14:45	<0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6728	Selenium - Dissolved	11/02/2021	00:00	<0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6728	Selenium - Dissolved	11/02/2021	14:35	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	11/02/2021	13:32	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	11/02/2021	13:45	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	11/02/2021	13:05	0.467	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	11/02/2021	13:15	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	11/02/2021	14:00	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	11/02/2021	14:10	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	11/02/2021	13:32	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	11/02/2021	13:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	11/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	11/02/2021	13:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	11/02/2021	14:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	11/02/2021	14:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	11/02/2021	13:32	6.7	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	11/02/2021	13:45	6.8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	11/02/2021	13:05	7.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	11/02/2021	13:15	6.4	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	11/02/2021	14:00	6.3	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	11/02/2021	14:10	6.7	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	11/02/2021	13:32	0.94	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	11/02/2021	13:45	0.94	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	11/02/2021	13:05	0.07	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	11/02/2021	13:15	<0.05	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	11/02/2021	14:00	0.67	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	11/02/2021	14:10	0.94	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	11/02/2021	13:32	1.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	11/02/2021	13:45	1.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	11/02/2021	13:05	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	11/02/2021	13:15	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	11/02/2021	14:00	0.8	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	11/02/2021	14:10	1.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	11/02/2021	13:32	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	11/02/2021	14:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	11/02/2021	14:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	11/02/2021	13:32	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	11/02/2021	14:40	No	water	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	11/02/2021	14:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	11/02/2021	14:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	11/02/2021	13:32	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	11/02/2021	13:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	11/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	11/02/2021	13:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	11/02/2021	14:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	11/02/2021	14:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	11/02/2021	14:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	11/02/2021	14:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	11/02/2021	00:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	11/02/2021	14:35	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	12/02/2021	13:52	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	12/02/2021	14:03	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	12/02/2021	13:27	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	12/02/2021	13:33	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	12/02/2021	14:14	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	12/02/2021	14:22	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	12/02/2021	15:30	8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	12/02/2021	14:47	7.9		(1 - 14)

	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	12/02/2021	14:55	8.1		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	12/02/2021	14:40	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	12/02/2021	15:45	8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	12/02/2021	13:52	<4	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	12/02/2021	14:03	<4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	12/02/2021	13:27	<4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	12/02/2021	13:33	<3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	12/02/2021	14:14	<4	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	12/02/2021	14:22	<3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	12/02/2021	15:30	<4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	12/02/2021	14:47	<4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	12/02/2021	14:55	<3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	12/02/2021	14:40	<4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	12/02/2021	15:45	<3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	12/02/2021	13:52	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	12/02/2021	14:03	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	12/02/2021	13:27	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	12/02/2021	13:33	67	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	12/02/2021	14:14	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	12/02/2021	14:22	66	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	12/02/2021	15:30	63	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	12/02/2021	14:47	66	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	12/02/2021	14:55	63	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	12/02/2021	14:40	65	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	12/02/2021	15:45	64	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	12/02/2021	13:52	17.7	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	12/02/2021	14:03	17.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	12/02/2021	13:27	18.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	12/02/2021	13:33	18.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	12/02/2021	14:14	18.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	12/02/2021	14:22	18	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	12/02/2021	15:30	19.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	12/02/2021	14:47	18.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	12/02/2021	14:55	16.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	12/02/2021	14:40	19.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	12/02/2021	15:45	16.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	12/02/2021	13:52	16.1	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	12/02/2021	14:03	16.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	12/02/2021	13:27	16.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	12/02/2021	13:33	16.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	12/02/2021	14:14	16.2	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	12/02/2021	14:22	16.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	12/02/2021	15:30	12.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	12/02/2021	14:47	12.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	12/02/2021	14:55	13.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	12/02/2021	14:40	16.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	12/02/2021	15:45	12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	12/02/2021	13:52	40.2	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	12/02/2021	14:03	46.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	12/02/2021	13:27	44.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	12/02/2021	13:33	44.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	12/02/2021	14:14	40	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	12/02/2021	14:22	46.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	12/02/2021	15:30	54	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	12/02/2021	14:47	40	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	12/02/2021	14:55	53.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	12/02/2021	14:40	48	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	12/02/2021	15:45	53.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	12/02/2021	13:52	165	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:03	169	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	12/02/2021	13:27	165	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	12/02/2021	13:33	166	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:14	164	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:22	161	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	12/02/2021	15:30	142	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:47	152	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:55	162	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	12/02/2021	14:40	162	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	12/02/2021	15:45	167	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	12/02/2021	13:52	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	12/02/2021	13:52	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	12/02/2021	14:03	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	12/02/2021	13:27	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	12/02/2021	13:33	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	12/02/2021	14:14	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	12/02/2021	14:22	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	12/02/2021	14:55	0.011	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	12/02/2021	14:40	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	12/02/2021	13:52	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	12/02/2021	14:03	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	12/02/2021	13:27	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	12/02/2021	13:33	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	12/02/2021	14:14	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	12/02/2021	14:22	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	12/02/2021	14:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	12/02/2021	14:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	12/02/2021	13:52	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	12/02/2021	14:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	12/02/2021	13:27	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	12/02/2021	13:33	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	12/02/2021	14:14	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	12/02/2021	14:22	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	12/02/2021	14:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	12/02/2021	14:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	12/02/2021	13:52	23.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	12/02/2021	14:03	23.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	12/02/2021	13:27	24.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	12/02/2021	13:33	24.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	12/02/2021	14:14	23.6	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	12/02/2021	14:22	24.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	12/02/2021	14:55	23.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	12/02/2021	14:40	23	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	12/02/2021	13:52	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	12/02/2021	14:03	0.0024	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	12/02/2021	13:27	0.0024	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	12/02/2021	13:33	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	12/02/2021	14:14	0.0019	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	12/02/2021	14:22	0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	12/02/2021	14:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	12/02/2021	14:40	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	12/02/2021	13:52	0.16	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	12/02/2021	14:03	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	12/02/2021	13:27	0.06	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	12/02/2021	13:33	0.08	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	12/02/2021	14:14	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	12/02/2021	14:22	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	12/02/2021	14:55	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	12/02/2021	14:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	12/02/2021	13:52	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	12/02/2021	14:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	12/02/2021	13:27	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	12/02/2021	13:33	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	12/02/2021	14:14	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	12/02/2021	14:22	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	12/02/2021	14:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	12/02/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	12/02/2021	13:52	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	12/02/2021	14:03	13.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	12/02/2021	13:27	12.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	12/02/2021	13:33	12.3	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	12/02/2021	14:14	12	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	12/02/2021	14:22	12.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	12/02/2021	14:55	14	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	12/02/2021	14:40	13.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	12/02/2021	13:52	0.002	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	12/02/2021	14:03	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	12/02/2021	13:27	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	12/02/2021	13:33	0.0011	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	12/02/2021	14:14	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	12/02/2021	14:22	0.0007	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	12/02/2021	14:55	0.0113	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	12/02/2021	14:40	0.0048	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	12/02/2021	13:52	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	12/02/2021	14:03	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	12/02/2021	13:27	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	12/02/2021	13:33	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	12/02/2021	14:14	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	12/02/2021	14:22	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	12/02/2021	14:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	12/02/2021	14:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	12/02/2021	13:52	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	12/02/2021	14:03	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	12/02/2021	13:27	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	12/02/2021	13:33	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	12/02/2021	14:14	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	12/02/2021	14:22	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	12/02/2021	14:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	12/02/2021	14:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	12/02/2021	13:52	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	12/02/2021	14:03	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	12/02/2021	13:27	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	12/02/2021	13:33	0.004	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	12/02/2021	14:14	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	12/02/2021	14:22	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	12/02/2021	14:55	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	12/02/2021	14:40	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	12/02/2021	15:10	154,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	12/02/2021	15:10	25	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	12/02/2021	15:10	0.13	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	12/02/2021	15:10	3,870	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	12/02/2021	15:10	21.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	12/02/2021	15:10	20,900	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	12/02/2021	15:10	8.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	12/02/2021	15:10	1,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	12/02/2021	15:10	1,790	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	12/02/2021	15:10	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	12/02/2021	15:10	12.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	12/02/2021	15:10	121	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	12/02/2021	15:30	0.023	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	12/02/2021	14:47	0.008	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	12/02/2021	15:45	0.024	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	12/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	12/02/2021	14:47	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	12/02/2021	15:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	12/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	12/02/2021	14:47	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	12/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	12/02/2021	15:30	22.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	12/02/2021	14:47	22.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	12/02/2021	15:45	22.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	12/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	12/02/2021	14:47	0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	12/02/2021	15:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	12/02/2021	15:30	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	12/02/2021	14:47	0.2	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	12/02/2021	15:45	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	12/02/2021	15:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	12/02/2021	14:47	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	12/02/2021	15:45	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	12/02/2021	15:30	13.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	12/02/2021	14:47	12.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	12/02/2021	15:45	13.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	12/02/2021	15:30	0.019	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	12/02/2021	14:47	0.013	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	12/02/2021	15:45	0.018	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	12/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	12/02/2021	14:47	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	12/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	12/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	12/02/2021	14:47	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	12/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	12/02/2021	15:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	12/02/2021	14:47	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	12/02/2021	15:45	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	12/02/2021	13:52	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	12/02/2021	14:03	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	12/02/2021	13:27	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	12/02/2021	13:33	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	12/02/2021	14:14	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	12/02/2021	14:22	0.013	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	12/02/2021	15:30	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	12/02/2021	14:47	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	12/02/2021	14:55	0.011	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	12/02/2021	14:40	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	12/02/2021	15:45	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	12/02/2021	13:52	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	12/02/2021	14:03	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	12/02/2021	13:27	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	12/02/2021	13:33	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	12/02/2021	14:14	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	12/02/2021	14:22	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	12/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	12/02/2021	14:47	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	12/02/2021	14:55	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	12/02/2021	14:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	12/02/2021	15:45	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	12/02/2021	13:52	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	12/02/2021	14:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	12/02/2021	13:27	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	12/02/2021	13:33	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	12/02/2021	14:14	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	12/02/2021	14:22	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	12/02/2021	15:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	12/02/2021	14:47	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	12/02/2021	14:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	12/02/2021	14:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	12/02/2021	15:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	12/02/2021	13:52	22.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	12/02/2021	14:03	22.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	12/02/2021	13:27	23.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	12/02/2021	13:33	23.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	12/02/2021	14:14	22.9	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	12/02/2021	14:22	23.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	12/02/2021	15:30	22.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	12/02/2021	14:47	22.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	12/02/2021	14:55	22.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	12/02/2021	14:40	22.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	12/02/2021	15:45	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	12/02/2021	13:52	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	12/02/2021	14:03	0.0023	g/m³	(2 - 2)

	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	12/02/2021	13:27	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	12/02/2021	13:33	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	12/02/2021	14:14	0.0033	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	12/02/2021	14:22	0.0019	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	12/02/2021	15:30	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	12/02/2021	14:47	0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	12/02/2021	14:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	12/02/2021	14:40	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	12/02/2021	15:45	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	12/02/2021	13:52	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	12/02/2021	14:03	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	12/02/2021	13:27	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	12/02/2021	13:33	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	12/02/2021	14:14	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	12/02/2021	14:22	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	12/02/2021	15:30	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	12/02/2021	14:47	0.04	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	12/02/2021	14:55	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	12/02/2021	14:40	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	12/02/2021	15:45	0.08	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	12/02/2021	13:52	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	12/02/2021	14:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	12/02/2021	13:27	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	12/02/2021	13:33	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	12/02/2021	14:14	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	12/02/2021	14:22	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	12/02/2021	15:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	12/02/2021	14:47	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	12/02/2021	14:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	12/02/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	12/02/2021	15:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	12/02/2021	13:52	12.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	12/02/2021	14:03	12.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	12/02/2021	13:27	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	12/02/2021	13:33	12.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	12/02/2021	14:14	11.8	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	12/02/2021	14:22	12.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	12/02/2021	15:30	13.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	12/02/2021	14:47	11.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	12/02/2021	14:55	13.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	12/02/2021	14:40	13.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	12/02/2021	15:45	13.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	12/02/2021	13:52	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	12/02/2021	14:03	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	12/02/2021	13:27	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	12/02/2021	13:33	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	12/02/2021	14:14	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	12/02/2021	14:22	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	12/02/2021	15:30	0.0142	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	12/02/2021	14:47	0.0009	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	12/02/2021	14:55	0.011	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	12/02/2021	14:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	12/02/2021	15:45	0.0139	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	12/02/2021	13:52	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	12/02/2021	14:03	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	12/02/2021	13:27	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	12/02/2021	13:33	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	12/02/2021	14:14	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	12/02/2021	14:22	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	12/02/2021	15:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	12/02/2021	14:47	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	12/02/2021	14:55	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	12/02/2021	14:40	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	12/02/2021	15:45	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	12/02/2021	13:52	<0.0005	g/m³	(.08 - .08)

	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	12/02/2021	14:03	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	12/02/2021	13:27	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	12/02/2021	13:33	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	12/02/2021	14:14	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	12/02/2021	14:22	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	12/02/2021	15:30	0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	12/02/2021	14:47	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	12/02/2021	14:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	12/02/2021	14:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	12/02/2021	15:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	12/02/2021	13:52	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	12/02/2021	14:03	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	12/02/2021	13:27	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	12/02/2021	13:33	0.003	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	12/02/2021	14:14	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	12/02/2021	14:22	0.003	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	12/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	12/02/2021	14:47	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	12/02/2021	14:55	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	12/02/2021	14:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	12/02/2021	15:45	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	12/02/2021	13:52	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	12/02/2021	14:03	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	12/02/2021	13:27	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	12/02/2021	13:33	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	12/02/2021	14:14	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	12/02/2021	14:22	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	12/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	12/02/2021	14:47	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	12/02/2021	14:55	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	12/02/2021	14:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	12/02/2021	15:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	12/02/2021	13:52	6	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:03	6.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	12/02/2021	13:27	5.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	12/02/2021	13:33	6.4	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:14	5.7	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:22	6.4	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	12/02/2021	15:30	10	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:47	5.6	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:55	6.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	12/02/2021	14:40	6.4	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	12/02/2021	15:45	9.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	12/02/2021	13:52	1.3	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	12/02/2021	14:03	1.5	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	12/02/2021	13:27	0.39	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	12/02/2021	13:33	0.43	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	12/02/2021	14:14	1.3	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	12/02/2021	14:22	1.4	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	12/02/2021	14:55	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	12/02/2021	14:40	1.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	12/02/2021	13:52	1.6	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	12/02/2021	14:03	1.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	12/02/2021	13:27	0.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	12/02/2021	13:33	0.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	12/02/2021	14:14	1.6	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	12/02/2021	14:22	1.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	12/02/2021	14:55	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	12/02/2021	14:40	1.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	12/02/2021	13:52	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	12/02/2021	15:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	12/02/2021	15:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	12/02/2021	13:52	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-1310	Temperature on arrival	12/02/2021	13:27	6.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-1310	Temperature on arrival	12/02/2021	13:33	6.5	Deg C	

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	12/02/2021	13:27	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	12/02/2021	13:33	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	12/02/2021	13:27	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	12/02/2021	13:33	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Settling Ponds Sediment	O1420	Sampler Observation	12/02/2021	15:10	Dup	analysis not homogenous highest value reported for affected elemen	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/02/2021	14:47	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/02/2021	15:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	12/02/2021	13:52	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	12/02/2021	14:03	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	12/02/2021	13:27	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	12/02/2021	13:33	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	12/02/2021	14:14	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	12/02/2021	14:22	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	12/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	12/02/2021	14:47	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	12/02/2021	14:55	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	12/02/2021	14:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	12/02/2021	15:45	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	12/02/2021	15:10	Completed		
	Catchment - Waikouaiti Confluence	O1420	Sampler Observation	12/02/2021	15:56:55	Sample	date 12.02.21, received 20.02.21	
	Catchment - Waikouaiti North Branch	O1420	Sampler Observation	12/02/2021	15:56:55	Sample	date 12.02.21, received 20.02.21	
	Catchment - Waikouaiti South Branch	O1420	Sampler Observation	12/02/2021	15:56:55	Sample	date 12.02.21, received 20.02.21	
	Catchment - Waikouaiti Confluence	SC039	Cyanobacteria - FW_CC_CYA Preserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti North Branch	SC039	Cyanobacteria - FW_CC_CYA Preserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti South Branch	SC039	Cyanobacteria - FW_CC_CYA Preserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti Confluence	SC039a	Cyanobacteria - FW_CC_CYA Unpreserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti North Branch	SC039a	Cyanobacteria - FW_CC_CYA Unpreserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti South Branch	SC039a	Cyanobacteria - FW_CC_CYA Unpreserved	12/02/2021	15:56:55	attached		
	Catchment - Waikouaiti Confluence	W-TO001	Geosmin by SPME	12/02/2021	15:56:55	2.7	ng/L	
	Catchment - Waikouaiti North Branch	W-TO001	Geosmin by SPME	12/02/2021	15:56:55	3.4	ng/L	
	Catchment - Waikouaiti South Branch	W-TO001	Geosmin by SPME	12/02/2021	15:56:55	1.9	ng/L	
	Catchment - Waikouaiti Confluence	W-TO002	2-Methylisoborneol by SPME	12/02/2021	15:56:55	5.2	ng/L	
	Catchment - Waikouaiti North Branch	W-TO002	2-Methylisoborneol by SPME	12/02/2021	15:56:55	6	ng/L	
	Catchment - Waikouaiti South Branch	W-TO002	2-Methylisoborneol by SPME	12/02/2021	15:56:55	2.7	ng/L	
	Catchment - Waikouaiti Confluence	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	15:56:55	<1	ng/L	
	Catchment - Waikouaiti North Branch	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	15:56:55	<1	ng/L	
	Catchment - Waikouaiti South Branch	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	15:56:55	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	

	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	O1420	Sampler Observation	12/02/2021	16:01:06	Sample	only half full and has sample date 12/02/21	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	69	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	11	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	962	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	988	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	1,170	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	13	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	2,130	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	325	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	5.3	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	157	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	8.9	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	8.8	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	47	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	6.1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO001	Geosmin by SPME	12/02/2021	16:01:06	3.5	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	17	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	841	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	5	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	1,220	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	627	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	92	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	2.2	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	3,070	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	8.6	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	2.8	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	251	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	1.2	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	1.7	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	54	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	173	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO002	2-Methylisoborneol by SPME	12/02/2021	16:01:06	43,300	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti WTP - Waikouaiti River	W-TO003	2,4,6-Trichloroanisole by SPME	12/02/2021	16:01:06	<1	ng/L	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	13/02/2021	10:43:39			

	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:43:54			

	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	13/02/2021	10:43:29	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	13/02/2021	10:43:54			

	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	13/02/2021	10:43:54			
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	13/02/2021	10:44:11			
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	13/02/2021	10:44:11			
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	13/02/2021	10:43:45			

	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	13/02/2021	10:44:08			
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	13/02/2021	10:43:45			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	13/02/2021	10:43:29			

	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	13/02/2021	10:43:39			

	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	10:43:29	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	13/02/2021	10:43:31	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	10:43:33	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	13/02/2021	10:43:36	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	10:43:37	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	13/02/2021	10:43:39	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	13/02/2021	10:43:41	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	13/02/2021	10:43:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	13/02/2021	10:43:48	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	13/02/2021	10:43:51	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	13/02/2021	10:43:54	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	13/02/2021	10:44:08	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0001F	pH - Field	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	13/02/2021	10:43:54			

	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	13/02/2021	10:44:08			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	13/02/2021	10:43:39			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	13/02/2021	10:43:54			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	13/02/2021	10:43:29	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	13/02/2021	10:43:41	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	13/02/2021	10:43:41	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	13/02/2021	10:43:29	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	10:43:36			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	10:43:36			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	13/02/2021	10:43:29			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	13/02/2021	10:43:31			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	13/02/2021	10:43:33			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	13/02/2021	10:43:36			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	13/02/2021	10:43:37			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	13/02/2021	10:43:39			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	13/02/2021	10:43:41			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	13/02/2021	10:43:45			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	13/02/2021	10:43:48			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	13/02/2021	10:43:51			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	13/02/2021	10:43:54			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	13/02/2021	10:44:08			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	13/02/2021	10:44:11			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	13/02/2021	12:00	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	13/02/2021	12:05	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	13/02/2021	11:30	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	13/02/2021	11:45	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	13/02/2021	12:22	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	13/02/2021	12:30	7.7		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	13/02/2021	13:10	7.9		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	13/02/2021	12:55	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	13/02/2021	12:44	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	13/02/2021	13:00	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	13/02/2021	12:00	<6	g/m^3	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	13/02/2021	12:05	<6	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	13/02/2021	11:30	<6	g/m^3	

	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	13/02/2021	11:45	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	13/02/2021	12:22	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	13/02/2021	12:30	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	13/02/2021	13:10	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	13/02/2021	12:55	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	13/02/2021	12:44	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	13/02/2021	13:00	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	13/02/2021	12:00	65	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	13/02/2021	12:05	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	13/02/2021	11:30	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	13/02/2021	11:45	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	13/02/2021	12:22	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	13/02/2021	12:30	65	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	13/02/2021	13:10	63	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	13/02/2021	12:55	61	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	13/02/2021	12:44	66	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	13/02/2021	13:00	62	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	12:00	18.2	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	13/02/2021	12:05	17.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	11:30	18.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	13/02/2021	11:45	18.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	12:22	18.3	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	13/02/2021	12:30	17.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	13/02/2021	13:10	16.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	13/02/2021	12:55	16.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	13/02/2021	12:44	17.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	13/02/2021	13:00	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	12:00	16.2	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	13/02/2021	12:05	16.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	11:30	16.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	13/02/2021	11:45	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	12:22	16.4	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	13/02/2021	12:30	16.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	13/02/2021	13:10	12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	13/02/2021	12:55	13.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	13/02/2021	12:44	16.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	13/02/2021	13:00	12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	12:00	46.5	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	13/02/2021	12:05	48.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	11:30	46.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	13/02/2021	11:45	47	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	12:22	46.6	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	13/02/2021	12:30	48	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	13/02/2021	13:10	51.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	13/02/2021	12:55	51.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	13/02/2021	12:44	48.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	13/02/2021	13:00	51.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:00	162	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:05	162	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	11:30	159	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	13/02/2021	11:45	154	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:22	148	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:30	127	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	13/02/2021	13:10	147	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:55	154	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	13/02/2021	12:44	159	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	13/02/2021	13:00	137	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	13/02/2021	12:00	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	12:00	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	13/02/2021	12:05	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	11:30	0.022	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	13/02/2021	11:45	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	12:22	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	13/02/2021	12:30	0.013	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	13/02/2021	12:55	0.009	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	13/02/2021	12:44	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	12:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	13/02/2021	12:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	11:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	13/02/2021	11:45	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	12:22	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	13/02/2021	12:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	13/02/2021	12:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	13/02/2021	12:44	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	13/02/2021	12:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	13/02/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	12:22	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	13/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	13/02/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	13/02/2021	12:44	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	13/02/2021	12:00	23.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	13/02/2021	12:05	23	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	11:30	24.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	13/02/2021	11:45	24.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	12:22	24.4	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	13/02/2021	12:30	25.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	13/02/2021	12:55	22.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	13/02/2021	12:44	23.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	13/02/2021	12:00	0.0024	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	13/02/2021	12:05	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	13/02/2021	11:30	0.0218	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	13/02/2021	11:45	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	13/02/2021	12:22	0.002	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	13/02/2021	12:30	0.0012	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	13/02/2021	12:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	13/02/2021	12:44	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	13/02/2021	12:00	0.03	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	13/02/2021	12:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	13/02/2021	11:30	0.22	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	13/02/2021	11:45	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	13/02/2021	12:22	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	13/02/2021	12:30	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	13/02/2021	12:55	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	13/02/2021	12:44	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	13/02/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	13/02/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	13/02/2021	11:30	0.0192	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	13/02/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	13/02/2021	12:22	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	13/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	13/02/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	13/02/2021	12:44	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	12:00	12.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	13/02/2021	12:05	12.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	11:30	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	13/02/2021	11:45	12	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	12:22	12	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	13/02/2021	12:30	12.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	13/02/2021	12:55	13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	13/02/2021	12:44	12.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	13/02/2021	12:00	0.0014	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	13/02/2021	12:05	0.0021	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	11:30	0.0032	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	13/02/2021	11:45	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	12:22	0.0007	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	13/02/2021	12:30	0.0012	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	13/02/2021	12:55	0.0127	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	13/02/2021	12:44	0.0062	g/m³	(.4 - .4)

	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	13/02/2021	12:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	13/02/2021	12:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	11:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	13/02/2021	11:45	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	12:22	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	13/02/2021	12:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	13/02/2021	12:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	13/02/2021	12:44	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	13/02/2021	12:00	0.004	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	13/02/2021	12:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	11:30	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	13/02/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	12:22	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	13/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	13/02/2021	12:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	13/02/2021	12:44	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	13/02/2021	12:00	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	13/02/2021	12:05	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	11:30	0.116	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	13/02/2021	11:45	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	12:22	0.004	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	13/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	13/02/2021	12:55	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	13/02/2021	12:44	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	13/02/2021	00:00:00	152,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	13/02/2021	00:00:00	46.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	13/02/2021	00:00:00	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	13/02/2021	00:00:00	4,580	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	13/02/2021	00:00:00	34.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	13/02/2021	00:00:00	31,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	13/02/2021	00:00:00	3.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	13/02/2021	00:00:00	1,380	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	13/02/2021	00:00:00	822	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	13/02/2021	00:00:00	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	13/02/2021	00:00:00	11.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	13/02/2021	00:00:00	46	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	13/02/2021	13:10	0.028	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	13/02/2021	13:00	0.034	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	13/02/2021	13:10	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	13/02/2021	13:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	13/02/2021	13:10	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	13/02/2021	13:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	13/02/2021	13:10	22.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	13/02/2021	13:00	22.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	13/02/2021	13:10	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	13/02/2021	13:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	13/02/2021	13:10	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	13/02/2021	13:00	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	13/02/2021	13:10	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	13/02/2021	13:00	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	13/02/2021	13:10	13.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	13/02/2021	13:00	13.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	13/02/2021	13:10	0.021	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	13/02/2021	13:00	0.022	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	13/02/2021	13:10	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	13/02/2021	13:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	13/02/2021	13:10	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	13/02/2021	13:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	13/02/2021	13:10	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	13/02/2021	13:00	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	13/02/2021	12:00	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	13/02/2021	12:05	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	13/02/2021	11:30	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	13/02/2021	11:45	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	13/02/2021	12:22	0.014	g/m³	

	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	13/02/2021	12:30	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	13/02/2021	13:10	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	13/02/2021	12:55	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	13/02/2021	12:44	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	13/02/2021	13:00	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	13/02/2021	12:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	13/02/2021	12:05	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	13/02/2021	11:30	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	13/02/2021	11:45	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	13/02/2021	12:22	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	13/02/2021	12:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	13/02/2021	13:10	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	13/02/2021	12:55	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	13/02/2021	12:44	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	13/02/2021	13:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	13/02/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	13/02/2021	12:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	13/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	13/02/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	13/02/2021	12:22	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	13/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	13/02/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	13/02/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	13/02/2021	12:44	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	13/02/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	13/02/2021	12:00	23.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	13/02/2021	12:05	24.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	13/02/2021	11:30	25.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	13/02/2021	11:45	25	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	13/02/2021	12:22	25.3	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	13/02/2021	12:30	25	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	13/02/2021	13:10	22.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	13/02/2021	12:55	22.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	13/02/2021	12:44	23.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	13/02/2021	13:00	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	13/02/2021	12:00	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	13/02/2021	12:05	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	13/02/2021	11:30	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	13/02/2021	11:45	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	13/02/2021	12:22	0.0022	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	13/02/2021	12:30	0.0012	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	13/02/2021	13:10	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	13/02/2021	12:55	0.0014	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	13/02/2021	12:44	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	13/02/2021	13:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	13/02/2021	12:00	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	13/02/2021	12:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	13/02/2021	11:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	13/02/2021	11:45	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	13/02/2021	12:22	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	13/02/2021	12:30	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	13/02/2021	13:10	0.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	13/02/2021	12:55	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	13/02/2021	12:44	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	13/02/2021	13:00	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	13/02/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	13/02/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	13/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	13/02/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	13/02/2021	12:22	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	13/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	13/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	13/02/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	13/02/2021	12:44	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	13/02/2021	13:00	<0.0005	g/m³	(.005 - .01)

	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	13/02/2021	12:00	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	13/02/2021	12:05	13.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	13/02/2021	11:30	12.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	13/02/2021	11:45	12.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	13/02/2021	12:22	12.3	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	13/02/2021	12:30	12.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	13/02/2021	13:10	13.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	13/02/2021	12:55	13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	13/02/2021	12:44	12.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	13/02/2021	13:00	13	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	13/02/2021	12:00	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	13/02/2021	12:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	13/02/2021	11:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	13/02/2021	11:45	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	13/02/2021	12:22	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	13/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	13/02/2021	13:10	0.0134	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	13/02/2021	12:55	0.0128	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	13/02/2021	12:44	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	13/02/2021	13:00	0.0153	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	13/02/2021	12:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	13/02/2021	12:05	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	13/02/2021	11:30	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	13/02/2021	11:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	13/02/2021	12:22	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	13/02/2021	12:30	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	13/02/2021	13:10	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	13/02/2021	12:55	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	13/02/2021	12:44	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	13/02/2021	13:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	13/02/2021	12:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	13/02/2021	12:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	13/02/2021	11:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	13/02/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	13/02/2021	12:22	0.0023	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	13/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	13/02/2021	13:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	13/02/2021	12:55	0.0007	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	13/02/2021	12:44	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	13/02/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	13/02/2021	12:00	0.002	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	13/02/2021	12:05	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	13/02/2021	11:30	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	13/02/2021	11:45	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	13/02/2021	12:22	0.004	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	13/02/2021	12:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	13/02/2021	13:10	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	13/02/2021	12:55	0.008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	13/02/2021	12:44	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	13/02/2021	13:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	12:00	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	13/02/2021	12:05	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	11:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	13/02/2021	11:45	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	12:22	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	13/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	13/02/2021	13:10	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	13/02/2021	12:55	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	13/02/2021	12:44	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	13/02/2021	13:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:00	6.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:05	6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	11:30	5.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	13/02/2021	11:45	6.4	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:22	6.7	g O2/m³	

	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:30	6.8	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	13/02/2021	13:10	8.7	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:55	6.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	13/02/2021	12:44	6.9	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	13/02/2021	13:00	8.6	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	13/02/2021	12:00	1.3	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	13/02/2021	12:05	1.3	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	11:30	0.19	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	13/02/2021	11:45	0.29	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	12:22	1.3	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	13/02/2021	12:30	1.3	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	13/02/2021	12:55	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	13/02/2021	12:44	1.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	13/02/2021	12:00	1.4	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	13/02/2021	12:05	1.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	13/02/2021	11:30	0.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	13/02/2021	11:45	0.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	13/02/2021	12:22	1.3	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	13/02/2021	12:30	1.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	13/02/2021	12:55	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	13/02/2021	12:44	1.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	13/02/2021	12:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	13/02/2021	13:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	13/02/2021	13:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	13/02/2021	12:00	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	11:30	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	11:45	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	11:30	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	11:45	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	13/02/2021	00:00:00	No	water	
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	13/02/2021	00:00	No	Water	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	13/02/2021	13:10	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	13/02/2021	13:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	13/02/2021	12:00	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	13/02/2021	12:05	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	13/02/2021	11:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	13/02/2021	11:45	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	13/02/2021	12:22	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	13/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	13/02/2021	13:10	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	13/02/2021	12:55	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	13/02/2021	12:44	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	13/02/2021	13:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	13/02/2021	00:00:00			

	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	13/02/2021	00:00:00	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			

	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			

	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	13/02/2021	00:00:00			

	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	13/02/2021	00:00:00			

	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	13/02/2021	00:00:00			

	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	13/02/2021	00:00:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	13/02/2021	00:00:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	13/02/2021	00:00:00	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	13/02/2021	00:00:00			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	13/02/2021	00:00:00			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	13/02/2021	00:00:00			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	13/02/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	14/02/2021	13:45	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	14/02/2021	13:50	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	14/02/2021	14:05	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	14/02/2021	13:30	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	14/02/2021	13:35	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	14/02/2021	13:05	7.9		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	14/02/2021	12:45	7.8		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	14/02/2021	12:35	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	14/02/2021	12:40	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	14/02/2021	13:10	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	14/02/2021	13:45	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	14/02/2021	13:50	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	14/02/2021	14:05	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	14/02/2021	13:30	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	14/02/2021	13:35	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	14/02/2021	13:05	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	14/02/2021	12:45	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	14/02/2021	12:35	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	14/02/2021	12:40	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	14/02/2021	13:10	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	14/02/2021	13:45	66	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	14/02/2021	13:50	64	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	14/02/2021	14:05	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	14/02/2021	13:30	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	14/02/2021	13:35	64	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	14/02/2021	13:05	63	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	14/02/2021	12:45	63	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	14/02/2021	12:35	61	g CaCO3/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	14/02/2021	12:40	61	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	14/02/2021	13:10	62	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	14/02/2021	13:45	17.2	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	14/02/2021	13:50	17.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	14/02/2021	14:05	17.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	14/02/2021	13:30	17.6	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	14/02/2021	13:35	17.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	14/02/2021	13:05	17	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	14/02/2021	12:45	17	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	14/02/2021	12:35	16.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	14/02/2021	12:40	16.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	14/02/2021	13:10	17	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	14/02/2021	13:45	16.1	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	14/02/2021	13:50	16.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	14/02/2021	14:05	16.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	14/02/2021	13:30	16.3	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	14/02/2021	13:35	16.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	14/02/2021	13:05	12.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	14/02/2021	12:45	12.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	14/02/2021	12:35	13.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	14/02/2021	12:40	13.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	14/02/2021	13:10	12.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	14/02/2021	13:45	48.9	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	14/02/2021	13:50	48.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	14/02/2021	14:05	48.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	14/02/2021	13:30	49	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	14/02/2021	13:35	49.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	14/02/2021	13:05	47.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	14/02/2021	12:45	47.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	14/02/2021	12:35	47.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	14/02/2021	12:40	47.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	14/02/2021	13:10	47.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:45	150	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:50	152	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	14/02/2021	14:05	163	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:30	165	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:35	137	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:05	146	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	14/02/2021	12:45	139	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	14/02/2021	12:35	137	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	14/02/2021	12:40	128	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	14/02/2021	13:10	163	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	14/02/2021	13:45	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	14/02/2021	13:45	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	14/02/2021	13:50	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	14/02/2021	14:05	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	14/02/2021	13:30	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	14/02/2021	13:35	0.013	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	14/02/2021	12:35	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	14/02/2021	12:40	0.008	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	14/02/2021	13:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	14/02/2021	13:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	14/02/2021	14:05	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	14/02/2021	13:30	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	14/02/2021	13:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	14/02/2021	12:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	14/02/2021	12:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	14/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	14/02/2021	13:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	14/02/2021	14:05	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	14/02/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	14/02/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	14/02/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	14/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	14/02/2021	13:45	22.7	g/m³	

	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	14/02/2021	13:50	23.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	14/02/2021	14:05	24.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	14/02/2021	13:30	24.1	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	14/02/2021	13:35	24	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	14/02/2021	12:35	23.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	14/02/2021	12:40	22.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	14/02/2021	13:45	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	14/02/2021	13:50	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	14/02/2021	14:05	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	14/02/2021	13:30	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	14/02/2021	13:35	0.0012	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	14/02/2021	12:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	14/02/2021	12:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	14/02/2021	13:45	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	14/02/2021	13:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	14/02/2021	14:05	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	14/02/2021	13:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	14/02/2021	13:35	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	14/02/2021	12:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	14/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	14/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	14/02/2021	13:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	14/02/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	14/02/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	14/02/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	14/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	14/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	14/02/2021	13:45	12.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	14/02/2021	13:50	12.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	14/02/2021	14:05	12.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	14/02/2021	13:30	12.2	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	14/02/2021	13:35	12.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	14/02/2021	12:35	12.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	14/02/2021	12:40	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	14/02/2021	13:45	0.0021	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	14/02/2021	13:50	0.0037	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	14/02/2021	14:05	0.0006	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	14/02/2021	13:30	0.001	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	14/02/2021	13:35	0.0011	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	14/02/2021	12:35	0.0144	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	14/02/2021	12:40	0.0115	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	14/02/2021	13:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	14/02/2021	13:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	14/02/2021	14:05	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	14/02/2021	13:30	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	14/02/2021	13:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	14/02/2021	12:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	14/02/2021	12:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	14/02/2021	13:45	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	14/02/2021	13:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	14/02/2021	14:05	0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	14/02/2021	13:30	0.0006	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	14/02/2021	13:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	14/02/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	14/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	14/02/2021	13:45	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	14/02/2021	13:50	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	14/02/2021	14:05	0.006	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	14/02/2021	13:30	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	14/02/2021	13:35	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	14/02/2021	12:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	14/02/2021	12:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	14/02/2021	13:05	0.014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	14/02/2021	12:45	0.012	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	14/02/2021	13:10	0.018	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	14/02/2021	13:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	14/02/2021	12:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	14/02/2021	13:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	14/02/2021	13:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	14/02/2021	12:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	14/02/2021	13:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	14/02/2021	13:05	21.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	14/02/2021	12:45	21.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	14/02/2021	13:10	21.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	14/02/2021	13:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	14/02/2021	12:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	14/02/2021	13:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	14/02/2021	13:05	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	14/02/2021	12:45	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	14/02/2021	13:10	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	14/02/2021	13:05	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	14/02/2021	12:45	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	14/02/2021	13:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	14/02/2021	13:05	12.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	14/02/2021	12:45	13	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	14/02/2021	13:10	13.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	14/02/2021	13:05	0.022	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	14/02/2021	12:45	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	14/02/2021	13:10	0.023	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	14/02/2021	13:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	14/02/2021	12:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	14/02/2021	13:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	14/02/2021	13:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	14/02/2021	12:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	14/02/2021	13:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	14/02/2021	13:05	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	14/02/2021	12:45	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	14/02/2021	13:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	14/02/2021	13:45	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	14/02/2021	13:50	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	14/02/2021	14:05	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	14/02/2021	13:30	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	14/02/2021	13:35	0.013	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	14/02/2021	13:05	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	14/02/2021	12:45	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	14/02/2021	12:35	0.008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	14/02/2021	12:40	0.008	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	14/02/2021	13:10	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	14/02/2021	13:45	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	14/02/2021	13:50	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	14/02/2021	14:05	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	14/02/2021	13:30	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	14/02/2021	13:35	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	14/02/2021	13:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	14/02/2021	12:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	14/02/2021	12:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	14/02/2021	12:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	14/02/2021	13:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	14/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	14/02/2021	13:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	14/02/2021	14:05	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	14/02/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	14/02/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	14/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	14/02/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	14/02/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	14/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	14/02/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	14/02/2021	13:45	23.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	14/02/2021	13:50	23.3	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	14/02/2021	14:05	25.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	14/02/2021	13:30	24.6	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	14/02/2021	13:35	24.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	14/02/2021	13:05	22.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	14/02/2021	12:45	22.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	14/02/2021	12:35	22.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	14/02/2021	12:40	22.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	14/02/2021	13:10	22.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	14/02/2021	13:45	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	14/02/2021	13:50	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	14/02/2021	14:05	0.0023	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	14/02/2021	13:30	0.0015	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	14/02/2021	13:35	0.0012	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	14/02/2021	13:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	14/02/2021	12:45	0.0013	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	14/02/2021	12:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	14/02/2021	12:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	14/02/2021	13:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	14/02/2021	13:45	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	14/02/2021	13:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	14/02/2021	14:05	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	14/02/2021	13:30	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	14/02/2021	13:35	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	14/02/2021	13:05	0.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	14/02/2021	12:45	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	14/02/2021	12:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	14/02/2021	12:40	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	14/02/2021	13:10	0.11	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	14/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	14/02/2021	13:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	14/02/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	14/02/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	14/02/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	14/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	14/02/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	14/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	14/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	14/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	14/02/2021	13:45	12.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	14/02/2021	13:50	12.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	14/02/2021	14:05	12.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	14/02/2021	13:30	12.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	14/02/2021	13:35	12.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	14/02/2021	13:05	12.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	14/02/2021	12:45	12.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	14/02/2021	12:35	12.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	14/02/2021	12:40	12.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	14/02/2021	13:10	12.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	14/02/2021	13:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	14/02/2021	13:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	14/02/2021	14:05	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	14/02/2021	13:30	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	14/02/2021	13:35	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	14/02/2021	13:05	0.0171	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	14/02/2021	12:45	0.0068	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	14/02/2021	12:35	0.0145	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	14/02/2021	12:40	0.0117	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	14/02/2021	13:10	0.0155	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	14/02/2021	13:45	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	14/02/2021	13:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	14/02/2021	14:05	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	14/02/2021	13:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	14/02/2021	13:35	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	14/02/2021	13:05	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	14/02/2021	12:45	<0.0005	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	14/02/2021	12:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	14/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	14/02/2021	13:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	14/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	14/02/2021	13:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	14/02/2021	14:05	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	14/02/2021	13:30	0.0006	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	14/02/2021	13:35	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	14/02/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	14/02/2021	12:45	0.0007	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	14/02/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	14/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	14/02/2021	13:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	14/02/2021	13:45	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	14/02/2021	13:50	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	14/02/2021	14:05	0.009	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	14/02/2021	13:30	0.01	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	14/02/2021	13:35	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	14/02/2021	13:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	14/02/2021	12:45	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	14/02/2021	12:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	14/02/2021	12:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	14/02/2021	13:10	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	14/02/2021	13:45	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	14/02/2021	13:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	14/02/2021	14:05	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	14/02/2021	13:30	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	14/02/2021	13:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	14/02/2021	13:05	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	14/02/2021	12:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	14/02/2021	12:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	14/02/2021	12:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	14/02/2021	13:10	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	14/02/2021	12:35	No	Water	
	Waikouaiti WTP - Settling Ponds Sediment	C-O1420	Sampler Observation	14/02/2021	12:50	No	Sampled	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:45	5.1	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:50	6.8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	14/02/2021	14:05	6.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	14/02/2021	14:10	5.8	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:30	5.6	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:35	7.8	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:05	8.5	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	14/02/2021	12:45	5.9	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	14/02/2021	12:35	6.3	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	14/02/2021	12:40	6.6	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	14/02/2021	13:10	8.4	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	14/02/2021	13:45	0.07	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	14/02/2021	13:50	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	14/02/2021	14:05	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	14/02/2021	14:10	0.39	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	14/02/2021	13:30	0.21	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	14/02/2021	13:35	1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	14/02/2021	12:35	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	14/02/2021	12:40	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	14/02/2021	13:45	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	14/02/2021	13:50	1.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	14/02/2021	14:05	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	14/02/2021	14:10	0.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	14/02/2021	13:30	0.3	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	14/02/2021	13:35	1.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	14/02/2021	12:35	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	14/02/2021	12:40	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	14/02/2021	13:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	14/02/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	14/02/2021	13:05	Completed		

	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	14/02/2021	13:45	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	14/02/2021	14:05	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	14/02/2021	14:10	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	14/02/2021	14:05	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	14/02/2021	14:10	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	O1420	Sampler Observation	14/02/2021	14:10	No	sample		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/02/2021	13:05	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/02/2021	12:45	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/02/2021	13:10	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	14/02/2021	13:45	Completed			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	14/02/2021	13:50	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	14/02/2021	14:05	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	14/02/2021	13:30	Completed			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	14/02/2021	13:35	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	14/02/2021	13:05	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	14/02/2021	12:45	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	14/02/2021	12:35	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	14/02/2021	12:40	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	14/02/2021	13:10	Completed			
	Waikouaiti SS - 210 Edinburgh St	1	pH	14/02/2021	14:10:00	7.9		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	14/02/2021	14:10:00	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	14/02/2021	14:10:00	66	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	14/02/2021	14:10:00	18	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	14/02/2021	14:10:00	16.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	14/02/2021	14:10:00	49.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	14/02/2021	14:10:00	187	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	14/02/2021	14:10:00	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	14/02/2021	14:10:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	14/02/2021	14:10:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	14/02/2021	14:10:00	24.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	14/02/2021	14:10:00	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	14/02/2021	14:10:00	0.07	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	14/02/2021	14:10:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	14/02/2021	14:10:00	12.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	14/02/2021	14:10:00	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	14/02/2021	14:10:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	14/02/2021	14:10:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	14/02/2021	14:10:00	0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	14/02/2021	14:10:00	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	14/02/2021	14:10:00	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	14/02/2021	14:10:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	14/02/2021	14:10:00	24.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	14/02/2021	14:10:00	0.011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	14/02/2021	14:10:00	0.02	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	14/02/2021	14:10:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	14/02/2021	14:10:00	12.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	14/02/2021	14:10:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	14/02/2021	14:10:00	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	14/02/2021	14:10:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	14/02/2021	14:10:00	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	14/02/2021	14:10:00	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	14/02/2021	14:10:00	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	15/02/2021	14:40	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	15/02/2021	14:45	7.8		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	15/02/2021	14:55	7.9		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	15/02/2021	15:00	8		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	15/02/2021	14:20	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	15/02/2021	14:25	7.9		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	15/02/2021	13:35	7.8		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	15/02/2021	13:55	7.9		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	15/02/2021	13:45	7.8		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	15/02/2021	13:55	7.8		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	15/02/2021	13:40	7.8		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	15/02/2021	14:40	<6	g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	15/02/2021	14:45	<6	g/m³		

	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	15/02/2021	14:55	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	15/02/2021	15:00	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	15/02/2021	14:20	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	15/02/2021	14:25	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	15/02/2021	13:35	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	15/02/2021	13:55	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	15/02/2021	13:45	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	15/02/2021	13:55	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	15/02/2021	13:40	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	15/02/2021	14:40	64	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	15/02/2021	14:45	63	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	15/02/2021	14:55	64	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	15/02/2021	15:00	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	15/02/2021	14:20	68	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	15/02/2021	14:25	66	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	15/02/2021	13:35	66	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	15/02/2021	13:55	63	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	15/02/2021	13:45	61	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	15/02/2021	13:55	61	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	15/02/2021	13:40	63	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	15/02/2021	14:40	17.5	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	15/02/2021	14:45	17.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	15/02/2021	14:55	17.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	15/02/2021	15:00	17.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	15/02/2021	14:20	17.8	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	15/02/2021	14:25	17.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	15/02/2021	13:35	17.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	15/02/2021	13:55	17.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	15/02/2021	13:45	16.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	15/02/2021	13:55	16.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	15/02/2021	13:40	17.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	15/02/2021	14:40	16.5	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	15/02/2021	14:45	16.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	15/02/2021	14:55	16.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	15/02/2021	15:00	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	15/02/2021	14:20	16.6	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	15/02/2021	14:25	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	15/02/2021	13:35	12.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	15/02/2021	13:55	12.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	15/02/2021	13:45	14.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	15/02/2021	13:55	14.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	15/02/2021	13:40	12.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	15/02/2021	14:40	45.8	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	15/02/2021	14:45	45.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	15/02/2021	14:55	45	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	15/02/2021	15:00	44.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	15/02/2021	14:20	46	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	15/02/2021	14:25	45.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	15/02/2021	13:35	41.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	15/02/2021	13:55	41.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	15/02/2021	13:45	40.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	15/02/2021	13:55	40.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	15/02/2021	13:40	41.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	15/02/2021	14:40	159	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	15/02/2021	14:45	158	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	15/02/2021	14:55	154	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	15/02/2021	15:00	154	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	15/02/2021	14:20	154	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	15/02/2021	14:25	153	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	15/02/2021	13:35	140	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	15/02/2021	13:55	126	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	15/02/2021	13:45	147	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	15/02/2021	13:55	135	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	15/02/2021	13:40	144	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	15/02/2021	14:40	$100		

	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	15/02/2021	14:40	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	15/02/2021	14:45	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	15/02/2021	14:55	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	15/02/2021	15:00	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	15/02/2021	14:20	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	15/02/2021	14:25	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	15/02/2021	13:45	0.008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	15/02/2021	13:55	0.009	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	15/02/2021	14:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	15/02/2021	14:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	15/02/2021	14:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	15/02/2021	15:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	15/02/2021	14:20	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	15/02/2021	14:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	15/02/2021	13:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	15/02/2021	13:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	15/02/2021	14:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	15/02/2021	14:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	15/02/2021	14:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	15/02/2021	15:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	15/02/2021	14:20	0.0005	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	15/02/2021	14:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	15/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	15/02/2021	13:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	15/02/2021	14:40	23.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	15/02/2021	14:45	22.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	15/02/2021	14:55	24.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	15/02/2021	15:00	24.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	15/02/2021	14:20	23.9	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	15/02/2021	14:25	24.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	15/02/2021	13:45	21.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	15/02/2021	13:55	22	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	15/02/2021	14:40	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	15/02/2021	14:45	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	15/02/2021	14:55	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	15/02/2021	15:00	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	15/02/2021	14:20	0.0021	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	15/02/2021	14:25	0.0011	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	15/02/2021	13:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	15/02/2021	13:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	15/02/2021	14:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	15/02/2021	14:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	15/02/2021	14:55	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	15/02/2021	15:00	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	15/02/2021	14:20	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	15/02/2021	14:25	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	15/02/2021	13:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	15/02/2021	13:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	15/02/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	15/02/2021	14:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	15/02/2021	14:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	15/02/2021	15:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	15/02/2021	14:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	15/02/2021	14:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	15/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	15/02/2021	13:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	15/02/2021	14:40	12.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	15/02/2021	14:45	12.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	15/02/2021	14:55	11.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	15/02/2021	15:00	11.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	15/02/2021	14:20	12.2	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	15/02/2021	14:25	12.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	15/02/2021	13:45	11.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	15/02/2021	13:55	11.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	15/02/2021	14:40	0.0029	g/m³	(.4 - .4)

	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	15/02/2021	14:45	0.0026	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	15/02/2021	14:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	15/02/2021	15:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	15/02/2021	14:20	0.0016	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	15/02/2021	14:25	0.0012	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	15/02/2021	13:45	0.0147	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	15/02/2021	13:55	0.0127	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	15/02/2021	14:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	15/02/2021	14:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	15/02/2021	14:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	15/02/2021	15:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	15/02/2021	14:20	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	15/02/2021	14:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	15/02/2021	13:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	15/02/2021	13:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	15/02/2021	14:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	15/02/2021	14:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	15/02/2021	14:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	15/02/2021	15:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	15/02/2021	14:20	0.0019	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	15/02/2021	14:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	15/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	15/02/2021	13:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	15/02/2021	14:40	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	15/02/2021	14:45	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	15/02/2021	14:55	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	15/02/2021	15:00	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	15/02/2021	14:20	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	15/02/2021	14:25	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	15/02/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	15/02/2021	13:55	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	15/02/2021	14:00	42,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	15/02/2021	14:00	8.95	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	15/02/2021	14:00	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	15/02/2021	14:00	2,880	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	15/02/2021	14:00	5.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	15/02/2021	14:00	22,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	15/02/2021	14:00	9.3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	15/02/2021	14:00	2,130	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	15/02/2021	14:00	366	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	15/02/2021	14:00	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	15/02/2021	14:00	6.3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	15/02/2021	14:00	39	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	15/02/2021	13:35	0.013	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	15/02/2021	13:55	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	15/02/2021	13:40	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	15/02/2021	13:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	15/02/2021	13:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	15/02/2021	13:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	15/02/2021	13:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	15/02/2021	13:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	15/02/2021	13:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	15/02/2021	13:35	21.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	15/02/2021	13:55	21.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	15/02/2021	13:40	21.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	15/02/2021	13:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	15/02/2021	13:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	15/02/2021	13:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	15/02/2021	13:35	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	15/02/2021	13:55	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	15/02/2021	13:40	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	15/02/2021	13:35	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	15/02/2021	13:55	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	15/02/2021	13:40	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	15/02/2021	13:35	12.4	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	15/02/2021	13:55	12.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	15/02/2021	13:40	12.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	15/02/2021	13:35	0.025	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	15/02/2021	13:55	0.026	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	15/02/2021	13:40	0.026	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	15/02/2021	13:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	15/02/2021	13:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	15/02/2021	13:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	15/02/2021	13:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	15/02/2021	13:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	15/02/2021	13:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	15/02/2021	13:35	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	15/02/2021	13:55	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	15/02/2021	13:40	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	15/02/2021	14:40	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	15/02/2021	14:45	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	15/02/2021	14:55	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	15/02/2021	15:00	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	15/02/2021	14:20	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	15/02/2021	14:25	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	15/02/2021	13:35	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	15/02/2021	13:55	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	15/02/2021	13:45	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	15/02/2021	13:55	0.009	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	15/02/2021	13:40	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	15/02/2021	14:40	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	15/02/2021	14:45	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	15/02/2021	14:55	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	15/02/2021	15:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	15/02/2021	14:20	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	15/02/2021	14:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	15/02/2021	13:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	15/02/2021	13:55	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	15/02/2021	13:45	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	15/02/2021	13:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	15/02/2021	13:40	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	15/02/2021	14:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	15/02/2021	14:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	15/02/2021	14:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	15/02/2021	15:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	15/02/2021	14:20	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	15/02/2021	14:25	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	15/02/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	15/02/2021	13:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	15/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	15/02/2021	13:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	15/02/2021	13:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	15/02/2021	14:40	23.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	15/02/2021	14:45	23.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	15/02/2021	14:55	26.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	15/02/2021	15:00	26.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	15/02/2021	14:20	23.8	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	15/02/2021	14:25	24.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	15/02/2021	13:35	22.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	15/02/2021	13:55	23.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	15/02/2021	13:45	23.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	15/02/2021	13:55	23.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	15/02/2021	13:40	23.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	15/02/2021	14:40	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	15/02/2021	14:45	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	15/02/2021	14:55	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	15/02/2021	15:00	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	15/02/2021	14:20	0.0018	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	15/02/2021	14:25	0.008	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	15/02/2021	13:35	<0.0005	g/m³	(2 - 2)

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	15/02/2021	13:55	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	15/02/2021	13:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	15/02/2021	13:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	15/02/2021	13:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	15/02/2021	14:40	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	15/02/2021	14:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	15/02/2021	14:55	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	15/02/2021	15:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	15/02/2021	14:20	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	15/02/2021	14:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	15/02/2021	13:35	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	15/02/2021	13:55	0.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	15/02/2021	13:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	15/02/2021	13:55	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	15/02/2021	13:40	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	15/02/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	15/02/2021	14:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	15/02/2021	14:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	15/02/2021	15:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	15/02/2021	14:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	15/02/2021	14:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	15/02/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	15/02/2021	13:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	15/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	15/02/2021	13:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	15/02/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	15/02/2021	14:40	12.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	15/02/2021	14:45	12.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	15/02/2021	14:55	12.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	15/02/2021	15:00	12.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	15/02/2021	14:20	12.2	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	15/02/2021	14:25	12.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	15/02/2021	13:35	12	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	15/02/2021	13:55	12.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	15/02/2021	13:45	12.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	15/02/2021	13:55	12.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	15/02/2021	13:40	12.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	15/02/2021	14:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	15/02/2021	14:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	15/02/2021	14:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	15/02/2021	15:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	15/02/2021	14:20	0.0011	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	15/02/2021	14:25	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	15/02/2021	13:35	0.02	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	15/02/2021	13:55	0.0076	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	15/02/2021	13:45	0.015	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	15/02/2021	13:55	0.0013	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	15/02/2021	13:40	0.0197	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	15/02/2021	14:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	15/02/2021	14:45	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	15/02/2021	14:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	15/02/2021	15:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	15/02/2021	14:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	15/02/2021	14:25	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	15/02/2021	13:35	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	15/02/2021	13:55	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	15/02/2021	13:45	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	15/02/2021	13:55	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	15/02/2021	13:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	15/02/2021	14:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	15/02/2021	14:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	15/02/2021	14:55	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	15/02/2021	15:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	15/02/2021	14:20	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	15/02/2021	14:25	<0.0005	g/m³	(.08 - .08)

	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	15/02/2021	13:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	15/02/2021	13:55	0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	15/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	15/02/2021	13:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	15/02/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	15/02/2021	14:40	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	15/02/2021	14:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	15/02/2021	14:55	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	15/02/2021	15:00	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	15/02/2021	14:20	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	15/02/2021	14:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	15/02/2021	13:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	15/02/2021	13:55	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	15/02/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	15/02/2021	13:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	15/02/2021	13:40	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	15/02/2021	14:40	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	15/02/2021	14:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	15/02/2021	14:55	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	15/02/2021	15:00	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	15/02/2021	14:20	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	15/02/2021	14:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	15/02/2021	13:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	15/02/2021	13:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	15/02/2021	13:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	15/02/2021	13:55	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	15/02/2021	13:40	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	15/02/2021	13:45	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	15/02/2021	14:40	6.6	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	15/02/2021	14:45	6.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	15/02/2021	14:55	6.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	15/02/2021	15:00	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	15/02/2021	14:20	6.1	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	15/02/2021	14:25	6.2	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	15/02/2021	13:35	8.5	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	15/02/2021	13:55	5.9	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	15/02/2021	13:45	7.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	15/02/2021	13:55	6.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	15/02/2021	13:40	8.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	15/02/2021	14:40	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	15/02/2021	14:45	1.2	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	15/02/2021	14:55	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	15/02/2021	15:00	0.3	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	15/02/2021	14:20	0.15	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	15/02/2021	14:25	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	15/02/2021	13:45	0.22	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/02/2021	13:55	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	15/02/2021	14:40	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	15/02/2021	14:45	1.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	15/02/2021	14:55	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	15/02/2021	15:00	0.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	15/02/2021	14:20	0.2	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	15/02/2021	14:25	1.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	15/02/2021	13:45	0.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	15/02/2021	13:55	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	15/02/2021	14:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	15/02/2021	13:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	15/02/2021	13:35	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	15/02/2021	14:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/02/2021	14:55	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/02/2021	15:00	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/02/2021	14:55	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/02/2021	15:00	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/02/2021	13:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/02/2021	13:55	Completed		

	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/02/2021	13:40	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	15/02/2021	14:40	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	15/02/2021	14:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	15/02/2021	14:55	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	15/02/2021	15:00	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	15/02/2021	14:20	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	15/02/2021	14:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	15/02/2021	13:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	15/02/2021	13:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	15/02/2021	13:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	15/02/2021	13:55	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	15/02/2021	13:40	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	15/02/2021	14:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	16/02/2021	12:10	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	16/02/2021	11:30	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	16/02/2021	11:25	7.7		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	16/02/2021	12:10	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	16/02/2021	11:30	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	16/02/2021	11:25	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0040B	Total Organic Carbon by TOC analyser	16/02/2021	12:10	1.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0040B	Total Organic Carbon by TOC analyser	16/02/2021	11:30	1.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0040B	Total Organic Carbon by TOC analyser	16/02/2021	11:25	0.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	49	Total Solids - g/m3 units	16/02/2021	12:10	193	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	49	Total Solids - g/m3 units	16/02/2021	11:30	201	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	49	Total Solids - g/m3 units	16/02/2021	11:25	173	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	16/02/2021	12:10	64	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	16/02/2021	11:30	65	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	16/02/2021	11:25	61	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	55	Conductivity at 25°C - mS/m unit	16/02/2021	12:10	25.8	mS/m (257.5 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	55	Conductivity at 25°C - mS/m unit	16/02/2021	11:30	25.8	mS/m (257.6 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	16/02/2021	11:25	26.1	mS/m (260.9 x .1)	
	Catchment - Waikouaiti River - Pump Station Intake	73	Bicarbonate by Calculation - requires tests 1 & 52	16/02/2021	12:10	64	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	73	Bicarbonate by Calculation - requires tests 1 & 52	16/02/2021	11:30	65	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	73	Bicarbonate by Calculation - requires tests 1 & 52	16/02/2021	11:25	61	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	74	Carbonate by Calculation - requires tests 1, 52, 73	16/02/2021	12:10	<1	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	74	Carbonate by Calculation - requires tests 1, 52, 73	16/02/2021	11:30	<1	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	74	Carbonate by Calculation - requires tests 1, 52, 73	16/02/2021	11:25	<1	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	76	Free CO2 by Calculation - requires tests 1, 52 & 73	16/02/2021	12:10	2	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	76	Free CO2 by Calculation - requires tests 1, 52 & 73	16/02/2021	11:30	2	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	76	Free CO2 by Calculation - requires tests 1, 52 & 73	16/02/2021	11:25	3	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	16/02/2021	12:10	58	g CO2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	16/02/2021	11:30	59	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 76	16/02/2021	11:25	56	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	84	Turbidity	16/02/2021	12:10	0.63	NTU	(2.5 - 2.5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	84	Turbidity	16/02/2021	11:30	0.53	NTU	(2.5 - 2.5)
	Waikouaiti WTP - Post Treated Water Reservoir	84	Turbidity	16/02/2021	11:25	0.06	NTU	(2.5 - 2.5)
	Catchment - Waikouaiti River - Pump Station Intake	123	Total Dissolved Solids - Calc by conductivity meter	16/02/2021	12:10	126	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	123	Total Dissolved Solids - Calc by conductivity meter	16/02/2021	11:30	126	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	123	Total Dissolved Solids - Calc by conductivity meter	16/02/2021	11:25	128	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440B	Dissolved Organic Carbon	16/02/2021	12:10	1.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440B	Dissolved Organic Carbon	16/02/2021	11:30	1.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440B	Dissolved Organic Carbon	16/02/2021	11:25	1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	601	Fluoride - Add P1859 Filtration	16/02/2021	12:10	0.11	g/m³	(1.5 - 1.5)
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	16/02/2021	11:25	0.1	g/m³	(1.5 - 1.5)
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	16/02/2021	12:10	12.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	16/02/2021	11:25	14.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	603	Nitrite - Nitrogen - Add P1859 Filtration	16/02/2021	12:10	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	603	Nitrite - Nitrogen - Add P1859 Filtration	16/02/2021	11:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	604	Bromide - Add P1859 Filtration	16/02/2021	12:10	0.04	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	604	Bromide - Add P1859 Filtration	16/02/2021	11:25	0.04	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	605	Nitrate - Nitrogen - Add P1859 Filtration	16/02/2021	12:10	0.03	g/m³	(11.3 - 11.3)
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	16/02/2021	11:25	0.03	g/m³	(11.3 - 11.3)
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	16/02/2021	12:10	35.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	16/02/2021	11:25	35.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	725	Cyanide by Discrete Analyser	16/02/2021	12:10	<0.005	g/m³	(.6 - .6)

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	725	Cyanide by Discrete Analyser	16/02/2021	11:30	<0.005	g/m³	(.6 - .6)
	Waikouaiti WTP - Post Treated Water Reservoir	725	Cyanide by Discrete Analyser	16/02/2021	11:25	<0.005	g/m³	(.6 - .6)
	Catchment - Waikouaiti River - Pump Station Intake	1250	Transmissivity @ 253.7nm	16/02/2021	12:10	83.6	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1250	Transmissivity @ 253.7nm	16/02/2021	11:30	83.9	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	16/02/2021	11:25	94.4	%	
	Catchment - Waikouaiti River - Pump Station Intake	1643	Silica by OES	16/02/2021	12:10	2.04	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1643	Silica by OES	16/02/2021	11:25	2.03	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	16/02/2021	11:25	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	16/02/2021	11:25	<0.001	g/m³	(.02 - .02)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	16/02/2021	11:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	16/02/2021	11:25	0.016	g/m³	(.7 - .7)
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	16/02/2021	11:25	<0.03	g/m³	(1.4 - 1.4)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	16/02/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	16/02/2021	11:25	20.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	16/02/2021	11:25	<0.001	g/m³	(.05 - .05)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	16/02/2021	11:25	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	16/02/2021	11:25	11.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	16/02/2021	11:25	0.0137	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	16/02/2021	11:25	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	16/02/2021	11:25	12.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	16/02/2021	12:10	0.027	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	16/02/2021	12:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	16/02/2021	12:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	16/02/2021	12:10	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	16/02/2021	12:10	<0.05	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	16/02/2021	12:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	16/02/2021	12:10	20.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	16/02/2021	12:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	16/02/2021	12:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	16/02/2021	12:10	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	16/02/2021	12:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	16/02/2021	12:10	11.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	16/02/2021	12:10	0.026	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	16/02/2021	12:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	16/02/2021	12:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	16/02/2021	12:10	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6631	Sodium - Total	16/02/2021	12:10	12	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	16/02/2021	12:10	16.3	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	16/02/2021	11:30	16.6	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	16/02/2021	11:25	16.7	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	16/02/2021	12:10	8.3	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	16/02/2021	11:30	6.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	16/02/2021	11:25	6.5	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-1201	Sampling / Inspection 15 Mins	16/02/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	16/02/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-M0102	Faecal Coliforms by MF - Environmental Water	16/02/2021	12:10	78	cfu/100ml (78 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0102	Faecal Coliforms by MF - Environmental Water	16/02/2021	11:30	44	cfu/100ml (44 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0107	Enterococci - Environmental water	16/02/2021	12:10	15	cfu/100mL (15 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0107	Enterococci - Environmental water	16/02/2021	11:30	19	cfu/100mL (19 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	16/02/2021	12:10	1,400	MPN/100ml (1413.6 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	16/02/2021	11:30	1,400	MPN/100ml (1413.6 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	16/02/2021	12:10	68	MPN/100mL (67.7 x 1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	16/02/2021	11:30	40	MPN/100mL (39.9 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0407	Enterococci - Drinking Water	16/02/2021	11:25	<1	cfu/100mL (<1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0408	Faecal Coliforms by MF - Drinking Water	16/02/2021	11:25	<1	cfu/100mL	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/02/2021	11:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/02/2021	11:25	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/02/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	16/02/2021	12:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	16/02/2021	11:25	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	16/02/2021	12:35	7.9		(1 - 14)

	Waikouaiti SS - 192 Main Rd	1	pH	16/02/2021	12:40	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	16/02/2021	13:05	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	16/02/2021	13:10	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	16/02/2021	13:25	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	16/02/2021	13:30	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	16/02/2021	12:10	8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	16/02/2021	11:35	7.8		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	16/02/2021	11:40	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	16/02/2021	11:25	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	16/02/2021	12:05	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	16/02/2021	12:35	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	16/02/2021	12:40	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	16/02/2021	13:05	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	16/02/2021	13:10	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	16/02/2021	13:25	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	16/02/2021	13:30	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	16/02/2021	12:10	10	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	16/02/2021	11:35	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	16/02/2021	11:40	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	16/02/2021	11:25	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	16/02/2021	12:05	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	16/02/2021	12:35	68	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	16/02/2021	12:40	65	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	16/02/2021	13:05	64	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	16/02/2021	13:10	64	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	16/02/2021	13:25	67	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	16/02/2021	13:30	67	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	16/02/2021	12:10	66	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	16/02/2021	11:35	63	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	16/02/2021	11:40	62	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	16/02/2021	11:25	62	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	16/02/2021	12:05	64	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	16/02/2021	12:35	18.5	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	16/02/2021	12:40	18.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	16/02/2021	13:05	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	16/02/2021	13:10	18	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	16/02/2021	13:25	18.4	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	16/02/2021	13:30	18.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	16/02/2021	12:10	18	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	16/02/2021	11:35	18.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	16/02/2021	11:40	17.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	16/02/2021	11:25	17.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	16/02/2021	12:05	17.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	16/02/2021	12:35	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	16/02/2021	12:40	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	16/02/2021	13:05	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	16/02/2021	13:10	16.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	16/02/2021	13:25	16.4	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	16/02/2021	13:30	16.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	16/02/2021	12:10	12.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	16/02/2021	11:35	12.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	16/02/2021	11:40	14.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	16/02/2021	11:25	14.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	16/02/2021	12:05	12.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	16/02/2021	12:35	41.3	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	16/02/2021	12:40	41.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	16/02/2021	13:05	44.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	16/02/2021	13:10	44.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	16/02/2021	13:25	41.4	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	16/02/2021	13:30	41.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	16/02/2021	12:10	35.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	16/02/2021	11:35	35.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	16/02/2021	11:40	34.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	16/02/2021	11:25	34.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	16/02/2021	12:05	35	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	16/02/2021	12:35	162	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	16/02/2021	12:40	154	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	16/02/2021	13:05	144	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	16/02/2021	13:10	165	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	16/02/2021	13:25	158	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	16/02/2021	13:30	161	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	16/02/2021	12:10	143	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	16/02/2021	11:35	147	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	16/02/2021	11:40	151	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	16/02/2021	11:25	129	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	16/02/2021	12:05	143	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	16/02/2021	12:35	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	16/02/2021	12:35	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	16/02/2021	12:40	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	16/02/2021	13:05	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	16/02/2021	13:10	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	16/02/2021	13:25	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	16/02/2021	13:30	0.015	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	16/02/2021	11:40	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	16/02/2021	11:25	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	16/02/2021	12:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	16/02/2021	12:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	16/02/2021	13:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	16/02/2021	13:10	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	16/02/2021	13:25	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	16/02/2021	13:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	16/02/2021	11:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	16/02/2021	11:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	16/02/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	16/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	16/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	16/02/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	16/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	16/02/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	16/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	16/02/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	16/02/2021	12:35	23.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	16/02/2021	12:40	22.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	16/02/2021	13:05	24.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	16/02/2021	13:10	24.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	16/02/2021	13:25	23.4	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	16/02/2021	13:30	23.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	16/02/2021	11:40	22	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	16/02/2021	11:25	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	16/02/2021	12:35	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	16/02/2021	12:40	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	16/02/2021	13:05	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	16/02/2021	13:10	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	16/02/2021	13:25	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	16/02/2021	13:30	0.0013	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	16/02/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	16/02/2021	12:35	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	16/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	16/02/2021	13:05	0.04	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	16/02/2021	13:10	0.03	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	16/02/2021	13:25	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	16/02/2021	13:30	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	16/02/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	16/02/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	16/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	16/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	16/02/2021	13:05	0.0008	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	16/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	16/02/2021	13:25	<0.0005	g/m³	(.005 - .01)

	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	16/02/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	16/02/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	16/02/2021	12:35	12.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	16/02/2021	12:40	12.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	16/02/2021	13:05	12.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	16/02/2021	13:10	12.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	16/02/2021	13:25	12.5	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	16/02/2021	13:30	12.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	16/02/2021	11:40	11.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	16/02/2021	11:25	11.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	16/02/2021	12:35	0.0045	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	16/02/2021	12:40	0.0035	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	16/02/2021	13:05	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	16/02/2021	13:10	0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	16/02/2021	13:25	0.0018	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	16/02/2021	13:30	0.0019	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	16/02/2021	11:40	0.0159	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	16/02/2021	11:25	0.0131	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	16/02/2021	12:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	16/02/2021	12:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	16/02/2021	13:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	16/02/2021	13:10	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	16/02/2021	13:25	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	16/02/2021	13:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	16/02/2021	11:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	16/02/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	16/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	16/02/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	16/02/2021	13:10	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	16/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	16/02/2021	13:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	16/02/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	16/02/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	16/02/2021	12:35	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	16/02/2021	12:40	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	16/02/2021	13:05	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	16/02/2021	13:10	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	16/02/2021	13:25	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	16/02/2021	13:30	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	16/02/2021	11:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	16/02/2021	11:25	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	16/02/2021	11:45	242,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	16/02/2021	11:45	37	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	16/02/2021	11:45	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	16/02/2021	11:45	4,940	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	16/02/2021	11:45	23.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	16/02/2021	11:45	17,500	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	16/02/2021	11:45	4.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	16/02/2021	11:45	991	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	16/02/2021	11:45	795	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	16/02/2021	11:45	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	16/02/2021	11:45	17.5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	16/02/2021	11:45	34	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	16/02/2021	12:10	0.026	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	16/02/2021	11:35	0.023	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	16/02/2021	12:05	0.02	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	16/02/2021	12:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	16/02/2021	11:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	16/02/2021	12:05	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	16/02/2021	12:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	16/02/2021	11:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	16/02/2021	12:05	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	16/02/2021	12:10	19.7	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	16/02/2021	11:35	19.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	16/02/2021	12:05	20.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	16/02/2021	12:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	16/02/2021	11:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	16/02/2021	12:05	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	16/02/2021	12:10	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	16/02/2021	11:35	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	16/02/2021	12:05	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	16/02/2021	12:10	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	16/02/2021	11:35	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	16/02/2021	12:05	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	16/02/2021	12:10	11.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	16/02/2021	11:35	11.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	16/02/2021	12:05	11.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	16/02/2021	12:10	0.026	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	16/02/2021	11:35	0.019	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	16/02/2021	12:05	0.028	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	16/02/2021	12:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	16/02/2021	11:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	16/02/2021	12:05	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	16/02/2021	12:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	16/02/2021	11:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	16/02/2021	12:05	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	16/02/2021	12:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	16/02/2021	11:35	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	16/02/2021	12:05	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	16/02/2021	12:35	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	16/02/2021	12:40	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	16/02/2021	13:05	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	16/02/2021	13:10	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	16/02/2021	13:25	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	16/02/2021	13:30	0.013	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	16/02/2021	12:10	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	16/02/2021	11:35	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	16/02/2021	11:40	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	16/02/2021	11:25	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	16/02/2021	12:05	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	16/02/2021	12:35	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	16/02/2021	12:40	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	16/02/2021	13:05	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	16/02/2021	13:10	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	16/02/2021	13:25	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	16/02/2021	13:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	16/02/2021	12:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	16/02/2021	11:35	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	16/02/2021	11:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	16/02/2021	11:25	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	16/02/2021	12:05	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	16/02/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	16/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	16/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	16/02/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	16/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	16/02/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	16/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	16/02/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	16/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	16/02/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	16/02/2021	12:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	16/02/2021	12:35	23.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	16/02/2021	12:40	22.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	16/02/2021	13:05	24.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	16/02/2021	13:10	24.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	16/02/2021	13:25	23.6	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	16/02/2021	13:30	23.5	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	16/02/2021	12:10	21.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	16/02/2021	11:35	21.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	16/02/2021	11:40	21.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	16/02/2021	11:25	21.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	16/02/2021	12:05	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	16/02/2021	12:35	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	16/02/2021	12:40	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	16/02/2021	13:05	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	16/02/2021	13:10	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	16/02/2021	13:25	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	16/02/2021	13:30	0.0012	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	16/02/2021	12:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	16/02/2021	11:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	16/02/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	16/02/2021	11:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	16/02/2021	12:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	16/02/2021	12:35	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	16/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	16/02/2021	13:05	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	16/02/2021	13:10	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	16/02/2021	13:25	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	16/02/2021	13:30	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	16/02/2021	12:10	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	16/02/2021	11:35	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	16/02/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	16/02/2021	11:25	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	16/02/2021	12:05	0.09	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	16/02/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	16/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	16/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	16/02/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	16/02/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	16/02/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	16/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	16/02/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	16/02/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	16/02/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	16/02/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	16/02/2021	12:35	12.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	16/02/2021	12:40	12.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	16/02/2021	13:05	12.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	16/02/2021	13:10	12.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	16/02/2021	13:25	12.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	16/02/2021	13:30	12.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	16/02/2021	12:10	11.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	16/02/2021	11:35	11.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	16/02/2021	11:40	11.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	16/02/2021	11:25	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	16/02/2021	12:05	11.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	16/02/2021	12:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	16/02/2021	12:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	16/02/2021	13:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	16/02/2021	13:10	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	16/02/2021	13:25	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	16/02/2021	13:30	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	16/02/2021	12:10	0.0182	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	16/02/2021	11:35	0.006	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	16/02/2021	11:40	0.0155	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	16/02/2021	11:25	0.0129	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	16/02/2021	12:05	0.0179	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	16/02/2021	12:35	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	16/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	16/02/2021	13:05	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	16/02/2021	13:10	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	16/02/2021	13:25	<0.0005	g/m³	

	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	16/02/2021	13:30	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	16/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	16/02/2021	11:35	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	16/02/2021	11:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	16/02/2021	11:25	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	16/02/2021	12:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	16/02/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	16/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	16/02/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	16/02/2021	13:10	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	16/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	16/02/2021	13:30	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	16/02/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	16/02/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	16/02/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	16/02/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	16/02/2021	12:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	16/02/2021	12:35	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	16/02/2021	12:40	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	16/02/2021	13:05	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	16/02/2021	13:10	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	16/02/2021	13:25	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	16/02/2021	13:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	16/02/2021	12:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	16/02/2021	11:35	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	16/02/2021	11:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	16/02/2021	11:25	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	16/02/2021	12:05	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	16/02/2021	12:35	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	16/02/2021	12:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	16/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	16/02/2021	13:10	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	16/02/2021	13:25	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	16/02/2021	13:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	16/02/2021	12:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	16/02/2021	11:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	16/02/2021	11:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	16/02/2021	11:25	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	16/02/2021	12:05	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	16/02/2021	11:40	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	16/02/2021	12:35	6.8	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	16/02/2021	12:40	6.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	16/02/2021	13:05	7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	16/02/2021	13:10	6.5	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	16/02/2021	13:25	7.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	16/02/2021	13:30	7.1	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	16/02/2021	12:10	8.3	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	16/02/2021	11:35	6.6	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	16/02/2021	11:40	6.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	16/02/2021	11:25	6.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	16/02/2021	12:05	8.4	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	16/02/2021	12:35	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	16/02/2021	12:40	1.3	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	16/02/2021	13:05	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	16/02/2021	13:10	0.29	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	16/02/2021	13:25	0.51	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	16/02/2021	13:30	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	16/02/2021	11:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	16/02/2021	11:25	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	16/02/2021	12:35	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	16/02/2021	12:40	1.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	16/02/2021	13:05	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	16/02/2021	13:10	0.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	16/02/2021	13:25	0.7	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	16/02/2021	13:30	1.2	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	16/02/2021	11:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	16/02/2021	11:25	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	16/02/2021	12:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	16/02/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	16/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	16/02/2021	12:35	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/02/2021	13:05	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/02/2021	13:10	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/02/2021	13:05	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/02/2021	13:10	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/02/2021	12:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/02/2021	11:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/02/2021	12:05	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	16/02/2021	12:35	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	16/02/2021	12:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	16/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	16/02/2021	13:10	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	16/02/2021	13:25	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	16/02/2021	13:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	16/02/2021	12:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	16/02/2021	11:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	16/02/2021	11:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	16/02/2021	11:25	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	16/02/2021	12:05	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	16/02/2021	11:45	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	16/02/2021	12:35	1.3	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	16/02/2021	12:35	1.4	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	16/02/2021	12:35	0.12	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	16/02/2021	12:35	8.9	Deg C	
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/02/2021	12:35	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/02/2021	12:35	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	17/02/2021	12:10	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	17/02/2021	12:15	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	17/02/2021	12:45	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	17/02/2021	12:50	8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	17/02/2021	11:50	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	17/02/2021	11:55	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	17/02/2021	11:05	7.7		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	17/02/2021	10:45	7.7		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	17/02/2021	10:35	7.3		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	17/02/2021	10:40	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	17/02/2021	11:00	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	17/02/2021	12:10	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	17/02/2021	12:15	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	17/02/2021	12:45	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	17/02/2021	12:50	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	17/02/2021	11:50	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	17/02/2021	11:55	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	17/02/2021	11:05	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	17/02/2021	10:45	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	17/02/2021	10:35	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	17/02/2021	10:40	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	17/02/2021	11:00	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	17/02/2021	12:10	65	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	17/02/2021	12:15	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	17/02/2021	12:45	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	17/02/2021	12:50	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	17/02/2021	11:50	66	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	17/02/2021	11:55	66	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	17/02/2021	11:05	65	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	17/02/2021	10:45	65	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	17/02/2021	10:35	64	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	17/02/2021	10:40	64	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	17/02/2021	11:00	66	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	17/02/2021	12:10	18.4	g/m³	

	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	17/02/2021	12:15	18.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	17/02/2021	12:45	18.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	17/02/2021	12:50	19	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	17/02/2021	11:50	18.6	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	17/02/2021	11:55	18.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	17/02/2021	11:05	18.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	17/02/2021	10:45	18.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	17/02/2021	10:35	17.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	17/02/2021	10:40	17.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	17/02/2021	11:00	18.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	17/02/2021	12:10	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	17/02/2021	12:15	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	17/02/2021	12:45	16.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	17/02/2021	12:50	16.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	17/02/2021	11:50	16.5	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	17/02/2021	11:55	16.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	17/02/2021	11:05	12.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	17/02/2021	10:45	12.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	17/02/2021	10:35	15.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	17/02/2021	10:40	15.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	17/02/2021	11:00	12.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	17/02/2021	12:10	38	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	17/02/2021	12:15	38	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	17/02/2021	12:45	40.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	17/02/2021	12:50	40.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	17/02/2021	11:50	38.2	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	17/02/2021	11:55	38.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	17/02/2021	11:05	33.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	17/02/2021	10:45	33.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	17/02/2021	10:35	32.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	17/02/2021	10:40	32.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	17/02/2021	11:00	33	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	17/02/2021	12:10	147	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	17/02/2021	12:15	157	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	17/02/2021	12:45	153	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	17/02/2021	12:50	160	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	17/02/2021	11:50	147	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	17/02/2021	11:55	158	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	17/02/2021	11:05	142	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	17/02/2021	10:45	155	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	17/02/2021	10:35	150	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	17/02/2021	10:40	149	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	17/02/2021	11:00	149	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	17/02/2021	12:10	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	17/02/2021	12:10	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	17/02/2021	12:15	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	17/02/2021	12:45	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	17/02/2021	12:50	0.029	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	17/02/2021	11:50	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	17/02/2021	11:55	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	17/02/2021	10:35	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	17/02/2021	10:40	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	17/02/2021	12:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	17/02/2021	12:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	17/02/2021	12:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	17/02/2021	12:50	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	17/02/2021	11:50	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	17/02/2021	11:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	17/02/2021	10:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	17/02/2021	10:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	17/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	17/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	17/02/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	17/02/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	17/02/2021	11:50	0.0005	g/m³	(.004 - .004)

	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	17/02/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	17/02/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	17/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	17/02/2021	12:10	22.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	17/02/2021	12:15	22.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	17/02/2021	12:45	23.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	17/02/2021	12:50	24.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	17/02/2021	11:50	23.2	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	17/02/2021	11:55	22.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	17/02/2021	10:35	21.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	17/02/2021	10:40	21.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	17/02/2021	12:10	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	17/02/2021	12:15	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	17/02/2021	12:45	0.0061	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	17/02/2021	12:50	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	17/02/2021	11:50	0.002	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	17/02/2021	11:55	0.0013	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	17/02/2021	10:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	17/02/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	17/02/2021	12:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	17/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	17/02/2021	12:45	0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	17/02/2021	12:50	0.52	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	17/02/2021	11:50	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	17/02/2021	11:55	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	17/02/2021	10:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	17/02/2021	10:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	17/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	17/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	17/02/2021	12:45	0.0008	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	17/02/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	17/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	17/02/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	17/02/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	17/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	17/02/2021	12:10	12.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	17/02/2021	12:15	12.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	17/02/2021	12:45	12.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	17/02/2021	12:50	12.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	17/02/2021	11:50	12.1	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	17/02/2021	11:55	12.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	17/02/2021	10:35	11.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	17/02/2021	10:40	11.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	17/02/2021	12:10	0.0063	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	17/02/2021	12:15	0.009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	17/02/2021	12:45	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	17/02/2021	12:50	0.0087	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	17/02/2021	11:50	0.0023	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	17/02/2021	11:55	0.002	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	17/02/2021	10:35	0.0184	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	17/02/2021	10:40	0.0158	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	17/02/2021	12:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	17/02/2021	12:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	17/02/2021	12:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	17/02/2021	12:50	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	17/02/2021	11:50	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	17/02/2021	11:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	17/02/2021	10:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	17/02/2021	10:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	17/02/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	17/02/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	17/02/2021	12:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	17/02/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	17/02/2021	11:50	0.0014	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	17/02/2021	11:55	<0.0005	g/m³	(.08 - .08)

	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	17/02/2021	10:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	17/02/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	17/02/2021	12:10	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	17/02/2021	12:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	17/02/2021	12:45	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	17/02/2021	12:50	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	17/02/2021	11:50	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	17/02/2021	11:55	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	17/02/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	17/02/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	17/02/2021	10:50	170,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	17/02/2021	10:50	43.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	17/02/2021	10:50	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	17/02/2021	10:50	5,130	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	17/02/2021	10:50	23.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	17/02/2021	10:50	17,400	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	17/02/2021	10:50	2.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	17/02/2021	10:50	1,240	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	17/02/2021	10:50	755	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	17/02/2021	10:50	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	17/02/2021	10:50	12	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	17/02/2021	10:50	33	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	17/02/2021	11:05	0.015	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	17/02/2021	10:45	0.013	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	17/02/2021	11:00	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	17/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	17/02/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	17/02/2021	11:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	17/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	17/02/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	17/02/2021	11:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	17/02/2021	11:05	19.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	17/02/2021	10:45	20.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	17/02/2021	11:00	20.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	17/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	17/02/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	17/02/2021	11:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	17/02/2021	11:05	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	17/02/2021	10:45	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	17/02/2021	11:00	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	17/02/2021	11:05	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	17/02/2021	10:45	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	17/02/2021	11:00	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	17/02/2021	11:05	11.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	17/02/2021	10:45	11.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	17/02/2021	11:00	11.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	17/02/2021	11:05	0.026	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	17/02/2021	10:45	0.016	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	17/02/2021	11:00	0.027	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	17/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	17/02/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	17/02/2021	11:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	17/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	17/02/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	17/02/2021	11:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	17/02/2021	11:05	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	17/02/2021	10:45	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	17/02/2021	11:00	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	17/02/2021	12:10	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	17/02/2021	12:15	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	17/02/2021	12:45	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	17/02/2021	12:50	0.017	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	17/02/2021	11:50	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	17/02/2021	11:55	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	17/02/2021	11:05	0.002	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	17/02/2021	10:45	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	17/02/2021	10:35	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	17/02/2021	10:40	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	17/02/2021	11:00	0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	17/02/2021	12:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	17/02/2021	12:15	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	17/02/2021	12:45	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	17/02/2021	12:50	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	17/02/2021	11:50	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	17/02/2021	11:55	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	17/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	17/02/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	17/02/2021	10:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	17/02/2021	10:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	17/02/2021	11:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	17/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	17/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	17/02/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	17/02/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	17/02/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	17/02/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	17/02/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	17/02/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	17/02/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	17/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	17/02/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	17/02/2021	12:10	23	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	17/02/2021	12:15	22.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	17/02/2021	12:45	23.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	17/02/2021	12:50	24.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	17/02/2021	11:50	23	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	17/02/2021	11:55	22.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	17/02/2021	11:05	21.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	17/02/2021	10:45	21.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	17/02/2021	10:35	21.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	17/02/2021	10:40	21.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	17/02/2021	11:00	21.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	17/02/2021	12:10	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	17/02/2021	12:15	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	17/02/2021	12:45	0.0056	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	17/02/2021	12:50	0.0007	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	17/02/2021	11:50	0.0018	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	17/02/2021	11:55	0.0009	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	17/02/2021	11:05	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	17/02/2021	10:45	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	17/02/2021	10:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	17/02/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	17/02/2021	11:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	17/02/2021	12:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	17/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	17/02/2021	12:45	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	17/02/2021	12:50	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	17/02/2021	11:50	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	17/02/2021	11:55	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	17/02/2021	11:05	0.11	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	17/02/2021	10:45	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	17/02/2021	10:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	17/02/2021	10:40	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	17/02/2021	11:00	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	17/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	17/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	17/02/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	17/02/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	17/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	17/02/2021	11:55	<0.0005	g/m³	(.005 - .01)

	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	17/02/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	17/02/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	17/02/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	17/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	17/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	17/02/2021	12:10	12.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	17/02/2021	12:15	12.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	17/02/2021	12:45	12.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	17/02/2021	12:50	12.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	17/02/2021	11:50	12.2	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	17/02/2021	11:55	12.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	17/02/2021	11:05	11.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	17/02/2021	10:45	11.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	17/02/2021	10:35	11.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	17/02/2021	10:40	1.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	17/02/2021	11:00	11.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	17/02/2021	12:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	17/02/2021	12:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	17/02/2021	12:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	17/02/2021	12:50	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	17/02/2021	11:50	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	17/02/2021	11:55	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	17/02/2021	11:05	0.0222	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	17/02/2021	10:45	0.0093	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	17/02/2021	10:35	0.0186	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	17/02/2021	10:40	0.0159	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	17/02/2021	11:00	0.0218	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	17/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	17/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	17/02/2021	12:45	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	17/02/2021	12:50	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	17/02/2021	11:50	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	17/02/2021	11:55	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	17/02/2021	11:05	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	17/02/2021	10:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	17/02/2021	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	17/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	17/02/2021	11:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	17/02/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	17/02/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	17/02/2021	12:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	17/02/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	17/02/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	17/02/2021	11:55	0.0006	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	17/02/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	17/02/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	17/02/2021	10:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	17/02/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	17/02/2021	11:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	17/02/2021	12:10	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	17/02/2021	12:15	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	17/02/2021	12:45	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	17/02/2021	12:50	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	17/02/2021	11:50	0.005	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	17/02/2021	11:55	0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	17/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	17/02/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	17/02/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	17/02/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	17/02/2021	11:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	17/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	17/02/2021	12:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	17/02/2021	12:45	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	17/02/2021	12:50	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	17/02/2021	11:50	Completed		

	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	17/02/2021	11:55	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	17/02/2021	11:05	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	17/02/2021	10:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	17/02/2021	10:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	17/02/2021	10:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	17/02/2021	11:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	17/02/2021	10:35	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	17/02/2021	12:10	9.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	17/02/2021	12:15	8.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	17/02/2021	12:45	8.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	17/02/2021	12:50	7.8	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	17/02/2021	11:50	9.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	17/02/2021	11:55	8.7	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	17/02/2021	11:05	9.2	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	17/02/2021	10:45	9.2	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	17/02/2021	10:35	8.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	17/02/2021	10:40	8.9	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	17/02/2021	11:00	9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	17/02/2021	12:10	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	17/02/2021	12:15	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	17/02/2021	12:45	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	17/02/2021	12:50	0.12	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	17/02/2021	11:50	0.36	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	17/02/2021	11:55	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	17/02/2021	10:35	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	17/02/2021	10:40	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	17/02/2021	12:10	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	17/02/2021	12:15	1.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	17/02/2021	12:45	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	17/02/2021	12:50	0.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	17/02/2021	11:50	0.5	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	17/02/2021	11:55	1.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	17/02/2021	10:35	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	17/02/2021	10:40	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	17/02/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	17/02/2021	11:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	17/02/2021	11:05	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	17/02/2021	12:10	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	17/02/2021	12:45	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	17/02/2021	12:50	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	17/02/2021	12:45	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	17/02/2021	12:50	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	17/02/2021	11:05	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	17/02/2021	10:45	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	17/02/2021	11:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	17/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	17/02/2021	12:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	17/02/2021	12:45	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	17/02/2021	12:50	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	17/02/2021	11:50	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	17/02/2021	11:55	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	17/02/2021	11:05	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	17/02/2021	10:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	17/02/2021	10:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	17/02/2021	10:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	17/02/2021	11:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	17/02/2021	10:50	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	18/02/2021	09:10	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	18/02/2021	09:15	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	18/02/2021	09:50	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	18/02/2021	09:55	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	18/02/2021	09:00	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	18/02/2021	09:05	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	18/02/2021	08:15	7.6		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	18/02/2021	07:55	7.4		(1 - 14)

	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	18/02/2021	07:45	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	18/02/2021	07:50	7.4		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	18/02/2021	08:10	7.6		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	18/02/2021	09:10	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	18/02/2021	09:15	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	18/02/2021	09:50	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	18/02/2021	09:55	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	18/02/2021	09:00	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	18/02/2021	09:05	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	18/02/2021	08:15	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	18/02/2021	07:55	28	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	18/02/2021	07:45	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	18/02/2021	07:50	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	18/02/2021	08:10	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	18/02/2021	09:10	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	18/02/2021	09:15	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	18/02/2021	09:50	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	18/02/2021	09:55	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	18/02/2021	09:00	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	18/02/2021	09:05	70	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	18/02/2021	08:15	66	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	18/02/2021	07:55	65	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	18/02/2021	07:45	67	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	18/02/2021	07:50	62	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	18/02/2021	08:10	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	18/02/2021	09:10	18.8	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	18/02/2021	09:15	18.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	18/02/2021	09:50	18.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	18/02/2021	09:55	18.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	18/02/2021	09:00	18.7	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	18/02/2021	09:05	18.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	18/02/2021	08:15	18.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	18/02/2021	07:55	17.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	18/02/2021	07:45	18.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	18/02/2021	07:50	17.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	18/02/2021	08:10	18.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	18/02/2021	09:10	16.5	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	18/02/2021	09:15	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	18/02/2021	09:50	16.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	18/02/2021	09:55	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	18/02/2021	09:00	16.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	18/02/2021	09:05	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	18/02/2021	08:15	12.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	18/02/2021	07:55	18.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	18/02/2021	07:45	14.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	18/02/2021	07:50	16.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	18/02/2021	08:10	12.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	18/02/2021	09:10	38.5	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	18/02/2021	09:15	38.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	18/02/2021	09:50	39.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	18/02/2021	09:55	38.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	18/02/2021	09:00	38.5	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	18/02/2021	09:05	38.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	18/02/2021	08:15	37.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	18/02/2021	07:55	35.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	18/02/2021	07:45	36.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	18/02/2021	07:50	36.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	18/02/2021	08:10	37.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:10	159	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:15	159	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:50	158	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:55	163	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:00	155	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	18/02/2021	09:05	154	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	18/02/2021	08:15	141	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	18/02/2021	07:55	146	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	18/02/2021	07:45	136	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	18/02/2021	07:50	153	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	18/02/2021	08:10	149	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	18/02/2021	09:10	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	18/02/2021	09:10	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	18/02/2021	09:15	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	18/02/2021	09:50	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	18/02/2021	09:55	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	18/02/2021	09:00	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	18/02/2021	09:05	0.015	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	18/02/2021	07:45	0.012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	18/02/2021	07:50	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	18/02/2021	09:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	18/02/2021	09:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	18/02/2021	09:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	18/02/2021	09:55	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	18/02/2021	09:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	18/02/2021	09:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	18/02/2021	07:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	18/02/2021	07:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	18/02/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	18/02/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	18/02/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	18/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	18/02/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	18/02/2021	09:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	18/02/2021	07:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	18/02/2021	07:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	18/02/2021	09:10	22.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	18/02/2021	09:15	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	18/02/2021	09:50	23.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	18/02/2021	09:55	23.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	18/02/2021	09:00	22.9	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	18/02/2021	09:05	22.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	18/02/2021	07:45	22.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	18/02/2021	07:50	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	18/02/2021	09:10	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	18/02/2021	09:15	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	18/02/2021	09:50	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	18/02/2021	09:55	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	18/02/2021	09:00	0.0018	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	18/02/2021	09:05	0.0011	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	18/02/2021	07:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	18/02/2021	07:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	18/02/2021	09:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	18/02/2021	09:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	18/02/2021	09:50	0.03	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	18/02/2021	09:55	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	18/02/2021	09:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	18/02/2021	09:05	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	18/02/2021	07:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	18/02/2021	07:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	18/02/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	18/02/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	18/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	18/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	18/02/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	18/02/2021	09:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	18/02/2021	07:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	18/02/2021	07:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	18/02/2021	09:10	12.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	18/02/2021	09:15	12.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	18/02/2021	09:50	12.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	18/02/2021	09:55	12.5	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	18/02/2021	09:00	12.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	18/02/2021	09:05	12.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	18/02/2021	07:45	12.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	18/02/2021	07:50	12.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	18/02/2021	09:10	0.0052	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	18/02/2021	09:15	0.005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	18/02/2021	09:50	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	18/02/2021	09:55	0.0007	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	18/02/2021	09:00	0.0023	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	18/02/2021	09:05	0.0024	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	18/02/2021	07:45	0.019	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	18/02/2021	07:50	0.0161	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	18/02/2021	09:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	18/02/2021	09:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	18/02/2021	09:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	18/02/2021	09:55	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	18/02/2021	09:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	18/02/2021	09:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	18/02/2021	07:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	18/02/2021	07:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	18/02/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	18/02/2021	09:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	18/02/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	18/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	18/02/2021	09:00	0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	18/02/2021	09:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	18/02/2021	07:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	18/02/2021	07:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	18/02/2021	09:10	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	18/02/2021	09:15	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	18/02/2021	09:50	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	18/02/2021	09:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	18/02/2021	09:00	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	18/02/2021	09:05	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	18/02/2021	07:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	18/02/2021	07:50	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	18/02/2021	08:05	459,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	18/02/2021	08:05	66	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	18/02/2021	08:05	0.13	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	18/02/2021	08:05	11,500	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	18/02/2021	08:05	34.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	18/02/2021	08:05	32,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	18/02/2021	08:05	5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	18/02/2021	08:05	1,430	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	18/02/2021	08:05	1,950	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	18/02/2021	08:05	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	18/02/2021	08:05	26.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	18/02/2021	08:05	64	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	18/02/2021	08:15	0.04	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	18/02/2021	07:55	6.77	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	18/02/2021	08:10	0.02	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	18/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	18/02/2021	07:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	18/02/2021	08:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	18/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	18/02/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	18/02/2021	08:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	18/02/2021	08:15	21	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	18/02/2021	07:55	21.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	18/02/2021	08:10	21.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	18/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	18/02/2021	07:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	18/02/2021	08:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	18/02/2021	08:15	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	18/02/2021	07:55	0.2	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	18/02/2021	08:10	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	18/02/2021	08:15	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	18/02/2021	07:55	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	18/02/2021	08:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	18/02/2021	08:15	12.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	18/02/2021	07:55	12.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	18/02/2021	08:10	12.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	18/02/2021	08:15	0.027	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	18/02/2021	07:55	0.02	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	18/02/2021	08:10	0.03	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	18/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	18/02/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	18/02/2021	08:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	18/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	18/02/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	18/02/2021	08:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	18/02/2021	08:15	0.007	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	18/02/2021	07:55	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	18/02/2021	08:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	18/02/2021	09:10	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	18/02/2021	09:15	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	18/02/2021	09:50	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	18/02/2021	09:55	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	18/02/2021	09:00	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	18/02/2021	09:05	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	18/02/2021	08:15	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	18/02/2021	07:55	0.619	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	18/02/2021	07:45	0.011	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	18/02/2021	07:50	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	18/02/2021	08:10	0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	18/02/2021	09:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	18/02/2021	09:15	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	18/02/2021	09:50	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	18/02/2021	09:55	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	18/02/2021	09:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	18/02/2021	09:05	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	18/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	18/02/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	18/02/2021	07:45	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	18/02/2021	07:50	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	18/02/2021	08:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	18/02/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	18/02/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	18/02/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	18/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	18/02/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	18/02/2021	09:05	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	18/02/2021	08:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	18/02/2021	07:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	18/02/2021	07:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	18/02/2021	07:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	18/02/2021	08:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	18/02/2021	09:10	22.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	18/02/2021	09:15	22.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	18/02/2021	09:50	23.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	18/02/2021	09:55	23.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	18/02/2021	09:00	23.3	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	18/02/2021	09:05	22.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	18/02/2021	08:15	22.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	18/02/2021	07:55	22.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	18/02/2021	07:45	22.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	18/02/2021	07:50	22.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	18/02/2021	08:10	22.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	18/02/2021	09:10	0.0022	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	18/02/2021	09:15	0.0012	g/m³	(2 - 2)

	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	18/02/2021	09:50	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	18/02/2021	09:55	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	18/02/2021	09:00	0.0018	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	18/02/2021	09:05	0.0011	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	18/02/2021	08:15	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	18/02/2021	07:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	18/02/2021	07:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	18/02/2021	07:50	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	18/02/2021	08:10	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	18/02/2021	09:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	18/02/2021	09:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	18/02/2021	09:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	18/02/2021	09:55	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	18/02/2021	09:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	18/02/2021	09:05	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	18/02/2021	08:15	0.13	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	18/02/2021	07:55	0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	18/02/2021	07:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	18/02/2021	07:50	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	18/02/2021	08:10	0.12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	18/02/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	18/02/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	18/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	18/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	18/02/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	18/02/2021	09:05	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	18/02/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	18/02/2021	07:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	18/02/2021	07:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	18/02/2021	07:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	18/02/2021	08:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	18/02/2021	09:10	12.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	18/02/2021	09:15	12.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	18/02/2021	09:50	12.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	18/02/2021	09:55	12.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	18/02/2021	09:00	12.3	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	18/02/2021	09:05	12.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	18/02/2021	08:15	12.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	18/02/2021	07:55	12.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	18/02/2021	07:45	12.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	18/02/2021	07:50	12.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	18/02/2021	08:10	12.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	18/02/2021	09:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	18/02/2021	09:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	18/02/2021	09:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	18/02/2021	09:55	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	18/02/2021	09:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	18/02/2021	09:05	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	18/02/2021	08:15	0.0209	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	18/02/2021	07:55	0.0107	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	18/02/2021	07:45	0.0194	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	18/02/2021	07:50	0.0053	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	18/02/2021	08:10	0.0216	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	18/02/2021	09:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	18/02/2021	09:15	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	18/02/2021	09:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	18/02/2021	09:55	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	18/02/2021	09:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	18/02/2021	09:05	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	18/02/2021	08:15	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	18/02/2021	07:55	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	18/02/2021	07:45	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	18/02/2021	07:50	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	18/02/2021	08:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	18/02/2021	09:10	0.0015	g/m³	(.08 - .08)

	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	18/02/2021	09:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	18/02/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	18/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	18/02/2021	09:00	0.0009	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	18/02/2021	09:05	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	18/02/2021	08:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	18/02/2021	07:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	18/02/2021	07:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	18/02/2021	07:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	18/02/2021	08:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	18/02/2021	09:10	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	18/02/2021	09:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	18/02/2021	09:50	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	18/02/2021	09:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	18/02/2021	09:00	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	18/02/2021	09:05	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	18/02/2021	08:15	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	18/02/2021	07:55	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	18/02/2021	07:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	18/02/2021	07:50	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	18/02/2021	08:10	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	18/02/2021	09:10	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	18/02/2021	09:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	18/02/2021	09:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	18/02/2021	09:55	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	18/02/2021	09:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	18/02/2021	09:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	18/02/2021	08:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	18/02/2021	07:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	18/02/2021	07:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	18/02/2021	07:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	18/02/2021	08:10	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	18/02/2021	07:45	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:10	7.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:15	8.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:50	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:55	7.1	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:00	7.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	18/02/2021	09:05	7.9	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	18/02/2021	08:15	7.4	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	18/02/2021	07:55	7.5	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	18/02/2021	07:45	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	18/02/2021	07:50	7.2	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	18/02/2021	08:10	7.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	18/02/2021	09:10	0.1	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	18/02/2021	09:15	0.66	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	18/02/2021	09:50	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	18/02/2021	09:55	0.09	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	18/02/2021	09:00	0.24	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	18/02/2021	09:05	1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	18/02/2021	07:45	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	18/02/2021	07:50	1.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	18/02/2021	09:10	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	18/02/2021	09:15	0.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	18/02/2021	09:50	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	18/02/2021	09:55	0.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	18/02/2021	09:00	0.3	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	18/02/2021	09:05	1.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	18/02/2021	07:45	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	18/02/2021	07:50	1.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	18/02/2021	09:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	18/02/2021	08:15	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	18/02/2021	08:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	18/02/2021	09:10	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	18/02/2021	09:50	<1	MPN/100mL	(0 - 0)

	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	18/02/2021	09:55	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	18/02/2021	09:50	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	18/02/2021	09:55	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	18/02/2021	08:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	18/02/2021	07:55	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	18/02/2021	08:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	18/02/2021	09:10	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	18/02/2021	09:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	18/02/2021	09:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	18/02/2021	09:55	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	18/02/2021	09:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	18/02/2021	09:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	18/02/2021	08:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	18/02/2021	07:55	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	18/02/2021	07:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	18/02/2021	07:50	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	18/02/2021	08:10	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	18/02/2021	08:05	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	19/02/2021	14:30	0.38	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0066H	Total Chlorine	19/02/2021	14:30	0.5	g/m³	
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	19/02/2021	14:30	0.18	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	19/02/2021	14:30	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	19/02/2021	14:30	8.4	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/02/2021	14:30	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/02/2021	14:30	1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	19/02/2021	11:40	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	19/02/2021	11:50	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	19/02/2021	12:20	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	19/02/2021	12:30	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	19/02/2021	14:00	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	19/02/2021	14:10	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	19/02/2021	11:05	7.7		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	19/02/2021	10:40	7.6		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	19/02/2021	10:30	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	19/02/2021	11:10	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	19/02/2021	11:40	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	19/02/2021	11:50	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	19/02/2021	12:20	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	19/02/2021	12:30	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	19/02/2021	14:00	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	19/02/2021	14:10	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	19/02/2021	11:05	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	19/02/2021	10:40	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	19/02/2021	10:30	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	19/02/2021	11:10	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	19/02/2021	11:40	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	19/02/2021	11:50	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	19/02/2021	12:20	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	19/02/2021	12:30	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	19/02/2021	14:00	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	19/02/2021	14:10	71	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	19/02/2021	11:05	67	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	19/02/2021	10:40	65	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	19/02/2021	10:30	69	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	19/02/2021	11:10	68	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	19/02/2021	11:40	18.9	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	19/02/2021	11:50	18.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	19/02/2021	12:20	18.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	19/02/2021	12:30	18.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	19/02/2021	14:00	18.9	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	19/02/2021	14:10	18.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	19/02/2021	11:05	18.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	19/02/2021	10:40	18.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	19/02/2021	10:30	18.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	19/02/2021	11:10	18.3	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	19/02/2021	11:40	15.9	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	19/02/2021	11:50	15.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	19/02/2021	12:20	16.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	19/02/2021	12:30	16.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	19/02/2021	14:00	16.1	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	19/02/2021	14:10	16.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	19/02/2021	11:05	12.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	19/02/2021	10:40	14.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	19/02/2021	10:30	15.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	19/02/2021	11:10	12.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	19/02/2021	11:40	37.6	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	19/02/2021	11:50	37.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	19/02/2021	12:20	37.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	19/02/2021	12:30	37.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	19/02/2021	14:00	37.6	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	19/02/2021	14:10	37.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	19/02/2021	11:05	36.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	19/02/2021	10:40	36.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	19/02/2021	10:30	37.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	19/02/2021	11:10	36.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	19/02/2021	11:40	140	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	19/02/2021	11:50	141	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	19/02/2021	12:20	153	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	19/02/2021	12:30	153	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	19/02/2021	14:00	137	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	19/02/2021	14:10	146	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	19/02/2021	11:05	146	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	19/02/2021	10:40	153	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	19/02/2021	10:30	148	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	19/02/2021	11:10	147	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	19/02/2021	11:40	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	19/02/2021	11:40	0.015	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	19/02/2021	11:50	0.019	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	19/02/2021	12:20	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	19/02/2021	12:30	0.015	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	19/02/2021	14:00	0.017	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	19/02/2021	14:10	0.016	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	19/02/2021	10:40	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	19/02/2021	10:30	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	19/02/2021	11:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	19/02/2021	11:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	19/02/2021	12:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	19/02/2021	12:30	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	19/02/2021	14:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	19/02/2021	14:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	19/02/2021	10:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	19/02/2021	10:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	19/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	19/02/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	19/02/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	19/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	19/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	19/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	19/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	19/02/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	19/02/2021	11:40	22.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	19/02/2021	11:50	22.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	19/02/2021	12:20	23.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	19/02/2021	12:30	23.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	19/02/2021	14:00	23.1	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	19/02/2021	14:10	23.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	19/02/2021	10:40	22.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	19/02/2021	10:30	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	19/02/2021	11:40	0.004	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	19/02/2021	11:50	0.0015	g/m³	(2 - 2)

	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	19/02/2021	12:20	0.0058	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	19/02/2021	12:30	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	19/02/2021	14:00	0.0025	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	19/02/2021	14:10	0.0009	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	19/02/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	19/02/2021	10:30	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	19/02/2021	11:40	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	19/02/2021	11:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	19/02/2021	12:20	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	19/02/2021	12:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	19/02/2021	14:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	19/02/2021	14:10	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	19/02/2021	10:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	19/02/2021	10:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	19/02/2021	11:40	0.0016	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	19/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	19/02/2021	12:20	0.0034	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	19/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	19/02/2021	14:00	0.0006	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	19/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	19/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	19/02/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	19/02/2021	11:40	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	19/02/2021	11:50	12.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	19/02/2021	12:20	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	19/02/2021	12:30	11.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	19/02/2021	14:00	12.1	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	19/02/2021	14:10	12.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	19/02/2021	10:40	12.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	19/02/2021	10:30	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	19/02/2021	11:40	0.0058	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	19/02/2021	11:50	0.0048	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	19/02/2021	12:20	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	19/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	19/02/2021	14:00	0.003	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	19/02/2021	14:10	0.0016	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	19/02/2021	10:40	0.0151	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	19/02/2021	10:30	0.0131	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	19/02/2021	11:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	19/02/2021	11:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	19/02/2021	12:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	19/02/2021	12:30	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	19/02/2021	14:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	19/02/2021	14:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	19/02/2021	10:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	19/02/2021	10:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	19/02/2021	11:40	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	19/02/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	19/02/2021	12:20	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	19/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	19/02/2021	14:00	0.0013	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	19/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	19/02/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	19/02/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	19/02/2021	11:40	0.043	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	19/02/2021	11:50	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	19/02/2021	12:20	0.089	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	19/02/2021	12:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	19/02/2021	14:00	0.035	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	19/02/2021	14:10	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	19/02/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	19/02/2021	10:30	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	19/02/2021	11:00	152,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	19/02/2021	11:00	24	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	19/02/2021	11:00	<0.10	mg/Kg	

	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	19/02/2021	11:00	7,750	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	19/02/2021	11:00	19.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	19/02/2021	11:00	13,700	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	19/02/2021	11:00	2.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	19/02/2021	11:00	2,010	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	19/02/2021	11:00	2,040	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	19/02/2021	11:00	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	19/02/2021	11:00	10.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	19/02/2021	11:00	32	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	19/02/2021	11:05	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	19/02/2021	11:10	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	19/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	19/02/2021	11:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	19/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	19/02/2021	11:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	19/02/2021	11:05	20.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	19/02/2021	11:10	21.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	19/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	19/02/2021	11:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	19/02/2021	11:05	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	19/02/2021	11:10	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	19/02/2021	11:05	0.002	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	19/02/2021	11:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	19/02/2021	11:05	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	19/02/2021	11:10	11.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	19/02/2021	11:05	0.034	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	19/02/2021	11:10	0.029	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	19/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	19/02/2021	11:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	19/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	19/02/2021	11:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	19/02/2021	11:05	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	19/02/2021	11:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	19/02/2021	11:40	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	19/02/2021	11:50	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	19/02/2021	12:20	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	19/02/2021	12:30	0.014	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	19/02/2021	14:00	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	19/02/2021	14:10	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	19/02/2021	11:05	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	19/02/2021	10:40	0.008	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	19/02/2021	10:30	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	19/02/2021	11:10	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	19/02/2021	11:40	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	19/02/2021	11:50	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	19/02/2021	12:20	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	19/02/2021	12:30	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	19/02/2021	14:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	19/02/2021	14:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	19/02/2021	11:05	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	19/02/2021	10:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	19/02/2021	10:30	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	19/02/2021	11:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	19/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	19/02/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	19/02/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	19/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	19/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	19/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	19/02/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	19/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	19/02/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	19/02/2021	11:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	19/02/2021	11:40	21.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	19/02/2021	11:50	21.8	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	19/02/2021	12:20	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	19/02/2021	12:30	22.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	19/02/2021	14:00	22	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	19/02/2021	14:10	22.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	19/02/2021	11:05	21.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	19/02/2021	10:40	22.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	19/02/2021	10:30	21.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	19/02/2021	11:10	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	19/02/2021	11:40	0.004	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	19/02/2021	11:50	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	19/02/2021	12:20	0.0055	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	19/02/2021	12:30	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	19/02/2021	14:00	0.0025	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	19/02/2021	14:10	0.0009	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	19/02/2021	11:05	0.0007	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	19/02/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	19/02/2021	10:30	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	19/02/2021	11:10	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	19/02/2021	11:40	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	19/02/2021	11:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	19/02/2021	12:20	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	19/02/2021	12:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	19/02/2021	14:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	19/02/2021	14:10	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	19/02/2021	11:05	0.12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	19/02/2021	10:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	19/02/2021	10:30	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	19/02/2021	11:10	0.12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	19/02/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	19/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	19/02/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	19/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	19/02/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	19/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	19/02/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	19/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	19/02/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	19/02/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	19/02/2021	11:40	12.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	19/02/2021	11:50	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	19/02/2021	12:20	11.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	19/02/2021	12:30	11.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	19/02/2021	14:00	11.7	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	19/02/2021	14:10	11.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	19/02/2021	11:05	11.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	19/02/2021	10:40	11.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	19/02/2021	10:30	11.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	19/02/2021	11:10	11.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	19/02/2021	11:40	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	19/02/2021	11:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	19/02/2021	12:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	19/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	19/02/2021	14:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	19/02/2021	14:10	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	19/02/2021	11:05	0.0203	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	19/02/2021	10:40	0.0146	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	19/02/2021	10:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	19/02/2021	11:10	0.0228	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	19/02/2021	11:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	19/02/2021	11:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	19/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	19/02/2021	12:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	19/02/2021	14:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	19/02/2021	14:10	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	19/02/2021	11:05	<0.0005	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	19/02/2021	10:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	19/02/2021	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	19/02/2021	11:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	19/02/2021	11:40	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	19/02/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	19/02/2021	12:20	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	19/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	19/02/2021	14:00	0.0014	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	19/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	19/02/2021	11:05	0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	19/02/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	19/02/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	19/02/2021	11:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	19/02/2021	11:40	0.044	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	19/02/2021	11:50	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	19/02/2021	12:20	0.092	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	19/02/2021	12:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	19/02/2021	14:00	0.038	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	19/02/2021	14:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	19/02/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	19/02/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	19/02/2021	10:30	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	19/02/2021	11:10	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	19/02/2021	11:40	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	19/02/2021	11:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	19/02/2021	12:20	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	19/02/2021	12:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	19/02/2021	14:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	19/02/2021	14:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	19/02/2021	11:05	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	19/02/2021	10:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	19/02/2021	10:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	19/02/2021	11:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	19/02/2021	11:40	6	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	19/02/2021	11:50	6.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	19/02/2021	12:20	5.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	19/02/2021	12:30	5.6	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	19/02/2021	14:00	6.5	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	19/02/2021	14:10	6.5	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	19/02/2021	11:05	6.6	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	19/02/2021	10:40	7.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	19/02/2021	10:30	6.7	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	19/02/2021	11:10	6.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	19/02/2021	11:40	0.27	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	19/02/2021	11:50	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	19/02/2021	12:20	0.25	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	19/02/2021	12:30	0.38	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	19/02/2021	14:00	0.39	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	19/02/2021	14:10	0.91	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	19/02/2021	10:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	19/02/2021	10:30	1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	19/02/2021	11:40	0.9	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	19/02/2021	11:50	1.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	19/02/2021	12:20	0.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	19/02/2021	12:30	0.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	19/02/2021	14:00	1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	19/02/2021	14:10	1.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	19/02/2021	10:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	19/02/2021	10:30	1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	19/02/2021	11:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	19/02/2021	11:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	19/02/2021	11:05	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	19/02/2021	11:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/02/2021	12:20	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/02/2021	12:30	<1	MPN/100mL	(0 - 0)

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/02/2021	12:20	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/02/2021	12:30	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	19/02/2021	11:05	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	19/02/2021	11:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	19/02/2021	11:40	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	19/02/2021	11:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	19/02/2021	12:20	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	19/02/2021	12:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	19/02/2021	14:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	19/02/2021	14:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	19/02/2021	11:05	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	19/02/2021	10:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	19/02/2021	10:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	19/02/2021	11:10	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	19/02/2021	11:00	Completed		
21/6968-02	Karitane Puketeraki Marae 520 Apes Road	D-M1403	Microorganism Identification	19/02/2021	14:30			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	20/02/2021	10:52	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	20/02/2021	10:58	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	20/02/2021	10:35	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	20/02/2021	10:42	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	20/02/2021	11:11	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	20/02/2021	11:16	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	20/02/2021	12:20	7.7		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	20/02/2021	11:40	7.6		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	20/02/2021	11:32	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	20/02/2021	00:00:00	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	20/02/2021	10:52	<4	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	20/02/2021	10:58	<4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	20/02/2021	10:35	<3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	20/02/2021	10:42	<3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	20/02/2021	11:11	<3	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	20/02/2021	11:16	<4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	20/02/2021	12:20	<4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	20/02/2021	11:40	<3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	20/02/2021	11:32	<3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	20/02/2021	00:00:00	<3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	20/02/2021	10:52	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	20/02/2021	10:58	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	20/02/2021	10:35	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	20/02/2021	10:42	69	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	20/02/2021	11:11	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	20/02/2021	11:16	70	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	20/02/2021	12:20	67	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	20/02/2021	11:40	67	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	20/02/2021	11:32	71	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	20/02/2021	00:00:00	68	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	20/02/2021	10:52	18.9	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	20/02/2021	10:58	18.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	20/02/2021	10:35	18.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	20/02/2021	10:42	19	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	20/02/2021	11:11	19.1	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	20/02/2021	11:16	19.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	20/02/2021	12:20	18.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	20/02/2021	11:40	18	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	20/02/2021	11:32	18.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	20/02/2021	00:00:00	18.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	20/02/2021	10:52	15.7	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	20/02/2021	10:58	15.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	20/02/2021	10:35	16	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	20/02/2021	10:42	16	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	20/02/2021	11:11	15.8	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	20/02/2021	11:16	16.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	20/02/2021	12:20	12.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	20/02/2021	11:40	14.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	20/02/2021	11:32	15.9	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	20/02/2021	00:00:00	12.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	20/02/2021	10:52	37.1	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	20/02/2021	10:58	36.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	20/02/2021	10:35	36.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	20/02/2021	10:42	36.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	20/02/2021	11:11	36.9	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	20/02/2021	11:16	36.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	20/02/2021	12:20	34.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	20/02/2021	11:40	34.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	20/02/2021	11:32	36.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	20/02/2021	00:00:00	34.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	20/02/2021	10:52	148	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	20/02/2021	10:58	156	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	20/02/2021	10:35	156	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	20/02/2021	10:42	152	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	20/02/2021	11:11	148	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	20/02/2021	11:16	150	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	20/02/2021	12:20	145	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	20/02/2021	11:40	130	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	20/02/2021	11:32	157	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	20/02/2021	00:00:00	141	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	20/02/2021	10:52	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	20/02/2021	10:52	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	20/02/2021	10:58	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	20/02/2021	10:35	0.024	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	20/02/2021	10:42	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	20/02/2021	11:11	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	20/02/2021	11:16	0.018	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	20/02/2021	11:40	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	20/02/2021	11:32	0.009	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	20/02/2021	10:52	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	20/02/2021	10:58	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	20/02/2021	10:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	20/02/2021	10:42	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	20/02/2021	11:11	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	20/02/2021	11:16	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	20/02/2021	11:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	20/02/2021	11:32	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	20/02/2021	10:52	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	20/02/2021	10:58	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	20/02/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	20/02/2021	10:42	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	20/02/2021	11:11	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	20/02/2021	11:16	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	20/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	20/02/2021	11:32	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	20/02/2021	10:52	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	20/02/2021	10:58	21.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	20/02/2021	10:35	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	20/02/2021	10:42	22.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	20/02/2021	11:11	22.2	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	20/02/2021	11:16	22.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	20/02/2021	11:40	21.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	20/02/2021	11:32	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	20/02/2021	10:52	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	20/02/2021	10:58	0.0017	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	20/02/2021	10:35	0.02	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	20/02/2021	10:42	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	20/02/2021	11:11	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	20/02/2021	11:16	0.001	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	20/02/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	20/02/2021	11:32	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	20/02/2021	10:52	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	20/02/2021	10:58	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	20/02/2021	10:35	0.01	g/m³	

	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	20/02/2021	10:42	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	20/02/2021	11:11	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	20/02/2021	11:16	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	20/02/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	20/02/2021	11:32	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	20/02/2021	10:52	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	20/02/2021	10:58	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	20/02/2021	10:35	0.009	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	20/02/2021	10:42	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	20/02/2021	11:11	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	20/02/2021	11:16	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	20/02/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	20/02/2021	11:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	20/02/2021	10:52	11	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	20/02/2021	10:58	11.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	20/02/2021	10:35	10.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	20/02/2021	10:42	10.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	20/02/2021	11:11	11	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	20/02/2021	11:16	11.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	20/02/2021	11:40	11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	20/02/2021	11:32	11.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	20/02/2021	10:52	0.0035	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	20/02/2021	10:58	0.0049	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	20/02/2021	10:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	20/02/2021	10:42	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	20/02/2021	11:11	0.0013	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	20/02/2021	11:16	0.0018	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	20/02/2021	11:40	0.0231	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	20/02/2021	11:32	0.0157	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	20/02/2021	10:52	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	20/02/2021	10:58	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	20/02/2021	10:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	20/02/2021	10:42	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	20/02/2021	11:11	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	20/02/2021	11:16	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	20/02/2021	11:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	20/02/2021	11:32	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	20/02/2021	10:52	0.0013	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	20/02/2021	10:58	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	20/02/2021	10:35	0.0012	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	20/02/2021	10:42	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	20/02/2021	11:11	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	20/02/2021	11:16	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	20/02/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	20/02/2021	11:32	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	20/02/2021	10:52	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	20/02/2021	10:58	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	20/02/2021	10:35	0.272	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	20/02/2021	10:42	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	20/02/2021	11:11	0.003	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	20/02/2021	11:16	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	20/02/2021	11:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	20/02/2021	11:32	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	20/02/2021	11:50	190,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	20/02/2021	11:50	39.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	20/02/2021	11:50	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	20/02/2021	11:50	6,730	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	20/02/2021	11:50	28.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	20/02/2021	11:50	25,700	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	20/02/2021	11:50	3.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	20/02/2021	11:50	1,880	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	20/02/2021	11:50	1,170	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	20/02/2021	11:50	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	20/02/2021	11:50	11	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	20/02/2021	11:50	39	mg/Kg	

	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	20/02/2021	12:20	0.019	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	20/02/2021	00:00:00	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	20/02/2021	12:20	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	20/02/2021	00:00:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	20/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	20/02/2021	00:00:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	20/02/2021	12:20	21.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	20/02/2021	00:00:00	22.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	20/02/2021	12:20	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	20/02/2021	00:00:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	20/02/2021	12:20	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	20/02/2021	00:00:00	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	20/02/2021	12:20	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	20/02/2021	00:00:00	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	20/02/2021	12:20	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	20/02/2021	00:00:00	11.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	20/02/2021	12:20	0.031	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	20/02/2021	00:00:00	0.029	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	20/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	20/02/2021	00:00:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	20/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	20/02/2021	00:00:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	20/02/2021	12:20	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	20/02/2021	00:00:00	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	20/02/2021	10:52	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	20/02/2021	10:58	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	20/02/2021	10:35	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	20/02/2021	10:42	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	20/02/2021	11:11	0.012	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	20/02/2021	11:16	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	20/02/2021	12:20	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	20/02/2021	11:40	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	20/02/2021	11:32	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	20/02/2021	00:00:00	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	20/02/2021	10:52	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	20/02/2021	10:58	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	20/02/2021	10:35	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	20/02/2021	10:42	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	20/02/2021	11:11	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	20/02/2021	11:16	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	20/02/2021	12:20	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	20/02/2021	11:40	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	20/02/2021	11:32	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	20/02/2021	00:00:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	20/02/2021	10:52	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	20/02/2021	10:58	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	20/02/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	20/02/2021	10:42	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	20/02/2021	11:11	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	20/02/2021	11:16	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	20/02/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	20/02/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	20/02/2021	11:32	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	20/02/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	20/02/2021	10:52	22.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	20/02/2021	10:58	21.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	20/02/2021	10:35	22.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	20/02/2021	10:42	22.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	20/02/2021	11:11	22.2	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	20/02/2021	11:16	22.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	20/02/2021	12:20	21.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	20/02/2021	11:40	21.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	20/02/2021	11:32	21.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	20/02/2021	00:00:00	22	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	20/02/2021	10:52	0.0011	g/m³	(2 - 2)

	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	20/02/2021	10:58	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	20/02/2021	10:35	0.0233	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	20/02/2021	10:42	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	20/02/2021	11:11	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	20/02/2021	11:16	0.0011	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	20/02/2021	12:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	20/02/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	20/02/2021	11:32	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	20/02/2021	00:00:00	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	20/02/2021	10:52	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	20/02/2021	10:58	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	20/02/2021	10:35	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	20/02/2021	10:42	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	20/02/2021	11:11	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	20/02/2021	11:16	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	20/02/2021	12:20	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	20/02/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	20/02/2021	11:32	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	20/02/2021	00:00:00	0.08	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	20/02/2021	10:52	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	20/02/2021	10:58	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	20/02/2021	10:35	0.0155	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	20/02/2021	10:42	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	20/02/2021	11:11	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	20/02/2021	11:16	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	20/02/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	20/02/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	20/02/2021	11:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	20/02/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	20/02/2021	10:52	12.4	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	20/02/2021	10:58	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	20/02/2021	10:35	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	20/02/2021	10:42	11.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	20/02/2021	11:11	11.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	20/02/2021	11:16	11.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	20/02/2021	12:20	11.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	20/02/2021	11:40	10.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	20/02/2021	11:32	11.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	20/02/2021	00:00:00	10.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	20/02/2021	10:52	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	20/02/2021	10:58	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	20/02/2021	10:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	20/02/2021	10:42	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	20/02/2021	11:11	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	20/02/2021	11:16	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	20/02/2021	12:20	0.0153	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	20/02/2021	11:40	0.0214	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	20/02/2021	11:32	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	20/02/2021	00:00:00	0.0128	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	20/02/2021	10:52	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	20/02/2021	10:58	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	20/02/2021	10:35	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	20/02/2021	10:42	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	20/02/2021	11:11	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	20/02/2021	11:16	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	20/02/2021	12:20	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	20/02/2021	11:40	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	20/02/2021	11:32	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	20/02/2021	00:00:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	20/02/2021	10:52	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	20/02/2021	10:58	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	20/02/2021	10:35	0.0011	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	20/02/2021	10:42	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	20/02/2021	11:11	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	20/02/2021	11:16	<0.0005	g/m³	(.08 - .08)

	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	20/02/2021	12:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	20/02/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	20/02/2021	11:32	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	20/02/2021	00:00:00	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	20/02/2021	10:52	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	20/02/2021	10:58	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	20/02/2021	10:35	0.263	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	20/02/2021	10:42	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	20/02/2021	11:11	0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	20/02/2021	11:16	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	20/02/2021	12:20	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	20/02/2021	11:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	20/02/2021	11:32	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	20/02/2021	00:00:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	20/02/2021	10:52	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	20/02/2021	10:58	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	20/02/2021	10:35	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	20/02/2021	10:42	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	20/02/2021	11:11	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	20/02/2021	11:16	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	20/02/2021	12:20	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	20/02/2021	11:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	20/02/2021	11:32	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	20/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	20/02/2021	10:52	7.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	20/02/2021	10:58	6.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	20/02/2021	10:35	6.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	20/02/2021	10:42	6.2	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	20/02/2021	11:11	6.3	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	20/02/2021	11:16	6.3	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	20/02/2021	12:20	7.9	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	20/02/2021	11:40	6.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	20/02/2021	11:32	1.1	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	20/02/2021	00:00:00	8.1	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	20/02/2021	10:52	1	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	20/02/2021	10:58	0.92	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	20/02/2021	10:35	0.23	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	20/02/2021	10:42	0.36	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	20/02/2021	11:11	0.9	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	20/02/2021	11:16	0.91	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	20/02/2021	11:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	20/02/2021	11:32	0.91	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	20/02/2021	10:52	1.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	20/02/2021	10:58	1.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	20/02/2021	10:35	0.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	20/02/2021	10:42	0.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	20/02/2021	11:11	1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	20/02/2021	11:16	1.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	20/02/2021	11:40	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	20/02/2021	11:32	1.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	20/02/2021	10:52	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	20/02/2021	12:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	20/02/2021	12:20	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	20/02/2021	10:52	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	20/02/2021	10:35	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	20/02/2021	10:42	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	20/02/2021	10:35	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	20/02/2021	10:42	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	20/02/2021	00:00:00	No	water	
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	20/02/2021	00:00:00	No	water	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	20/02/2021	12:20	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	20/02/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	20/02/2021	10:52	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	20/02/2021	10:58	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	20/02/2021	10:35	Completed		

	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	20/02/2021	10:42	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	20/02/2021	11:11	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	20/02/2021	11:16	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	20/02/2021	12:20	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	20/02/2021	11:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	20/02/2021	11:32	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	20/02/2021	00:00:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	20/02/2021	11:50	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	20/02/2021	12:48:00	0.3	g/m^3	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0066H	Total Chlorine	20/02/2021	12:48:00	0.4	g/m^3	
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	20/02/2021	12:48:00	0.25	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	20/02/2021	12:48:00	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	20/02/2021	12:48:00	7.4	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	20/02/2021	12:48:00	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	20/02/2021	12:48:00	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	21/02/2021	09:50	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	21/02/2021	09:55	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	21/02/2021	10:10	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	21/02/2021	10:15	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	21/02/2021	09:20	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	21/02/2021	09:25	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	21/02/2021	08:55	7.6		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	21/02/2021	08:40	7.7		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	21/02/2021	08:30	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	21/02/2021	08:35	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	21/02/2021	09:00	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	21/02/2021	09:50	<3	g/m^3	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	21/02/2021	09:55	<3	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	21/02/2021	10:10	<3	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	21/02/2021	10:15	<3	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	21/02/2021	09:20	<3	g/m^3	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	21/02/2021	09:25	<3	g/m^3	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	21/02/2021	08:55	<4	g/m^3	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	21/02/2021	08:40	<3	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	21/02/2021	08:30	<3	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	21/02/2021	08:35	<3	g/m^3	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	21/02/2021	09:00	<3	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	21/02/2021	09:50	71	g $CaCO3/m^3$	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	21/02/2021	09:55	69	g $CaCO3/m^3$	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	21/02/2021	10:10	71	g $CaCO3/m^3$	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	21/02/2021	10:15	71	g $CaCO3/m^3$	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	21/02/2021	09:20	72	g $CaCO3/m^3$	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	21/02/2021	09:25	72	g $CaCO3/m^3$	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	21/02/2021	08:55	69	g $CaCO3/m^3$	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	21/02/2021	08:40	69	g $CaCO3/m^3$	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	21/02/2021	08:30	67	g $CaCO3/m^3$	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	21/02/2021	08:35	67	g $CaCO3/m^3$	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	21/02/2021	09:00	69	g $CaCO3/m^3$	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	21/02/2021	09:50	19.1	g/m^3	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	21/02/2021	09:55	18.9	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	21/02/2021	10:10	19.3	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	21/02/2021	10:15	18.9	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	21/02/2021	09:20	19.1	g/m^3	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	21/02/2021	09:25	19.1	g/m^3	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	21/02/2021	08:55	18.6	g/m^3	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	21/02/2021	08:40	18.5	g/m^3	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	21/02/2021	08:30	18.3	g/m^3	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	21/02/2021	08:35	18.5	g/m^3	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	21/02/2021	09:00	18.6	g/m^3	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	21/02/2021	09:50	16	g/m^3	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	21/02/2021	09:55	15.9	g/m^3	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	21/02/2021	10:10	16	g/m^3	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	21/02/2021	10:15	16.1	g/m^3	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	21/02/2021	09:20	16.1	g/m^3	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	21/02/2021	09:25	16.1	g/m^3	

	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	21/02/2021	08:55	12.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	21/02/2021	08:40	12.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	21/02/2021	08:30	14.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	21/02/2021	08:35	14.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	21/02/2021	09:00	12.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	21/02/2021	09:50	35.8	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	21/02/2021	09:55	35.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	21/02/2021	10:10	36.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	21/02/2021	10:15	36.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	21/02/2021	09:20	35.9	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	21/02/2021	09:25	35.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	21/02/2021	08:55	33.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	21/02/2021	08:40	33.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	21/02/2021	08:30	33.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	21/02/2021	08:35	33.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	21/02/2021	09:00	33.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	21/02/2021	09:50	152	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	21/02/2021	09:55	142	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	21/02/2021	10:10	154	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	21/02/2021	10:15	149	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	21/02/2021	09:20	150	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	21/02/2021	09:25	144	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	21/02/2021	08:55	140	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	21/02/2021	08:40	136	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	21/02/2021	08:30	144	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	21/02/2021	08:35	145	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	21/02/2021	09:00	134	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	21/02/2021	09:50	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	21/02/2021	09:50	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	21/02/2021	09:55	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	21/02/2021	10:10	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	21/02/2021	10:15	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	21/02/2021	09:20	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	21/02/2021	09:25	0.022	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	21/02/2021	08:30	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	21/02/2021	08:35	0.008	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	21/02/2021	09:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	21/02/2021	09:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	21/02/2021	10:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	21/02/2021	10:15	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	21/02/2021	09:20	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	21/02/2021	09:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	21/02/2021	08:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	21/02/2021	08:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	21/02/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	21/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	21/02/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	21/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	21/02/2021	09:20	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	21/02/2021	09:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	21/02/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	21/02/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	21/02/2021	09:50	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	21/02/2021	09:55	22	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	21/02/2021	10:10	23.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	21/02/2021	10:15	22.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	21/02/2021	09:20	22.5	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	21/02/2021	09:25	22.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	21/02/2021	08:30	22.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	21/02/2021	08:35	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	21/02/2021	09:50	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	21/02/2021	09:55	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	21/02/2021	10:10	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	21/02/2021	10:15	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	21/02/2021	09:20	0.0007	g/m³	(2 - 2)

	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	21/02/2021	09:25	0.0007	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	21/02/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	21/02/2021	08:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	21/02/2021	09:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	21/02/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	21/02/2021	10:10	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	21/02/2021	10:15	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	21/02/2021	09:20	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	21/02/2021	09:25	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	21/02/2021	08:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	21/02/2021	08:35	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	21/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	21/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	21/02/2021	10:10	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	21/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	21/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	21/02/2021	09:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	21/02/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	21/02/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	21/02/2021	09:50	11	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	21/02/2021	09:55	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	21/02/2021	10:10	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	21/02/2021	10:15	10.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	21/02/2021	09:20	10.8	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	21/02/2021	09:25	10.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	21/02/2021	08:30	11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	21/02/2021	08:35	10.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	21/02/2021	09:50	0.0086	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	21/02/2021	09:55	0.0061	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	21/02/2021	10:10	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	21/02/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	21/02/2021	09:20	0.0017	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	21/02/2021	09:25	0.0018	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	21/02/2021	08:30	0.0303	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	21/02/2021	08:35	0.0248	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	21/02/2021	09:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	21/02/2021	09:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	21/02/2021	10:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	21/02/2021	10:15	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	21/02/2021	09:20	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	21/02/2021	09:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	21/02/2021	08:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	21/02/2021	08:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	21/02/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	21/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	21/02/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	21/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	21/02/2021	09:20	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	21/02/2021	09:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	21/02/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	21/02/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	21/02/2021	09:50	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	21/02/2021	09:55	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	21/02/2021	10:10	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	21/02/2021	10:15	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	21/02/2021	09:20	0.006	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	21/02/2021	09:25	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	21/02/2021	08:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	21/02/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	21/02/2021	08:45	130,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	21/02/2021	08:45	25.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	21/02/2021	08:45	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	21/02/2021	08:45	6,130	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	21/02/2021	08:45	24.7	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	21/02/2021	08:45	18,900	mg/Kg	

	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	21/02/2021	08:45	4.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	21/02/2021	08:45	1,750	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	21/02/2021	08:45	2,070	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	21/02/2021	08:45	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	21/02/2021	08:45	10.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	21/02/2021	08:45	44	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	21/02/2021	08:55	0.036	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	21/02/2021	08:40	0.012	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	21/02/2021	09:00	0.026	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	21/02/2021	08:55	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	21/02/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	21/02/2021	09:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	21/02/2021	08:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	21/02/2021	08:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	21/02/2021	09:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	21/02/2021	08:55	20.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	21/02/2021	08:40	21.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	21/02/2021	09:00	21.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	21/02/2021	08:55	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	21/02/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	21/02/2021	09:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	21/02/2021	08:55	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	21/02/2021	08:40	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	21/02/2021	09:00	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	21/02/2021	08:55	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	21/02/2021	08:40	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	21/02/2021	09:00	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	21/02/2021	08:55	11.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	21/02/2021	08:40	11.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	21/02/2021	09:00	11.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	21/02/2021	08:55	0.036	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	21/02/2021	08:40	0.02	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	21/02/2021	09:00	0.037	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	21/02/2021	08:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	21/02/2021	08:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	21/02/2021	09:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	21/02/2021	08:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	21/02/2021	08:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	21/02/2021	09:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	21/02/2021	08:55	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	21/02/2021	08:40	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	21/02/2021	09:00	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	21/02/2021	09:50	0.009	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	21/02/2021	09:55	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	21/02/2021	10:10	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	21/02/2021	10:15	0.014	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	21/02/2021	09:20	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	21/02/2021	09:25	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	21/02/2021	08:55	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	21/02/2021	08:40	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	21/02/2021	08:30	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	21/02/2021	08:35	0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	21/02/2021	09:00	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	21/02/2021	09:50	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	21/02/2021	09:55	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	21/02/2021	10:10	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	21/02/2021	10:15	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	21/02/2021	09:20	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	21/02/2021	09:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	21/02/2021	08:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	21/02/2021	08:40	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	21/02/2021	08:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	21/02/2021	08:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	21/02/2021	09:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	21/02/2021	09:50	<0.0002	g/m³	(.004 - .004)

	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	21/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	21/02/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	21/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	21/02/2021	09:20	0.0003	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	21/02/2021	09:25	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	21/02/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	21/02/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	21/02/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	21/02/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	21/02/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	21/02/2021	09:50	21.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	21/02/2021	09:55	22.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	21/02/2021	10:10	22.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	21/02/2021	10:15	22.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	21/02/2021	09:20	22.7	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	21/02/2021	09:25	22.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	21/02/2021	08:55	21.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	21/02/2021	08:40	21.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	21/02/2021	08:30	21.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	21/02/2021	08:35	21.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	21/02/2021	09:00	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	21/02/2021	09:50	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	21/02/2021	09:55	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	21/02/2021	10:10	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	21/02/2021	10:15	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	21/02/2021	09:20	0.0014	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	21/02/2021	09:25	0.0006	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	21/02/2021	08:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	21/02/2021	08:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	21/02/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	21/02/2021	08:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	21/02/2021	09:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	21/02/2021	09:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	21/02/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	21/02/2021	10:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	21/02/2021	10:15	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	21/02/2021	09:20	1	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	21/02/2021	09:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	21/02/2021	08:55	0.08	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	21/02/2021	08:40	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	21/02/2021	08:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	21/02/2021	08:35	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	21/02/2021	09:00	0.07	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	21/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	21/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	21/02/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	21/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	21/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	21/02/2021	09:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	21/02/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	21/02/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	21/02/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	21/02/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	21/02/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	21/02/2021	09:50	11	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	21/02/2021	09:55	11.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	21/02/2021	10:10	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	21/02/2021	10:15	10.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	21/02/2021	09:20	10.6	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	21/02/2021	09:25	10.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	21/02/2021	08:55	10.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	21/02/2021	08:40	10.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	21/02/2021	08:30	10.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	21/02/2021	08:35	10.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	21/02/2021	09:00	10.3	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	21/02/2021	09:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	21/02/2021	09:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	21/02/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	21/02/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	21/02/2021	09:20	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	21/02/2021	09:25	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	21/02/2021	08:55	0.0237	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	21/02/2021	08:40	0.0093	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	21/02/2021	08:30	0.0294	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	21/02/2021	08:35	0.0241	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	21/02/2021	09:00	0.018	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	21/02/2021	09:50	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	21/02/2021	09:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	21/02/2021	10:10	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	21/02/2021	10:15	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	21/02/2021	09:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	21/02/2021	09:25	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	21/02/2021	08:55	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	21/02/2021	08:40	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	21/02/2021	08:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	21/02/2021	08:35	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	21/02/2021	09:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	21/02/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	21/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	21/02/2021	10:10	0.0012	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	21/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	21/02/2021	09:20	0.0012	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	21/02/2021	09:25	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	21/02/2021	08:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	21/02/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	21/02/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	21/02/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	21/02/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	21/02/2021	09:50	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	21/02/2021	09:55	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	21/02/2021	10:10	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	21/02/2021	10:15	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	21/02/2021	09:20	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	21/02/2021	09:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	21/02/2021	08:55	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	21/02/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	21/02/2021	08:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	21/02/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	21/02/2021	09:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	21/02/2021	09:50	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	21/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	21/02/2021	10:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	21/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	21/02/2021	09:20	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	21/02/2021	09:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	21/02/2021	08:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	21/02/2021	08:40	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	21/02/2021	08:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	21/02/2021	08:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	21/02/2021	09:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	21/02/2021	08:30	No	water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	21/02/2021	09:50	6.7	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	21/02/2021	09:55	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	21/02/2021	10:10	5.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	21/02/2021	10:15	6	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	21/02/2021	09:20	7.4	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	21/02/2021	09:25	7	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	21/02/2021	08:55	6.1	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	21/02/2021	08:40	6.7	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	21/02/2021	08:30	6.6	g O2/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	21/02/2021	08:35	6.7	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	21/02/2021	09:00	6	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	21/02/2021	09:50	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	21/02/2021	09:55	1.4	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	21/02/2021	10:10	0.22	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	21/02/2021	10:15	0.24	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	21/02/2021	09:20	0.6	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	21/02/2021	09:25	1.2	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	21/02/2021	08:30	0.17	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	21/02/2021	08:35	0.11	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	21/02/2021	09:50	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	21/02/2021	09:55	1.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	21/02/2021	10:10	0.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	21/02/2021	10:15	0.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	21/02/2021	09:20	0.8	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	21/02/2021	09:25	1.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	21/02/2021	08:30	0.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	21/02/2021	08:35	0.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	21/02/2021	09:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	21/02/2021	08:55	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	21/02/2021	08:55	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	21/02/2021	09:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	21/02/2021	10:10	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	21/02/2021	10:15	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	21/02/2021	10:10	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	21/02/2021	10:15	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	21/02/2021	08:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	21/02/2021	08:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	21/02/2021	09:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	21/02/2021	09:50	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	21/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	21/02/2021	10:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	21/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	21/02/2021	09:20	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	21/02/2021	09:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	21/02/2021	08:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	21/02/2021	08:40	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	21/02/2021	08:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	21/02/2021	08:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	21/02/2021	09:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	21/02/2021	08:45	Completed		
tc retest 2	Karitane Puketeraki Marae 520 Apes Road	C-O1420	Sampler Observation	21/02/2021	10:00	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	22/02/2021	11:50	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	22/02/2021	11:55	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	22/02/2021	12:25	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	22/02/2021	12:30	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	22/02/2021	13:00	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	22/02/2021	13:05	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	22/02/2021	10:50	7.7		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	22/02/2021	10:35	7.6		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	22/02/2021	10:25	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	22/02/2021	10:30	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	22/02/2021	10:55	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	22/02/2021	11:50	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	22/02/2021	11:55	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	22/02/2021	12:25	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	22/02/2021	12:30	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	22/02/2021	13:00	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	22/02/2021	13:05	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	22/02/2021	10:50	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	22/02/2021	10:35	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	22/02/2021	10:25	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	22/02/2021	10:30	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	22/02/2021	10:55	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	22/02/2021	11:50	70	g CaCO3/m³	

	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	22/02/2021	11:55	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	22/02/2021	12:25	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	22/02/2021	12:30	71	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	22/02/2021	13:00	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	22/02/2021	13:05	72	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	22/02/2021	10:50	67	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	22/02/2021	10:35	68	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	22/02/2021	10:25	66	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	22/02/2021	10:30	66	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	22/02/2021	10:55	67	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	22/02/2021	11:50	19.6	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	22/02/2021	11:55	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	22/02/2021	12:25	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	22/02/2021	12:30	19.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	22/02/2021	13:00	19.8	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	22/02/2021	13:05	19.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	22/02/2021	10:50	19.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	22/02/2021	10:35	19.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	22/02/2021	10:25	19	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	22/02/2021	10:30	19	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	22/02/2021	10:55	19.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	22/02/2021	11:50	16.5	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	22/02/2021	11:55	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	22/02/2021	12:25	16.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	22/02/2021	12:30	16.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	22/02/2021	13:00	16.6	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	22/02/2021	13:05	16.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	22/02/2021	10:50	12.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	22/02/2021	10:35	12.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	22/02/2021	10:25	15.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	22/02/2021	10:30	15.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	22/02/2021	10:55	12.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	22/02/2021	11:50	34.6	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	22/02/2021	11:55	34.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	22/02/2021	12:25	35.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	22/02/2021	12:30	35.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	22/02/2021	13:00	34.8	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	22/02/2021	13:05	34.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	22/02/2021	10:50	32.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	22/02/2021	10:35	32.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	22/02/2021	10:25	32.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	22/02/2021	10:30	31.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	22/02/2021	10:55	32.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	22/02/2021	11:50	147	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	22/02/2021	11:55	142	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	22/02/2021	12:25	153	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	22/02/2021	12:30	160	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	22/02/2021	13:00	177	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	22/02/2021	13:05	156	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	22/02/2021	10:50	146	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	22/02/2021	10:35	157	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	22/02/2021	10:25	179	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	22/02/2021	10:30	164	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	22/02/2021	10:55	175	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	22/02/2021	11:50	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	22/02/2021	11:50	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	22/02/2021	11:55	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	22/02/2021	12:25	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	22/02/2021	12:30	0.015	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	22/02/2021	13:00	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	22/02/2021	13:05	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	22/02/2021	10:25	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	22/02/2021	10:30	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	22/02/2021	11:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	22/02/2021	11:55	<0.001	g/m³	(.01 - .01)

	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	22/02/2021	12:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	22/02/2021	12:30	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	22/02/2021	13:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	22/02/2021	13:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	22/02/2021	10:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	22/02/2021	10:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	22/02/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	22/02/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	22/02/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	22/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	22/02/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	22/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	22/02/2021	10:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	22/02/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	22/02/2021	11:50	23	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	22/02/2021	11:55	23	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	22/02/2021	12:25	23.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	22/02/2021	12:30	24	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	22/02/2021	13:00	23.5	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	22/02/2021	13:05	23.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	22/02/2021	10:25	23.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	22/02/2021	10:30	23	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	22/02/2021	11:50	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	22/02/2021	11:55	0.0018	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	22/02/2021	12:25	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	22/02/2021	12:30	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	22/02/2021	13:00	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	22/02/2021	13:05	0.0009	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	22/02/2021	10:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	22/02/2021	10:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	22/02/2021	11:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	22/02/2021	11:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	22/02/2021	12:25	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	22/02/2021	12:30	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	22/02/2021	13:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	22/02/2021	13:05	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	22/02/2021	10:25	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	22/02/2021	10:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	22/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	22/02/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	22/02/2021	12:25	0.0007	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	22/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	22/02/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	22/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	22/02/2021	10:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	22/02/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	22/02/2021	11:50	12.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	22/02/2021	11:55	12.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	22/02/2021	12:25	12.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	22/02/2021	12:30	12	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	22/02/2021	13:00	12	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	22/02/2021	13:05	12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	22/02/2021	10:25	12.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	22/02/2021	10:30	12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	22/02/2021	11:50	0.0089	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	22/02/2021	11:55	0.0061	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	22/02/2021	12:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	22/02/2021	12:30	0.0007	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	22/02/2021	13:00	0.0035	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	22/02/2021	13:05	0.0031	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	22/02/2021	10:25	0.0246	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	22/02/2021	10:30	0.0208	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	22/02/2021	11:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	22/02/2021	11:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	22/02/2021	12:25	<0.0005	g/m³	(.007 - .007)

	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	22/02/2021	12:30	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	22/02/2021	13:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	22/02/2021	13:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	22/02/2021	10:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	22/02/2021	10:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	22/02/2021	11:50	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	22/02/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	22/02/2021	12:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	22/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	22/02/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	22/02/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	22/02/2021	10:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	22/02/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	22/02/2021	11:50	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	22/02/2021	11:55	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	22/02/2021	12:25	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	22/02/2021	12:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	22/02/2021	13:00	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	22/02/2021	13:05	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	22/02/2021	10:25	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	22/02/2021	10:30	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	22/02/2021	10:45	66,200	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	22/02/2021	10:45	13.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	22/02/2021	10:45	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	22/02/2021	10:45	4,400	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	22/02/2021	10:45	16.2	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	22/02/2021	10:45	14,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	22/02/2021	10:45	4.3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	22/02/2021	10:45	1,620	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	22/02/2021	10:45	2,630	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	22/02/2021	10:45	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	22/02/2021	10:45	9.5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	22/02/2021	10:45	44	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	22/02/2021	10:50	0.036	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	22/02/2021	10:35	0.012	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	22/02/2021	10:55	0.023	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	22/02/2021	10:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	22/02/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	22/02/2021	10:55	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	22/02/2021	10:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	22/02/2021	10:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	22/02/2021	10:55	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	22/02/2021	10:50	21.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	22/02/2021	10:35	22.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	22/02/2021	10:55	21.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	22/02/2021	10:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	22/02/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	22/02/2021	10:55	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	22/02/2021	10:50	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	22/02/2021	10:35	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	22/02/2021	10:55	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	22/02/2021	10:50	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	22/02/2021	10:35	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	22/02/2021	10:55	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	22/02/2021	10:50	11.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	22/02/2021	10:35	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	22/02/2021	10:55	11.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	22/02/2021	10:50	0.036	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	22/02/2021	10:35	0.02	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	22/02/2021	10:55	0.037	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	22/02/2021	10:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	22/02/2021	10:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	22/02/2021	10:55	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	22/02/2021	10:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	22/02/2021	10:35	<0.001	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	22/02/2021	10:55	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	22/02/2021	10:50	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	22/02/2021	10:35	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	22/02/2021	10:55	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	22/02/2021	11:50	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	22/02/2021	11:55	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	22/02/2021	12:25	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	22/02/2021	12:30	0.014	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	22/02/2021	13:00	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	22/02/2021	13:05	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	22/02/2021	10:50	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	22/02/2021	10:35	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	22/02/2021	10:25	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	22/02/2021	10:30	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	22/02/2021	10:55	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	22/02/2021	11:50	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	22/02/2021	11:55	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	22/02/2021	12:25	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	22/02/2021	12:30	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	22/02/2021	13:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	22/02/2021	13:05	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	22/02/2021	10:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	22/02/2021	10:35	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	22/02/2021	10:25	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	22/02/2021	10:30	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	22/02/2021	10:55	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	22/02/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	22/02/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	22/02/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	22/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	22/02/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	22/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	22/02/2021	10:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	22/02/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	22/02/2021	10:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	22/02/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	22/02/2021	10:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	22/02/2021	11:50	23.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	22/02/2021	11:55	23.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	22/02/2021	12:25	24.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	22/02/2021	12:30	24	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	22/02/2021	13:00	23.9	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	22/02/2021	13:05	23.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	22/02/2021	10:50	23.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	22/02/2021	10:35	23.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	22/02/2021	10:25	23.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	22/02/2021	10:30	22.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	22/02/2021	10:55	23.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	22/02/2021	11:50	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	22/02/2021	11:55	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	22/02/2021	12:25	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	22/02/2021	12:30	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	22/02/2021	13:00	0.0017	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	22/02/2021	13:05	0.0009	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	22/02/2021	10:50	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	22/02/2021	10:35	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	22/02/2021	10:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	22/02/2021	10:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	22/02/2021	10:55	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	22/02/2021	11:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	22/02/2021	11:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	22/02/2021	12:25	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	22/02/2021	12:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	22/02/2021	13:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	22/02/2021	13:05	<0.01	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	22/02/2021	10:50	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	22/02/2021	10:35	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	22/02/2021	10:25	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	22/02/2021	10:30	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	22/02/2021	10:55	0.09	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	22/02/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	22/02/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	22/02/2021	12:25	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	22/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	22/02/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	22/02/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	22/02/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	22/02/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	22/02/2021	10:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	22/02/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	22/02/2021	10:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	22/02/2021	11:50	12	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	22/02/2021	11:55	12.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	22/02/2021	12:25	12.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	22/02/2021	12:30	12	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	22/02/2021	13:00	11.9	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	22/02/2021	13:05	12	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	22/02/2021	10:50	11.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	22/02/2021	10:35	12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	22/02/2021	10:25	11.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	22/02/2021	10:30	12	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	22/02/2021	10:55	12	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	22/02/2021	11:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	22/02/2021	11:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	22/02/2021	12:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	22/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	22/02/2021	13:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	22/02/2021	13:05	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	22/02/2021	10:50	0.0303	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	22/02/2021	10:35	0.0098	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	22/02/2021	10:25	0.0243	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	22/02/2021	10:30	0.0196	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	22/02/2021	10:55	0.0313	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	22/02/2021	11:50	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	22/02/2021	11:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	22/02/2021	12:25	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	22/02/2021	12:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	22/02/2021	13:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	22/02/2021	13:05	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	22/02/2021	10:50	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	22/02/2021	10:35	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	22/02/2021	10:25	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	22/02/2021	10:30	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	22/02/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	22/02/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	22/02/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	22/02/2021	12:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	22/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	22/02/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	22/02/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	22/02/2021	10:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	22/02/2021	10:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	22/02/2021	10:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	22/02/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	22/02/2021	10:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	22/02/2021	11:50	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	22/02/2021	11:55	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	22/02/2021	12:25	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	22/02/2021	12:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	22/02/2021	13:00	0.007	g/m³	

	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	22/02/2021	13:05	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	22/02/2021	10:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	22/02/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	22/02/2021	10:25	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	22/02/2021	10:30	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	22/02/2021	10:55	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	22/02/2021	11:50	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	22/02/2021	11:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	22/02/2021	12:25	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	22/02/2021	12:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	22/02/2021	13:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	22/02/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	22/02/2021	10:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	22/02/2021	10:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	22/02/2021	10:25	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	22/02/2021	10:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	22/02/2021	10:55	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	22/02/2021	10:25	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	22/02/2021	11:50	8.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	22/02/2021	11:55	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	22/02/2021	12:25	5.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	22/02/2021	12:30	5.8	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	22/02/2021	13:00	6.4	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	22/02/2021	13:05	6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	22/02/2021	10:50	5.6	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	22/02/2021	10:35	6.1	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	22/02/2021	10:25	7.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	22/02/2021	10:30	6.2	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	22/02/2021	10:55	6.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	22/02/2021	11:50	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	22/02/2021	11:55	0.89	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	22/02/2021	12:25	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	22/02/2021	12:30	0.22	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	22/02/2021	13:00	0.07	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	22/02/2021	13:05	0.81	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	22/02/2021	10:25	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/02/2021	10:30	<0.05	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	22/02/2021	11:50	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	22/02/2021	11:55	1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	22/02/2021	12:25	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	22/02/2021	12:30	0.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	22/02/2021	13:00	0.1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	22/02/2021	13:05	0.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	22/02/2021	10:25	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	22/02/2021	10:30	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	22/02/2021	11:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	22/02/2021	10:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	22/02/2021	10:50	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	22/02/2021	11:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/02/2021	12:25	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/02/2021	12:30	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/02/2021	12:25	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/02/2021	12:30	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	22/02/2021	10:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	22/02/2021	10:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	22/02/2021	10:55	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	22/02/2021	11:50	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	22/02/2021	11:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	22/02/2021	12:25	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	22/02/2021	12:30	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	22/02/2021	13:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	22/02/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	22/02/2021	10:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	22/02/2021	10:35	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	22/02/2021	10:25	Completed		

	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	22/02/2021	10:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	22/02/2021	10:55	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	22/02/2021	10:45	Completed		
	Karitane School	C-O1420	Sampler Observation	22/02/2021	13:15	No	Sample Point	
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	22/02/2021	13:25	0.35	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	22/02/2021	13:25	0.26	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	22/02/2021	13:25	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	22/02/2021	13:25	9.1	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/02/2021	13:25	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/02/2021	13:25	<1	MPN/100ml	(0 - 0)
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	22/02/2021	13:25	0.35	g/m³	(.2 - 5)
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-0066H	Total Chlorine	22/02/2021	13:25	0.5	g/m³	
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	22/02/2021	13:25	0.32	NTU	
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	22/02/2021	13:25	Completed		
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	22/02/2021	13:25	9.1	Deg C	
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	22/02/2021	13:25	<1	MPN/100mL	(0 - 0)
Tc retest	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	22/02/2021	13:25	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	23/02/2021	09:35	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	23/02/2021	09:40	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	23/02/2021	09:55	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	23/02/2021	10:00	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	23/02/2021	08:55	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	23/02/2021	09:00	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	23/02/2021	08:10	7.7		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	23/02/2021	07:45	7.6		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	23/02/2021	07:30	7.6		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	23/02/2021	07:35	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	23/02/2021	08:00	7.7		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	23/02/2021	09:15	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	23/02/2021	09:20	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	23/02/2021	09:35	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	23/02/2021	09:40	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	23/02/2021	09:55	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	23/02/2021	10:00	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	23/02/2021	08:55	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	23/02/2021	09:00	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	23/02/2021	08:10	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	23/02/2021	07:45	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	23/02/2021	07:30	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	23/02/2021	07:35	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	23/02/2021	08:00	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	23/02/2021	09:15	15	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	23/02/2021	09:20	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	23/02/2021	09:35	73	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	23/02/2021	09:40	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	23/02/2021	09:55	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	23/02/2021	10:00	71	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	23/02/2021	08:55	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	23/02/2021	09:00	72	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	23/02/2021	08:10	69	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	23/02/2021	07:45	70	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	23/02/2021	07:30	68	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	23/02/2021	07:35	68	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	23/02/2021	08:00	69	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	23/02/2021	09:15	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	23/02/2021	09:20	71	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	23/02/2021	09:35	19.9	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	23/02/2021	09:40	19.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	23/02/2021	09:55	19	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	23/02/2021	10:00	18.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	23/02/2021	08:55	19.8	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	23/02/2021	09:00	19.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	23/02/2021	08:10	19.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	23/02/2021	07:45	19.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	23/02/2021	07:30	19.2	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	23/02/2021	07:35	19.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	23/02/2021	08:00	19.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	23/02/2021	09:15	20	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	23/02/2021	09:20	19.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	23/02/2021	09:35	16.4	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	23/02/2021	09:40	16.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	23/02/2021	09:55	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	23/02/2021	10:00	16.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	23/02/2021	08:55	16.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	23/02/2021	09:00	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	23/02/2021	08:10	13	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	23/02/2021	07:45	12.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	23/02/2021	07:30	14.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	23/02/2021	07:35	15.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	23/02/2021	08:00	13.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	23/02/2021	09:15	16.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	23/02/2021	09:20	16.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	23/02/2021	09:35	33.8	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	23/02/2021	09:40	34.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	23/02/2021	09:55	37.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	23/02/2021	10:00	38.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	23/02/2021	08:55	34.2	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	23/02/2021	09:00	34.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	23/02/2021	08:10	31.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	23/02/2021	07:45	31.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	23/02/2021	07:30	31.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	23/02/2021	07:35	32.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	23/02/2021	08:00	31.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	23/02/2021	09:15	34.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	23/02/2021	09:20	34.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:35	159	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:40	166	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:55	165	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	23/02/2021	10:00	164	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	23/02/2021	08:55	178	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:00	163	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	23/02/2021	08:10	157	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	23/02/2021	07:45	148	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	23/02/2021	07:30	152	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	23/02/2021	07:35	157	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	23/02/2021	08:00	163	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:15	178	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	23/02/2021	09:20	164	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	23/02/2021	09:35	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	23/02/2021	09:35	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	23/02/2021	09:40	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	23/02/2021	09:55	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	23/02/2021	10:00	0.016	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	23/02/2021	08:55	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	23/02/2021	09:00	0.016	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	23/02/2021	07:30	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	23/02/2021	07:35	0.006	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	23/02/2021	09:15	0.015	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	23/02/2021	09:20	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	23/02/2021	09:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	23/02/2021	09:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	23/02/2021	09:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	23/02/2021	10:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	23/02/2021	08:55	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	23/02/2021	09:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	23/02/2021	07:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	23/02/2021	07:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	23/02/2021	09:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	23/02/2021	09:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	23/02/2021	09:35	<0.0002	g/m³	(.004 - .004)

	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	23/02/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	23/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	23/02/2021	10:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	23/02/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	23/02/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	23/02/2021	07:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	23/02/2021	07:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	23/02/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	23/02/2021	09:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	23/02/2021	09:35	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	23/02/2021	09:40	22.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	23/02/2021	09:55	23.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	23/02/2021	10:00	23.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	23/02/2021	08:55	23	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	23/02/2021	09:00	23.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	23/02/2021	07:30	23	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	23/02/2021	07:35	22.6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	23/02/2021	09:15	22.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	23/02/2021	09:20	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	23/02/2021	09:35	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	23/02/2021	09:40	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	23/02/2021	09:55	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	23/02/2021	10:00	0.0007	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	23/02/2021	08:55	0.0014	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	23/02/2021	09:00	0.0009	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	23/02/2021	07:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	23/02/2021	07:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	23/02/2021	09:15	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	23/02/2021	09:20	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	23/02/2021	09:35	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	23/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	23/02/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	23/02/2021	10:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	23/02/2021	08:55	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	23/02/2021	09:00	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	23/02/2021	07:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	23/02/2021	07:35	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	23/02/2021	09:15	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	23/02/2021	09:20	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	23/02/2021	09:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	23/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	23/02/2021	09:55	0.0008	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	23/02/2021	10:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	23/02/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	23/02/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	23/02/2021	07:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	23/02/2021	07:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	23/02/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	23/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	23/02/2021	09:35	11.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	23/02/2021	09:40	11.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	23/02/2021	09:55	11.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	23/02/2021	10:00	12	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	23/02/2021	08:55	11.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	23/02/2021	09:00	12	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	23/02/2021	07:30	11.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	23/02/2021	07:35	11.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	23/02/2021	09:15	12	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	23/02/2021	09:20	11.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	23/02/2021	09:35	0.005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	23/02/2021	09:40	0.0065	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	23/02/2021	09:55	0.0012	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	23/02/2021	10:00	0.0015	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	23/02/2021	08:55	0.0021	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	23/02/2021	09:00	0.0021	g/m³	(.4 - .4)

	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	23/02/2021	07:30	0.0285	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	23/02/2021	07:35	0.0233	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	23/02/2021	09:15	0.0056	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	23/02/2021	09:20	0.0044	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	23/02/2021	09:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	23/02/2021	09:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	23/02/2021	09:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	23/02/2021	10:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	23/02/2021	08:55	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	23/02/2021	09:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	23/02/2021	07:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	23/02/2021	07:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	23/02/2021	09:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	23/02/2021	09:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	23/02/2021	09:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	23/02/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	23/02/2021	09:55	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	23/02/2021	10:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	23/02/2021	08:55	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	23/02/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	23/02/2021	07:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	23/02/2021	07:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	23/02/2021	09:15	0.0024	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	23/02/2021	09:20	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	23/02/2021	09:35	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	23/02/2021	09:40	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	23/02/2021	09:55	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	23/02/2021	10:00	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	23/02/2021	08:55	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	23/02/2021	09:00	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	23/02/2021	07:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	23/02/2021	07:35	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	23/02/2021	09:15	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	23/02/2021	09:20	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	23/02/2021	07:50	20,400	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	23/02/2021	07:50	9.18	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	23/02/2021	07:50	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	23/02/2021	07:50	3,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	23/02/2021	07:50	7.3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	23/02/2021	07:50	27,700	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	23/02/2021	07:50	14.5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	23/02/2021	07:50	3,070	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	23/02/2021	07:50	444	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	23/02/2021	07:50	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	23/02/2021	07:50	7.5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	23/02/2021	07:50	35	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	23/02/2021	08:10	0.014	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	23/02/2021	07:45	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	23/02/2021	08:00	0.013	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	23/02/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	23/02/2021	07:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	23/02/2021	08:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	23/02/2021	08:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	23/02/2021	07:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	23/02/2021	08:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	23/02/2021	08:10	19.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	23/02/2021	07:45	21.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	23/02/2021	08:00	21.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	23/02/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	23/02/2021	07:45	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	23/02/2021	08:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	23/02/2021	08:10	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	23/02/2021	07:45	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	23/02/2021	08:00	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	23/02/2021	08:10	<0.001	g/m³	(.005 - .01)

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	23/02/2021	07:45	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	23/02/2021	08:00	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	23/02/2021	08:10	10.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	23/02/2021	07:45	11	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	23/02/2021	08:00	11	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	23/02/2021	08:10	0.038	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	23/02/2021	07:45	0.037	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	23/02/2021	08:00	0.043	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	23/02/2021	08:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	23/02/2021	07:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	23/02/2021	08:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	23/02/2021	08:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	23/02/2021	07:45	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	23/02/2021	08:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	23/02/2021	08:10	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	23/02/2021	07:45	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	23/02/2021	08:00	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	23/02/2021	09:35	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	23/02/2021	09:40	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	23/02/2021	09:55	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	23/02/2021	10:00	0.015	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	23/02/2021	08:55	0.016	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	23/02/2021	09:00	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	23/02/2021	08:10	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	23/02/2021	07:45	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	23/02/2021	07:30	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	23/02/2021	07:35	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	23/02/2021	08:00	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	23/02/2021	09:15	0.014	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	23/02/2021	09:20	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	23/02/2021	09:35	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	23/02/2021	09:40	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	23/02/2021	09:55	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	23/02/2021	10:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	23/02/2021	08:55	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	23/02/2021	09:00	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	23/02/2021	08:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	23/02/2021	07:45	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	23/02/2021	07:30	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	23/02/2021	07:35	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	23/02/2021	08:00	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	23/02/2021	09:15	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	23/02/2021	09:20	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	23/02/2021	09:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	23/02/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	23/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	23/02/2021	10:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	23/02/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	23/02/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	23/02/2021	08:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	23/02/2021	07:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	23/02/2021	07:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	23/02/2021	07:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	23/02/2021	08:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	23/02/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	23/02/2021	09:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	23/02/2021	09:35	22.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	23/02/2021	09:40	22.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	23/02/2021	09:55	23.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	23/02/2021	10:00	23.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	23/02/2021	08:55	23.1	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	23/02/2021	09:00	23.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	23/02/2021	08:10	22.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	23/02/2021	07:45	22.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	23/02/2021	07:30	22.5	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	23/02/2021	07:35	22.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	23/02/2021	08:00	23.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	23/02/2021	09:15	23.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	23/02/2021	09:20	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	23/02/2021	09:35	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	23/02/2021	09:40	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	23/02/2021	09:55	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	23/02/2021	10:00	0.0007	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	23/02/2021	08:55	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	23/02/2021	09:00	0.0009	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	23/02/2021	08:10	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	23/02/2021	07:45	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	23/02/2021	07:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	23/02/2021	07:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	23/02/2021	08:00	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	23/02/2021	09:15	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	23/02/2021	09:20	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	23/02/2021	09:35	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	23/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	23/02/2021	09:55	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	23/02/2021	10:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	23/02/2021	08:55	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	23/02/2021	09:00	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	23/02/2021	08:10	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	23/02/2021	07:45	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	23/02/2021	07:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	23/02/2021	07:35	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	23/02/2021	08:00	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	23/02/2021	09:15	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	23/02/2021	09:20	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	23/02/2021	09:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	23/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	23/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	23/02/2021	10:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	23/02/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	23/02/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	23/02/2021	08:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	23/02/2021	07:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	23/02/2021	07:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	23/02/2021	07:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	23/02/2021	08:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	23/02/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	23/02/2021	09:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	23/02/2021	09:35	11.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	23/02/2021	09:40	11.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	23/02/2021	09:55	12	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	23/02/2021	10:00	12	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	23/02/2021	08:55	11.8	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	23/02/2021	09:00	11.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	23/02/2021	08:10	11.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	23/02/2021	07:45	11.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	23/02/2021	07:30	11.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	23/02/2021	07:35	11.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	23/02/2021	08:00	11.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	23/02/2021	09:15	12.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	23/02/2021	09:20	11.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	23/02/2021	09:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	23/02/2021	09:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	23/02/2021	09:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	23/02/2021	10:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	23/02/2021	08:55	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	23/02/2021	09:00	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	23/02/2021	08:10	0.0295	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	23/02/2021	07:45	0.0089	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	23/02/2021	07:30	0.0279	g/m³	(.4 - .4)

	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	23/02/2021	07:35	0.0226	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	23/02/2021	08:00	0.0414	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	23/02/2021	09:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	23/02/2021	09:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	23/02/2021	09:35	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	23/02/2021	09:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	23/02/2021	09:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	23/02/2021	10:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	23/02/2021	08:55	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	23/02/2021	09:00	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	23/02/2021	08:10	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	23/02/2021	07:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	23/02/2021	07:30	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	23/02/2021	07:35	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	23/02/2021	08:00	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	23/02/2021	09:15	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	23/02/2021	09:20	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	23/02/2021	09:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	23/02/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	23/02/2021	09:55	0.0007	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	23/02/2021	10:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	23/02/2021	08:55	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	23/02/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	23/02/2021	08:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	23/02/2021	07:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	23/02/2021	07:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	23/02/2021	07:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	23/02/2021	08:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	23/02/2021	09:15	0.002	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	23/02/2021	09:20	0.0009	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	23/02/2021	09:35	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	23/02/2021	09:40	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	23/02/2021	09:55	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	23/02/2021	10:00	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	23/02/2021	08:55	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	23/02/2021	09:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	23/02/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	23/02/2021	07:45	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	23/02/2021	07:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	23/02/2021	07:35	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	23/02/2021	08:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	23/02/2021	09:15	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	23/02/2021	09:20	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	23/02/2021	09:35	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	23/02/2021	09:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	23/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	23/02/2021	10:00	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	23/02/2021	08:55	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	23/02/2021	09:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	23/02/2021	08:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	23/02/2021	07:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	23/02/2021	07:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	23/02/2021	07:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	23/02/2021	08:00	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	23/02/2021	09:15	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	23/02/2021	09:20	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	23/02/2021	07:30	No	Water	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:35	6.4	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:40	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:55	7.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	23/02/2021	10:00	6.6	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	23/02/2021	08:55	6.9	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:00	6.7	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	23/02/2021	08:10	5.9	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	23/02/2021	07:45	6	g O2/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	23/02/2021	07:30	6.3	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	23/02/2021	07:35	5.8	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	23/02/2021	08:00	5.8	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:15	6.5	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	23/02/2021	09:20	6.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	23/02/2021	09:35	0.07	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	23/02/2021	09:40	0.63	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	23/02/2021	09:55	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	23/02/2021	10:00	0.31	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	23/02/2021	08:55	0.19	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	23/02/2021	09:00	0.74	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	23/02/2021	07:30	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	23/02/2021	07:35	<0.05	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	23/02/2021	09:15	0.14	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	23/02/2021	09:20	0.75	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	23/02/2021	09:35	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	23/02/2021	09:40	0.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	23/02/2021	09:55	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	23/02/2021	10:00	0.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	23/02/2021	08:55	0.2	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	23/02/2021	09:00	0.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	23/02/2021	07:30	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	23/02/2021	07:35	<0.05	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	23/02/2021	09:15	0.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	23/02/2021	09:20	0.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	23/02/2021	09:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	23/02/2021	08:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	23/02/2021	08:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1206	Sampling / Inspection 3 hours	23/02/2021	09:35	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	23/02/2021	09:55	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	23/02/2021	10:00	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	23/02/2021	09:55	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	23/02/2021	10:00	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	23/02/2021	08:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	23/02/2021	07:45	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	23/02/2021	08:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	23/02/2021	09:35	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	23/02/2021	09:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	23/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	23/02/2021	10:00	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	23/02/2021	08:55	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	23/02/2021	09:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	23/02/2021	08:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	23/02/2021	07:45	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	23/02/2021	07:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	23/02/2021	07:35	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	23/02/2021	08:00	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	23/02/2021	09:15	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	23/02/2021	09:20	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	23/02/2021	07:50	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1	pH	23/02/2021	08:30	7.9		(1 - 14)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1	pH	23/02/2021	08:35	7.9		(1 - 14)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	2	Suspended Solids - Total	23/02/2021	08:30	<6	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	2	Suspended Solids - Total	23/02/2021	08:35	<6	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	52	Alkalinity - Total	23/02/2021	08:30	71	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	23/02/2021	08:35	70	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	0440D	Dissolved Inorganic Carbon	23/02/2021	08:30	19.2	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	23/02/2021	08:35	19.2	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	602	Chloride - Add P1859 Filtration	23/02/2021	08:30	16.2	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	602	Chloride - Add P1859 Filtration	23/02/2021	08:35	16.4	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	607	Sulphate - Add P1859 Filtration	23/02/2021	08:30	37.7	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	607	Sulphate - Add P1859 Filtration	23/02/2021	08:35	37.9	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1024	Total Dissolved Solids by Evaporation	23/02/2021	08:30	158	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1024	Total Dissolved Solids by Evaporation	23/02/2021	08:35	173	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6001	Aluminium - Acid Soluble	23/02/2021	08:30	0.014	g/m³	

	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6001	Aluminium - Acid Soluble	23/02/2021	08:35	0.014	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6003	Arsenic - Acid Soluble	23/02/2021	08:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6003	Arsenic - Acid Soluble	23/02/2021	08:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6008	Cadmium - Acid Soluble	23/02/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6008	Cadmium - Acid Soluble	23/02/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6010	Calcium - Acid Soluble	23/02/2021	08:30	22.6	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6010	Calcium - Acid Soluble	23/02/2021	08:35	22.9	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6013	Copper - Acid Soluble	23/02/2021	08:30	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6013	Copper - Acid Soluble	23/02/2021	08:35	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6017	Iron - Acid Soluble	23/02/2021	08:30	0.02	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6017	Iron - Acid Soluble	23/02/2021	08:35	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6018	Lead - Acid Soluble	23/02/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6018	Lead - Acid Soluble	23/02/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6020	Magnesium - Acid Soluble	23/02/2021	08:30	12.1	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6020	Magnesium - Acid Soluble	23/02/2021	08:35	12.3	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6021	Manganese - Acid Soluble	23/02/2021	08:30	0.0104	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6021	Manganese - Acid Soluble	23/02/2021	08:35	0.008	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6022	Mercury - Acid Soluble	23/02/2021	08:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6022	Mercury - Acid Soluble	23/02/2021	08:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6024	Nickel - Acid Soluble	23/02/2021	08:30	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6024	Nickel - Acid Soluble	23/02/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6038	Zinc - Acid Soluble	23/02/2021	08:30	0.004	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6038	Zinc - Acid Soluble	23/02/2021	08:35	<0.002	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6701	Aluminium - Dissolved	23/02/2021	08:30	0.013	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	23/02/2021	08:35	0.013	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6703	Arsenic - Dissolved	23/02/2021	08:30	<0.001	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6703	Arsenic - Dissolved	23/02/2021	08:35	<0.001	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6708	Cadmium - Dissolved	23/02/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	23/02/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6710	Calcium - Dissolved	23/02/2021	08:30	23.1	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6710	Calcium - Dissolved	23/02/2021	08:35	22.8	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6713	Copper - Dissolved	23/02/2021	08:30	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	23/02/2021	08:35	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6717	Iron - Dissolved	23/02/2021	08:30	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	23/02/2021	08:35	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6718	Lead - Dissolved	23/02/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	23/02/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6720	Magnesium - Dissolved	23/02/2021	08:30	12.3	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6720	Magnesium - Dissolved	23/02/2021	08:35	12.3	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6721	Manganese - Dissolved	23/02/2021	08:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	23/02/2021	08:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6722	Mercury - Dissolved	23/02/2021	08:30	<0.0005	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6722	Mercury - Dissolved	23/02/2021	08:35	<0.0005	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6724	Nickel - Dissolved	23/02/2021	08:30	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	23/02/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6738	Zinc - Dissolved	23/02/2021	08:30	0.004	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	23/02/2021	08:35	<0.002	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	9402	ICP-MS - 2 Elements	23/02/2021	08:30	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	9402	ICP-MS - 2 Elements	23/02/2021	08:35	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0056F	Dissolved Oxygen - Field	23/02/2021	08:30	6.4	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	23/02/2021	08:35	7.2	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0058H	Free Available Chlorine	23/02/2021	08:30	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	23/02/2021	08:35	0.64	g/m³	(.2 - 5)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0066H	Total Chlorine	23/02/2021	08:30	0.1	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0066H	Total Chlorine	23/02/2021	08:35	0.7	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-1203	Sampling / Inspection 45 Mins	23/02/2021	08:30	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	P1859	Sample Filtration	23/02/2021	08:30	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	23/02/2021	08:35	Completed		
	Waikouaiti Pumping Main	1	pH	24/02/2021	15:00	7.8		(1 - 14)
	Waikouaiti Pumping Main	52	Alkalinity - Total	24/02/2021	15:00	68	g CaCO3/m³	
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	24/02/2021	15:00	25.2	mS/m (251.8 x .1)	
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	24/02/2021	15:00	0.08	g/m³	(11.3 - 11.3)
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	24/02/2021	15:00	164	g/m³	
	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	24/02/2021	15:00	22.1	g/m³	
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	24/02/2021	15:00	11.2	g/m³	

	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	24/02/2021	15:00	101	g CaCO3/m³	
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	24/02/2021	15:00	55	g CaCO3/m³	
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	24/02/2021	15:00	<0.005	g/m³	
	Waikouaiti Pumping Main	O1420	Sampler Observation	24/02/2021	15:00	Samples	tested as received, unfrozen	
	Waikouaiti Pumping Main	P1859	Sample Filtration	24/02/2021	15:00	Completed		
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	24/02/2021	15:00	<0.0005	mg/L	(.04 - .04)
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	24/02/2021	15:00	<0.005	mg/L	(.1 - .1)
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	24/02/2021	15:00	<0.0005	mg/L	(.01 - .01)
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	24/02/2021	15:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	24/02/2021	15:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	24/02/2021	15:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	24/02/2021	15:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	24/02/2021	15:00	<0.0005	mg/L	(.1 - .1)
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	24/02/2021	15:00	<0.0005	mg/L	
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	24/02/2021	15:00	<0.0005	mg/L	(.01 - .01)
	Waikouaiti Pumping Main	W-AH031	MCPA in water	24/02/2021	15:00	<0.0005	mg/L	(.002 - .002)
	Waikouaiti Pumping Main	W-AH034	MCPB in water	24/02/2021	15:00	<0.005	mg/L	
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	24/02/2021	15:00	<0.0005	mg/L	(.01 - .01)
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	24/02/2021	15:00	<0.0005	mg/L	(.009 - .009)
	Waikouaiti Pumping Main	W-AH043	Picloram in water	24/02/2021	15:00	<0.005	mg/L	(.02 - .2)
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	24/02/2021	15:00	<0.0005	mg/L	(.1 - .1)
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	24/02/2021	15:00	<0.0005	mg/L	
	Karitane Bowls	D-0058H	Free Available Chlorine	24/02/2021	12:39	0.89	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	24/02/2021	12:39	0.9	g/m³	
	Karitane Bowls	D-0084	Turbidity	24/02/2021	12:39	0.08	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	24/02/2021	12:39	6.3	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/02/2021	12:39	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/02/2021	12:39	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	24/02/2021	14:07	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	24/02/2021	14:13	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	24/02/2021	13:48	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	24/02/2021	13:57	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	24/02/2021	12:25	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	24/02/2021	12:30	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	24/02/2021	15:05	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	24/02/2021	14:32	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	24/02/2021	15:10	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	24/02/2021	12:55	8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	24/02/2021	13:00	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	24/02/2021	14:07	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	24/02/2021	14:13	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	24/02/2021	13:48	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	24/02/2021	13:57	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	24/02/2021	12:25	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	24/02/2021	12:30	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	24/02/2021	15:05	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	24/02/2021	14:32	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	24/02/2021	15:10	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	24/02/2021	12:55	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	24/02/2021	13:00	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	24/02/2021	14:07	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	24/02/2021	14:13	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	24/02/2021	13:48	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	24/02/2021	13:57	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	24/02/2021	12:25	73	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	24/02/2021	12:30	73	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	24/02/2021	15:05	68	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	24/02/2021	14:32	70	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	24/02/2021	15:10	68	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	24/02/2021	12:55	71	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	24/02/2021	13:00	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	24/02/2021	14:07	19.7	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	24/02/2021	14:13	19.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	24/02/2021	13:48	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	24/02/2021	13:57	19.8	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	24/02/2021	12:25	19.7	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	24/02/2021	12:30	19.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	24/02/2021	15:05	19	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	24/02/2021	14:32	19.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	24/02/2021	15:10	19.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	24/02/2021	12:55	19.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	24/02/2021	13:00	19.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	24/02/2021	14:07	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	24/02/2021	14:13	16.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	24/02/2021	13:48	16.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	24/02/2021	13:57	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	24/02/2021	12:25	16.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	24/02/2021	12:30	17.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	24/02/2021	15:05	13.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	24/02/2021	14:32	16.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	24/02/2021	15:10	13.6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	24/02/2021	12:55	16.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	24/02/2021	13:00	16.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	24/02/2021	14:07	34.3	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	24/02/2021	14:13	32.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	24/02/2021	13:48	33	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	24/02/2021	13:57	33.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	24/02/2021	12:25	34.6	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	24/02/2021	12:30	33.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	24/02/2021	15:05	29.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	24/02/2021	14:32	32.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	24/02/2021	15:10	30.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	24/02/2021	12:55	34.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	24/02/2021	13:00	33	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	24/02/2021	14:07	155	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	24/02/2021	14:13	147	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	24/02/2021	13:48	186	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	24/02/2021	13:57	160	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	24/02/2021	12:25	181	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	24/02/2021	12:30	192	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	24/02/2021	15:05	146	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	24/02/2021	14:32	174	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	24/02/2021	15:10	157	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	24/02/2021	12:55	156	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	24/02/2021	13:00	156	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	24/02/2021	14:07	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	24/02/2021	14:07	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	24/02/2021	14:13	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	24/02/2021	13:48	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	24/02/2021	13:57	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	24/02/2021	12:25	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	24/02/2021	12:30	0.014	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	24/02/2021	14:32	0.009	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	24/02/2021	12:55	0.013	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	24/02/2021	13:00	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	24/02/2021	14:07	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	24/02/2021	14:13	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	24/02/2021	13:48	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	24/02/2021	13:57	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	24/02/2021	12:25	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	24/02/2021	12:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	24/02/2021	14:32	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	24/02/2021	12:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	24/02/2021	13:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	24/02/2021	14:07	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	24/02/2021	14:13	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	24/02/2021	13:48	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	24/02/2021	13:57	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	24/02/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	24/02/2021	12:30	<0.0002	g/m³	(.004 - .004)

	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	24/02/2021	14:32	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	24/02/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	24/02/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	24/02/2021	14:07	23	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	24/02/2021	14:13	22.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	24/02/2021	13:48	23.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	24/02/2021	13:57	22.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	24/02/2021	12:25	22.9	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	24/02/2021	12:30	22.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	24/02/2021	14:32	22.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	24/02/2021	12:55	22.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	24/02/2021	13:00	22.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	24/02/2021	14:07	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	24/02/2021	14:13	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	24/02/2021	13:48	0.0157	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	24/02/2021	13:57	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	24/02/2021	12:25	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	24/02/2021	12:30	0.0007	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	24/02/2021	14:32	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	24/02/2021	12:55	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	24/02/2021	13:00	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	24/02/2021	14:07	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	24/02/2021	14:13	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	24/02/2021	13:48	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	24/02/2021	13:57	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	24/02/2021	12:25	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	24/02/2021	12:30	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	24/02/2021	14:32	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	24/02/2021	12:55	0.03	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	24/02/2021	13:00	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	24/02/2021	14:07	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	24/02/2021	14:13	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	24/02/2021	13:48	0.0037	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	24/02/2021	13:57	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	24/02/2021	12:25	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	24/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	24/02/2021	14:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	24/02/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	24/02/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	24/02/2021	14:07	11.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	24/02/2021	14:13	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	24/02/2021	13:48	11.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	24/02/2021	13:57	10.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	24/02/2021	12:25	10.9	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	24/02/2021	12:30	10.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	24/02/2021	14:32	10.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	24/02/2021	12:55	10.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	24/02/2021	13:00	10.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	24/02/2021	14:07	0.0066	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	24/02/2021	14:13	0.0845	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	24/02/2021	13:48	0.0012	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	24/02/2021	13:57	0.0028	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	24/02/2021	12:25	0.002	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	24/02/2021	12:30	0.0019	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	24/02/2021	14:32	0.0158	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	24/02/2021	12:55	0.0088	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	24/02/2021	13:00	0.0458	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	24/02/2021	14:07	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	24/02/2021	14:13	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	24/02/2021	13:48	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	24/02/2021	13:57	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	24/02/2021	12:25	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	24/02/2021	12:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	24/02/2021	14:32	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	24/02/2021	12:55	<0.0005	g/m³	(.007 - .007)

	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	24/02/2021	13:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	24/02/2021	14:07	0.0021	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	24/02/2021	14:13	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	24/02/2021	13:48	0.0041	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	24/02/2021	13:57	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	24/02/2021	12:25	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	24/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	24/02/2021	14:32	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	24/02/2021	12:55	0.0125	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	24/02/2021	13:00	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	24/02/2021	14:07	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	24/02/2021	14:13	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	24/02/2021	13:48	0.403	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	24/02/2021	13:57	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	24/02/2021	12:25	0.002	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	24/02/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	24/02/2021	14:32	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	24/02/2021	12:55	0.009	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	24/02/2021	13:00	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	24/02/2021	14:48	196,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	24/02/2021	14:48	30.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	24/02/2021	14:48	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	24/02/2021	14:48	5,280	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	24/02/2021	14:48	29.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	24/02/2021	14:48	18,900	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	24/02/2021	14:48	3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	24/02/2021	14:48	1,250	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	24/02/2021	14:48	349	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	24/02/2021	14:48	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	24/02/2021	14:48	13.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	24/02/2021	14:48	35	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	24/02/2021	15:05	0.021	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	24/02/2021	15:10	0.067	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	24/02/2021	15:05	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	24/02/2021	15:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	24/02/2021	15:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	24/02/2021	15:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	24/02/2021	15:05	21.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	24/02/2021	15:10	21.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	24/02/2021	15:05	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	24/02/2021	15:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	24/02/2021	15:05	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	24/02/2021	15:10	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	24/02/2021	15:05	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	24/02/2021	15:10	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	24/02/2021	15:05	10.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	24/02/2021	15:10	10.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	24/02/2021	15:05	0.031	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	24/02/2021	15:10	0.04	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	24/02/2021	15:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	24/02/2021	15:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	24/02/2021	15:05	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	24/02/2021	15:10	0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	24/02/2021	15:05	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	24/02/2021	15:10	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	24/02/2021	14:07	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	24/02/2021	14:13	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	24/02/2021	13:48	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	24/02/2021	13:57	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	24/02/2021	12:25	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	24/02/2021	12:30	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	24/02/2021	15:05	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	24/02/2021	14:32	0.009	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	24/02/2021	15:10	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	24/02/2021	12:55	0.012	g/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	24/02/2021	13:00	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	24/02/2021	14:07	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	24/02/2021	14:13	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	24/02/2021	13:48	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	24/02/2021	13:57	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	24/02/2021	12:25	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	24/02/2021	12:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	24/02/2021	15:05	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	24/02/2021	14:32	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	24/02/2021	15:10	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	24/02/2021	12:55	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	24/02/2021	13:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	24/02/2021	14:07	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	24/02/2021	14:13	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	24/02/2021	13:48	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	24/02/2021	13:57	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	24/02/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	24/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	24/02/2021	15:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	24/02/2021	14:32	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	24/02/2021	15:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	24/02/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	24/02/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	24/02/2021	14:07	22.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	24/02/2021	14:13	22.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	24/02/2021	13:48	22.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	24/02/2021	13:57	22.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	24/02/2021	12:25	23.1	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	24/02/2021	12:30	23.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	24/02/2021	15:05	21.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	24/02/2021	14:32	22.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	24/02/2021	15:10	22	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	24/02/2021	12:55	22.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	24/02/2021	13:00	22.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	24/02/2021	14:07	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	24/02/2021	14:13	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	24/02/2021	13:48	0.0343	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	24/02/2021	13:57	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	24/02/2021	12:25	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	24/02/2021	12:30	0.0008	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	24/02/2021	15:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	24/02/2021	14:32	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	24/02/2021	15:10	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	24/02/2021	12:55	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	24/02/2021	13:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	24/02/2021	14:07	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	24/02/2021	14:13	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	24/02/2021	13:48	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	24/02/2021	13:57	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	24/02/2021	12:25	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	24/02/2021	12:30	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	24/02/2021	15:05	0.09	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	24/02/2021	14:32	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	24/02/2021	15:10	0.08	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	24/02/2021	12:55	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	24/02/2021	13:00	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	24/02/2021	14:07	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	24/02/2021	14:13	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	24/02/2021	13:48	0.0272	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	24/02/2021	13:57	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	24/02/2021	12:25	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	24/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	24/02/2021	15:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	24/02/2021	14:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	24/02/2021	15:10	<0.0005	g/m³	(.005 - .01)

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	24/02/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	24/02/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	24/02/2021	14:07	11.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	24/02/2021	14:13	11.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	24/02/2021	13:48	11.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	24/02/2021	13:57	11.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	24/02/2021	12:25	11	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	24/02/2021	12:30	10.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	24/02/2021	15:05	10.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	24/02/2021	14:32	11.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	24/02/2021	15:10	10.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	24/02/2021	12:55	11.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	24/02/2021	13:00	11	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	24/02/2021	14:07	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	24/02/2021	14:13	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	24/02/2021	13:48	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	24/02/2021	13:57	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	24/02/2021	12:25	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	24/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	24/02/2021	15:05	0.027	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	24/02/2021	14:32	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	24/02/2021	15:10	0.027	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	24/02/2021	12:55	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	24/02/2021	13:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	24/02/2021	14:07	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	24/02/2021	14:13	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	24/02/2021	13:48	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	24/02/2021	13:57	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	24/02/2021	12:25	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	24/02/2021	12:30	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	24/02/2021	15:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	24/02/2021	14:32	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	24/02/2021	15:10	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	24/02/2021	12:55	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	24/02/2021	13:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	24/02/2021	14:07	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	24/02/2021	14:13	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	24/02/2021	13:48	0.0018	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	24/02/2021	13:57	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	24/02/2021	12:25	0.0019	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	24/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	24/02/2021	15:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	24/02/2021	14:32	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	24/02/2021	15:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	24/02/2021	12:55	0.0028	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	24/02/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	24/02/2021	14:07	0.003	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	24/02/2021	14:13	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	24/02/2021	13:48	0.489	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	24/02/2021	13:57	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	24/02/2021	12:25	0.003	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	24/02/2021	12:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	24/02/2021	15:05	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	24/02/2021	14:32	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	24/02/2021	15:10	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	24/02/2021	12:55	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	24/02/2021	13:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	24/02/2021	14:07	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	24/02/2021	14:13	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	24/02/2021	13:48	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	24/02/2021	13:57	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	24/02/2021	12:25	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	24/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	24/02/2021	15:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	24/02/2021	14:32	Completed		

	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	24/02/2021	15:10	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	24/02/2021	12:55	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	24/02/2021	13:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	24/02/2021	14:07	6.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	24/02/2021	14:13	6.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	24/02/2021	13:48	7.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	24/02/2021	13:57	7.1	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	24/02/2021	12:25	7.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	24/02/2021	12:30	6.6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	24/02/2021	15:05	6.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	24/02/2021	14:32	6.2	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	24/02/2021	15:10	7.2	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	24/02/2021	12:55	7.1	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	24/02/2021	13:00	7.2	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	24/02/2021	14:07	1	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	24/02/2021	14:13	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	24/02/2021	13:48	0.35	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	24/02/2021	13:57	0.36	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	24/02/2021	12:25	0.74	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	24/02/2021	12:30	0.77	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/02/2021	14:32	0.93	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	24/02/2021	12:55	0.89	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	24/02/2021	13:00	0.91	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	24/02/2021	14:07	1.2	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	24/02/2021	14:13	1.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	24/02/2021	13:48	0.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	24/02/2021	13:57	0.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	24/02/2021	12:25	0.9	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	24/02/2021	12:30	0.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	24/02/2021	14:32	1.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	24/02/2021	12:55	1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	24/02/2021	13:00	1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	24/02/2021	12:55	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	24/02/2021	13:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	24/02/2021	14:07	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	24/02/2021	15:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	24/02/2021	15:05	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	24/02/2021	14:07	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/02/2021	13:48	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	24/02/2021	13:57	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/02/2021	13:48	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	24/02/2021	13:57	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	24/02/2021	00:00:00	No	water	
	Waikouaiti WTP - Containerised Plant Filtrate	O1420	Sampler Observation	24/02/2021	14:41	No	water	
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	24/02/2021	14:38	No	water	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	24/02/2021	15:05	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	24/02/2021	15:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	24/02/2021	14:07	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	24/02/2021	14:13	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	24/02/2021	13:48	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	24/02/2021	13:57	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	24/02/2021	12:25	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	24/02/2021	12:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	24/02/2021	15:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	24/02/2021	14:32	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	24/02/2021	15:10	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	24/02/2021	12:55	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	24/02/2021	13:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	24/02/2021	14:48	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	25/02/2021	11:30	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	25/02/2021	11:45	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	25/02/2021	12:30	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	25/02/2021	12:40	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	25/02/2021	10:15	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	25/02/2021	10:28	7.9		(1 - 14)

	Catchment - Waikouaiti River - Pump Station Intake	1	pH	25/02/2021	14:35	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	25/02/2021	13:40	7.8		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	25/02/2021	13:45	7.7		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	25/02/2021	14:07	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	25/02/2021	13:25	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	25/02/2021	14:45	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	25/02/2021	11:03	7.9		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	25/02/2021	11:15:00	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	25/02/2021	11:30	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	25/02/2021	11:45	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	25/02/2021	12:30	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	25/02/2021	12:40	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	25/02/2021	10:15	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	25/02/2021	10:28	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	25/02/2021	14:35	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	25/02/2021	13:40	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	25/02/2021	13:45	<6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	25/02/2021	14:07	120	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	25/02/2021	13:25	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	25/02/2021	14:45	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	25/02/2021	11:03	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	25/02/2021	11:15:00	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	25/02/2021	11:30	71	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	25/02/2021	11:45	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	25/02/2021	12:30	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	25/02/2021	12:40	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	25/02/2021	10:15	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	25/02/2021	10:28	72	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	25/02/2021	14:35	68	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	25/02/2021	13:40	69	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	25/02/2021	13:45	67	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	25/02/2021	14:07	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	25/02/2021	13:25	71	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	25/02/2021	14:45	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	25/02/2021	11:03	71	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	25/02/2021	11:15:00	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	25/02/2021	11:30	19.8	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	25/02/2021	11:45	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	25/02/2021	12:30	19.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	25/02/2021	12:40	19.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	25/02/2021	10:15	19.4	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	25/02/2021	10:28	19.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	25/02/2021	14:35	19	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	25/02/2021	13:40	19.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	25/02/2021	13:45	18.8	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	25/02/2021	14:07	18.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	25/02/2021	13:25	19.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	25/02/2021	14:45	19.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	25/02/2021	11:03	19.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	25/02/2021	11:15:00	19.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	25/02/2021	11:30	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	25/02/2021	11:45	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	25/02/2021	12:30	16.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	25/02/2021	12:40	16.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	25/02/2021	10:15	26.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	25/02/2021	10:28	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	25/02/2021	14:35	13	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	25/02/2021	13:40	13.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	25/02/2021	13:45	14.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	25/02/2021	14:07	14.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	25/02/2021	13:25	16.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	25/02/2021	14:45	13	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	25/02/2021	11:03	16.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	25/02/2021	11:15:00	16.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	25/02/2021	11:30	32.1	g/m³	

	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	25/02/2021	11:45	30.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	25/02/2021	12:30	32.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	25/02/2021	12:40	31.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	25/02/2021	10:15	33.5	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	25/02/2021	10:28	31	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	25/02/2021	14:35	27.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	25/02/2021	13:40	28.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	25/02/2021	13:45	27.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	25/02/2021	14:07	28.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	25/02/2021	13:25	30.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	25/02/2021	14:45	27.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	25/02/2021	11:03	32.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	25/02/2021	11:15:00	31.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	25/02/2021	11:30	155	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	25/02/2021	11:45	151	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	25/02/2021	12:30	166	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	25/02/2021	12:40	163	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	25/02/2021	10:15	120	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	25/02/2021	10:28	133	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	25/02/2021	14:35	129	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	25/02/2021	13:40	125	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	25/02/2021	13:45	123	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	25/02/2021	14:07	145	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	25/02/2021	13:25	142	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	25/02/2021	14:45	144	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	25/02/2021	11:03	147	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	25/02/2021	11:15:00	147	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	25/02/2021	11:30	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	25/02/2021	11:30	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	25/02/2021	11:45	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	25/02/2021	12:30	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	25/02/2021	12:40	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	25/02/2021	10:15	0.016	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	25/02/2021	10:28	0.016	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	25/02/2021	13:45	0.011	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	25/02/2021	14:07	24	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	25/02/2021	13:25	0.013	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	25/02/2021	11:03	0.015	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	25/02/2021	11:15:00	0.015	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	25/02/2021	11:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	25/02/2021	11:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	25/02/2021	12:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	25/02/2021	12:40	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	25/02/2021	10:15	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	25/02/2021	10:28	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	25/02/2021	13:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	25/02/2021	14:07	0.004	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	25/02/2021	13:25	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	25/02/2021	11:03	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	25/02/2021	11:15:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	25/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	25/02/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	25/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	25/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	25/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	25/02/2021	10:28	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	25/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	25/02/2021	14:07	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	25/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	25/02/2021	11:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	25/02/2021	11:15:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	25/02/2021	11:30	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	25/02/2021	11:45	22.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	25/02/2021	12:30	22.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	25/02/2021	12:40	22.6	g/m³	

	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	25/02/2021	10:15	23.2	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	25/02/2021	10:28	22.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	25/02/2021	13:45	22	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	25/02/2021	14:07	22	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	25/02/2021	13:25	22.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	25/02/2021	11:03	21.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	25/02/2021	11:15:00	22.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	25/02/2021	11:30	0.002	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	25/02/2021	11:45	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	25/02/2021	12:30	0.0294	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	25/02/2021	12:40	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	25/02/2021	10:15	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	25/02/2021	10:28	0.0017	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	25/02/2021	13:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	25/02/2021	14:07	0.0037	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	25/02/2021	13:25	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	25/02/2021	11:03	0.001	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	25/02/2021	11:15:00	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	25/02/2021	11:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	25/02/2021	11:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	25/02/2021	12:30	0.03	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	25/02/2021	12:40	0.07	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	25/02/2021	10:15	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	25/02/2021	10:28	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	25/02/2021	13:45	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	25/02/2021	14:07	2.67	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	25/02/2021	13:25	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	25/02/2021	11:03	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	25/02/2021	11:15:00	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	25/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	25/02/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	25/02/2021	12:30	0.0173	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	25/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	25/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	25/02/2021	10:28	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	25/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	25/02/2021	14:07	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	25/02/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	25/02/2021	11:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	25/02/2021	11:15:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	25/02/2021	11:30	11.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	25/02/2021	11:45	11.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	25/02/2021	12:30	11.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	25/02/2021	12:40	11.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	25/02/2021	10:15	11.2	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	25/02/2021	10:28	11	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	25/02/2021	13:45	10.7	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	25/02/2021	14:07	10.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	25/02/2021	13:25	11.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	25/02/2021	11:03	11.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	25/02/2021	11:15:00	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	25/02/2021	11:30	0.106	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	25/02/2021	11:45	0.0041	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	25/02/2021	12:30	0.0113	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	25/02/2021	12:40	0.0299	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	25/02/2021	10:15	0.0018	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	25/02/2021	10:28	0.0028	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	25/02/2021	13:45	0.0212	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	25/02/2021	14:07	0.152	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	25/02/2021	13:25	0.0171	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	25/02/2021	11:03	0.0715	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	25/02/2021	11:15:00	0.0045	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	25/02/2021	11:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	25/02/2021	11:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	25/02/2021	12:30	<0.0005	g/m³	(.007 - .007)

	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	25/02/2021	12:40	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	25/02/2021	10:15	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	25/02/2021	10:28	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	25/02/2021	13:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	25/02/2021	14:07	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	25/02/2021	13:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	25/02/2021	11:03	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	25/02/2021	11:15:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	25/02/2021	11:30	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	25/02/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	25/02/2021	12:30	0.0021	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	25/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	25/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	25/02/2021	10:28	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	25/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	25/02/2021	14:07	0.0019	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	25/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	25/02/2021	11:03	0.0015	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	25/02/2021	11:15:00	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	25/02/2021	11:30	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	25/02/2021	11:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	25/02/2021	12:30	0.302	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	25/02/2021	12:40	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	25/02/2021	10:15	0.002	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	25/02/2021	10:28	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	25/02/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	25/02/2021	14:07	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	25/02/2021	13:25	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	25/02/2021	11:03	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	25/02/2021	11:15:00	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	25/02/2021	14:20	221,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	25/02/2021	14:20	25.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	25/02/2021	14:20	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	25/02/2021	14:20	3,540	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	25/02/2021	14:20	17.6	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	25/02/2021	14:20	11,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	25/02/2021	14:20	1.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	25/02/2021	14:20	522	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	25/02/2021	14:20	586	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	25/02/2021	14:20	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	25/02/2021	14:20	11.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	25/02/2021	14:20	19	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	25/02/2021	14:35	0.02	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	25/02/2021	13:40	0.015	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	25/02/2021	14:45	0.074	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	25/02/2021	14:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	25/02/2021	13:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	25/02/2021	14:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	25/02/2021	14:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	25/02/2021	13:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	25/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	25/02/2021	14:35	21.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	25/02/2021	13:40	21.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	25/02/2021	14:45	21.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	25/02/2021	14:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	25/02/2021	13:40	0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	25/02/2021	14:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	25/02/2021	14:35	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	25/02/2021	13:40	0.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	25/02/2021	14:45	0.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	25/02/2021	14:35	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	25/02/2021	13:40	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	25/02/2021	14:45	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	25/02/2021	14:35	10.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	25/02/2021	13:40	10.9	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	25/02/2021	14:45	10.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	25/02/2021	14:35	0.033	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	25/02/2021	13:40	0.034	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	25/02/2021	14:45	0.052	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	25/02/2021	14:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	25/02/2021	13:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	25/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	25/02/2021	14:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	25/02/2021	13:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	25/02/2021	14:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	25/02/2021	14:35	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	25/02/2021	13:40	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	25/02/2021	14:45	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	25/02/2021	11:30	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	25/02/2021	11:45	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	25/02/2021	12:30	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	25/02/2021	12:40	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	25/02/2021	10:15	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	25/02/2021	10:28	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	25/02/2021	14:35	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	25/02/2021	13:40	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	25/02/2021	13:45	0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	25/02/2021	14:07	0.167	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	25/02/2021	13:25	0.011	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	25/02/2021	14:45	0.008	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	25/02/2021	11:03	0.012	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	25/02/2021	11:15:00	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	25/02/2021	11:30	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	25/02/2021	11:45	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	25/02/2021	12:30	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	25/02/2021	12:40	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	25/02/2021	10:15	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	25/02/2021	10:28	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	25/02/2021	14:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	25/02/2021	13:40	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	25/02/2021	13:45	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	25/02/2021	14:07	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	25/02/2021	13:25	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	25/02/2021	14:45	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	25/02/2021	11:03	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	25/02/2021	11:15:00	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	25/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	25/02/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	25/02/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	25/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	25/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	25/02/2021	10:28	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	25/02/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	25/02/2021	13:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	25/02/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	25/02/2021	14:07	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	25/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	25/02/2021	14:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	25/02/2021	11:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	25/02/2021	11:15:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	25/02/2021	11:30	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	25/02/2021	11:45	22.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	25/02/2021	12:30	22.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	25/02/2021	12:40	22.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	25/02/2021	10:15	22.9	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	25/02/2021	10:28	22.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	25/02/2021	14:35	21.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	25/02/2021	13:40	21.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	25/02/2021	13:45	21.7	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	25/02/2021	14:07	21.3	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	25/02/2021	13:25	21.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	25/02/2021	14:45	22.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	25/02/2021	11:03	23.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	25/02/2021	11:15:00	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	25/02/2021	11:30	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	25/02/2021	11:45	0.0016	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	25/02/2021	12:30	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	25/02/2021	12:40	0.0007	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	25/02/2021	10:15	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	25/02/2021	10:28	0.0016	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	25/02/2021	14:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	25/02/2021	13:40	0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	25/02/2021	13:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	25/02/2021	14:07	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	25/02/2021	13:25	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	25/02/2021	14:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	25/02/2021	11:03	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	25/02/2021	11:15:00	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	25/02/2021	11:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	25/02/2021	11:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	25/02/2021	12:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	25/02/2021	12:40	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	25/02/2021	10:15	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	25/02/2021	10:28	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	25/02/2021	14:35	0.09	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	25/02/2021	13:40	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	25/02/2021	13:45	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	25/02/2021	14:07	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	25/02/2021	13:25	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	25/02/2021	14:45	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	25/02/2021	11:03	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	25/02/2021	11:15:00	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	25/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	25/02/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	25/02/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	25/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	25/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	25/02/2021	10:28	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	25/02/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	25/02/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	25/02/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	25/02/2021	14:07	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	25/02/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	25/02/2021	14:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	25/02/2021	11:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	25/02/2021	11:15:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	25/02/2021	11:30	11.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	25/02/2021	11:45	11.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	25/02/2021	12:30	11.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	25/02/2021	12:40	11.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	25/02/2021	10:15	11.1	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	25/02/2021	10:28	10.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	25/02/2021	14:35	10.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	25/02/2021	13:40	10.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	25/02/2021	13:45	10.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	25/02/2021	14:07	10.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	25/02/2021	13:25	10.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	25/02/2021	14:45	10.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	25/02/2021	11:03	11.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	25/02/2021	11:15:00	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	25/02/2021	11:30	0.0027	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	25/02/2021	11:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	25/02/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	25/02/2021	12:40	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	25/02/2021	10:15	<0.0005	g/m³	(.4 - .4)

	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	25/02/2021	10:28	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	25/02/2021	14:35	0.026	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	25/02/2021	13:40	0.0254	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	25/02/2021	13:45	0.0209	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	25/02/2021	14:07	0.0064	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	25/02/2021	13:25	0.0007	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	25/02/2021	14:45	0.0254	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	25/02/2021	11:03	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	25/02/2021	11:15:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	25/02/2021	11:30	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	25/02/2021	11:45	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	25/02/2021	12:30	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	25/02/2021	12:40	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	25/02/2021	10:15	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	25/02/2021	10:28	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	25/02/2021	14:35	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	25/02/2021	13:40	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	25/02/2021	13:45	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	25/02/2021	14:07	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	25/02/2021	13:25	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	25/02/2021	14:45	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	25/02/2021	11:03	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	25/02/2021	11:15:00	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	25/02/2021	11:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	25/02/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	25/02/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	25/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	25/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	25/02/2021	10:28	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	25/02/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	25/02/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	25/02/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	25/02/2021	14:07	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	25/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	25/02/2021	14:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	25/02/2021	11:03	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	25/02/2021	11:15:00	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	25/02/2021	11:30	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	25/02/2021	11:45	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	25/02/2021	12:30	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	25/02/2021	12:40	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	25/02/2021	10:15	0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	25/02/2021	10:28	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	25/02/2021	14:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	25/02/2021	13:40	0.005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	25/02/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	25/02/2021	14:07	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	25/02/2021	13:25	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	25/02/2021	14:45	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	25/02/2021	11:03	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	25/02/2021	11:15:00	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	25/02/2021	11:30	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	25/02/2021	11:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	25/02/2021	12:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	25/02/2021	12:40	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	25/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	25/02/2021	10:28	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	25/02/2021	14:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	25/02/2021	13:40	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	25/02/2021	13:45	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	25/02/2021	14:07	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	25/02/2021	13:25	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	25/02/2021	14:45	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	25/02/2021	11:03	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	25/02/2021	11:15:00	Completed		

	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	25/02/2021	11:30	8.1	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	25/02/2021	11:45	8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	25/02/2021	12:30	7.3	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	25/02/2021	12:40	5.7	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	25/02/2021	10:15	8.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	25/02/2021	10:28	8	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	25/02/2021	14:35	7.7	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	25/02/2021	13:40	7	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	25/02/2021	13:45	8.6	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	25/02/2021	14:07	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	25/02/2021	13:25	6.3	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	25/02/2021	14:45	7.1	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	25/02/2021	11:03	7.3	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	25/02/2021	11:15:00	7.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	25/02/2021	11:30	0.09	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	25/02/2021	11:45	1.2	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	25/02/2021	12:30	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	25/02/2021	12:40	0.4	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	25/02/2021	10:15	0.1	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	25/02/2021	10:28	0.81	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	25/02/2021	13:45	0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	25/02/2021	14:07	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	25/02/2021	13:25	1.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	25/02/2021	11:03	<0.05	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	25/02/2021	11:15:00	0.83	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	25/02/2021	11:30	0.2	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	25/02/2021	11:45	1.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	25/02/2021	12:30	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	25/02/2021	12:40	0.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	25/02/2021	10:15	0.2	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	25/02/2021	10:28	0.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	25/02/2021	13:45	<0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	25/02/2021	14:07	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	25/02/2021	13:25	1.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	25/02/2021	11:03	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	25/02/2021	11:15:00	1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	25/02/2021	11:03	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	25/02/2021	11:15:00	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	25/02/2021	11:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	25/02/2021	14:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	25/02/2021	14:35	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	25/02/2021	11:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	25/02/2021	14:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	25/02/2021	13:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	25/02/2021	14:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	25/02/2021	11:30	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	25/02/2021	11:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	25/02/2021	12:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	25/02/2021	12:40	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	25/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	25/02/2021	10:28	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	25/02/2021	14:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	25/02/2021	13:40	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	25/02/2021	13:45	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	25/02/2021	14:07	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	25/02/2021	13:25	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	25/02/2021	14:45	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	25/02/2021	11:03	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	25/02/2021	11:15:00	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	25/02/2021	14:20	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	26/02/2021	14:50	7.9		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	26/02/2021	14:50	<5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	26/02/2021	14:50	69	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	26/02/2021	14:50	19	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	26/02/2021	14:50	12.8	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	26/02/2021	14:50	27.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	26/02/2021	14:50	129	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6001	Aluminium - Acid Soluble	26/02/2021	14:50	0.008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6003	Arsenic - Acid Soluble	26/02/2021	14:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6008	Cadmium - Acid Soluble	26/02/2021	14:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6010	Calcium - Acid Soluble	26/02/2021	14:50	22.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6013	Copper - Acid Soluble	26/02/2021	14:50	0.0013	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6017	Iron - Acid Soluble	26/02/2021	14:50	0.26	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6018	Lead - Acid Soluble	26/02/2021	14:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6020	Magnesium - Acid Soluble	26/02/2021	14:50	10.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6021	Manganese - Acid Soluble	26/02/2021	14:50	0.0325	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6022	Mercury - Acid Soluble	26/02/2021	14:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6024	Nickel - Acid Soluble	26/02/2021	14:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6038	Zinc - Acid Soluble	26/02/2021	14:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	26/02/2021	14:50	0.006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	26/02/2021	14:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	26/02/2021	14:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	26/02/2021	14:50	22	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	26/02/2021	14:50	0.0015	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	26/02/2021	14:50	0.13	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	26/02/2021	14:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	26/02/2021	14:50	10.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	26/02/2021	14:50	0.0107	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	26/02/2021	14:50	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	26/02/2021	14:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	26/02/2021	14:50	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	26/02/2021	14:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	26/02/2021	14:50	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	26/02/2021	12:05	7.6		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	26/02/2021	12:15	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	26/02/2021	13:05	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	26/02/2021	13:25	7.7		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	26/02/2021	10:40	7.7		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	26/02/2021	10:58	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	26/02/2021	15:15	7.9		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	26/02/2021	14:35	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	26/02/2021	14:00	7.7		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	26/02/2021	15:25	7.9		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	26/02/2021	11:30	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	26/02/2021	11:34	7.7		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	26/02/2021	12:05	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	26/02/2021	12:15	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	26/02/2021	13:05	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	26/02/2021	13:25	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	26/02/2021	10:40	<6	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	26/02/2021	10:58	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	26/02/2021	15:15	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	26/02/2021	14:35	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	26/02/2021	14:00	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	26/02/2021	15:25	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	26/02/2021	11:30	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	26/02/2021	11:34	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	26/02/2021	12:05	69	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	26/02/2021	12:15	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	26/02/2021	13:05	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	26/02/2021	13:25	69	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	26/02/2021	10:40	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	26/02/2021	10:58	70	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	26/02/2021	15:15	71	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	26/02/2021	14:35	69	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	26/02/2021	14:00	69	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	26/02/2021	15:25	70	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	26/02/2021	11:30	70	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	26/02/2021	11:34	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	26/02/2021	12:05	19.4	g/m³	

	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	26/02/2021	12:15	19	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	26/02/2021	13:05	19.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	26/02/2021	13:25	19.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	26/02/2021	10:40	19.3	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	26/02/2021	10:58	19.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	26/02/2021	15:15	19.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	26/02/2021	14:35	18.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	26/02/2021	14:00	18.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	26/02/2021	15:25	18.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	26/02/2021	11:30	19.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	26/02/2021	11:34	18	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	26/02/2021	12:05	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	26/02/2021	12:15	16.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	26/02/2021	13:05	16.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	26/02/2021	13:25	16.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	26/02/2021	10:40	16.5	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	26/02/2021	10:58	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	26/02/2021	15:15	13	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	26/02/2021	14:35	14.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	26/02/2021	14:00	16.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	26/02/2021	15:25	13	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	26/02/2021	11:30	16.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	26/02/2021	11:34	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	26/02/2021	12:05	30.7	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	26/02/2021	12:15	29.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	26/02/2021	13:05	29.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	26/02/2021	13:25	29.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	26/02/2021	10:40	31.2	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	26/02/2021	10:58	29.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	26/02/2021	15:15	26.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	26/02/2021	14:35	26.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	26/02/2021	14:00	29.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	26/02/2021	15:25	26.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	26/02/2021	11:30	31.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	26/02/2021	11:34	29.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	26/02/2021	12:05	137	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	26/02/2021	12:15	128	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	26/02/2021	13:05	129	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	26/02/2021	13:25	139	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	26/02/2021	10:40	138	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	26/02/2021	10:58	145	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	26/02/2021	15:15	126	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	26/02/2021	14:35	124	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	26/02/2021	14:00	103	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	26/02/2021	15:25	100	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	26/02/2021	11:30	102	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	26/02/2021	11:34	139	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	26/02/2021	12:05	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	26/02/2021	12:05	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	26/02/2021	12:15	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	26/02/2021	13:05	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	26/02/2021	13:25	0.009	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	26/02/2021	10:40	0.014	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	26/02/2021	10:58	0.012	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	26/02/2021	14:35	0.013	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	26/02/2021	14:00	0.012	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	26/02/2021	11:30	0.014	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	26/02/2021	11:34	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	26/02/2021	12:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	26/02/2021	12:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	26/02/2021	13:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	26/02/2021	13:25	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	26/02/2021	10:40	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	26/02/2021	10:58	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	26/02/2021	14:35	<0.001	g/m³	(.01 - .01)

	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	26/02/2021	14:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	26/02/2021	11:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	26/02/2021	11:34	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	26/02/2021	12:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	26/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	26/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	26/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	26/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	26/02/2021	10:58	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	26/02/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	26/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	26/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	26/02/2021	11:34	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	26/02/2021	12:05	21.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	26/02/2021	12:15	20.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	26/02/2021	13:05	20.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	26/02/2021	13:25	20.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	26/02/2021	10:40	21	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	26/02/2021	10:58	20.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	26/02/2021	14:35	20	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	26/02/2021	14:00	20.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	26/02/2021	11:30	20.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	26/02/2021	11:34	20.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	26/02/2021	12:05	0.0022	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	26/02/2021	12:15	0.0022	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	26/02/2021	13:05	0.0265	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	26/02/2021	13:25	0.0014	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	26/02/2021	10:40	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	26/02/2021	10:58	0.0015	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	26/02/2021	14:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	26/02/2021	14:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	26/02/2021	11:30	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	26/02/2021	11:34	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	26/02/2021	12:05	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	26/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	26/02/2021	13:05	0.03	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	26/02/2021	13:25	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	26/02/2021	10:40	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	26/02/2021	10:58	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	26/02/2021	14:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	26/02/2021	14:00	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	26/02/2021	11:30	0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	26/02/2021	11:34	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	26/02/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	26/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	26/02/2021	13:05	0.0128	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	26/02/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	26/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	26/02/2021	10:58	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	26/02/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	26/02/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	26/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	26/02/2021	11:34	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	26/02/2021	12:05	11.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	26/02/2021	12:15	11.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	26/02/2021	13:05	11.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	26/02/2021	13:25	11.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	26/02/2021	10:40	11.4	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	26/02/2021	10:58	11.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	26/02/2021	14:35	10.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	26/02/2021	14:00	11.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	26/02/2021	11:30	11.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	26/02/2021	11:34	11.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	26/02/2021	12:05	0.0036	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	26/02/2021	12:15	0.0031	g/m³	(.4 - .4)

	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	26/02/2021	13:05	0.0254	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	26/02/2021	13:25	0.0032	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	26/02/2021	10:40	0.002	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	26/02/2021	10:58	0.002	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	26/02/2021	14:35	0.0169	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	26/02/2021	14:00	0.0144	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	26/02/2021	11:30	0.0043	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	26/02/2021	11:34	0.0048	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	26/02/2021	12:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	26/02/2021	12:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	26/02/2021	13:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	26/02/2021	13:25	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	26/02/2021	10:40	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	26/02/2021	10:58	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	26/02/2021	14:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	26/02/2021	14:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	26/02/2021	11:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	26/02/2021	11:34	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	26/02/2021	12:05	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	26/02/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	26/02/2021	13:05	0.0015	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	26/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	26/02/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	26/02/2021	10:58	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	26/02/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	26/02/2021	14:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	26/02/2021	11:30	0.0018	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	26/02/2021	11:34	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	26/02/2021	12:05	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	26/02/2021	12:15	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	26/02/2021	13:05	0.129	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	26/02/2021	13:25	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	26/02/2021	10:40	0.003	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	26/02/2021	10:58	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	26/02/2021	14:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	26/02/2021	14:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	26/02/2021	11:30	0.005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	26/02/2021	11:34	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	26/02/2021	14:40	172,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	26/02/2021	14:40	27	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	26/02/2021	14:40	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	26/02/2021	14:40	11,400	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	26/02/2021	14:40	21.7	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	26/02/2021	14:40	20,800	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	26/02/2021	14:40	3.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	26/02/2021	14:40	2,290	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	26/02/2021	14:40	1,970	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	26/02/2021	14:40	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	26/02/2021	14:40	11.7	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	26/02/2021	14:40	39	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	26/02/2021	15:15	0.013	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	26/02/2021	15:25	0.017	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	26/02/2021	15:15	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	26/02/2021	15:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	26/02/2021	15:15	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	26/02/2021	15:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	26/02/2021	15:15	20.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	26/02/2021	15:25	20.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	26/02/2021	15:15	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	26/02/2021	15:25	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	26/02/2021	15:15	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	26/02/2021	15:25	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	26/02/2021	15:15	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	26/02/2021	15:25	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	26/02/2021	15:15	10.4	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	26/02/2021	15:25	10.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	26/02/2021	15:15	0.03	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	26/02/2021	15:25	0.03	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	26/02/2021	15:15	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	26/02/2021	15:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	26/02/2021	15:15	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	26/02/2021	15:25	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	26/02/2021	15:15	0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	26/02/2021	15:25	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	26/02/2021	12:05	0.009	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	26/02/2021	12:15	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	26/02/2021	13:05	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	26/02/2021	13:25	0.008	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	26/02/2021	10:40	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	26/02/2021	10:58	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	26/02/2021	15:15	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	26/02/2021	14:35	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	26/02/2021	14:00	0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	26/02/2021	15:25	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	26/02/2021	11:30	0.014	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	26/02/2021	11:34	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	26/02/2021	12:05	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	26/02/2021	12:15	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	26/02/2021	13:05	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	26/02/2021	13:25	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	26/02/2021	10:40	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	26/02/2021	10:58	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	26/02/2021	15:15	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	26/02/2021	14:35	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	26/02/2021	14:00	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	26/02/2021	15:25	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	26/02/2021	11:30	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	26/02/2021	11:34	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	26/02/2021	12:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	26/02/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	26/02/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	26/02/2021	13:25	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	26/02/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	26/02/2021	10:58	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	26/02/2021	15:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	26/02/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	26/02/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	26/02/2021	15:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	26/02/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	26/02/2021	11:34	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	26/02/2021	12:05	20.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	26/02/2021	12:15	20.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	26/02/2021	13:05	20.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	26/02/2021	13:25	20.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	26/02/2021	10:40	21.2	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	26/02/2021	10:58	20.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	26/02/2021	15:15	20.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	26/02/2021	14:35	20.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	26/02/2021	14:00	20.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	26/02/2021	15:25	20	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	26/02/2021	11:30	20.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	26/02/2021	11:34	20.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	26/02/2021	12:05	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	26/02/2021	12:15	0.0017	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	26/02/2021	13:05	0.0251	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	26/02/2021	13:25	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	26/02/2021	10:40	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	26/02/2021	10:58	0.0013	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	26/02/2021	15:15	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	26/02/2021	14:35	<0.0005	g/m³	(2 - 2)

	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	26/02/2021	14:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	26/02/2021	15:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	26/02/2021	11:30	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	26/02/2021	11:34	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	26/02/2021	12:05	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	26/02/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	26/02/2021	13:05	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	26/02/2021	13:25	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	26/02/2021	10:40	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	26/02/2021	10:58	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	26/02/2021	15:15	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	26/02/2021	14:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	26/02/2021	14:00	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	26/02/2021	15:25	0.08	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	26/02/2021	11:30	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	26/02/2021	11:34	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	26/02/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	26/02/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	26/02/2021	13:05	0.0066	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	26/02/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	26/02/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	26/02/2021	10:58	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	26/02/2021	15:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	26/02/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	26/02/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	26/02/2021	15:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	26/02/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	26/02/2021	11:34	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	26/02/2021	12:05	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	26/02/2021	12:15	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	26/02/2021	13:05	11.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	26/02/2021	13:25	11.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	26/02/2021	10:40	11.3	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	26/02/2021	10:58	11.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	26/02/2021	15:15	10.7	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	26/02/2021	14:35	10.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	26/02/2021	14:00	11	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	26/02/2021	15:25	10.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	26/02/2021	11:30	11.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	26/02/2021	11:34	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	26/02/2021	12:05	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	26/02/2021	12:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	26/02/2021	13:05	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	26/02/2021	13:25	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	26/02/2021	10:40	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	26/02/2021	10:58	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	26/02/2021	15:15	0.0216	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	26/02/2021	14:35	0.0165	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	26/02/2021	14:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	26/02/2021	15:25	0.0223	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	26/02/2021	11:30	0.0012	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	26/02/2021	11:34	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	26/02/2021	12:05	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	26/02/2021	12:15	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	26/02/2021	13:05	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	26/02/2021	13:25	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	26/02/2021	10:40	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	26/02/2021	10:58	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	26/02/2021	15:15	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	26/02/2021	14:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	26/02/2021	14:00	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	26/02/2021	15:25	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	26/02/2021	11:30	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	26/02/2021	11:34	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	26/02/2021	12:05	0.0007	g/m³	(.08 - .08)

	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	26/02/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	26/02/2021	13:05	0.0023	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	26/02/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	26/02/2021	10:40	0.0016	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	26/02/2021	10:58	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	26/02/2021	15:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	26/02/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	26/02/2021	14:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	26/02/2021	15:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	26/02/2021	11:30	0.0023	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	26/02/2021	11:34	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	26/02/2021	12:05	0.004	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	26/02/2021	12:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	26/02/2021	13:05	0.25	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	26/02/2021	13:25	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	26/02/2021	10:40	0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	26/02/2021	10:58	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	26/02/2021	15:15	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	26/02/2021	14:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	26/02/2021	14:00	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	26/02/2021	15:25	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	26/02/2021	11:30	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	26/02/2021	11:34	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	26/02/2021	12:05	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	26/02/2021	12:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	26/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	26/02/2021	13:25	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	26/02/2021	10:40	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	26/02/2021	10:58	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	26/02/2021	15:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	26/02/2021	14:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	26/02/2021	14:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	26/02/2021	15:25	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	26/02/2021	11:30	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	26/02/2021	11:34	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	26/02/2021	12:05	8.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	26/02/2021	12:15	7.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	26/02/2021	13:05	6.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	26/02/2021	13:25	7.4	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	26/02/2021	10:40	8.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	26/02/2021	10:58	8	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	26/02/2021	15:15	7	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	26/02/2021	14:50	7.1	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	26/02/2021	14:35	7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	26/02/2021	14:00	7.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	26/02/2021	15:25	7.2	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	26/02/2021	11:30	8.2	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	26/02/2021	11:34	7.9	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	26/02/2021	12:05	0.15	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	26/02/2021	12:15	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	26/02/2021	13:05	0.05	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	26/02/2021	13:25	0.58	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	26/02/2021	10:40	1	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	26/02/2021	10:58	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	26/02/2021	14:35	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	26/02/2021	14:00	1.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	26/02/2021	11:30	0.07	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	26/02/2021	11:34	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	26/02/2021	12:05	0.5	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	26/02/2021	12:15	0.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	26/02/2021	13:05	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	26/02/2021	13:25	0.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	26/02/2021	10:40	0.9	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	26/02/2021	10:58	1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	26/02/2021	14:35	<0.05	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	26/02/2021	14:00	1.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	26/02/2021	11:30	0.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	26/02/2021	11:34	0.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	26/02/2021	11:30	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	26/02/2021	11:34	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	26/02/2021	12:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	26/02/2021	15:15	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	26/02/2021	15:15	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	26/02/2021	12:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	26/02/2021	15:15	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	26/02/2021	15:25	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	26/02/2021	12:05	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	26/02/2021	12:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	26/02/2021	13:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	26/02/2021	13:25	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	26/02/2021	10:40	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	26/02/2021	10:58	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	26/02/2021	15:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	26/02/2021	14:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	26/02/2021	14:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	26/02/2021	15:25	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	26/02/2021	11:30	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	26/02/2021	11:34	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	26/02/2021	14:40	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	27/02/2021	12:12	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	27/02/2021	12:40	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	27/02/2021	13:24	7.8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	27/02/2021	13:44	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	27/02/2021	11:00	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	27/02/2021	11:20	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	27/02/2021	15:30	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	27/02/2021	14:14	7.9		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	27/02/2021	15:00	7.9		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	27/02/2021	14:44	7.8		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	27/02/2021	14:10	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	27/02/2021	15:45	7.9		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	27/02/2021	11:58	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	27/02/2021	12:10	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	27/02/2021	12:12	<5	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	27/02/2021	12:40	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	27/02/2021	13:24	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	27/02/2021	13:44	<5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	27/02/2021	11:00	<5	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	27/02/2021	11:20	<5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	27/02/2021	15:30	<5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	27/02/2021	14:14	<5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	27/02/2021	15:00	<5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	27/02/2021	14:44	109	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	27/02/2021	14:10	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	27/02/2021	15:45	<5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	27/02/2021	11:58	<5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	27/02/2021	12:10	<5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	27/02/2021	12:12	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	27/02/2021	12:40	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	27/02/2021	13:24	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	27/02/2021	13:44	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	27/02/2021	11:00	70	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	27/02/2021	11:20	70	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	27/02/2021	15:30	70	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	27/02/2021	14:14	70	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	27/02/2021	15:00	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	27/02/2021	14:44	73	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	27/02/2021	14:10	70	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	27/02/2021	15:45	71	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	27/02/2021	11:58	70	g CaCO3/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	27/02/2021	12:10	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	27/02/2021	12:12	19.4	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	27/02/2021	12:40	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	27/02/2021	13:24	19	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	27/02/2021	13:44	19.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	27/02/2021	11:00	19.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	27/02/2021	11:20	19.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	27/02/2021	15:30	19	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	27/02/2021	14:14	19.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	27/02/2021	15:00	19	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	27/02/2021	14:44	18.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	27/02/2021	14:10	19.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	27/02/2021	15:45	19.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	27/02/2021	11:58	19.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	27/02/2021	12:10	19.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	27/02/2021	12:12	16.6	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	27/02/2021	12:40	16.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	27/02/2021	13:24	17.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	27/02/2021	13:44	16.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	27/02/2021	11:00	16.8	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	27/02/2021	11:20	16.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	27/02/2021	15:30	13.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	27/02/2021	14:14	13.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	27/02/2021	15:00	14.8	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	27/02/2021	14:44	14.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	27/02/2021	14:10	16.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	27/02/2021	15:45	13	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	27/02/2021	11:58	16.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	27/02/2021	12:10	16.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	27/02/2021	12:12	28.4	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	27/02/2021	12:40	27.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	27/02/2021	13:24	29	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	27/02/2021	13:44	26.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	27/02/2021	11:00	28.8	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	27/02/2021	11:20	28.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	27/02/2021	15:30	25	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	27/02/2021	14:14	27.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	27/02/2021	15:00	24.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	27/02/2021	14:44	25.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	27/02/2021	14:10	26.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	27/02/2021	15:45	25.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	27/02/2021	11:58	29.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	27/02/2021	12:10	27.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	27/02/2021	12:12	125	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	27/02/2021	12:40	128	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	27/02/2021	13:24	139	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	27/02/2021	13:44	121	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	27/02/2021	11:00	128	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	27/02/2021	11:20	142	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	27/02/2021	15:30	131	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	27/02/2021	14:14	135	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	27/02/2021	15:00	123	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	27/02/2021	14:44	143	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	27/02/2021	14:10	141	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	27/02/2021	15:45	141	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	27/02/2021	11:58	124	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	27/02/2021	12:10	145	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	27/02/2021	12:12	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	27/02/2021	12:12	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	27/02/2021	12:40	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	27/02/2021	13:24	0.015	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	27/02/2021	13:44	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	27/02/2021	11:00	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	27/02/2021	11:20	0.014	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	27/02/2021	15:00	0.01	g/m³	

	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	27/02/2021	14:44	20.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	27/02/2021	14:10	0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	27/02/2021	11:58	0.011	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	27/02/2021	12:10	0.012	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	27/02/2021	12:12	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	27/02/2021	12:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	27/02/2021	13:24	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	27/02/2021	13:44	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	27/02/2021	11:00	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	27/02/2021	11:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	27/02/2021	15:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	27/02/2021	14:44	0.004	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	27/02/2021	14:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	27/02/2021	11:58	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	27/02/2021	12:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	27/02/2021	12:12	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	27/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	27/02/2021	13:24	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	27/02/2021	13:44	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	27/02/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	27/02/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	27/02/2021	15:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	27/02/2021	14:44	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	27/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	27/02/2021	11:58	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	27/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	27/02/2021	12:12	22.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	27/02/2021	12:40	22.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	27/02/2021	13:24	22.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	27/02/2021	13:44	22.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	27/02/2021	11:00	22.8	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	27/02/2021	11:20	22.9	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	27/02/2021	15:00	22	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	27/02/2021	14:44	22.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	27/02/2021	14:10	22	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	27/02/2021	11:58	22.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	27/02/2021	12:10	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	27/02/2021	12:12	0.0018	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	27/02/2021	12:40	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	27/02/2021	13:24	0.0061	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	27/02/2021	13:44	0.0016	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	27/02/2021	11:00	0.0016	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	27/02/2021	11:20	0.001	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	27/02/2021	15:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	27/02/2021	14:44	0.0033	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	27/02/2021	14:10	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	27/02/2021	11:58	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	27/02/2021	12:10	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	27/02/2021	12:12	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	27/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	27/02/2021	13:24	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	27/02/2021	13:44	0.05	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	27/02/2021	11:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	27/02/2021	11:20	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	27/02/2021	15:00	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	27/02/2021	14:44	1.91	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	27/02/2021	14:10	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	27/02/2021	11:58	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	27/02/2021	12:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	27/02/2021	12:12	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	27/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	27/02/2021	13:24	0.0024	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	27/02/2021	13:44	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	27/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	27/02/2021	11:20	<0.0005	g/m³	(.005 - .01)

	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	27/02/2021	15:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	27/02/2021	14:44	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	27/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	27/02/2021	11:58	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	27/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	27/02/2021	12:12	11.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	27/02/2021	12:40	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	27/02/2021	13:24	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	27/02/2021	13:44	11	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	27/02/2021	11:00	11.4	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	27/02/2021	11:20	11.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	27/02/2021	15:00	10.8	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	27/02/2021	14:44	10.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	27/02/2021	14:10	11	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	27/02/2021	11:58	11.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	27/02/2021	12:10	11.2	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	27/02/2021	12:12	0.0039	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	27/02/2021	12:40	0.0196	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	27/02/2021	13:24	0.0068	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	27/02/2021	13:44	0.0035	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	27/02/2021	11:00	0.0021	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	27/02/2021	11:20	0.0038	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	27/02/2021	15:00	0.0169	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	27/02/2021	14:44	0.121	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	27/02/2021	14:10	0.0163	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	27/02/2021	11:58	0.0086	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	27/02/2021	12:10	0.0079	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	27/02/2021	12:12	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	27/02/2021	12:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	27/02/2021	13:24	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	27/02/2021	13:44	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	27/02/2021	11:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	27/02/2021	11:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	27/02/2021	15:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	27/02/2021	14:44	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	27/02/2021	14:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	27/02/2021	11:58	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	27/02/2021	12:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	27/02/2021	12:12	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	27/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	27/02/2021	13:24	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	27/02/2021	13:44	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	27/02/2021	11:00	0.0019	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	27/02/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	27/02/2021	15:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	27/02/2021	14:44	0.0018	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	27/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	27/02/2021	11:58	0.001	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	27/02/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	27/02/2021	12:12	0.006	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	27/02/2021	12:40	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	27/02/2021	13:24	0.018	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	27/02/2021	13:44	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	27/02/2021	11:00	0.003	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	27/02/2021	11:20	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	27/02/2021	15:00	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	27/02/2021	14:44	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	27/02/2021	14:10	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	27/02/2021	11:58	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	27/02/2021	12:10	<0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	27/02/2021	14:39	181,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	27/02/2021	14:39	31.7	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	27/02/2021	14:39	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	27/02/2021	14:39	5,740	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	27/02/2021	14:39	33.8	mg/Kg	

	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	27/02/2021	14:39	20,400	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	27/02/2021	14:39	4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	27/02/2021	14:39	1,360	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	27/02/2021	14:39	277	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	27/02/2021	14:39	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	27/02/2021	14:39	13.2	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	27/02/2021	14:39	772	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	27/02/2021	15:30	0.008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	27/02/2021	14:14	0.014	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	27/02/2021	15:45	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	27/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	27/02/2021	14:14	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	27/02/2021	15:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	27/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	27/02/2021	14:14	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	27/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	27/02/2021	15:30	19.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	27/02/2021	14:14	19.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	27/02/2021	15:45	19.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	27/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	27/02/2021	14:14	0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	27/02/2021	15:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	27/02/2021	15:30	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	27/02/2021	14:14	0.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	27/02/2021	15:45	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	27/02/2021	15:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	27/02/2021	14:14	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	27/02/2021	15:45	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	27/02/2021	15:30	10.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	27/02/2021	14:14	11	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	27/02/2021	15:45	10.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	27/02/2021	15:30	0.03	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	27/02/2021	14:14	0.025	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	27/02/2021	15:45	0.03	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	27/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	27/02/2021	14:14	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	27/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	27/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	27/02/2021	14:14	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	27/02/2021	15:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	27/02/2021	15:30	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	27/02/2021	14:14	0.012	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	27/02/2021	15:45	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	27/02/2021	12:12	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	27/02/2021	12:40	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	27/02/2021	13:24	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	27/02/2021	13:44	0.012	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	27/02/2021	11:00	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	27/02/2021	11:20	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	27/02/2021	15:30	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	27/02/2021	14:14	0.004	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	27/02/2021	15:00	0.011	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	27/02/2021	14:44	0.102	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	27/02/2021	14:10	0.009	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	27/02/2021	15:45	0.003	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	27/02/2021	11:58	0.011	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	27/02/2021	12:10	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	27/02/2021	12:12	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	27/02/2021	12:40	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	27/02/2021	13:24	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	27/02/2021	13:44	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	27/02/2021	11:00	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	27/02/2021	11:20	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	27/02/2021	15:30	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	27/02/2021	14:14	<0.001	g/m³	

	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	27/02/2021	15:00	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	27/02/2021	14:44	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	27/02/2021	14:10	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	27/02/2021	15:45	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	27/02/2021	11:58	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	27/02/2021	12:10	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	27/02/2021	12:12	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	27/02/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	27/02/2021	13:24	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	27/02/2021	13:44	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	27/02/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	27/02/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	27/02/2021	15:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	27/02/2021	14:14	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	27/02/2021	15:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	27/02/2021	14:44	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	27/02/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	27/02/2021	15:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	27/02/2021	11:58	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	27/02/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	27/02/2021	12:12	20	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	27/02/2021	12:40	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	27/02/2021	13:24	20.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	27/02/2021	13:44	20.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	27/02/2021	11:00	20.4	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	27/02/2021	11:20	20.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	27/02/2021	15:30	19.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	27/02/2021	14:14	20.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	27/02/2021	15:00	20	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	27/02/2021	14:44	19.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	27/02/2021	14:10	20	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	27/02/2021	15:45	19.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	27/02/2021	11:58	20.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	27/02/2021	12:10	20.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	27/02/2021	12:12	0.0089	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	27/02/2021	12:40	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	27/02/2021	13:24	0.0035	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	27/02/2021	13:44	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	27/02/2021	11:00	0.0069	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	27/02/2021	11:20	0.0012	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	27/02/2021	15:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	27/02/2021	14:14	0.0025	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	27/02/2021	15:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	27/02/2021	14:44	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	27/02/2021	14:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	27/02/2021	15:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	27/02/2021	11:58	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	27/02/2021	12:10	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	27/02/2021	12:12	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	27/02/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	27/02/2021	13:24	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	27/02/2021	13:44	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	27/02/2021	11:00	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	27/02/2021	11:20	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	27/02/2021	15:30	0.07	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	27/02/2021	14:14	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	27/02/2021	15:00	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	27/02/2021	14:44	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	27/02/2021	14:10	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	27/02/2021	15:45	0.08	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	27/02/2021	11:58	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	27/02/2021	12:10	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	27/02/2021	12:12	0.0033	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	27/02/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	27/02/2021	13:24	<0.0005	g/m³	(.005 - .01)

	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	27/02/2021	13:44	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	27/02/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	27/02/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	27/02/2021	15:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	27/02/2021	14:14	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	27/02/2021	15:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	27/02/2021	14:44	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	27/02/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	27/02/2021	15:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	27/02/2021	11:58	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	27/02/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	27/02/2021	12:12	11	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	27/02/2021	12:40	10.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	27/02/2021	13:24	10.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	27/02/2021	13:44	10.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	27/02/2021	11:00	10.7	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	27/02/2021	11:20	10.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	27/02/2021	15:30	10.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	27/02/2021	14:14	10.6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	27/02/2021	15:00	10.4	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	27/02/2021	14:44	10.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	27/02/2021	14:10	10.7	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	27/02/2021	15:45	10.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	27/02/2021	11:58	11	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	27/02/2021	12:10	10.8	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	27/02/2021	12:12	0.0014	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	27/02/2021	12:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	27/02/2021	13:24	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	27/02/2021	13:44	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	27/02/2021	11:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	27/02/2021	11:20	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	27/02/2021	15:30	0.0093	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	27/02/2021	14:14	0.0079	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	27/02/2021	15:00	0.0167	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	27/02/2021	14:44	0.0031	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	27/02/2021	14:10	0.0007	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	27/02/2021	15:45	0.0127	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	27/02/2021	11:58	0.0014	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	27/02/2021	12:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	27/02/2021	12:12	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	27/02/2021	12:40	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	27/02/2021	13:24	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	27/02/2021	13:44	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	27/02/2021	11:00	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	27/02/2021	11:20	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	27/02/2021	15:30	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	27/02/2021	14:14	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	27/02/2021	15:00	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	27/02/2021	14:44	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	27/02/2021	14:10	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	27/02/2021	15:45	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	27/02/2021	11:58	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	27/02/2021	12:10	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	27/02/2021	12:12	0.0019	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	27/02/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	27/02/2021	13:24	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	27/02/2021	13:44	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	27/02/2021	11:00	0.001	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	27/02/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	27/02/2021	15:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	27/02/2021	14:14	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	27/02/2021	15:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	27/02/2021	14:44	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	27/02/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	27/02/2021	15:45	<0.0005	g/m³	(.08 - .08)

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	27/02/2021	11:58	0.001	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	27/02/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	27/02/2021	12:12	0.208	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	27/02/2021	12:40	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	27/02/2021	13:24	0.013	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	27/02/2021	13:44	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	27/02/2021	11:00	0.038	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	27/02/2021	11:20	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	27/02/2021	15:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	27/02/2021	14:14	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	27/02/2021	15:00	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	27/02/2021	14:44	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	27/02/2021	14:10	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	27/02/2021	15:45	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	27/02/2021	11:58	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	27/02/2021	12:10	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	27/02/2021	12:12	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	27/02/2021	12:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	27/02/2021	13:24	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	27/02/2021	13:44	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	27/02/2021	11:00	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	27/02/2021	11:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	27/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	27/02/2021	14:14	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	27/02/2021	15:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	27/02/2021	14:44	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	27/02/2021	14:10	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	27/02/2021	15:45	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	27/02/2021	11:58	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	27/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	27/02/2021	12:12	7.4	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	27/02/2021	12:40	7.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	27/02/2021	13:24	7.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	27/02/2021	13:44	8	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	27/02/2021	11:00	8.2	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	27/02/2021	11:20	7.9	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	27/02/2021	15:30	6.8	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	27/02/2021	14:14	7.9	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	27/02/2021	15:00	7.3	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	27/02/2021	14:44	7.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	27/02/2021	14:10	7.8	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	27/02/2021	15:45	6.9	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	27/02/2021	11:58	7.4	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	27/02/2021	12:10	7.6	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	27/02/2021	12:12	0.15	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	27/02/2021	12:40	0.83	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	27/02/2021	13:24	0.61	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	27/02/2021	13:44	0.6	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	27/02/2021	11:00	0.06	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	27/02/2021	11:20	0.82	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	27/02/2021	15:00	<0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	27/02/2021	14:44	0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	27/02/2021	14:10	0.88	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	27/02/2021	11:58	0.05	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	27/02/2021	12:10	0.79	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	27/02/2021	12:12	0.2	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	27/02/2021	12:40	1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	27/02/2021	13:24	0.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	27/02/2021	13:44	0.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	27/02/2021	11:00	0.1	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	27/02/2021	11:20	0.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	27/02/2021	15:00	<0.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	27/02/2021	14:44	<0.05	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	27/02/2021	14:10	1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	27/02/2021	11:58	0.2	g/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	27/02/2021	12:10	0.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	27/02/2021	11:58	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	27/02/2021	12:10	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	27/02/2021	12:12	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	27/02/2021	15:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	27/02/2021	15:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	27/02/2021	12:12	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	27/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	27/02/2021	14:14	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	27/02/2021	15:45	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	27/02/2021	12:12	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	27/02/2021	12:40	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	27/02/2021	13:24	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	27/02/2021	13:44	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	27/02/2021	11:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	27/02/2021	11:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	27/02/2021	15:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	27/02/2021	14:14	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	27/02/2021	15:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	27/02/2021	14:44	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	27/02/2021	14:10	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	27/02/2021	15:45	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	27/02/2021	11:58	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	27/02/2021	12:10	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	27/02/2021	14:39	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	28/02/2021	09:50	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	28/02/2021	09:55	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	28/02/2021	10:10	7.7		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	28/02/2021	10:15	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	28/02/2021	09:05	7.8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	28/02/2021	09:10	7.8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	28/02/2021	08:35	7.5		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	28/02/2021	08:15	7.5		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	28/02/2021	08:05	7.6		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	28/02/2021	08:00	7.6		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	28/02/2021	08:30	7.6		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	28/02/2021	09:35	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	28/02/2021	09:40	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	28/02/2021	09:50	<5	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	28/02/2021	09:55	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	28/02/2021	10:10	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	28/02/2021	10:15	<5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	28/02/2021	09:05	<5	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	28/02/2021	09:10	<5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	28/02/2021	08:35	<5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	28/02/2021	08:15	<5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	28/02/2021	08:05	<5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	28/02/2021	08:00	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	28/02/2021	08:30	<5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	28/02/2021	09:35	<5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	28/02/2021	09:40	<5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	28/02/2021	09:50	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	28/02/2021	09:55	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	28/02/2021	10:10	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	28/02/2021	10:15	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	28/02/2021	09:05	71	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	28/02/2021	09:10	71	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	28/02/2021	08:35	70	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	28/02/2021	08:15	70	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	28/02/2021	08:05	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	28/02/2021	08:00	70	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	28/02/2021	08:30	69	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	28/02/2021	09:35	71	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	28/02/2021	09:40	70	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	28/02/2021	09:50	19.1	g/m³	

	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	28/02/2021	09:55	18.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	28/02/2021	10:10	19	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	28/02/2021	10:15	19	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	28/02/2021	09:05	19	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	28/02/2021	09:10	19	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	28/02/2021	08:35	19.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	28/02/2021	08:15	19.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	28/02/2021	08:05	19	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	28/02/2021	08:00	18.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	28/02/2021	08:30	19.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	28/02/2021	09:35	19.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	28/02/2021	09:40	19.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	28/02/2021	09:50	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	28/02/2021	09:55	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	28/02/2021	10:10	16.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	28/02/2021	10:15	16.3	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	28/02/2021	09:05	16.5	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	28/02/2021	09:10	16.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	28/02/2021	08:35	13.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	28/02/2021	08:15	13.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	28/02/2021	08:05	14.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	28/02/2021	08:00	14.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	28/02/2021	08:30	13.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	28/02/2021	09:35	16.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	28/02/2021	09:40	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	28/02/2021	09:50	25.7	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	28/02/2021	09:55	25.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	28/02/2021	10:10	25.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	28/02/2021	10:15	25.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	28/02/2021	09:05	25.9	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	28/02/2021	09:10	25.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	28/02/2021	08:35	24.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	28/02/2021	08:15	24.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	28/02/2021	08:05	23.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	28/02/2021	08:00	23.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	28/02/2021	08:30	24	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	28/02/2021	09:35	25.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	28/02/2021	09:40	25.9	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:50	139	g/m³	
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:55	142	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	28/02/2021	10:10	145	g/m³	
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	28/02/2021	10:15	126	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:05	129	g/m³	
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:10	129	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	28/02/2021	08:35	130	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	28/02/2021	08:15	133	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	28/02/2021	08:05	135	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	28/02/2021	08:00	135	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	28/02/2021	08:30	142	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:35	134	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	28/02/2021	09:40	124	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	28/02/2021	09:50	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	28/02/2021	09:50	0.014	g/m³	
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	28/02/2021	09:55	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	28/02/2021	10:10	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	28/02/2021	10:15	0.013	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	28/02/2021	09:05	0.015	g/m³	
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	28/02/2021	09:10	0.025	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	28/02/2021	08:05	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	28/02/2021	08:00	0.006	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	28/02/2021	09:35	0.013	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	28/02/2021	09:40	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	28/02/2021	09:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	28/02/2021	09:55	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	28/02/2021	10:10	<0.001	g/m³	(.01 - .01)

	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	28/02/2021	10:15	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	28/02/2021	09:05	<0.001	g/m³	(.01 - .01)
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	28/02/2021	09:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	28/02/2021	08:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	28/02/2021	08:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	28/02/2021	09:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	28/02/2021	09:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	28/02/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	28/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	28/02/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	28/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	28/02/2021	09:05	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	28/02/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	28/02/2021	08:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	28/02/2021	08:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	28/02/2021	09:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	28/02/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	28/02/2021	09:50	23.5	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	28/02/2021	09:55	22.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	28/02/2021	10:10	22.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	28/02/2021	10:15	22.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	28/02/2021	09:05	22.9	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	28/02/2021	09:10	22.8	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	28/02/2021	08:05	22.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	28/02/2021	08:00	22.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	28/02/2021	09:35	22.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	28/02/2021	09:40	22.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	28/02/2021	09:50	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	28/02/2021	09:55	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	28/02/2021	10:10	0.0018	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	28/02/2021	10:15	0.0015	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	28/02/2021	09:05	0.0015	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	28/02/2021	09:10	0.0016	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	28/02/2021	08:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	28/02/2021	08:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	28/02/2021	09:35	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	28/02/2021	09:40	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	28/02/2021	09:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	28/02/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	28/02/2021	10:10	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	28/02/2021	10:15	0.02	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	28/02/2021	09:05	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	28/02/2021	09:10	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	28/02/2021	08:05	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	28/02/2021	08:00	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	28/02/2021	09:35	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	28/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	28/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	28/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	28/02/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	28/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	28/02/2021	09:05	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	28/02/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	28/02/2021	08:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	28/02/2021	08:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	28/02/2021	09:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	28/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	28/02/2021	09:50	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	28/02/2021	09:55	11	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	28/02/2021	10:10	10.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	28/02/2021	10:15	10.8	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	28/02/2021	09:05	11	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	28/02/2021	09:10	11	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	28/02/2021	08:05	10.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	28/02/2021	08:00	10.7	g/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	28/02/2021	09:35	11	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	28/02/2021	09:40	11.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	28/02/2021	09:50	0.0034	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	28/02/2021	09:55	0.0075	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	28/02/2021	10:10	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	28/02/2021	10:15	0.0006	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	28/02/2021	09:05	0.0018	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	28/02/2021	09:10	0.0018	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	28/02/2021	08:05	0.0213	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	28/02/2021	08:00	0.0177	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	28/02/2021	09:35	0.0036	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	28/02/2021	09:40	0.0027	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	28/02/2021	09:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	28/02/2021	09:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	28/02/2021	10:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	28/02/2021	10:15	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	28/02/2021	09:05	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	28/02/2021	09:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	28/02/2021	08:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	28/02/2021	08:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	28/02/2021	09:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	28/02/2021	09:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	28/02/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	28/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	28/02/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	28/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	28/02/2021	09:05	0.0016	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	28/02/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	28/02/2021	08:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	28/02/2021	08:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	28/02/2021	09:35	0.0019	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	28/02/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	28/02/2021	09:50	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	28/02/2021	09:55	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	28/02/2021	10:10	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	28/02/2021	10:15	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	28/02/2021	09:05	0.006	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	28/02/2021	09:10	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	28/02/2021	08:05	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	28/02/2021	08:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	28/02/2021	09:35	0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	28/02/2021	09:40	0.002	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	28/02/2021	08:25	222,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	28/02/2021	08:25	38.2	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	28/02/2021	08:25	0.13	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	28/02/2021	08:25	13,300	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	28/02/2021	08:25	34.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	28/02/2021	08:25	27,200	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	28/02/2021	08:25	7.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	28/02/2021	08:25	4,190	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	28/02/2021	08:25	3,680	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	28/02/2021	08:25	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	28/02/2021	08:25	18.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	28/02/2021	08:25	65	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	28/02/2021	08:35	0.023	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	28/02/2021	08:15	0.013	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	28/02/2021	08:30	0.016	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	28/02/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	28/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	28/02/2021	08:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	28/02/2021	08:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	28/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	28/02/2021	08:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	28/02/2021	08:35	19	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	28/02/2021	08:15	19.4	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	28/02/2021	08:30	19.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	28/02/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	28/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	28/02/2021	08:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	28/02/2021	08:35	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	28/02/2021	08:15	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	28/02/2021	08:30	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	28/02/2021	08:35	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	28/02/2021	08:15	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	28/02/2021	08:30	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	28/02/2021	08:35	10.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	28/02/2021	08:15	10.4	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	28/02/2021	08:30	10.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	28/02/2021	08:35	0.04	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	28/02/2021	08:15	0.023	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	28/02/2021	08:30	0.04	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	28/02/2021	08:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	28/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	28/02/2021	08:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	28/02/2021	08:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	28/02/2021	08:15	0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	28/02/2021	08:30	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	28/02/2021	08:35	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	28/02/2021	08:15	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	28/02/2021	08:30	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	28/02/2021	09:50	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	28/02/2021	09:55	0.077	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	28/02/2021	10:10	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	28/02/2021	10:15	0.011	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	28/02/2021	09:05	0.013	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	28/02/2021	09:10	0.014	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	28/02/2021	08:35	0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	28/02/2021	08:15	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	28/02/2021	08:05	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	28/02/2021	08:00	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	28/02/2021	08:30	0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	28/02/2021	09:35	0.013	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	28/02/2021	09:40	0.013	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	28/02/2021	09:50	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	28/02/2021	09:55	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	28/02/2021	10:10	<0.001	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	28/02/2021	10:15	<0.001	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	28/02/2021	09:05	<0.001	g/m³	
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	28/02/2021	09:10	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	28/02/2021	08:35	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	28/02/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	28/02/2021	08:05	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	28/02/2021	08:00	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	28/02/2021	08:30	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	28/02/2021	09:35	<0.001	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	28/02/2021	09:40	<0.001	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	28/02/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	28/02/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	28/02/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	28/02/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	28/02/2021	09:05	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	28/02/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	28/02/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	28/02/2021	08:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	28/02/2021	08:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	28/02/2021	08:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	28/02/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	28/02/2021	09:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	28/02/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	28/02/2021	09:50	19	g/m³	

	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	28/02/2021	09:55	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	28/02/2021	10:10	19.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	28/02/2021	10:15	19.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	28/02/2021	09:05	19.8	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	28/02/2021	09:10	19.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	28/02/2021	08:35	19.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	28/02/2021	08:15	19.5	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	28/02/2021	08:05	19.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	28/02/2021	08:00	19.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	28/02/2021	08:30	19.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	28/02/2021	09:35	20.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	28/02/2021	09:40	20	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	28/02/2021	09:50	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	28/02/2021	09:55	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	28/02/2021	10:10	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	28/02/2021	10:15	0.0013	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	28/02/2021	09:05	0.0036	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	28/02/2021	09:10	0.0014	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	28/02/2021	08:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	28/02/2021	08:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	28/02/2021	08:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	28/02/2021	08:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	28/02/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	28/02/2021	09:35	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	28/02/2021	09:40	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	28/02/2021	09:50	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	28/02/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	28/02/2021	10:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	28/02/2021	10:15	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	28/02/2021	09:05	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	28/02/2021	09:10	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	28/02/2021	08:35	0.06	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	28/02/2021	08:15	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	28/02/2021	08:05	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	28/02/2021	08:00	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	28/02/2021	08:30	0.07	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	28/02/2021	09:35	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	28/02/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	28/02/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	28/02/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	28/02/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	28/02/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	28/02/2021	09:05	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	28/02/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	28/02/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	28/02/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	28/02/2021	08:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	28/02/2021	08:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	28/02/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	28/02/2021	09:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	28/02/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	28/02/2021	09:50	10.4	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	28/02/2021	09:55	10.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	28/02/2021	10:10	10.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	28/02/2021	10:15	10.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	28/02/2021	09:05	10.5	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	28/02/2021	09:10	10.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	28/02/2021	08:35	10.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	28/02/2021	08:15	10.2	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	28/02/2021	08:05	10.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	28/02/2021	08:00	10.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	28/02/2021	08:30	10.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	28/02/2021	09:35	10.6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	28/02/2021	09:40	10.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	28/02/2021	09:50	<0.0005	g/m³	(.4 - .4)

	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	28/02/2021	09:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	28/02/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	28/02/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	28/02/2021	09:05	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	28/02/2021	09:10	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	28/02/2021	08:35	0.0138	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	28/02/2021	08:15	0.0051	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	28/02/2021	08:05	0.0223	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	28/02/2021	08:00	0.0185	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	28/02/2021	08:30	0.016	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	28/02/2021	09:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	28/02/2021	09:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	28/02/2021	09:50	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	28/02/2021	09:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	28/02/2021	10:10	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	28/02/2021	10:15	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	28/02/2021	09:05	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	28/02/2021	09:10	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	28/02/2021	08:35	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	28/02/2021	08:15	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	28/02/2021	08:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	28/02/2021	08:00	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	28/02/2021	08:30	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	28/02/2021	09:35	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	28/02/2021	09:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	28/02/2021	09:50	0.0021	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	28/02/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	28/02/2021	10:10	0.0009	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	28/02/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	28/02/2021	09:05	0.0009	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	28/02/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	28/02/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	28/02/2021	08:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	28/02/2021	08:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	28/02/2021	08:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	28/02/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	28/02/2021	09:35	0.0018	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	28/02/2021	09:40	0.0017	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	28/02/2021	09:50	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	28/02/2021	09:55	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	28/02/2021	10:10	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	28/02/2021	10:15	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	28/02/2021	09:05	0.033	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	28/02/2021	09:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	28/02/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	28/02/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	28/02/2021	08:05	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	28/02/2021	08:00	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	28/02/2021	08:30	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	28/02/2021	09:35	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	28/02/2021	09:40	<0.002	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	28/02/2021	09:50	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	28/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	28/02/2021	10:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	28/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	28/02/2021	09:05	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	28/02/2021	09:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	28/02/2021	08:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	28/02/2021	08:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	28/02/2021	08:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	28/02/2021	08:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	28/02/2021	08:30	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	28/02/2021	09:35	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	28/02/2021	09:40	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	28/02/2021	08:05	No	Water	

	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:50	6.3	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:55	7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	28/02/2021	10:10	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	28/02/2021	10:15	6.8	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:05	7.3	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:10	6.3	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	28/02/2021	08:35	6.3	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	28/02/2021	08:15	5.5	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	28/02/2021	08:05	6.3	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	28/02/2021	08:00	6.4	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	28/02/2021	08:30	6.3	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:35	6.4	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	28/02/2021	09:40	6.5	g O2/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	28/02/2021	09:50	0.05	g/m³	(0 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	28/02/2021	09:55	0.77	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	28/02/2021	10:10	0.06	g/m³	(0 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	28/02/2021	10:15	0.76	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	28/02/2021	09:05	0.28	g/m³	(0 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	28/02/2021	09:10	0.82	g/m³	(.2 - 5)
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	28/02/2021	08:05	0.23	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	28/02/2021	08:00	0.08	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	28/02/2021	09:35	0.1	g/m³	(0 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	28/02/2021	09:40	1	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	28/02/2021	09:50	0.1	g/m³	
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	28/02/2021	09:55	0.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	28/02/2021	10:10	0.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	28/02/2021	10:15	0.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	28/02/2021	09:05	0.4	g/m³	
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	28/02/2021	09:10	1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	28/02/2021	08:05	0.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	28/02/2021	08:00	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	28/02/2021	09:35	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	28/02/2021	09:40	1.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	28/02/2021	09:35	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	28/02/2021	09:40	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	28/02/2021	09:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	28/02/2021	08:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	28/02/2021	08:35	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	28/02/2021	09:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	28/02/2021	10:10	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	28/02/2021	10:15	<1	MPN/100mL	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	28/02/2021	10:10	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	28/02/2021	10:15	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	28/02/2021	08:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	28/02/2021	08:15	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	28/02/2021	08:30	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	28/02/2021	09:50	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	28/02/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	28/02/2021	10:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	28/02/2021	10:15	Completed		
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	28/02/2021	09:05	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	28/02/2021	09:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	28/02/2021	08:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	28/02/2021	08:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	28/02/2021	08:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	28/02/2021	08:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	28/02/2021	08:30	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	28/02/2021	09:35	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	28/02/2021	09:40	Completed		
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	28/02/2021	08:25	Completed		

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	01/03/2021	11:40	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	01/03/2021	11:50	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	01/03/2021	12:25	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	01/03/2021	12:35	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	01/03/2021	13:50	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	01/03/2021	14:00	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	01/03/2021	11:25	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	01/03/2021	11:55	7.9		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	01/03/2021	10:50	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	01/03/2021	11:20	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	01/03/2021	12:00	7.9		(1 - 14)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	01/03/2021	12:55	8		(1 - 14)
	Waikouaiti SS - 319 Bendigo Rd	1	pH	01/03/2021	13:05	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	01/03/2021	11:40	<5	g/m³	
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	01/03/2021	11:50	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	01/03/2021	12:25	<5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	01/03/2021	12:35	<5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	01/03/2021	13:50	<5	g/m³	
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	01/03/2021	14:00	<5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	01/03/2021	11:25	<5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	01/03/2021	11:55	<5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	01/03/2021	10:50	<5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	01/03/2021	11:20	<5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	01/03/2021	12:00	<5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	01/03/2021	12:55	<5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	01/03/2021	13:05	<5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	01/03/2021	11:40	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	01/03/2021	11:50	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	01/03/2021	12:25	73	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	01/03/2021	12:35	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	01/03/2021	13:50	73	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	01/03/2021	14:00	74	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	01/03/2021	11:25	70	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/03/2021	11:55	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/03/2021	10:50	72	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	01/03/2021	11:20	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	01/03/2021	12:00	73	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	01/03/2021	12:55	74	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	01/03/2021	13:05	72	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/03/2021	11:40	19.2	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	01/03/2021	11:50	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	01/03/2021	12:25	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	01/03/2021	12:35	19.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	01/03/2021	13:50	19.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	01/03/2021	14:00	19.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	01/03/2021	11:25	19.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/03/2021	11:55	18.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/03/2021	10:50	19.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	01/03/2021	11:20	19.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	01/03/2021	12:00	19.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/03/2021	12:55	19	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	01/03/2021	13:05	19.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	01/03/2021	11:40	16.3	g/m³	
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	01/03/2021	11:50	16.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	01/03/2021	12:25	16.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	01/03/2021	12:35	16.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	01/03/2021	13:50	16.7	g/m³	
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	01/03/2021	14:00	16.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	01/03/2021	11:25	13.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	01/03/2021	11:55	13.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	01/03/2021	10:50	16.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	01/03/2021	11:20	13.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	01/03/2021	12:00	16.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	01/03/2021	12:55	16.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	01/03/2021	13:05	16.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/03/2021	11:40	24.9	g/m³	
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	01/03/2021	11:50	24.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	01/03/2021	12:25	25.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	01/03/2021	12:35	25.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	01/03/2021	13:50	24.7	g/m³	
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	01/03/2021	14:00	24.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	01/03/2021	11:25	23.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	01/03/2021	11:55	26.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	01/03/2021	10:50	24	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	01/03/2021	11:20	22.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	01/03/2021	12:00	24.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/03/2021	12:55	26.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	01/03/2021	13:05	24.4	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	01/03/2021	11:40	124	g/m³	

	Waikouaiti SS - 192 Main Rd	1024 Total Dissolved Solids by Evaporation	01/03/2021	11:50	129	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024 Total Dissolved Solids by Evaporation	01/03/2021	12:25	136	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024 Total Dissolved Solids by Evaporation	01/03/2021	12:35	143	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024 Total Dissolved Solids by Evaporation	01/03/2021	13:50	143	g/m³		
	Karitane SS - 99 Stornoway St	1024 Total Dissolved Solids by Evaporation	01/03/2021	14:00	129	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024 Total Dissolved Solids by Evaporation	01/03/2021	11:25	107	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024 Total Dissolved Solids by Evaporation	01/03/2021	11:55	124	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024 Total Dissolved Solids by Evaporation	01/03/2021	10:50	125	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024 Total Dissolved Solids by Evaporation	01/03/2021	11:20	122	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024 Total Dissolved Solids by Evaporation	01/03/2021	12:00	131	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024 Total Dissolved Solids by Evaporation	01/03/2021	12:55	137	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024 Total Dissolved Solids by Evaporation	01/03/2021	13:05	143	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214 Surcharge Fee	01/03/2021	11:40	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001 Aluminium - Acid Soluble	01/03/2021	11:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd	6001 Aluminium - Acid Soluble	01/03/2021	11:50	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001 Aluminium - Acid Soluble	01/03/2021	12:25	0.013	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001 Aluminium - Acid Soluble	01/03/2021	12:35	0.012	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001 Aluminium - Acid Soluble	01/03/2021	13:50	0.015	g/m³		
	Karitane SS - 99 Stornoway St	6001 Aluminium - Acid Soluble	01/03/2021	14:00	0.014	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001 Aluminium - Acid Soluble	01/03/2021	10:50	0.009	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001 Aluminium - Acid Soluble	01/03/2021	12:00	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001 Aluminium - Acid Soluble	01/03/2021	12:55	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001 Aluminium - Acid Soluble	01/03/2021	13:05	0.013	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003 Arsenic - Acid Soluble	01/03/2021	11:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003 Arsenic - Acid Soluble	01/03/2021	11:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003 Arsenic - Acid Soluble	01/03/2021	12:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003 Arsenic - Acid Soluble	01/03/2021	12:35	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003 Arsenic - Acid Soluble	01/03/2021	13:50	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003 Arsenic - Acid Soluble	01/03/2021	14:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003 Arsenic - Acid Soluble	01/03/2021	10:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003 Arsenic - Acid Soluble	01/03/2021	12:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003 Arsenic - Acid Soluble	01/03/2021	12:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003 Arsenic - Acid Soluble	01/03/2021	13:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008 Cadmium - Acid Soluble	01/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008 Cadmium - Acid Soluble	01/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008 Cadmium - Acid Soluble	01/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008 Cadmium - Acid Soluble	01/03/2021	12:35	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008 Cadmium - Acid Soluble	01/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008 Cadmium - Acid Soluble	01/03/2021	14:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008 Cadmium - Acid Soluble	01/03/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008 Cadmium - Acid Soluble	01/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008 Cadmium - Acid Soluble	01/03/2021	12:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	01/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	01/03/2021	11:40	19.6	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	01/03/2021	11:50	20.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	01/03/2021	12:25	20.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	01/03/2021	12:35	20.9	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	01/03/2021	13:50	20.9	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	01/03/2021	14:00	21	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	01/03/2021	10:50	20.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	01/03/2021	12:00	20.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	01/03/2021	12:55	20.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	01/03/2021	13:05	20.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	01/03/2021	11:40	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	01/03/2021	11:50	0.0016	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	01/03/2021	12:25	0.007	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	01/03/2021	12:35	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	01/03/2021	13:50	0.0033	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	01/03/2021	14:00	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	01/03/2021	10:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	01/03/2021	12:00	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	01/03/2021	12:55	0.0195	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	01/03/2021	13:05	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	01/03/2021	11:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	01/03/2021	11:50	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	01/03/2021	12:25	0.03	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	01/03/2021	12:35	0.03	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	01/03/2021	13:50	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	01/03/2021	14:00	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	01/03/2021	10:50	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	01/03/2021	12:00	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	01/03/2021	12:55	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	01/03/2021	13:05	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	01/03/2021	11:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	01/03/2021	11:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	01/03/2021	12:25	0.003	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	01/03/2021	12:35	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	01/03/2021	13:50	0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	01/03/2021	14:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	01/03/2021	10:50	<0.0005	g/m³	(.005 - .01)	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	01/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	01/03/2021	12:55	0.0316	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	01/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	01/03/2021	11:40	10.5	g/m³		
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	01/03/2021	11:50	10.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	01/03/2021	12:25	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	01/03/2021	12:35	10.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	01/03/2021	13:50	11.5	g/m³		
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	01/03/2021	14:00	10.6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	01/03/2021	10:50	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	01/03/2021	12:00	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	01/03/2021	12:55	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	01/03/2021	13:05	10.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	01/03/2021	11:40	0.0221	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	01/03/2021	11:50	0.0231	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	01/03/2021	12:25	0.0115	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	01/03/2021	12:35	0.0008	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	01/03/2021	13:50	0.0054	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	01/03/2021	14:00	0.0027	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	01/03/2021	10:50	0.0129	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	01/03/2021	12:00	0.0075	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	01/03/2021	12:55	0.0057	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	01/03/2021	13:05	0.0092	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	01/03/2021	11:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	01/03/2021	11:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	01/03/2021	12:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	01/03/2021	12:35	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	01/03/2021	13:50	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	01/03/2021	14:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	01/03/2021	10:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	01/03/2021	12:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	01/03/2021	12:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	01/03/2021	13:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	01/03/2021	11:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	01/03/2021	11:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	01/03/2021	12:25	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	01/03/2021	12:35	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	01/03/2021	13:50	0.0012	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	01/03/2021	14:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	01/03/2021	10:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	01/03/2021	12:00	0.0021	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	01/03/2021	12:55	0.0011	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	01/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	01/03/2021	11:40	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	01/03/2021	11:50	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	01/03/2021	12:25	0.083	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	01/03/2021	12:35	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	01/03/2021	13:50	0.037	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	01/03/2021	14:00	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	01/03/2021	10:50	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	01/03/2021	12:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	01/03/2021	12:55	0.449	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	01/03/2021	13:05	<0.002	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	01/03/2021	11:15	110,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	01/03/2021	11:15	18.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	01/03/2021	11:15	0.09	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	01/03/2021	11:15	8,550	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	01/03/2021	11:15	19.9	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	01/03/2021	11:15	17,600	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	01/03/2021	11:15	3.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	01/03/2021	11:15	2,130	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	01/03/2021	11:15	2,130	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	01/03/2021	11:15	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	01/03/2021	11:15	9.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	01/03/2021	11:15	62	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	01/03/2021	11:25	0.014	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	01/03/2021	11:55	0.018	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	01/03/2021	11:20	0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	01/03/2021	11:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	01/03/2021	11:55	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	01/03/2021	11:20	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	01/03/2021	11:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	01/03/2021	11:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	01/03/2021	11:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	01/03/2021	11:25	17.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	01/03/2021	11:55	18.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	01/03/2021	11:20	19.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	01/03/2021	11:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	01/03/2021	11:55	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	01/03/2021	11:20	<0.002	g/m³		

	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	01/03/2021	11:25	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	01/03/2021	11:55	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	01/03/2021	11:20	0.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	01/03/2021	11:25	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	01/03/2021	11:55	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	01/03/2021	11:20	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	01/03/2021	11:25	9.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	01/03/2021	11:55	10.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	01/03/2021	11:20	10.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	01/03/2021	11:25	0.035	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	01/03/2021	11:55	0.02	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	01/03/2021	11:20	0.037	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	01/03/2021	11:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	01/03/2021	11:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	01/03/2021	11:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	01/03/2021	11:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	01/03/2021	11:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	01/03/2021	11:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	01/03/2021	11:25	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	01/03/2021	11:55	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	01/03/2021	11:20	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	01/03/2021	11:40	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	01/03/2021	11:50	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	01/03/2021	12:25	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	01/03/2021	12:35	0.012	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	01/03/2021	13:50	0.013	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	01/03/2021	14:00	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	01/03/2021	11:25	0.003	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/03/2021	11:55	0.004	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/03/2021	10:50	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	01/03/2021	11:20	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	01/03/2021	12:00	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	01/03/2021	12:55	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	01/03/2021	13:05	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	01/03/2021	11:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	01/03/2021	11:50	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	01/03/2021	12:25	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	01/03/2021	12:35	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	01/03/2021	13:50	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	01/03/2021	14:00	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	01/03/2021	11:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	01/03/2021	11:55	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	01/03/2021	10:50	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	01/03/2021	11:20	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	01/03/2021	12:00	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	01/03/2021	12:55	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	01/03/2021	13:05	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	01/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	01/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	01/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	01/03/2021	12:35	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	01/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	01/03/2021	14:00	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	01/03/2021	11:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/03/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	01/03/2021	11:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	01/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	01/03/2021	12:55	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	01/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	01/03/2021	11:40	19.6	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	01/03/2021	11:50	19.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	01/03/2021	12:25	20.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	01/03/2021	12:35	20.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	01/03/2021	13:50	19.9	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	01/03/2021	14:00	20.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	01/03/2021	11:25	19.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	01/03/2021	11:55	19.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	01/03/2021	10:50	19.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	01/03/2021	11:20	19.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	01/03/2021	12:00	19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	01/03/2021	12:55	20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	01/03/2021	13:05	19.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	01/03/2021	11:40	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	01/03/2021	11:50	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	01/03/2021	12:25	0.0061	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	01/03/2021	12:35	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	01/03/2021	13:50	0.0026	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	01/03/2021	14:00	0.0007	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	01/03/2021	11:25	<0.0005	g/m³	(2 - 2)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713 Copper - Dissolved	01/03/2021	11:55	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713 Copper - Dissolved	01/03/2021	10:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713 Copper - Dissolved	01/03/2021	11:20	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713 Copper - Dissolved	01/03/2021	12:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713 Copper - Dissolved	01/03/2021	12:55	0.03	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713 Copper - Dissolved	01/03/2021	13:05	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717 Iron - Dissolved	01/03/2021	11:40	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717 Iron - Dissolved	01/03/2021	11:50	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717 Iron - Dissolved	01/03/2021	12:25	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717 Iron - Dissolved	01/03/2021	12:35	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717 Iron - Dissolved	01/03/2021	13:50	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717 Iron - Dissolved	01/03/2021	14:00	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717 Iron - Dissolved	01/03/2021	11:25	0.09	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717 Iron - Dissolved	01/03/2021	11:55	0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717 Iron - Dissolved	01/03/2021	10:50	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717 Iron - Dissolved	01/03/2021	11:20	0.08	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717 Iron - Dissolved	01/03/2021	12:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717 Iron - Dissolved	01/03/2021	12:55	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717 Iron - Dissolved	01/03/2021	13:05	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718 Lead - Dissolved	01/03/2021	11:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718 Lead - Dissolved	01/03/2021	11:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718 Lead - Dissolved	01/03/2021	12:25	0.001	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718 Lead - Dissolved	01/03/2021	12:35	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718 Lead - Dissolved	01/03/2021	13:50	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718 Lead - Dissolved	01/03/2021	14:00	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718 Lead - Dissolved	01/03/2021	11:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718 Lead - Dissolved	01/03/2021	11:55	0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718 Lead - Dissolved	01/03/2021	10:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718 Lead - Dissolved	01/03/2021	11:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718 Lead - Dissolved	01/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718 Lead - Dissolved	01/03/2021	12:55	0.0564	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718 Lead - Dissolved	01/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720 Magnesium - Dissolved	01/03/2021	11:40	10.3	g/m³		
	Waikouaiti SS - 192 Main Rd	6720 Magnesium - Dissolved	01/03/2021	11:50	10.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720 Magnesium - Dissolved	01/03/2021	12:25	10.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720 Magnesium - Dissolved	01/03/2021	12:35	10.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720 Magnesium - Dissolved	01/03/2021	13:50	10.4	g/m³		
	Karitane SS - 99 Stornoway St	6720 Magnesium - Dissolved	01/03/2021	14:00	10.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720 Magnesium - Dissolved	01/03/2021	11:25	10	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720 Magnesium - Dissolved	01/03/2021	11:55	10.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720 Magnesium - Dissolved	01/03/2021	10:50	10.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720 Magnesium - Dissolved	01/03/2021	11:20	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720 Magnesium - Dissolved	01/03/2021	12:00	10.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720 Magnesium - Dissolved	01/03/2021	12:55	10.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720 Magnesium - Dissolved	01/03/2021	13:05	10.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721 Manganese - Dissolved	01/03/2021	11:40	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721 Manganese - Dissolved	01/03/2021	11:50	0.0014	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721 Manganese - Dissolved	01/03/2021	12:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721 Manganese - Dissolved	01/03/2021	12:35	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721 Manganese - Dissolved	01/03/2021	13:50	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721 Manganese - Dissolved	01/03/2021	14:00	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721 Manganese - Dissolved	01/03/2021	11:25	0.0213	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721 Manganese - Dissolved	01/03/2021	11:55	0.0046	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721 Manganese - Dissolved	01/03/2021	10:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721 Manganese - Dissolved	01/03/2021	11:20	0.024	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721 Manganese - Dissolved	01/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721 Manganese - Dissolved	01/03/2021	12:55	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721 Manganese - Dissolved	01/03/2021	13:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722 Mercury - Dissolved	01/03/2021	11:40	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722 Mercury - Dissolved	01/03/2021	11:50	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722 Mercury - Dissolved	01/03/2021	12:25	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722 Mercury - Dissolved	01/03/2021	12:35	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722 Mercury - Dissolved	01/03/2021	13:50	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722 Mercury - Dissolved	01/03/2021	14:00	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722 Mercury - Dissolved	01/03/2021	11:25	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722 Mercury - Dissolved	01/03/2021	11:55	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722 Mercury - Dissolved	01/03/2021	10:50	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722 Mercury - Dissolved	01/03/2021	11:20	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722 Mercury - Dissolved	01/03/2021	12:00	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722 Mercury - Dissolved	01/03/2021	12:55	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722 Mercury - Dissolved	01/03/2021	13:05	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724 Nickel - Dissolved	01/03/2021	11:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724 Nickel - Dissolved	01/03/2021	11:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724 Nickel - Dissolved	01/03/2021	12:25	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724 Nickel - Dissolved	01/03/2021	12:35	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724 Nickel - Dissolved	01/03/2021	13:50	0.001	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724 Nickel - Dissolved	01/03/2021	14:00	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724 Nickel - Dissolved	01/03/2021	11:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724 Nickel - Dissolved	01/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724 Nickel - Dissolved	01/03/2021	10:50	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	01/03/2021	11:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	01/03/2021	12:00	0.0023	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	01/03/2021	12:55	0.0018	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	01/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	01/03/2021	11:40	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	01/03/2021	11:50	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	01/03/2021	12:25	0.081	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	01/03/2021	12:35	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	01/03/2021	13:50	0.031	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	01/03/2021	14:00	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	01/03/2021	11:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/03/2021	11:55	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/03/2021	10:50	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	01/03/2021	11:20	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	01/03/2021	12:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	01/03/2021	12:55	0.826	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	01/03/2021	13:05	<0.002	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	01/03/2021	11:40	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	01/03/2021	11:50	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	01/03/2021	12:25	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	01/03/2021	12:35	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	01/03/2021	13:50	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	01/03/2021	14:00	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	01/03/2021	11:25	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	01/03/2021	11:55	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	01/03/2021	10:50	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	01/03/2021	11:20	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	01/03/2021	12:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	01/03/2021	12:55	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	01/03/2021	13:05	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/03/2021	11:40	5.6	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	01/03/2021	11:50	5.5	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	01/03/2021	12:25	5.4	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	01/03/2021	12:35	5.1	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	01/03/2021	13:50	6.1	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	01/03/2021	14:00	5.8	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	01/03/2021	11:25	6	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/03/2021	11:55	5.7	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/03/2021	10:50	6.3	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	01/03/2021	11:20	5.6	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	01/03/2021	12:00	5.8	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	01/03/2021	12:10	5.2	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/03/2021	12:55	6.1	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	01/03/2021	13:05	5.7	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	01/03/2021	11:40	0.3	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	01/03/2021	11:50	1	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	01/03/2021	12:25	0.6	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	01/03/2021	12:35	0.62	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	01/03/2021	13:50	0.3	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	01/03/2021	14:00	0.91	g/m³	(.2 - 5)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/03/2021	10:50	1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	01/03/2021	12:00	0.22	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	01/03/2021	12:10	0.93	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	01/03/2021	12:55	0.62	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	01/03/2021	13:05	0.78	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	01/03/2021	11:40	0.6	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	01/03/2021	11:50	1.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	01/03/2021	12:25	0.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	01/03/2021	12:35	0.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	01/03/2021	13:50	0.7	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	01/03/2021	14:00	1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	01/03/2021	10:50	1.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	01/03/2021	12:00	0.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	01/03/2021	12:10	1.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	01/03/2021	12:55	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	01/03/2021	13:05	0.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	01/03/2021	12:00	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	01/03/2021	12:10	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-1201	Sampling / Inspection 15 Mins	01/03/2021	12:55	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1201	Sampling / Inspection 15 Mins	01/03/2021	13:05	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	01/03/2021	11:40	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	01/03/2021	11:25	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	01/03/2021	11:25	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	01/03/2021	11:40	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/03/2021	12:25	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/03/2021	12:35	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/03/2021	12:25	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/03/2021	12:35	<1	MPN/100ml	(0 - 0)	
No water	Waikouaiti WTP - Containerised Plant Filtrate	O1420	Sampler Observation	01/03/2021	11:10	No	water		
No water	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	01/03/2021	11:10	No	Water		

	Waikouaiti SS - Intersection Beach St/Stewart St	O1420	Sampler Observation	01/03/2021	12:10	Issue	with unidentified sample containors			
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/03/2021	11:25	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/03/2021	11:55	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/03/2021	11:20	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	01/03/2021	11:40	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	01/03/2021	11:50	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	01/03/2021	12:25	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	01/03/2021	12:35	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	01/03/2021	13:50	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	01/03/2021	14:00	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	01/03/2021	11:25	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/03/2021	11:55	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/03/2021	10:50	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	01/03/2021	11:20	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	01/03/2021	12:00	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	01/03/2021	12:55	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	01/03/2021	13:05	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	01/03/2021	11:15	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	02/03/2021	12:40	7.9		(1 - 14)		
	Waikouaiti SS - 192 Main Rd	1	pH	02/03/2021	12:45	7.8		(1 - 14)		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	02/03/2021	12:00	7.8		(1 - 14)		
	Waikouaiti SS - 210 Edinburgh St	1	pH	02/03/2021	12:05	7.9		(1 - 14)		
	Karitane SS - 99 Stornoway St - Preflush	1	pH	02/03/2021	13:00	7.8		(1 - 14)		
	Karitane SS - 99 Stornoway St	1	pH	02/03/2021	13:05	7.8		(1 - 14)		
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	02/03/2021	10:45	7.7		(1 - 14)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	02/03/2021	11:00	7.8		(1 - 14)		
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	02/03/2021	11:15	7.7		(1 - 14)		
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	02/03/2021	10:55	7.7		(1 - 14)		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	02/03/2021	10:50	7.7		(1 - 14)		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	02/03/2021	11:40	7.8		(1 - 14)		
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	02/03/2021	11:45	7.8		(1 - 14)		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	02/03/2021	12:20	7.9		(1 - 14)		
	Waikouaiti SS - 319 Bendigo Rd	1	pH	02/03/2021	12:25	7.8		(1 - 14)		
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	02/03/2021	12:40	<6	g/m³			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	02/03/2021	12:45	<6	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	02/03/2021	12:00	<6	g/m³			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	02/03/2021	12:05	<6	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	02/03/2021	13:00	<6	g/m³			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	02/03/2021	13:05	<6	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	02/03/2021	10:45	<6	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	02/03/2021	11:00	<6	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	02/03/2021	11:15	<6	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	02/03/2021	10:55	<6	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	02/03/2021	10:50	<6	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	02/03/2021	11:40	<6	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	02/03/2021	11:45	<6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	02/03/2021	12:20	<6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	02/03/2021	12:25	<6	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	02/03/2021	12:40	71	g CaCO3/m³			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	02/03/2021	12:45	72	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	02/03/2021	12:00	72	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	02/03/2021	12:05	71	g CaCO3/m³			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	02/03/2021	13:00	72	g CaCO3/m³			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	02/03/2021	13:05	71	g CaCO3/m³			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	02/03/2021	10:45	70	g CaCO3/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	02/03/2021	11:00	70	g CaCO3/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	02/03/2021	11:15	70	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	02/03/2021	10:55	70	g CaCO3/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	02/03/2021	10:50	71	g CaCO3/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	02/03/2021	11:40	74	g CaCO3/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	02/03/2021	11:45	71	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	02/03/2021	12:20	77	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	02/03/2021	12:25	73	g CaCO3/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	02/03/2021	12:40	19.2	g/m³			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	02/03/2021	12:45	19.1	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	02/03/2021	12:00	19.6	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	02/03/2021	12:05	19.7	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	02/03/2021	13:00	19.4	g/m³			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	02/03/2021	13:05	19.1	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	02/03/2021	10:45	19	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	02/03/2021	11:00	18.7	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	02/03/2021	11:15	19	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	02/03/2021	10:55	19.2	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	02/03/2021	10:50	19.4	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	02/03/2021	11:40	18.7	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	02/03/2021	11:45	19.4	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	02/03/2021	12:20	19.3	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	02/03/2021	12:25	19.4	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	02/03/2021	12:40	16.5	g/m³			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	02/03/2021	12:45	16.6	g/m³			

	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	02/03/2021	12:00	16.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	02/03/2021	12:05	16.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	02/03/2021	13:00	16.6	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	02/03/2021	13:05	16.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	02/03/2021	10:45	13.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	02/03/2021	11:00	13.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	02/03/2021	11:15	15.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	02/03/2021	10:55	16.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	02/03/2021	10:50	13.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	02/03/2021	11:40	16.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	02/03/2021	11:45	16.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	02/03/2021	12:20	16.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	02/03/2021	12:25	16.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	02/03/2021	12:40	24.1	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	02/03/2021	12:45	24	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	02/03/2021	12:00	24.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	02/03/2021	12:05	24.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	02/03/2021	13:00	24.2	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	02/03/2021	13:05	24	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	02/03/2021	10:45	23	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	02/03/2021	11:00	25.8	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	02/03/2021	11:15	22.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	02/03/2021	10:55	24	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	02/03/2021	10:50	23	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	02/03/2021	11:40	24.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	02/03/2021	11:45	24	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	02/03/2021	12:20	25	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	02/03/2021	12:25	24	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:40	128	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:45	143	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:00	143	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:05	144	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	02/03/2021	13:00	130	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	02/03/2021	13:05	132	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	02/03/2021	10:45	129	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	02/03/2021	11:00	149	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	02/03/2021	11:15	137	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	02/03/2021	10:55	138	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	02/03/2021	10:50	134	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	02/03/2021	11:40	147	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	02/03/2021	11:45	140	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:20	138	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	02/03/2021	12:25	148	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	02/03/2021	12:40	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	02/03/2021	12:40	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	02/03/2021	12:45	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	02/03/2021	12:00	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	02/03/2021	12:05	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	02/03/2021	13:00	0.015	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	02/03/2021	13:05	0.012	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	02/03/2021	11:15	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	02/03/2021	10:55	0.009	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	02/03/2021	11:40	0.013	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	02/03/2021	11:45	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	02/03/2021	12:20	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	02/03/2021	12:25	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	02/03/2021	12:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	02/03/2021	12:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	02/03/2021	12:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	02/03/2021	12:05	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	02/03/2021	13:00	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	02/03/2021	13:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	02/03/2021	11:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	02/03/2021	10:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	02/03/2021	11:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	02/03/2021	11:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	02/03/2021	12:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	02/03/2021	12:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	02/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	02/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	02/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	02/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	02/03/2021	13:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	02/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	02/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	02/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	02/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	02/03/2021	11:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	02/03/2021	12:20	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	02/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	

	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	02/03/2021	12:40	20.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	02/03/2021	12:45	20.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	02/03/2021	12:00	20.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	02/03/2021	12:05	20.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	02/03/2021	13:00	20.5	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	02/03/2021	13:05	20.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	02/03/2021	11:15	20.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	02/03/2021	10:55	19.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	02/03/2021	11:40	20.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	02/03/2021	11:45	20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	02/03/2021	12:20	20.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	02/03/2021	12:25	20.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	02/03/2021	12:40	0.0044	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	02/03/2021	12:45	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	02/03/2021	12:00	0.0055	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	02/03/2021	12:05	0.0009	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	02/03/2021	13:00	0.0062	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	02/03/2021	13:05	0.0008	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	02/03/2021	11:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	02/03/2021	10:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	02/03/2021	11:40	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	02/03/2021	11:45	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	02/03/2021	12:20	0.0148	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	02/03/2021	12:25	0.0034	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	02/03/2021	12:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	02/03/2021	12:45	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	02/03/2021	12:00	0.04	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	02/03/2021	12:05	0.04	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	02/03/2021	13:00	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	02/03/2021	13:05	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	02/03/2021	11:15	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	02/03/2021	10:55	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	02/03/2021	11:40	0.59	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	02/03/2021	11:45	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	02/03/2021	12:20	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	02/03/2021	12:25	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	02/03/2021	12:40	0.0024	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	02/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	02/03/2021	12:00	0.0026	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	02/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	02/03/2021	13:00	0.0012	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	02/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	02/03/2021	11:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	02/03/2021	10:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	02/03/2021	11:40	0.001	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	02/03/2021	11:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	02/03/2021	12:20	0.039	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	02/03/2021	12:25	0.0009	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	02/03/2021	12:40	10.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	02/03/2021	12:45	10.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	02/03/2021	12:00	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	02/03/2021	12:05	10.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	02/03/2021	13:00	10.4	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	02/03/2021	13:05	10.4	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	02/03/2021	11:15	10.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	02/03/2021	10:55	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	02/03/2021	11:40	10.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	02/03/2021	11:45	10.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	02/03/2021	12:20	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	02/03/2021	12:25	10.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	02/03/2021	12:40	0.0214	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	02/03/2021	12:45	0.0102	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	02/03/2021	12:00	0.0018	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	02/03/2021	12:05	0.0013	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	02/03/2021	13:00	0.016	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	02/03/2021	13:05	0.0042	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	02/03/2021	11:15	0.0106	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	02/03/2021	10:55	0.0155	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	02/03/2021	11:40	0.0499	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	02/03/2021	11:45	0.0145	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	02/03/2021	12:20	0.0029	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	02/03/2021	12:25	0.0014	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	02/03/2021	12:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	02/03/2021	12:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	02/03/2021	12:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	02/03/2021	12:05	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	02/03/2021	13:00	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	02/03/2021	13:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	02/03/2021	11:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	02/03/2021	10:55	<0.0005	g/m³	(.007 - .007)	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	02/03/2021	11:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	02/03/2021	11:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	02/03/2021	12:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	02/03/2021	12:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	02/03/2021	12:40	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	02/03/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	02/03/2021	12:00	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	02/03/2021	12:05	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	02/03/2021	13:00	0.0012	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	02/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	02/03/2021	11:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	02/03/2021	10:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	02/03/2021	11:40	0.0161	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	02/03/2021	11:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	02/03/2021	12:20	0.0028	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	02/03/2021	12:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	02/03/2021	12:40	0.06	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	02/03/2021	12:45	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	02/03/2021	12:00	0.064	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	02/03/2021	12:05	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	02/03/2021	13:00	0.037	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	02/03/2021	13:05	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	02/03/2021	11:15	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	02/03/2021	10:55	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	02/03/2021	11:40	0.005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	02/03/2021	11:45	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	02/03/2021	12:20	0.712	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	02/03/2021	12:25	0.01	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	02/03/2021	11:10	394,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	02/03/2021	11:10	79.9	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	02/03/2021	11:10	0.36	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	02/03/2021	11:10	15,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	02/03/2021	11:10	74.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	02/03/2021	11:10	69,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	02/03/2021	11:10	18.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	02/03/2021	11:10	4,040	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	02/03/2021	11:10	5,600	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	02/03/2021	11:10	0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	02/03/2021	11:10	32.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	02/03/2021	11:10	179	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	02/03/2021	10:45	0.008	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	02/03/2021	11:00	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	02/03/2021	10:50	0.009	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	02/03/2021	10:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	02/03/2021	11:00	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	02/03/2021	10:50	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	02/03/2021	10:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	02/03/2021	11:00	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	02/03/2021	10:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	02/03/2021	10:45	18.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	02/03/2021	11:00	19.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	02/03/2021	10:50	19.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	02/03/2021	10:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	02/03/2021	11:00	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	02/03/2021	10:50	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	02/03/2021	10:45	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	02/03/2021	11:00	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	02/03/2021	10:50	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	02/03/2021	10:45	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	02/03/2021	11:00	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	02/03/2021	10:50	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	02/03/2021	10:45	10.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	02/03/2021	11:00	10.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	02/03/2021	10:50	10.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	02/03/2021	10:45	0.036	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	02/03/2021	11:00	0.017	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	02/03/2021	10:50	0.037	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	02/03/2021	10:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	02/03/2021	11:00	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	02/03/2021	10:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	02/03/2021	10:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	02/03/2021	11:00	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	02/03/2021	10:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	02/03/2021	10:45	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	02/03/2021	11:00	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	02/03/2021	10:50	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	02/03/2021	12:40	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	02/03/2021	12:45	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	02/03/2021	12:00	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	02/03/2021	12:05	0.01	g/m³		

	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	02/03/2021	13:00	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	02/03/2021	13:05	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	02/03/2021	10:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	02/03/2021	11:00	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	02/03/2021	11:15	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	02/03/2021	10:55	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	02/03/2021	10:50	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	02/03/2021	11:40	0.007	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	02/03/2021	11:45	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	02/03/2021	12:20	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	02/03/2021	12:25	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	02/03/2021	12:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	02/03/2021	12:45	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	02/03/2021	12:00	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	02/03/2021	12:05	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	02/03/2021	13:00	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	02/03/2021	13:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	02/03/2021	10:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	02/03/2021	11:00	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	02/03/2021	11:15	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	02/03/2021	10:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	02/03/2021	10:50	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	02/03/2021	11:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	02/03/2021	11:45	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	02/03/2021	12:20	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	02/03/2021	12:25	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	02/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	02/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	02/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	02/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	02/03/2021	13:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	02/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	02/03/2021	10:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	02/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	02/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	02/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	02/03/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	02/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	02/03/2021	11:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	02/03/2021	12:20	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	02/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	02/03/2021	12:40	20.7	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	02/03/2021	12:45	20.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	02/03/2021	12:00	20.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	02/03/2021	12:05	20.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	02/03/2021	13:00	20.6	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	02/03/2021	13:05	20.9	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	02/03/2021	10:45	20.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	02/03/2021	11:00	20.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	02/03/2021	11:15	20.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	02/03/2021	10:55	20.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	02/03/2021	10:50	20.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	02/03/2021	11:40	20.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	02/03/2021	11:45	20.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	02/03/2021	12:20	20.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	02/03/2021	12:25	20.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	02/03/2021	12:40	0.0035	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	02/03/2021	12:45	0.0014	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	02/03/2021	12:00	0.0048	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	02/03/2021	12:05	0.0008	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	02/03/2021	13:00	0.0042	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	02/03/2021	13:05	0.0007	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	02/03/2021	10:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	02/03/2021	11:00	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	02/03/2021	11:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	02/03/2021	10:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	02/03/2021	10:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	02/03/2021	11:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	02/03/2021	11:45	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	02/03/2021	12:20	0.0148	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	02/03/2021	12:25	0.0029	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	02/03/2021	12:40	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	02/03/2021	12:45	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	02/03/2021	12:00	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	02/03/2021	12:05	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	02/03/2021	13:00	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	02/03/2021	13:05	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	02/03/2021	10:45	0.08	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	02/03/2021	11:00	0.05	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	02/03/2021	11:15	<0.01	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	02/03/2021	10:55	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	02/03/2021	10:50	0.07	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	02/03/2021	11:40	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	02/03/2021	11:45	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	02/03/2021	12:20	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	02/03/2021	12:25	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	02/03/2021	12:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	02/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	02/03/2021	12:00	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	02/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	02/03/2021	13:00	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	02/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	02/03/2021	10:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	02/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	02/03/2021	11:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	02/03/2021	10:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	02/03/2021	10:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	02/03/2021	11:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	02/03/2021	11:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	02/03/2021	12:20	0.0385	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	02/03/2021	12:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	02/03/2021	12:40	10.5	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	02/03/2021	12:45	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	02/03/2021	12:00	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	02/03/2021	12:05	10.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	02/03/2021	13:00	10.5	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	02/03/2021	13:05	10.4	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	02/03/2021	10:45	10.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	02/03/2021	11:00	10.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	02/03/2021	11:15	10.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	02/03/2021	10:55	10.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	02/03/2021	10:50	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	02/03/2021	11:40	10.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	02/03/2021	11:45	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	02/03/2021	12:20	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	02/03/2021	12:25	10.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	02/03/2021	12:40	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	02/03/2021	12:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	02/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	02/03/2021	12:05	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	02/03/2021	13:00	0.0008	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	02/03/2021	13:05	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	02/03/2021	10:45	0.0199	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	02/03/2021	11:00	0.0025	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	02/03/2021	11:15	0.0106	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	02/03/2021	10:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	02/03/2021	10:50	0.0218	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	02/03/2021	11:40	0.0022	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	02/03/2021	11:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	02/03/2021	12:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	02/03/2021	12:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	02/03/2021	12:40	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	02/03/2021	12:45	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	02/03/2021	12:00	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	02/03/2021	12:05	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	02/03/2021	13:00	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	02/03/2021	13:05	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	02/03/2021	10:45	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	02/03/2021	11:00	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	02/03/2021	11:15	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	02/03/2021	10:55	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	02/03/2021	10:50	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	02/03/2021	11:40	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	02/03/2021	11:45	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	02/03/2021	12:20	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	02/03/2021	12:25	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	02/03/2021	12:40	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	02/03/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	02/03/2021	12:00	0.001	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	02/03/2021	12:05	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	02/03/2021	13:00	0.0012	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	02/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	02/03/2021	10:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	02/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	02/03/2021	11:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	02/03/2021	10:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	02/03/2021	10:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	02/03/2021	11:40	0.0136	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	02/03/2021	11:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	02/03/2021	12:20	0.0026	g/m³	(.08 - .08)	

	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	02/03/2021	12:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	02/03/2021	12:40	0.056	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	02/03/2021	12:45	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	02/03/2021	12:00	0.086	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	02/03/2021	12:05	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	02/03/2021	13:00	0.034	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	02/03/2021	13:05	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	02/03/2021	10:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	02/03/2021	11:00	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	02/03/2021	11:15	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	02/03/2021	10:55	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	02/03/2021	10:50	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	02/03/2021	11:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	02/03/2021	11:45	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	02/03/2021	12:20	0.715	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	02/03/2021	12:25	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	02/03/2021	12:40	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	02/03/2021	12:45	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	02/03/2021	12:00	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	02/03/2021	12:05	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	02/03/2021	13:00	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	02/03/2021	13:05	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	02/03/2021	10:45	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	02/03/2021	11:00	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	02/03/2021	11:15	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	02/03/2021	10:55	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	02/03/2021	10:50	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	02/03/2021	11:40	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	02/03/2021	11:45	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	02/03/2021	12:20	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	02/03/2021	12:25	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:40	6.3	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:45	6.1	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:00	5	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:05	5.9	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	02/03/2021	13:00	5.4	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	02/03/2021	13:05	6	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	02/03/2021	10:45	6.3	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	02/03/2021	11:00	5.5	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	02/03/2021	11:15	5.9	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	02/03/2021	10:55	5.7	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	02/03/2021	10:50	6.2	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	02/03/2021	11:40	5.4	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	02/03/2021	11:45	5.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:20	6.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	02/03/2021	12:25	6	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	02/03/2021	12:40	0.73	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	02/03/2021	12:45	0.79	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	02/03/2021	12:00	0.42	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	02/03/2021	12:05	0.59	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	02/03/2021	13:00	0.8	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	02/03/2021	13:05	0.88	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	02/03/2021	11:15	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	02/03/2021	10:55	0.76	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	02/03/2021	11:40	0.24	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	02/03/2021	11:45	0.79	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	02/03/2021	12:20	0.48	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	02/03/2021	12:25	0.84	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	02/03/2021	12:40	0.8	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	02/03/2021	12:45	0.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	02/03/2021	12:00	0.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	02/03/2021	12:05	0.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	02/03/2021	13:00	0.8	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	02/03/2021	13:05	1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	02/03/2021	11:15	0.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	02/03/2021	10:55	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	02/03/2021	11:40	0.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	02/03/2021	11:45	1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	02/03/2021	12:20	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	02/03/2021	12:25	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-1201	Sampling / Inspection 15 Mins	02/03/2021	11:40	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-1201	Sampling / Inspection 15 Mins	02/03/2021	12:20	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1202	Sampling / Inspection 30 Mins	02/03/2021	12:40	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	02/03/2021	10:45	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	02/03/2021	10:45	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1205	Sampling / Inspection 2 hours	02/03/2021	12:40	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	02/03/2021	12:00	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	02/03/2021	12:05	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	02/03/2021	12:00	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	02/03/2021	12:05	<1	MPN/100ml	(0 - 0)	

	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	02/03/2021	10:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	02/03/2021	11:00	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	02/03/2021	10:50	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	02/03/2021	12:40	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	02/03/2021	12:45	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	02/03/2021	12:00	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	02/03/2021	12:05	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	02/03/2021	13:00	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	02/03/2021	13:05	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	02/03/2021	10:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	02/03/2021	11:00	Completed				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	02/03/2021	11:15	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	02/03/2021	10:55	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	02/03/2021	10:50	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	02/03/2021	11:40	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	02/03/2021	11:45	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	02/03/2021	12:20	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	02/03/2021	12:25	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	02/03/2021	11:10	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	03/03/2021	12:00	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	03/03/2021	12:05	7.9			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	03/03/2021	12:45	7.9			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	03/03/2021	12:50	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	03/03/2021	10:10	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	03/03/2021	08:50	7.9			(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	03/03/2021	10:15	7.7			(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	03/03/2021	08:30	7.7			(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	03/03/2021	08:20	8			(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	03/03/2021	08:15	7.6			(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	03/03/2021	08:45	7.7			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	03/03/2021	10:55	7.9			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	03/03/2021	11:00	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	03/03/2021	13:00	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	03/03/2021	13:05	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	03/03/2021	12:00	<5	g/m³			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	03/03/2021	12:05	<5	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	03/03/2021	12:45	<5	g/m³			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	03/03/2021	12:50	<5	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	03/03/2021	10:10	<5	g/m³			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	03/03/2021	08:50	<5	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	03/03/2021	10:15	<5	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	03/03/2021	08:30	7	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	03/03/2021	08:20	<5	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	03/03/2021	08:15	<5	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	03/03/2021	08:45	<5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	03/03/2021	10:55	<5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	03/03/2021	11:00	<5	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	03/03/2021	13:00	<5	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	03/03/2021	13:05	<5	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	03/03/2021	12:00	72	g CaCO3/m³			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	03/03/2021	12:05	72	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	03/03/2021	12:45	70	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	03/03/2021	12:50	71	g CaCO3/m³			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	03/03/2021	10:10	72	g CaCO3/m³			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	03/03/2021	08:50	71	g CaCO3/m³			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	03/03/2021	10:15	70	g CaCO3/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	03/03/2021	08:30	71	g CaCO3/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	03/03/2021	08:20	72	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	03/03/2021	08:15	64	g CaCO3/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	03/03/2021	08:45	71	g CaCO3/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	03/03/2021	10:55	71	g CaCO3/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	03/03/2021	11:00	70	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	03/03/2021	13:00	76	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	03/03/2021	13:05	72	g CaCO3/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	12:00	18.8	g/m³			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	03/03/2021	12:05	19	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	12:45	19.2	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	03/03/2021	12:50	19.1	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	10:10	19.2	g/m³			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	03/03/2021	08:50	19.3	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	03/03/2021	10:15	18.9	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	03/03/2021	08:30	18.3	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	03/03/2021	08:20	18.6	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	03/03/2021	08:15	18	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	03/03/2021	08:45	19	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	10:55	19	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	03/03/2021	11:00	18.7	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	13:00	18.6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	03/03/2021	13:05	18.8	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	12:00	16.3	g/m³			

	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	03/03/2021	12:05	16.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	12:45	16.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	03/03/2021	12:50	16.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	10:10	16.5	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	03/03/2021	08:50	16.4	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	03/03/2021	10:15	13.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	03/03/2021	08:30	13.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	03/03/2021	08:20	14.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	03/03/2021	08:15	18.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	03/03/2021	08:45	13.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	10:55	16.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	03/03/2021	11:00	16.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	13:00	16.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	03/03/2021	13:05	16.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	12:00	25.4	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	03/03/2021	12:05	25.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	12:45	25.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	03/03/2021	12:50	25.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	10:10	25.3	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	03/03/2021	08:50	25.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	03/03/2021	10:15	24.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	03/03/2021	08:30	25.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	03/03/2021	08:20	25.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	03/03/2021	08:15	25.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	03/03/2021	08:45	24.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	10:55	25.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	03/03/2021	11:00	25.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	13:00	26.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	03/03/2021	13:05	26.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	12:00	148	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	03/03/2021	12:05	140	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	12:45	146	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	03/03/2021	12:50	129	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	10:10	149	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:50	147	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	03/03/2021	10:15	122	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:30	143	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:20	122	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:15	145	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:45	122	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	10:55	134	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	03/03/2021	11:00	148	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	13:00	128	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	03/03/2021	13:05	141	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	03/03/2021	12:00	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	12:00	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	03/03/2021	12:05	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	12:45	0.012	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	03/03/2021	12:50	0.013	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	10:10	0.015	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	03/03/2021	08:50	0.012	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	03/03/2021	08:20	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	03/03/2021	08:15	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	10:55	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	03/03/2021	11:00	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	13:00	0.022	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	03/03/2021	13:05	0.021	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	12:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	03/03/2021	12:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	12:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	03/03/2021	12:50	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	10:10	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	03/03/2021	08:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	03/03/2021	08:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	03/03/2021	08:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	10:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	03/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	13:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	03/03/2021	13:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	03/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	03/03/2021	12:50	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	10:10	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	03/03/2021	08:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	03/03/2021	08:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	03/03/2021	08:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	03/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	13:00	<0.0002	g/m³	(.004 - .004)	

	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	03/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	03/03/2021	12:00	19.6	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	03/03/2021	12:05	19.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	03/03/2021	12:45	20.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	03/03/2021	12:50	20.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	03/03/2021	10:10	20.3	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	03/03/2021	08:50	20.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	03/03/2021	08:20	19.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	03/03/2021	08:15	19.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	03/03/2021	10:55	19.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	03/03/2021	11:00	19.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	03/03/2021	13:00	20.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	03/03/2021	13:05	20.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	03/03/2021	12:00	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	03/03/2021	12:05	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	03/03/2021	12:45	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	03/03/2021	12:50	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	03/03/2021	10:10	0.0009	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	03/03/2021	08:50	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	03/03/2021	08:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	03/03/2021	08:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	03/03/2021	10:55	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	03/03/2021	11:00	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	03/03/2021	13:00	0.0067	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	03/03/2021	13:05	0.0027	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	03/03/2021	12:00	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	03/03/2021	12:05	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	03/03/2021	12:45	0.09	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	03/03/2021	12:50	0.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	03/03/2021	10:10	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	03/03/2021	08:50	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	03/03/2021	08:20	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	03/03/2021	08:15	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	03/03/2021	10:55	0.02	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	03/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	03/03/2021	13:00	0.02	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	03/03/2021	13:05	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	03/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	03/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	03/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	03/03/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	03/03/2021	10:10	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	03/03/2021	08:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	03/03/2021	08:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	03/03/2021	08:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	03/03/2021	10:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	03/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	03/03/2021	13:00	0.0025	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	03/03/2021	13:05	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	03/03/2021	12:00	10.3	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	03/03/2021	12:05	10.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	03/03/2021	12:45	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	03/03/2021	12:50	10.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	03/03/2021	10:10	10.3	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	03/03/2021	08:50	10.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	03/03/2021	08:20	10.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	03/03/2021	08:15	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	03/03/2021	10:55	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	03/03/2021	11:00	10.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	03/03/2021	13:00	10.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	03/03/2021	13:05	10.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	03/03/2021	12:00	0.0066	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	03/03/2021	12:05	0.0065	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	03/03/2021	12:45	0.0064	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	03/03/2021	12:50	0.0073	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	03/03/2021	10:10	0.0029	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	03/03/2021	08:50	0.0025	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	03/03/2021	08:20	0.004	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	03/03/2021	08:15	0.0034	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	03/03/2021	10:55	0.0094	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	03/03/2021	11:00	0.0117	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	03/03/2021	13:00	0.0657	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	03/03/2021	13:05	0.0589	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	03/03/2021	12:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	03/03/2021	12:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	03/03/2021	12:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	03/03/2021	12:50	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	03/03/2021	10:10	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	03/03/2021	08:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	03/03/2021	08:20	<0.0005	g/m³	(.007 - .007)	

	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	03/03/2021	08:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	03/03/2021	10:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	03/03/2021	11:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	03/03/2021	13:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	03/03/2021	13:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	03/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	03/03/2021	12:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	03/03/2021	12:45	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	03/03/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	03/03/2021	10:10	0.0006	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	03/03/2021	08:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	03/03/2021	08:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	03/03/2021	08:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	03/03/2021	10:55	0.0026	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	03/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	03/03/2021	13:00	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	03/03/2021	13:05	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	03/03/2021	12:00	0.006	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	03/03/2021	12:05	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	03/03/2021	12:45	0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	03/03/2021	12:50	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	03/03/2021	10:10	0.01	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	03/03/2021	08:50	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	03/03/2021	08:20	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	03/03/2021	08:15	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	03/03/2021	10:55	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	03/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	03/03/2021	13:00	0.046	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	03/03/2021	13:05	0.007	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	03/03/2021	08:35	18,800	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	03/03/2021	08:35	4.56	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	03/03/2021	08:35	0.01	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	03/03/2021	08:35	2,270	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	03/03/2021	08:35	5.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	03/03/2021	08:35	14,300	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	03/03/2021	08:35	7.6	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	03/03/2021	08:35	1,990	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	03/03/2021	08:35	211	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	03/03/2021	08:35	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	03/03/2021	08:35	4.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	03/03/2021	08:35	27	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	03/03/2021	10:15	0.011	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	03/03/2021	08:30	0.798	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	03/03/2021	08:45	0.011	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	03/03/2021	10:15	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	03/03/2021	08:30	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	03/03/2021	08:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	03/03/2021	10:15	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	03/03/2021	08:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	03/03/2021	08:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	03/03/2021	10:15	19.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	03/03/2021	08:30	19.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	03/03/2021	08:45	20	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	03/03/2021	10:15	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	03/03/2021	08:30	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	03/03/2021	08:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	03/03/2021	10:15	0.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	03/03/2021	08:30	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	03/03/2021	08:45	0.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	03/03/2021	10:15	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	03/03/2021	08:30	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	03/03/2021	08:45	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	03/03/2021	10:15	10.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	03/03/2021	08:30	10.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	03/03/2021	08:45	10.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	03/03/2021	10:15	0.037	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	03/03/2021	08:30	0.027	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	03/03/2021	08:45	0.042	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	03/03/2021	10:15	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	03/03/2021	08:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	03/03/2021	08:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	03/03/2021	10:15	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	03/03/2021	08:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	03/03/2021	08:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	03/03/2021	10:15	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	03/03/2021	08:30	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	03/03/2021	08:45	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	03/03/2021	12:00	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	03/03/2021	12:05	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	03/03/2021	12:45	0.01	g/m³		

	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	03/03/2021	12:50	0.01	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	03/03/2021	10:10	0.012	g/m³			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	03/03/2021	08:50	0.012	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	03/03/2021	10:15	0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	03/03/2021	08:30	0.2	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	03/03/2021	08:20	0.008	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	03/03/2021	08:15	0.008	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	03/03/2021	08:45	0.002	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	03/03/2021	10:55	0.011	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	03/03/2021	11:00	0.011	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	03/03/2021	13:00	0.013	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	03/03/2021	13:05	0.013	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	03/03/2021	12:00	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	03/03/2021	12:05	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	03/03/2021	12:45	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	03/03/2021	12:50	<0.001	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	03/03/2021	10:10	<0.001	g/m³			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	03/03/2021	08:50	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	03/03/2021	10:15	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	03/03/2021	08:30	<0.001	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	03/03/2021	08:20	<0.001	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	03/03/2021	08:15	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	03/03/2021	08:45	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	03/03/2021	10:55	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	03/03/2021	11:00	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	03/03/2021	13:00	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	03/03/2021	13:05	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	03/03/2021	12:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	03/03/2021	12:05	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	03/03/2021	12:45	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	03/03/2021	12:50	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	03/03/2021	10:10	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	03/03/2021	08:50	<0.0002	g/m³		(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	03/03/2021	10:15	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	03/03/2021	08:30	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	03/03/2021	08:20	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	03/03/2021	08:15	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	03/03/2021	08:45	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	03/03/2021	10:55	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	03/03/2021	11:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	03/03/2021	13:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	03/03/2021	13:05	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	03/03/2021	12:00	18.9	g/m³			
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	03/03/2021	12:05	19.2	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	03/03/2021	12:45	19.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	03/03/2021	12:50	19.9	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	03/03/2021	10:10	19.7	g/m³			
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	03/03/2021	08:50	19.8	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	03/03/2021	10:15	19.1	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	03/03/2021	08:30	19	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	03/03/2021	08:20	19	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	03/03/2021	08:15	19.1	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	03/03/2021	08:45	18.5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	03/03/2021	10:55	19.4	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	03/03/2021	11:00	19.9	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	03/03/2021	13:00	20	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	03/03/2021	13:05	19.8	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	03/03/2021	12:00	0.0012	g/m³		(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	03/03/2021	12:05	0.001	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	03/03/2021	12:45	0.0019	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	03/03/2021	12:50	0.0008	g/m³		(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	03/03/2021	10:10	0.0007	g/m³		(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	03/03/2021	08:50	0.0006	g/m³		(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	03/03/2021	10:15	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	03/03/2021	08:30	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	03/03/2021	08:20	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	03/03/2021	08:15	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	03/03/2021	08:45	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	03/03/2021	10:55	0.0007	g/m³		(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	03/03/2021	11:00	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	03/03/2021	13:00	0.0019	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	03/03/2021	13:05	0.001	g/m³		(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	03/03/2021	12:00	<0.01	g/m³		(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	03/03/2021	12:05	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	03/03/2021	12:45	<0.01	g/m³		(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	03/03/2021	12:50	<0.01	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	03/03/2021	10:10	<0.01	g/m³		(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	03/03/2021	08:50	<0.01	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	03/03/2021	10:15	0.09	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	03/03/2021	08:30	<0.01	g/m³			

	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	03/03/2021	08:20	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	03/03/2021	08:15	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	03/03/2021	08:45	0.09	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	03/03/2021	10:55	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	03/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	03/03/2021	13:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	03/03/2021	13:05	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	03/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	03/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	03/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	03/03/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	03/03/2021	10:10	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	03/03/2021	08:50	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	03/03/2021	10:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	03/03/2021	08:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	03/03/2021	08:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	03/03/2021	08:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	03/03/2021	08:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	03/03/2021	10:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	03/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	03/03/2021	13:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	03/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	03/03/2021	12:00	10.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	03/03/2021	12:05	10.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	03/03/2021	12:45	10.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	03/03/2021	12:50	10.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	03/03/2021	10:10	10.3	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	03/03/2021	08:50	10.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	03/03/2021	10:15	10.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	03/03/2021	08:30	10.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	03/03/2021	08:20	10.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	03/03/2021	08:15	10.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	03/03/2021	08:45	9.98	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	03/03/2021	10:55	10.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	03/03/2021	11:00	10.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	03/03/2021	13:00	10.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	03/03/2021	13:05	10.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	03/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	03/03/2021	12:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	03/03/2021	12:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	03/03/2021	12:50	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	03/03/2021	10:10	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	03/03/2021	08:50	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	03/03/2021	10:15	0.0195	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	03/03/2021	08:30	0.0009	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	03/03/2021	08:20	0.004	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	03/03/2021	08:15	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	03/03/2021	08:45	0.0224	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	03/03/2021	10:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	03/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	03/03/2021	13:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	03/03/2021	13:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	03/03/2021	12:00	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	03/03/2021	12:05	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	03/03/2021	12:45	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	03/03/2021	12:50	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	03/03/2021	10:10	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	03/03/2021	08:50	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	03/03/2021	10:15	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	03/03/2021	08:30	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	03/03/2021	08:20	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	03/03/2021	08:15	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	03/03/2021	08:45	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	03/03/2021	10:55	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	03/03/2021	11:00	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	03/03/2021	13:00	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	03/03/2021	13:05	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	03/03/2021	12:00	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	03/03/2021	12:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	03/03/2021	12:45	0.0033	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	03/03/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	03/03/2021	10:10	0.0006	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	03/03/2021	08:50	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	03/03/2021	10:15	0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	03/03/2021	08:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	03/03/2021	08:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	03/03/2021	08:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	03/03/2021	08:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	03/03/2021	10:55	0.0043	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	03/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	03/03/2021	13:00	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	03/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	03/03/2021	12:00	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	03/03/2021	12:05	0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	03/03/2021	12:45	0.005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	03/03/2021	12:50	0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	03/03/2021	10:10	0.008	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	03/03/2021	08:50	0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	03/03/2021	10:15	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	03/03/2021	08:30	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	03/03/2021	08:20	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	03/03/2021	08:15	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	03/03/2021	08:45	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	03/03/2021	10:55	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	03/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	03/03/2021	13:00	0.031	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	03/03/2021	13:05	0.003	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	12:00	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	03/03/2021	12:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	12:45	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	03/03/2021	12:50	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	10:10	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	03/03/2021	08:50	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	03/03/2021	10:15	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	03/03/2021	08:30	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	03/03/2021	08:20	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	03/03/2021	08:15	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	03/03/2021	08:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	10:55	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	03/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	13:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	03/03/2021	13:05	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	03/03/2021	08:20	No	Water		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	12:00	5.5	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	03/03/2021	12:05	6.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	12:45	4.9	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	03/03/2021	12:50	6.3	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	10:10	5.7	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:50	6.1	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	03/03/2021	10:15	5.5	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:30	5.6	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:20	6.1	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:15	5.8	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:45	5.4	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	10:55	5.6	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	03/03/2021	11:00	5.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	13:00	4.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	03/03/2021	13:05	7.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	03/03/2021	12:00	0.17	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	03/03/2021	12:05	0.37	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	03/03/2021	12:45	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	03/03/2021	12:50	0.2	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	03/03/2021	10:10	0.43	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	03/03/2021	08:50	0.86	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	03/03/2021	08:20	0.07	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	03/03/2021	08:15	3.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	03/03/2021	10:55	0.1	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	03/03/2021	11:00	0.66	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	03/03/2021	13:00	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	03/03/2021	13:05	0.68	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	03/03/2021	12:00	0.2	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	03/03/2021	12:05	0.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	03/03/2021	12:45	<0.05	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	03/03/2021	12:50	0.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	03/03/2021	10:10	0.6	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	03/03/2021	08:50	0.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	03/03/2021	08:20	0.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	03/03/2021	08:15	3.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	03/03/2021	10:55	0.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	03/03/2021	11:00	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	03/03/2021	13:00	<0.05	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	03/03/2021	13:05	0.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	03/03/2021	12:00	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/03/2021	12:45	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/03/2021	12:50	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/03/2021	12:45	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/03/2021	12:50	<1	MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	03/03/2021	10:15	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	03/03/2021	08:30	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	03/03/2021	08:45	Completed			

	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	03/03/2021	12:00	Completed			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	03/03/2021	12:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	03/03/2021	12:45	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	03/03/2021	12:50	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	03/03/2021	10:10	Completed			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	03/03/2021	08:50	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	03/03/2021	10:15	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	03/03/2021	08:30	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	03/03/2021	08:20	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	03/03/2021	08:15	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	03/03/2021	08:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	03/03/2021	10:55	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	03/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	03/03/2021	13:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	03/03/2021	13:05	Completed			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	03/03/2021	08:35	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1	pH	03/03/2021	08:55	8		(1 - 14)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1	pH	03/03/2021	09:00	8		(1 - 14)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	2	Suspended Solids - Total	03/03/2021	08:55	<5	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	2	Suspended Solids - Total	03/03/2021	09:00	<5	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	52	Alkalinity - Total	03/03/2021	08:55	71	g CaCO3/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	03/03/2021	09:00	72	g CaCO3/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	0440D	Dissolved Inorganic Carbon	03/03/2021	08:55	18.7	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	03/03/2021	09:00	18.9	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	602	Chloride - Add P1859 Filtration	03/03/2021	08:55	16.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	602	Chloride - Add P1859 Filtration	03/03/2021	09:00	16.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	607	Sulphate - Add P1859 Filtration	03/03/2021	08:55	26.3	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	607	Sulphate - Add P1859 Filtration	03/03/2021	09:00	26.2	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1024	Total Dissolved Solids by Evaporation	03/03/2021	08:55	129	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1024	Total Dissolved Solids by Evaporation	03/03/2021	09:00	143	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6001	Aluminium - Acid Soluble	03/03/2021	08:55	0.013	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6001	Aluminium - Acid Soluble	03/03/2021	09:00	0.015	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6003	Arsenic - Acid Soluble	03/03/2021	08:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6003	Arsenic - Acid Soluble	03/03/2021	09:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6008	Cadmium - Acid Soluble	03/03/2021	08:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6008	Cadmium - Acid Soluble	03/03/2021	09:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6010	Calcium - Acid Soluble	03/03/2021	08:55	20.6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6010	Calcium - Acid Soluble	03/03/2021	09:00	20.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6013	Copper - Acid Soluble	03/03/2021	08:55	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6013	Copper - Acid Soluble	03/03/2021	09:00	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6017	Iron - Acid Soluble	03/03/2021	08:55	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6017	Iron - Acid Soluble	03/03/2021	09:00	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6018	Lead - Acid Soluble	03/03/2021	08:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6018	Lead - Acid Soluble	03/03/2021	09:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6020	Magnesium - Acid Soluble	03/03/2021	08:55	10.6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6020	Magnesium - Acid Soluble	03/03/2021	09:00	10.7	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6021	Manganese - Acid Soluble	03/03/2021	08:55	0.0073	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6021	Manganese - Acid Soluble	03/03/2021	09:00	0.009	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6022	Mercury - Acid Soluble	03/03/2021	08:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6022	Mercury - Acid Soluble	03/03/2021	09:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6024	Nickel - Acid Soluble	03/03/2021	08:55	0.0033	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6024	Nickel - Acid Soluble	03/03/2021	09:00	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6038	Zinc - Acid Soluble	03/03/2021	08:55	0.006	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6038	Zinc - Acid Soluble	03/03/2021	09:00	0.003	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6701	Aluminium - Dissolved	03/03/2021	08:55	0.011	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	03/03/2021	09:00	0.011	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6703	Arsenic - Dissolved	03/03/2021	08:55	<0.001	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6703	Arsenic - Dissolved	03/03/2021	09:00	<0.001	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6708	Cadmium - Dissolved	03/03/2021	08:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	03/03/2021	09:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6710	Calcium - Dissolved	03/03/2021	08:55	19.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6710	Calcium - Dissolved	03/03/2021	09:00	19.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6713	Copper - Dissolved	03/03/2021	08:55	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	03/03/2021	09:00	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6717	Iron - Dissolved	03/03/2021	08:55	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	03/03/2021	09:00	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6718	Lead - Dissolved	03/03/2021	08:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	03/03/2021	09:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6720	Magnesium - Dissolved	03/03/2021	08:55	10.5	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6720	Magnesium - Dissolved	03/03/2021	09:00	10.5	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6721	Manganese - Dissolved	03/03/2021	08:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	03/03/2021	09:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6722	Mercury - Dissolved	03/03/2021	08:55	<0.0005	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6722	Mercury - Dissolved	03/03/2021	09:00	<0.0005	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6724	Nickel - Dissolved	03/03/2021	08:55	0.0021	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	03/03/2021	09:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6738	Zinc - Dissolved	03/03/2021	08:55	0.006	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	03/03/2021	09:00	0.003	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	9402	ICP-MS - 2 Elements	03/03/2021	08:55	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	9402	ICP-MS - 2 Elements	03/03/2021	09:00	Completed			

	Karitane School	C-O1420	Sampler Observation	03/03/2021	10:25	No	Sample		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0056F	Dissolved Oxygen - Field	03/03/2021	08:55	6.9	g O2/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	03/03/2021	09:00	6.8	g O2/m³		
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	03/03/2021	10:30	0.28	g/m³	(.2 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0058H	Free Available Chlorine	03/03/2021	08:55	0.41	g/m³	(0 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	03/03/2021	09:00	0.91	g/m³	(.2 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0066H	Total Chlorine	03/03/2021	08:55	0.6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0066H	Total Chlorine	03/03/2021	09:00	1	g/m³		
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	03/03/2021	10:30	0.19	NTU		
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	03/03/2021	10:30	Completed			
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	03/03/2021	10:30	6.1	Deg C		
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	03/03/2021	10:30	<1	MPN/100mL	(0 - 0)	
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	03/03/2021	10:30	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	P1859	Sample Filtration	03/03/2021	08:55	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	03/03/2021	09:00	Completed			
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	1	pH	03/03/2021	09:55	7.8		(1 - 14)	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	52	Alkalinity - Total	03/03/2021	09:55	72	g CaCO3/m³		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	55	Conductivity at 25°C - mS/m unit	03/03/2021	09:55	25.9	mS/m (258.6 x .1)		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	0440D	Dissolved Inorganic Carbon	03/03/2021	09:55	18.8	g/m³		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	702	Chloride - Ultra Trace	03/03/2021	09:55	17.3	g/m³		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	707	Sulphate - Ultra Trace	03/03/2021	09:55	25.6	g/m³		
#0	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:45	0.013	g/m³		
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:46	0.011	g/m³		
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:47	0.011	g/m³		
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:48	0.012	g/m³		
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:49	0.014	g/m³		
#5 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:50	0.013	g/m³		
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:51	0.013	g/m³		
#7 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:52	0.012	g/m³		
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:53	0.013	g/m³		
#9 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:54	0.012	g/m³		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	03/03/2021	09:55	0.013	g/m³		
#0	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:45	0.0468	g/m³	(2 - 2)	
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:46	0.0112	g/m³	(2 - 2)	
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:47	0.0158	g/m³	(2 - 2)	
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:48	0.0162	g/m³	(2 - 2)	
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:49	0.0719	g/m³	(2 - 2)	
#5 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:50	0.0129	g/m³	(2 - 2)	
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:51	0.0177	g/m³	(2 - 2)	
#7 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:52	0.0126	g/m³	(2 - 2)	
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:53	0.0089	g/m³	(2 - 2)	
#9 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:54	0.0082	g/m³	(2 - 2)	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	03/03/2021	09:55	0.0214	g/m³	(2 - 2)	
#0	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:45	<0.01	g/m³		
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:46	<0.01	g/m³		
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:47	<0.01	g/m³		
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:48	<0.01	g/m³		
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:49	<0.01	g/m³		
#5 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:50	<0.01	g/m³		
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:51	<0.01	g/m³		
#7 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:52	<0.01	g/m³		
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:53	<0.01	g/m³		
#9 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:54	<0.01	g/m³		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	03/03/2021	09:55	<0.01	g/m³		
#0	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:45	0.0086	g/m³	(.005 - .01)	
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:46	0.0009	g/m³	(.005 - .01)	
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:47	0.0013	g/m³	(.005 - .01)	
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:48	0.0013	g/m³	(.005 - .01)	
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:49	0.0045	g/m³	(.005 - .01)	
#5 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:50	0.0008	g/m³	(.005 - .01)	
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:51	0.001	g/m³	(.005 - .01)	
#7 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:52	0.0007	g/m³	(.005 - .01)	
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:53	0.0006	g/m³	(.005 - .01)	
#9 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:54	0.0005	g/m³	(.005 - .01)	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	03/03/2021	09:55	0.0052	g/m³	(.005 - .01)	
#0	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:45	0.0113	g/m³	(.4 - .4)	
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:46	0.005	g/m³	(.4 - .4)	
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:47	0.0056	g/m³	(.4 - .4)	
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:48	0.0041	g/m³	(.4 - .4)	
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:49	0.0058	g/m³	(.4 - .4)	
#5 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:50	0.0033	g/m³	(.4 - .4)	
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:51	0.0033	g/m³	(.4 - .4)	
#7 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:52	0.0024	g/m³	(.4 - .4)	
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:53	0.0031	g/m³	(.4 - .4)	
#9 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:54	0.0029	g/m³	(.4 - .4)	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	03/03/2021	09:55	0.0031	g/m³	(.4 - .4)	
#0	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	03/03/2021	09:45	0.0005	g/m³	(.08 - .08)	
#1 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	03/03/2021	09:46	<0.0005	g/m³	(.08 - .08)	
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	03/03/2021	09:47	<0.0005	g/m³	(.08 - .08)	
#3 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	03/03/2021	09:48	<0.0005	g/m³	(.08 - .08)	

#4 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:49	0.0006	g/m³	(.08 - .08)
#5 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:50	<0.0005	g/m³	(.08 - .08)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:51	<0.0005	g/m³	(.08 - .08)
#7 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:52	<0.0005	g/m³	(.08 - .08)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:53	<0.0005	g/m³	(.08 - .08)
#9 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:54	<0.0005	g/m³	(.08 - .08)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample		6024	Nickel - Acid Soluble	03/03/2021	09:55	<0.0005	g/m³	(.08 - .08)
#0	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:45	0.231	g/m³	
#1 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:46	0.018	g/m³	
#2 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:47	0.021	g/m³	
#3 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:48	0.021	g/m³	
#4 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:49	0.074	g/m³	
#5 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:50	0.013	g/m³	
#6 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:51	0.011	g/m³	
#7 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:52	0.012	g/m³	
#8 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:53	0.011	g/m³	
#9 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:54	0.008	g/m³	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample		6038	Zinc - Acid Soluble	03/03/2021	09:55	0.044	g/m³	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	D-0056F		Dissolved Oxygen - Field	03/03/2021	09:55	5.5	g O2/m³	
#0	Karitane Bowls - Customer Tap - Profile Sample	D-1202		Sampling / Inspection 30 Mins	03/03/2021	09:45	Completed		
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	O0994b		Flow Rate performed by ELS	03/03/2021	09:55	0.1	litres/sec	
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	P1859		Sample Filtration	03/03/2021	09:55	Completed		
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		1	pH	04/03/2021	09:54	7.9		(1 - 14)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		52	Alkalinity - Total	04/03/2021	09:54	72	g CaCO3/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		55	Conductivity at 25°C - mS/m unit	04/03/2021	09:54	25.8	mS/m (257.6 x .1)	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	0440D		Dissolved Inorganic Carbon	04/03/2021	09:54	18.7	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		702	Chloride - Ultra Trace	04/03/2021	09:54	16.2	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		707	Sulphate - Ultra Trace	04/03/2021	09:54	24.9	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:44	0.017	g/m³	
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:45	0.016	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:46	0.016	g/m³	
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:47	0.013	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:48	0.021	g/m³	
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:49	0.018	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:50	0.024	g/m³	
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:51	0.027	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:52	0.023	g/m³	
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:53	0.027	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6001	Aluminium - Acid Soluble	04/03/2021	09:54	0.017	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:44	0.0318	g/m³	(2 - 2)
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:45	0.0251	g/m³	(2 - 2)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:46	0.0235	g/m³	(2 - 2)
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:47	0.0326	g/m³	(2 - 2)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:48	0.0332	g/m³	(2 - 2)
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:49	0.0273	g/m³	(2 - 2)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:50	0.0404	g/m³	(2 - 2)
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:51	0.0364	g/m³	(2 - 2)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:52	0.0328	g/m³	(2 - 2)
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:53	0.0392	g/m³	(2 - 2)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6013	Copper - Acid Soluble	04/03/2021	09:54	0.0181	g/m³	(2 - 2)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:44	0.19	g/m³	
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:45	0.07	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:46	0.06	g/m³	
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:47	0.19	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:48	0.18	g/m³	
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:49	0.09	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:50	0.24	g/m³	
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:51	0.19	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:52	0.2	g/m³	
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:53	0.25	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6017	Iron - Acid Soluble	04/03/2021	09:54	0.09	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:44	0.0061	g/m³	(.005 - .01)
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:45	0.006	g/m³	(.005 - .01)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:46	0.005	g/m³	(.005 - .01)
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:47	0.0064	g/m³	(.005 - .01)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:48	0.0069	g/m³	(.005 - .01)
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:49	0.0059	g/m³	(.005 - .01)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:50	0.0091	g/m³	(.005 - .01)
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:51	0.0088	g/m³	(.005 - .01)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:52	0.0078	g/m³	(.005 - .01)
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:53	0.0101	g/m³	(.005 - .01)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6018	Lead - Acid Soluble	04/03/2021	09:54	0.0037	g/m³	(.005 - .01)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:44	0.0114	g/m³	(.4 - .4)
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:45	0.0045	g/m³	(.4 - .4)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:46	0.0088	g/m³	(.4 - .4)
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:47	0.0268	g/m³	(.4 - .4)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:48	0.0238	g/m³	(.4 - .4)
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:49	0.0108	g/m³	(.4 - .4)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:50	0.0159	g/m³	(.4 - .4)
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:51	0.0161	g/m³	(.4 - .4)

#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:52	0.0158	g/m³	(.4 - .4)
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:53	0.0146	g/m³	(.4 - .4)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6021	Manganese - Acid Soluble	04/03/2021	09:54	0.0043	g/m³	(.4 - .4)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:44	0.0009	g/m³	(.08 - .08)
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:45	0.0011	g/m³	(.08 - .08)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:46	0.0008	g/m³	(.08 - .08)
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:47	0.0009	g/m³	(.08 - .08)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:48	0.0009	g/m³	(.08 - .08)
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:49	0.0009	g/m³	(.08 - .08)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:50	0.0011	g/m³	(.08 - .08)
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:51	0.001	g/m³	(.08 - .08)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:52	0.008	g/m³	(.08 - .08)
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:53	0.008	g/m³	(.08 - .08)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6024	Nickel - Acid Soluble	04/03/2021	09:54	0.006	g/m³	(.08 - .08)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:44	0.141	g/m³	
#1 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:45	0.085	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:46	0.078	g/m³	
#3 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:47	0.082	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:48	0.088	g/m³	
#5 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:49	0.109	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:50	0.107	g/m³	
#7 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:51	0.108	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:52	0.093	g/m³	
#9 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:53	0.088	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample		6038	Zinc - Acid Soluble	04/03/2021	09:54	0.049	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	D-0056F		Dissolved Oxygen - Field	04/03/2021	09:54	7.3	g O2/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	D-1202		Sampling / Inspection 30 Mins	04/03/2021	09:44	Completed		
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	O0994b		Flow Rate performed by ELS	04/03/2021	09:54	0.3	litres/sec	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	P1859		Sample Filtration	04/03/2021	09:54	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush		1	pH	04/03/2021	10:55	8.1		(1 - 14)
	Waikouaiti SS - 192 Main Rd		1	pH	04/03/2021	11:00	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush		1	pH	04/03/2021	10:15	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St		1	pH	04/03/2021	10:20	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush		1	pH	04/03/2021	13:20	8		(1 - 14)
	Karitane SS - 99 Stornoway St		1	pH	04/03/2021	13:25	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake		1	pH	04/03/2021	11:40	7.9		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		1	pH	04/03/2021	12:05	7.9		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate		1	pH	04/03/2021	12:10	7.9		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir		1	pH	04/03/2021	12:00	7.8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream		1	pH	04/03/2021	11:45	7.8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		1	pH	04/03/2021	11:10	8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St		1	pH	04/03/2021	11:15	8.1		(1 - 14)
	Waikouaiti SS - 319 Bendigo Rd - Preflush		1	pH	04/03/2021	10:35	7.9		(1 - 14)
	Waikouaiti SS - 319 Bendigo Rd		1	pH	04/03/2021	10:40	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd - Preflush		2	Suspended Solids - Total	04/03/2021	10:55	<6	g/m³	
	Waikouaiti SS - 192 Main Rd		2	Suspended Solids - Total	04/03/2021	11:00	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush		2	Suspended Solids - Total	04/03/2021	10:15	<6	g/m³	
	Waikouaiti SS - 210 Edinburgh St		2	Suspended Solids - Total	04/03/2021	10:20	<6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush		2	Suspended Solids - Total	04/03/2021	13:20	<6	g/m³	
	Karitane SS - 99 Stornoway St		2	Suspended Solids - Total	04/03/2021	13:25	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake		2	Suspended Solids - Total	04/03/2021	11:40	<6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		2	Suspended Solids - Total	04/03/2021	12:05	<6	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate		2	Suspended Solids - Total	04/03/2021	12:10	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		2	Suspended Solids - Total	04/03/2021	12:00	<6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream		2	Suspended Solids - Total	04/03/2021	11:45	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2	Suspended Solids - Total	04/03/2021	11:10	<6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St		2	Suspended Solids - Total	04/03/2021	11:15	<6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2	Suspended Solids - Total	04/03/2021	10:35	<6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		2	Suspended Solids - Total	04/03/2021	10:40	<6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush		52	Alkalinity - Total	04/03/2021	10:55	71	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd		52	Alkalinity - Total	04/03/2021	11:00	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush		52	Alkalinity - Total	04/03/2021	10:15	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St		52	Alkalinity - Total	04/03/2021	10:20	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St - Preflush		52	Alkalinity - Total	04/03/2021	13:20	73	g CaCO3/m³	
	Karitane SS - 99 Stornoway St		52	Alkalinity - Total	04/03/2021	13:25	71	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake		52	Alkalinity - Total	04/03/2021	11:40	71	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	04/03/2021	12:05	71	g CaCO3/m³	
	Waikouaiti WTP - Containerised Plant Filtrate		52	Alkalinity - Total	04/03/2021	12:10	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	04/03/2021	12:00	70	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream		52	Alkalinity - Total	04/03/2021	11:45	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52	Alkalinity - Total	04/03/2021	11:10	73	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St		52	Alkalinity - Total	04/03/2021	11:15	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52	Alkalinity - Total	04/03/2021	10:35	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	04/03/2021	10:40	71	g CaCO3/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	0440D		Dissolved Inorganic Carbon	04/03/2021	10:55	18.7	g/m³	
	Waikouaiti SS - 192 Main Rd	0440D		Dissolved Inorganic Carbon	04/03/2021	11:00	18.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D		Dissolved Inorganic Carbon	04/03/2021	10:15	18.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D		Dissolved Inorganic Carbon	04/03/2021	10:20	18.7	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	0440D		Dissolved Inorganic Carbon	04/03/2021	13:20	19	g/m³	
	Karitane SS - 99 Stornoway St	0440D		Dissolved Inorganic Carbon	04/03/2021	13:25	18.9	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	04/03/2021	11:40	18.9	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	04/03/2021	12:05	18.6	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	04/03/2021	12:10	18.6	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	04/03/2021	12:00	18.6	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	04/03/2021	11:45	19.1	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	04/03/2021	11:10	18.6	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	04/03/2021	11:15	18.5	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	04/03/2021	10:35	19.3	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	04/03/2021	10:40	18.7	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	04/03/2021	10:55	16.6	g/m³			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	04/03/2021	11:00	16.7	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	04/03/2021	10:15	16.8	g/m³			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	04/03/2021	10:20	16.7	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	04/03/2021	13:20	16.9	g/m³			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	04/03/2021	13:25	17	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	04/03/2021	11:40	13.9	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	04/03/2021	12:05	13.8	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	04/03/2021	12:10	15.2	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	04/03/2021	12:00	16.2	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	04/03/2021	11:45	13.3	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	04/03/2021	11:10	16.1	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	04/03/2021	11:15	16.1	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	04/03/2021	10:35	16.6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	04/03/2021	10:40	16.1	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	04/03/2021	10:55	25.6	g/m³			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	04/03/2021	11:00	26.5	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	04/03/2021	10:15	25.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	04/03/2021	10:20	25.7	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	04/03/2021	13:20	25.8	g/m³			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	04/03/2021	13:25	26.1	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	04/03/2021	11:40	25.7	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	04/03/2021	12:05	26.2	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	04/03/2021	12:10	25.8	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	04/03/2021	12:00	25.5	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	04/03/2021	11:45	25.3	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	04/03/2021	11:10	25.5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	04/03/2021	11:15	25.5	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	04/03/2021	10:35	26.2	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	04/03/2021	10:40	25.6	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	04/03/2021	10:55	126	g/m³			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	04/03/2021	11:00	148	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	04/03/2021	10:15	131	g/m³			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	04/03/2021	10:20	133	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	04/03/2021	13:20	148	g/m³			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	04/03/2021	13:25	131	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	04/03/2021	11:40	133	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	04/03/2021	12:05	143	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	04/03/2021	12:10	137	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	04/03/2021	12:00	143	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	04/03/2021	11:45	135	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	04/03/2021	11:10	140	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	04/03/2021	11:15	136	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	04/03/2021	10:35	129	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	04/03/2021	10:40	132	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	04/03/2021	10:55	$100				
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	04/03/2021	10:55	0.01	g/m³			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	04/03/2021	11:00	0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	04/03/2021	10:15	0.013	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	04/03/2021	10:20	0.012	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	04/03/2021	13:20	0.014	g/m³			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	04/03/2021	13:25	0.012	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	04/03/2021	12:10	0.009	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	04/03/2021	12:00	0.01	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	04/03/2021	11:10	0.015	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	04/03/2021	11:15	0.012	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	04/03/2021	10:35	0.023	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	04/03/2021	10:40	0.012	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	04/03/2021	10:55	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	04/03/2021	11:00	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	04/03/2021	10:15	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	04/03/2021	10:20	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	04/03/2021	13:20	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	04/03/2021	13:25	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	04/03/2021	12:10	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	04/03/2021	12:00	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	04/03/2021	11:10	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	04/03/2021	11:15	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	04/03/2021	10:35	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	04/03/2021	10:40	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	04/03/2021	10:55	<0.0002	g/m³		(.004 - .004)	

	Waikouaiti SS - 192 Main Rd	6008 Cadmium - Acid Soluble	04/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008 Cadmium - Acid Soluble	04/03/2021	10:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008 Cadmium - Acid Soluble	04/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008 Cadmium - Acid Soluble	04/03/2021	13:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008 Cadmium - Acid Soluble	04/03/2021	13:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008 Cadmium - Acid Soluble	04/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008 Cadmium - Acid Soluble	04/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008 Cadmium - Acid Soluble	04/03/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008 Cadmium - Acid Soluble	04/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008 Cadmium - Acid Soluble	04/03/2021	10:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	04/03/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	04/03/2021	10:55	20.3	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	04/03/2021	11:00	20.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	04/03/2021	10:15	20.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	04/03/2021	10:20	20.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	04/03/2021	13:20	20.8	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	04/03/2021	13:25	21.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	04/03/2021	12:10	20	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	04/03/2021	12:00	20.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	04/03/2021	11:10	20.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	04/03/2021	11:15	20.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	04/03/2021	10:35	20.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	04/03/2021	10:40	21	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	04/03/2021	10:55	0.0054	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	04/03/2021	11:00	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	04/03/2021	10:15	0.006	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	04/03/2021	10:20	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	04/03/2021	13:20	0.0116	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	04/03/2021	13:25	0.0008	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	04/03/2021	12:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	04/03/2021	12:00	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	04/03/2021	11:10	0.0016	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	04/03/2021	11:15	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	04/03/2021	10:35	0.011	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	04/03/2021	10:40	0.0025	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	04/03/2021	10:55	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	04/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	04/03/2021	10:15	0.04	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	04/03/2021	10:20	0.02	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	04/03/2021	13:20	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	04/03/2021	13:25	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	04/03/2021	12:10	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	04/03/2021	12:00	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	04/03/2021	11:10	0.44	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	04/03/2021	11:15	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	04/03/2021	10:35	0.05	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	04/03/2021	10:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	04/03/2021	10:55	0.0026	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	04/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	04/03/2021	10:15	0.0029	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	04/03/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	04/03/2021	13:20	0.0024	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	04/03/2021	13:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	04/03/2021	12:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	04/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	04/03/2021	11:10	0.0009	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	04/03/2021	11:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	04/03/2021	10:35	0.0254	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	04/03/2021	10:40	0.0007	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	04/03/2021	10:55	10.5	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	04/03/2021	11:00	10.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	04/03/2021	10:15	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	04/03/2021	10:20	10.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	04/03/2021	13:20	10.4	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	04/03/2021	13:25	10.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	04/03/2021	12:10	10.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	04/03/2021	12:00	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	04/03/2021	11:10	10.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	04/03/2021	11:15	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	04/03/2021	10:35	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	04/03/2021	10:40	10.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	04/03/2021	10:55	0.0148	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	04/03/2021	11:00	0.0096	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	04/03/2021	10:15	0.0055	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	04/03/2021	10:20	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	04/03/2021	13:20	0.0302	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	04/03/2021	13:25	0.0017	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	04/03/2021	12:10	0.0039	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	04/03/2021	12:00	0.0051	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	04/03/2021	11:10	0.0415	g/m³	(.4 - .4)	

	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	04/03/2021	11:15	0.0073	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	04/03/2021	10:35	0.0816	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	04/03/2021	10:40	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	04/03/2021	10:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	04/03/2021	11:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	04/03/2021	10:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	04/03/2021	10:20	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	04/03/2021	13:20	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	04/03/2021	13:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	04/03/2021	12:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	04/03/2021	12:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	04/03/2021	11:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	04/03/2021	11:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	04/03/2021	10:35	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	04/03/2021	10:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	04/03/2021	10:55	0.0011	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	04/03/2021	11:00	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	04/03/2021	10:15	0.001	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	04/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	04/03/2021	13:20	0.0014	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	04/03/2021	13:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	04/03/2021	12:10	0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	04/03/2021	12:00	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	04/03/2021	11:10	0.0146	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	04/03/2021	11:15	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	04/03/2021	10:35	0.0086	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	04/03/2021	10:40	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	04/03/2021	10:55	0.06	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	04/03/2021	11:00	0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	04/03/2021	10:15	0.028	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	04/03/2021	10:20	0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	04/03/2021	13:20	0.037	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	04/03/2021	13:25	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	04/03/2021	12:10	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	04/03/2021	12:00	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	04/03/2021	11:10	0.004	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	04/03/2021	11:15	0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	04/03/2021	10:35	0.169	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	04/03/2021	10:40	0.007	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	04/03/2021	12:20	106,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	04/03/2021	12:20	16	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	04/03/2021	12:20	<0.10	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	04/03/2021	12:20	4,340	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	04/03/2021	12:20	15.2	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	04/03/2021	12:20	13,500	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	04/03/2021	12:20	3.9	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	04/03/2021	12:20	1,030	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	04/03/2021	12:20	1,200	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	04/03/2021	12:20	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	04/03/2021	12:20	7.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	04/03/2021	12:20	34	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	04/03/2021	11:40	0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	04/03/2021	12:05	0.012	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	04/03/2021	11:45	0.013	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	04/03/2021	11:40	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	04/03/2021	12:05	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	04/03/2021	11:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	04/03/2021	11:40	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	04/03/2021	12:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	04/03/2021	11:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	04/03/2021	11:40	20.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	04/03/2021	12:05	20.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	04/03/2021	11:45	20.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	04/03/2021	11:40	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	04/03/2021	12:05	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	04/03/2021	11:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	04/03/2021	11:40	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	04/03/2021	12:05	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	04/03/2021	11:45	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	04/03/2021	11:40	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	04/03/2021	12:05	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	04/03/2021	11:45	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	04/03/2021	11:40	10.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	04/03/2021	12:05	10.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	04/03/2021	11:45	10.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	04/03/2021	11:40	0.037	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	04/03/2021	12:05	0.023	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	04/03/2021	11:45	0.038	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	04/03/2021	11:40	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	04/03/2021	12:05	<0.001	g/m³		

	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	04/03/2021	11:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	04/03/2021	11:40	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	04/03/2021	12:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	04/03/2021	11:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	04/03/2021	11:40	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	04/03/2021	12:05	0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	04/03/2021	11:45	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	04/03/2021	10:55	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	04/03/2021	11:00	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	04/03/2021	10:15	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	04/03/2021	10:20	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	04/03/2021	13:20	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	04/03/2021	13:25	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	04/03/2021	11:40	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	04/03/2021	12:05	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	04/03/2021	12:10	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	04/03/2021	12:00	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	04/03/2021	11:45	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	04/03/2021	11:10	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	04/03/2021	11:15	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	04/03/2021	10:35	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	04/03/2021	10:40	0.013	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	04/03/2021	10:55	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	04/03/2021	11:00	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	04/03/2021	10:15	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	04/03/2021	10:20	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	04/03/2021	13:20	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	04/03/2021	13:25	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	04/03/2021	11:40	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	04/03/2021	12:05	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	04/03/2021	12:10	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	04/03/2021	12:00	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	04/03/2021	11:45	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	04/03/2021	11:10	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	04/03/2021	11:15	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	04/03/2021	10:35	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	04/03/2021	10:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	04/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	04/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	04/03/2021	10:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	04/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	04/03/2021	13:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	04/03/2021	13:25	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	04/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	04/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	04/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	04/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	04/03/2021	11:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	04/03/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	04/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	04/03/2021	10:35	0.0004	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	04/03/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	04/03/2021	10:55	19.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	04/03/2021	11:00	19.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	04/03/2021	10:15	20.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	04/03/2021	10:20	20.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	04/03/2021	13:20	20.2	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	04/03/2021	13:25	20.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	04/03/2021	11:40	19.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	04/03/2021	12:05	19.4	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	04/03/2021	12:10	19.6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	04/03/2021	12:00	19.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	04/03/2021	11:45	19.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	04/03/2021	11:10	19.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	04/03/2021	11:15	19.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	04/03/2021	10:35	19.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	04/03/2021	10:40	20.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	04/03/2021	10:55	0.0047	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	04/03/2021	11:00	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	04/03/2021	10:15	0.0046	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	04/03/2021	10:20	0.0009	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	04/03/2021	13:20	0.0065	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	04/03/2021	13:25	0.0008	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	04/03/2021	11:40	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	04/03/2021	12:05	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	04/03/2021	12:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	04/03/2021	12:00	0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	04/03/2021	11:45	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	04/03/2021	11:10	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	04/03/2021	11:15	0.0007	g/m³	(2 - 2)	

	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	04/03/2021	10:35	0.0301	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	04/03/2021	10:40	0.0028	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	04/03/2021	10:55	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	04/03/2021	11:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	04/03/2021	10:15	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	04/03/2021	10:20	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	04/03/2021	13:20	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	04/03/2021	13:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	04/03/2021	11:40	0.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	04/03/2021	12:05	0.08	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	04/03/2021	12:10	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	04/03/2021	12:00	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	04/03/2021	11:45	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	04/03/2021	11:10	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	04/03/2021	11:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	04/03/2021	10:35	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	04/03/2021	10:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	04/03/2021	10:55	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	04/03/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	04/03/2021	10:15	0.0007	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	04/03/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	04/03/2021	13:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	04/03/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	04/03/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	04/03/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	04/03/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	04/03/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	04/03/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	04/03/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	04/03/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	04/03/2021	10:35	0.0707	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	04/03/2021	10:40	0.0011	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	04/03/2021	10:55	10.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	04/03/2021	11:00	10.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	04/03/2021	10:15	10.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	04/03/2021	10:20	10.4	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	04/03/2021	13:20	10.3	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	04/03/2021	13:25	10.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	04/03/2021	11:40	10.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	04/03/2021	12:05	10.3	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	04/03/2021	12:10	10.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	04/03/2021	12:00	10.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	04/03/2021	11:45	10.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	04/03/2021	11:10	10.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	04/03/2021	11:15	10.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	04/03/2021	10:35	10.1	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	04/03/2021	10:40	10.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	04/03/2021	10:55	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	04/03/2021	11:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	04/03/2021	10:15	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	04/03/2021	10:20	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	04/03/2021	13:20	0.0007	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	04/03/2021	13:25	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	04/03/2021	11:40	0.026	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	04/03/2021	12:05	0.0044	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	04/03/2021	12:10	0.0039	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	04/03/2021	12:00	0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	04/03/2021	11:45	0.0262	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	04/03/2021	11:10	0.0018	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	04/03/2021	11:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	04/03/2021	10:35	0.0012	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	04/03/2021	10:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	04/03/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	04/03/2021	11:00	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	04/03/2021	10:15	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	04/03/2021	10:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	04/03/2021	13:20	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	04/03/2021	13:25	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	04/03/2021	11:40	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	04/03/2021	12:05	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	04/03/2021	12:10	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	04/03/2021	12:00	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	04/03/2021	11:45	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	04/03/2021	11:10	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	04/03/2021	11:15	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	04/03/2021	10:35	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	04/03/2021	10:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	04/03/2021	10:55	0.0011	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	04/03/2021	11:00	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	04/03/2021	10:15	0.0011	g/m³	(.08 - .08)

	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	04/03/2021	10:20	0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	04/03/2021	13:20	0.0014	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	04/03/2021	13:25	0.0009	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	04/03/2021	11:40	0.0009	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	04/03/2021	12:05	0.0008	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	04/03/2021	12:10	0.0007	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	04/03/2021	12:00	0.0007	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	04/03/2021	11:45	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	04/03/2021	11:10	0.0128	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	04/03/2021	11:15	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	04/03/2021	10:35	0.0053	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	04/03/2021	10:40	0.0011	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	04/03/2021	10:55	0.059	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	04/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	04/03/2021	10:15	0.026	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	04/03/2021	10:20	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	04/03/2021	13:20	0.029	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	04/03/2021	13:25	0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	04/03/2021	11:40	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	04/03/2021	12:05	0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	04/03/2021	12:10	0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	04/03/2021	12:00	0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	04/03/2021	11:45	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	04/03/2021	11:10	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	04/03/2021	11:15	0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	04/03/2021	10:35	1.25	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	04/03/2021	10:40	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	04/03/2021	10:55	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	04/03/2021	11:00	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	04/03/2021	10:15	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	04/03/2021	10:20	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	04/03/2021	13:20	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	04/03/2021	13:25	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	04/03/2021	11:40	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	04/03/2021	12:05	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	04/03/2021	12:10	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	04/03/2021	12:00	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	04/03/2021	11:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	04/03/2021	11:10	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	04/03/2021	11:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	04/03/2021	10:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	04/03/2021	10:40	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	04/03/2021	10:55	6	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	04/03/2021	11:00	5.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	04/03/2021	10:15	6.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	04/03/2021	10:20	5.5	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	04/03/2021	13:20	6.7	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	04/03/2021	13:25	6.5	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	04/03/2021	11:40	6.2	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	04/03/2021	12:05	5.3	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	04/03/2021	12:10	5.6	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	04/03/2021	12:00	6.6	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	04/03/2021	11:45	5.8	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	04/03/2021	11:10	6.2	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	04/03/2021	11:15	5.4	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	04/03/2021	10:35	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	04/03/2021	10:40	6.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	04/03/2021	10:55	0.46	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	04/03/2021	11:00	0.63	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	04/03/2021	10:15	0.14	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	04/03/2021	10:20	0.19	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	04/03/2021	13:20	0.54	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	04/03/2021	13:25	0.71	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	04/03/2021	12:10	0.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	04/03/2021	12:00	0.66	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	04/03/2021	11:10	0.44	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	04/03/2021	11:15	0.62	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	04/03/2021	10:35	0.56	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	04/03/2021	10:40	0.64	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	04/03/2021	10:55	0.6	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	04/03/2021	11:00	0.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	04/03/2021	10:15	0.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	04/03/2021	10:20	0.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	04/03/2021	13:20	0.7	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	04/03/2021	13:25	0.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	04/03/2021	12:10	0.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	04/03/2021	12:00	0.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	04/03/2021	11:10	0.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	04/03/2021	11:15	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	04/03/2021	10:35	0.7	g/m³		

	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	04/03/2021	10:40	0.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	04/03/2021	10:55	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/03/2021	10:15	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	04/03/2021	10:20	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/03/2021	10:15	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	04/03/2021	10:20	<1	MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/03/2021	11:40	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/03/2021	12:05	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	04/03/2021	11:45	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	04/03/2021	10:55	Completed			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	04/03/2021	11:00	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	04/03/2021	10:15	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	04/03/2021	10:20	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	04/03/2021	13:20	Completed			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	04/03/2021	13:25	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	04/03/2021	11:40	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	04/03/2021	12:05	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	04/03/2021	12:10	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	04/03/2021	12:00	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	04/03/2021	11:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	04/03/2021	11:10	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	04/03/2021	11:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	04/03/2021	10:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	04/03/2021	10:40	Completed			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	04/03/2021	12:20	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	05/03/2021	10:55	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	05/03/2021	11:00	7.9		(1 - 14)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	05/03/2021	09:55	7.9		(1 - 14)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	1	pH	05/03/2021	10:10	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	05/03/2021	12:45	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	05/03/2021	11:35	7.9		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	05/03/2021	12:50	7.8		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	05/03/2021	12:10	7.8		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	05/03/2021	12:00	7.9		(1 - 14)	
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	05/03/2021	12:35	7.9		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	05/03/2021	11:55	8.1		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	05/03/2021	11:40	8		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	05/03/2021	11:00	8.1		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	05/03/2021	11:05	8.1		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	05/03/2021	10:35	8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	05/03/2021	10:40	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	05/03/2021	10:55	<6	g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	05/03/2021	11:00	<6	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	05/03/2021	09:55	<6	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	05/03/2021	10:10	<6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	05/03/2021	12:45	<6	g/m³		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	05/03/2021	11:35	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	05/03/2021	12:50	<6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	05/03/2021	12:10	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	05/03/2021	12:00	<6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	05/03/2021	12:35	105	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	05/03/2021	11:55	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	05/03/2021	11:40	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	05/03/2021	11:00	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	05/03/2021	11:05	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	05/03/2021	10:35	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	05/03/2021	10:40	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	05/03/2021	10:55	73	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	05/03/2021	11:00	71	g CaCO3/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	05/03/2021	09:55	72	g CaCO3/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	05/03/2021	10:10	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	05/03/2021	12:45	74	g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	05/03/2021	11:35	72	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	05/03/2021	12:50	72	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	05/03/2021	12:10	71	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	05/03/2021	12:00	72	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	05/03/2021	12:35	77	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	05/03/2021	11:55	72	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	05/03/2021	11:40	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	05/03/2021	11:00	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	05/03/2021	11:05	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	05/03/2021	10:35	76	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	05/03/2021	10:40	73	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	05/03/2021	10:55	18.7	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	05/03/2021	11:00	18.9	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	05/03/2021	09:55	19	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	05/03/2021	10:10	18.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	05/03/2021	12:45	18.9	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	05/03/2021	11:35	18.9	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	05/03/2021	12:50	19.2	g/m³		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	05/03/2021	12:10	19.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	05/03/2021	12:00	18.9	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	05/03/2021	12:35	18.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	05/03/2021	11:55	18.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	05/03/2021	11:40	19	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	05/03/2021	11:00	18.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	05/03/2021	11:05	18.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	05/03/2021	10:35	19	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	05/03/2021	10:40	18.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	05/03/2021	10:55	15.9	g/m³		
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	05/03/2021	11:00	16	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	05/03/2021	09:55	16.3	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	05/03/2021	10:10	16.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	05/03/2021	12:45	16	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	05/03/2021	11:35	16.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	05/03/2021	12:50	13.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	05/03/2021	12:10	13.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	05/03/2021	12:00	14.3	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	05/03/2021	12:35	14.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	05/03/2021	11:55	16	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	05/03/2021	11:40	13.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	05/03/2021	11:00	15.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	05/03/2021	11:05	15.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	05/03/2021	10:35	15.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	05/03/2021	10:40	15.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	05/03/2021	10:55	24.2	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	05/03/2021	11:00	24.4	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	05/03/2021	09:55	24.6	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	05/03/2021	10:10	24.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	05/03/2021	12:45	24.5	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	05/03/2021	11:35	24.4	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	05/03/2021	12:50	23.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	05/03/2021	12:10	24.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	05/03/2021	12:00	24	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	05/03/2021	12:35	24.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	05/03/2021	11:55	24.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	05/03/2021	11:40	23.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	05/03/2021	11:00	24.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	05/03/2021	11:05	24.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	05/03/2021	10:35	24.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	05/03/2021	10:40	24.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	05/03/2021	10:55	128	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:00	141	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	05/03/2021	09:55	136	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	05/03/2021	10:10	125	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	05/03/2021	12:45	136	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:35	132	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	05/03/2021	12:50	129	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	05/03/2021	12:10	135	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	05/03/2021	12:00	141	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	05/03/2021	12:35	127	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:55	144	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:40	142	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:00	150	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	05/03/2021	11:05	131	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	05/03/2021	10:35	128	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	05/03/2021	10:40	134	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	05/03/2021	10:55	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	05/03/2021	10:55	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	05/03/2021	11:00	0.009	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	05/03/2021	09:55	0.009	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	05/03/2021	10:10	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	05/03/2021	12:45	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	05/03/2021	11:35	0.011	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	05/03/2021	12:00	0.008	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	05/03/2021	12:35	21.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	05/03/2021	11:55	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	05/03/2021	11:00	0.013	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	05/03/2021	11:05	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	05/03/2021	10:35	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	05/03/2021	10:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	05/03/2021	10:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	05/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	05/03/2021	09:55	<0.001	g/m³	(.01 - .01)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	05/03/2021	10:10	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	05/03/2021	12:45	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	05/03/2021	11:35	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	05/03/2021	12:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	05/03/2021	12:35	0.004	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	05/03/2021	11:55	<0.001	g/m³	(.01 - .01)	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	05/03/2021	11:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	05/03/2021	11:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	05/03/2021	10:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	05/03/2021	10:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	05/03/2021	10:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	05/03/2021	11:00	<0.0002	g/m³	(.004 - .004)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	05/03/2021	09:55	<0.0002	g/m³	(.004 - .004)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	05/03/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	05/03/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	05/03/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	05/03/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	05/03/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	05/03/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	05/03/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	05/03/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	05/03/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	05/03/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	05/03/2021	10:55	22.4	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	05/03/2021	11:00	22	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	05/03/2021	09:55	22.5	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	05/03/2021	10:10	22.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	05/03/2021	12:45	22.8	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	05/03/2021	11:35	22.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	05/03/2021	12:00	22.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	05/03/2021	12:35	22.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	05/03/2021	11:55	21.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	05/03/2021	11:00	22.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	05/03/2021	11:05	22.3	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	05/03/2021	10:35	22.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	05/03/2021	10:40	22.5	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	05/03/2021	10:55	0.0049	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	05/03/2021	11:00	0.001	g/m³	(2 - 2)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	05/03/2021	09:55	0.0025	g/m³	(2 - 2)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	05/03/2021	10:10	0.0012	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	05/03/2021	12:45	0.0023	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	05/03/2021	11:35	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	05/03/2021	12:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	05/03/2021	12:35	0.0037	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	05/03/2021	11:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	05/03/2021	11:00	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	05/03/2021	11:05	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	05/03/2021	10:35	0.0145	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	05/03/2021	10:40	0.0035	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	05/03/2021	10:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	05/03/2021	11:00	<0.01	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	05/03/2021	09:55	0.02	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	05/03/2021	10:10	0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	05/03/2021	12:45	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	05/03/2021	11:35	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	05/03/2021	12:00	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	05/03/2021	12:35	2.48	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	05/03/2021	11:55	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	05/03/2021	11:00	0.54	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	05/03/2021	11:05	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	05/03/2021	10:35	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	05/03/2021	10:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	05/03/2021	10:55	0.0025	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	05/03/2021	11:00	<0.0005	g/m³	(.005 - .01)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	05/03/2021	09:55	<0.0005	g/m³	(.005 - .01)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	05/03/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	05/03/2021	12:45	0.0006	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	05/03/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	05/03/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	05/03/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	05/03/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	05/03/2021	11:00	0.0009	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	05/03/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	05/03/2021	10:35	0.0356	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	05/03/2021	10:40	0.0008	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	05/03/2021	10:55	10.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	05/03/2021	11:00	10.6	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	05/03/2021	09:55	10.6	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	05/03/2021	10:10	10.6	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	05/03/2021	12:45	10.6	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	05/03/2021	11:35	10.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	05/03/2021	12:00	10.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	05/03/2021	12:35	10.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	05/03/2021	11:55	10.6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	05/03/2021	11:00	10.5	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	05/03/2021	11:05	10.7	g/m³	

	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	05/03/2021	10:35	10.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	05/03/2021	10:40	10.6	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	05/03/2021	10:55	0.007	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	05/03/2021	11:00	0.0035	g/m³	(.4 - .4)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	05/03/2021	09:55	0.0012	g/m³	(.4 - .4)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	05/03/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	05/03/2021	12:45	0.0028	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	05/03/2021	11:35	0.0013	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	05/03/2021	12:00	0.0018	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	05/03/2021	12:35	0.267	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	05/03/2021	11:55	0.0041	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	05/03/2021	11:00	0.0181	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	05/03/2021	11:05	0.0021	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	05/03/2021	10:35	0.0013	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	05/03/2021	10:40	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	05/03/2021	10:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	05/03/2021	11:00	<0.0005	g/m³	(.007 - .007)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	05/03/2021	09:55	<0.0005	g/m³	(.007 - .007)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	05/03/2021	10:10	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	05/03/2021	12:45	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	05/03/2021	11:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	05/03/2021	12:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	05/03/2021	12:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	05/03/2021	11:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	05/03/2021	11:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	05/03/2021	11:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	05/03/2021	10:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	05/03/2021	10:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	05/03/2021	10:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	05/03/2021	11:00	<0.0005	g/m³	(.08 - .08)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	05/03/2021	09:55	0.0017	g/m³	(.08 - .08)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	05/03/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	05/03/2021	12:45	0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	05/03/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	05/03/2021	12:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	05/03/2021	12:35	0.0013	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	05/03/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	05/03/2021	11:00	0.015	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	05/03/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	05/03/2021	10:35	0.0025	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	05/03/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	05/03/2021	10:55	0.072	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	05/03/2021	11:00	0.006	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	05/03/2021	09:55	0.004	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	05/03/2021	10:10	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	05/03/2021	12:45	0.037	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	05/03/2021	11:35	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	05/03/2021	12:00	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	05/03/2021	12:35	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	05/03/2021	11:55	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	05/03/2021	11:00	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	05/03/2021	11:05	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	05/03/2021	10:35	0.838	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	05/03/2021	10:40	0.009	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	05/03/2021	12:20	165,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	05/03/2021	12:20	28.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	05/03/2021	12:20	0.23	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	05/03/2021	12:20	7,230	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	05/03/2021	12:20	26.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	05/03/2021	12:20	29,600	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	05/03/2021	12:20	12.4	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	05/03/2021	12:20	2,250	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	05/03/2021	12:20	3,250	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	05/03/2021	12:20	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	05/03/2021	12:20	13.9	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	05/03/2021	12:20	100	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	05/03/2021	12:50	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	05/03/2021	12:10	0.011	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	05/03/2021	11:40	0.124	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	05/03/2021	12:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	05/03/2021	12:10	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	05/03/2021	11:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	05/03/2021	12:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	05/03/2021	12:10	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	05/03/2021	11:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	05/03/2021	12:50	19.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	05/03/2021	12:10	20.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	05/03/2021	11:40	20.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	05/03/2021	12:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	05/03/2021	12:10	<0.002	g/m³	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	05/03/2021	11:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	05/03/2021	12:50	0.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	05/03/2021	12:10	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	05/03/2021	11:40	0.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	05/03/2021	12:50	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	05/03/2021	12:10	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	05/03/2021	11:40	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	05/03/2021	12:50	10	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	05/03/2021	12:10	10.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	05/03/2021	11:40	10.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	05/03/2021	12:50	0.039	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	05/03/2021	12:10	0.022	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	05/03/2021	11:40	0.083	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	05/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	05/03/2021	12:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	05/03/2021	11:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	05/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	05/03/2021	12:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	05/03/2021	11:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	05/03/2021	12:50	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	05/03/2021	12:10	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	05/03/2021	11:40	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	05/03/2021	10:55	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	05/03/2021	11:00	0.009	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	05/03/2021	09:55	0.011	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	05/03/2021	10:10	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	05/03/2021	12:45	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	05/03/2021	11:35	0.011	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	05/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	05/03/2021	12:10	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	05/03/2021	12:00	0.008	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	05/03/2021	12:35	0.337	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	05/03/2021	11:55	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	05/03/2021	11:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	05/03/2021	11:00	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	05/03/2021	11:05	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	05/03/2021	10:35	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	05/03/2021	10:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	05/03/2021	10:55	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	05/03/2021	11:00	<0.001	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	05/03/2021	09:55	<0.001	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	05/03/2021	10:10	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	05/03/2021	12:45	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	05/03/2021	11:35	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	05/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	05/03/2021	12:10	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	05/03/2021	12:00	<0.001	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	05/03/2021	12:35	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	05/03/2021	11:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	05/03/2021	11:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	05/03/2021	11:00	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	05/03/2021	11:05	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	05/03/2021	10:35	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	05/03/2021	10:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	05/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	05/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	05/03/2021	09:55	<0.0002	g/m³	(.004 - .004)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	05/03/2021	10:10	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	05/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	05/03/2021	11:35	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	05/03/2021	12:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	05/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	05/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	05/03/2021	12:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	05/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	05/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	05/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	05/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	05/03/2021	10:35	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	05/03/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	05/03/2021	10:55	22.9	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	05/03/2021	11:00	22.3	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	05/03/2021	09:55	22.9	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	05/03/2021	10:10	22.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	05/03/2021	12:45	22.5	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	05/03/2021	11:35	22.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	05/03/2021	12:50	22.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	05/03/2021	12:10	22.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	05/03/2021	12:00	22.2	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	05/03/2021	12:35	21.7	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	05/03/2021	11:55	21.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	05/03/2021	11:40	22.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	05/03/2021	11:00	22.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	05/03/2021	11:05	22.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	05/03/2021	10:35	22.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	05/03/2021	10:40	22.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	05/03/2021	10:55	0.0046	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	05/03/2021	11:00	0.001	g/m³	(2 - 2)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	05/03/2021	09:55	0.0011	g/m³	(2 - 2)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	05/03/2021	10:10	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	05/03/2021	12:45	0.0021	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	05/03/2021	11:35	0.0006	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	05/03/2021	12:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	05/03/2021	12:10	0.0008	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	05/03/2021	12:00	0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	05/03/2021	12:35	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	05/03/2021	11:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	05/03/2021	11:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	05/03/2021	11:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	05/03/2021	11:05	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	05/03/2021	10:35	0.014	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	05/03/2021	10:40	0.0031	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	05/03/2021	10:55	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	05/03/2021	11:00	<0.01	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	05/03/2021	09:55	<0.01	g/m³	(.2 - .2)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	05/03/2021	10:10	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	05/03/2021	12:45	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	05/03/2021	11:35	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	05/03/2021	12:50	0.11	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	05/03/2021	12:10	0.07	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	05/03/2021	12:00	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	05/03/2021	12:35	0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	05/03/2021	11:55	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	05/03/2021	11:40	0.11	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	05/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	05/03/2021	11:05	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	05/03/2021	10:35	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	05/03/2021	10:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	05/03/2021	10:55	0.0012	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	05/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	05/03/2021	09:55	<0.0005	g/m³	(.005 - .01)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	05/03/2021	10:10	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	05/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	05/03/2021	11:35	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	05/03/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	05/03/2021	12:10	0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	05/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	05/03/2021	12:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	05/03/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	05/03/2021	11:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	05/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	05/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	05/03/2021	10:35	0.0344	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	05/03/2021	10:40	0.0007	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	05/03/2021	10:55	10.8	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	05/03/2021	11:00	10.6	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	05/03/2021	09:55	10.4	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	05/03/2021	10:10	10.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	05/03/2021	12:45	10.5	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	05/03/2021	11:35	10.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	05/03/2021	12:50	10.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	05/03/2021	12:10	10.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	05/03/2021	12:00	10.6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	05/03/2021	12:35	10.6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	05/03/2021	11:55	10.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	05/03/2021	11:40	10.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	05/03/2021	11:00	10.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	05/03/2021	11:05	10.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	05/03/2021	10:35	10.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	05/03/2021	10:40	10.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	05/03/2021	10:55	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	05/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	05/03/2021	09:55	<0.0005	g/m³	(.4 - .4)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	05/03/2021	10:10	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	05/03/2021	12:45	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	05/03/2021	11:35	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	05/03/2021	12:50	0.0277	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	05/03/2021	12:10	0.0041	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	05/03/2021	12:00	0.0018	g/m³	(.4 - .4)	
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	05/03/2021	12:35	0.0012	g/m³	(.4 - .4)	

	Waikouaiti WTP - Post Treated Water Reservoir		6721	Manganese - Dissolved	05/03/2021	11:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream		6721	Manganese - Dissolved	05/03/2021	11:40	0.0277	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6721	Manganese - Dissolved	05/03/2021	11:00	0.0012	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St		6721	Manganese - Dissolved	05/03/2021	11:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6721	Manganese - Dissolved	05/03/2021	10:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd		6721	Manganese - Dissolved	05/03/2021	10:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush		6722	Mercury - Dissolved	05/03/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd		6722	Mercury - Dissolved	05/03/2021	11:00	<0.0005	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush		6722	Mercury - Dissolved	05/03/2021	09:55	<0.0005	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St		6722	Mercury - Dissolved	05/03/2021	10:10	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush		6722	Mercury - Dissolved	05/03/2021	12:45	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St		6722	Mercury - Dissolved	05/03/2021	11:35	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake		6722	Mercury - Dissolved	05/03/2021	12:50	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6722	Mercury - Dissolved	05/03/2021	12:10	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate		6722	Mercury - Dissolved	05/03/2021	12:00	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler		6722	Mercury - Dissolved	05/03/2021	12:35	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		6722	Mercury - Dissolved	05/03/2021	11:55	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream		6722	Mercury - Dissolved	05/03/2021	11:40	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6722	Mercury - Dissolved	05/03/2021	11:00	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St		6722	Mercury - Dissolved	05/03/2021	11:05	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6722	Mercury - Dissolved	05/03/2021	10:35	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		6722	Mercury - Dissolved	05/03/2021	10:40	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush		6724	Nickel - Dissolved	05/03/2021	10:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd		6724	Nickel - Dissolved	05/03/2021	11:00	<0.0005	g/m³	(.08 - .08)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush		6724	Nickel - Dissolved	05/03/2021	09:55	<0.0005	g/m³	(.08 - .08)
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St		6724	Nickel - Dissolved	05/03/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush		6724	Nickel - Dissolved	05/03/2021	12:45	0.0006	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St		6724	Nickel - Dissolved	05/03/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake		6724	Nickel - Dissolved	05/03/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6724	Nickel - Dissolved	05/03/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate		6724	Nickel - Dissolved	05/03/2021	12:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler		6724	Nickel - Dissolved	05/03/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir		6724	Nickel - Dissolved	05/03/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream		6724	Nickel - Dissolved	05/03/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6724	Nickel - Dissolved	05/03/2021	11:00	0.0137	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St		6724	Nickel - Dissolved	05/03/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6724	Nickel - Dissolved	05/03/2021	10:35	0.0026	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd		6724	Nickel - Dissolved	05/03/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush		6738	Zinc - Dissolved	05/03/2021	10:55	0.07	g/m³	
	Waikouaiti SS - 192 Main Rd		6738	Zinc - Dissolved	05/03/2021	11:00	<0.002	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush		6738	Zinc - Dissolved	05/03/2021	09:55	0.003	g/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St		6738	Zinc - Dissolved	05/03/2021	10:10	0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush		6738	Zinc - Dissolved	05/03/2021	12:45	0.037	g/m³	
	Karitane SS - 99 Stornoway St		6738	Zinc - Dissolved	05/03/2021	11:35	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake		6738	Zinc - Dissolved	05/03/2021	12:50	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6738	Zinc - Dissolved	05/03/2021	12:10	0.003	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate		6738	Zinc - Dissolved	05/03/2021	12:00	0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler		6738	Zinc - Dissolved	05/03/2021	12:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		6738	Zinc - Dissolved	05/03/2021	11:55	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream		6738	Zinc - Dissolved	05/03/2021	11:40	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6738	Zinc - Dissolved	05/03/2021	11:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St		6738	Zinc - Dissolved	05/03/2021	11:05	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6738	Zinc - Dissolved	05/03/2021	10:35	0.834	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		6738	Zinc - Dissolved	05/03/2021	10:40	0.011	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush		9402	ICP-MS - 2 Elements	05/03/2021	10:55	Completed		
	Waikouaiti SS - 192 Main Rd		9402	ICP-MS - 2 Elements	05/03/2021	11:00	Completed		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush		9402	ICP-MS - 2 Elements	05/03/2021	09:55	Completed		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St		9402	ICP-MS - 2 Elements	05/03/2021	10:10	Completed		
	Karitane SS - 99 Stornoway St - Preflush		9402	ICP-MS - 2 Elements	05/03/2021	12:45	Completed		
	Karitane SS - 99 Stornoway St		9402	ICP-MS - 2 Elements	05/03/2021	11:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake		9402	ICP-MS - 2 Elements	05/03/2021	12:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		9402	ICP-MS - 2 Elements	05/03/2021	12:10	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate		9402	ICP-MS - 2 Elements	05/03/2021	12:00	Completed		
	Waikouaiti WTP - Supernatant Tube Settler		9402	ICP-MS - 2 Elements	05/03/2021	12:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir		9402	ICP-MS - 2 Elements	05/03/2021	11:55	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream		9402	ICP-MS - 2 Elements	05/03/2021	11:40	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		9402	ICP-MS - 2 Elements	05/03/2021	11:00	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St		9402	ICP-MS - 2 Elements	05/03/2021	11:05	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		9402	ICP-MS - 2 Elements	05/03/2021	10:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd		9402	ICP-MS - 2 Elements	05/03/2021	10:40	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F		Dissolved Oxygen - Field	05/03/2021	10:55	6.4	g O2/m³	
	Waikouaiti SS - 192 Main Rd	D-0056F		Dissolved Oxygen - Field	05/03/2021	11:00	6.2	g O2/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F		Dissolved Oxygen - Field	05/03/2021	09:55	6	g O2/m³	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	D-0056F		Dissolved Oxygen - Field	05/03/2021	10:10	5.9	g O2/m³	
	Karitane SS - 99 Stornoway St - Preflush	D-0056F		Dissolved Oxygen - Field	05/03/2021	12:45	5.6	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F		Dissolved Oxygen - Field	05/03/2021	11:35	6.1	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F		Dissolved Oxygen - Field	05/03/2021	12:50	6.1	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F		Dissolved Oxygen - Field	05/03/2021	12:10	5.6	g O2/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F		Dissolved Oxygen - Field	05/03/2021	12:00	6.3	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F		Dissolved Oxygen - Field	05/03/2021	12:35	5.9	g O2/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	05/03/2021	11:55	6.4	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	05/03/2021	11:40	7.3	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	05/03/2021	11:00	6.2	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	05/03/2021	11:05	5.8	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	05/03/2021	10:35	6.4	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	05/03/2021	10:40	5.9	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	05/03/2021	10:55	0.57	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	05/03/2021	11:00	0.68	g/m³	(.2 - 5)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	05/03/2021	09:55	0.31	g/m³	(0 - 5)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	05/03/2021	10:10	0.44	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	05/03/2021	12:45	0.81	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	05/03/2021	11:35	0.56	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	05/03/2021	12:00	<0.05	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	05/03/2021	12:35	0.28	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	05/03/2021	11:55	0.46	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	05/03/2021	11:00	0.56	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	05/03/2021	11:05	0.69	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	05/03/2021	10:35	0.42	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	05/03/2021	10:40	0.82	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	05/03/2021	10:55	0.8	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	05/03/2021	11:00	0.9	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	05/03/2021	09:55	0.4	g/m³		
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	05/03/2021	10:10	0.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	05/03/2021	12:45	0.8	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	05/03/2021	11:35	0.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	05/03/2021	12:00	0.2	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	05/03/2021	12:35	0.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	05/03/2021	11:55	0.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	05/03/2021	11:00	0.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	05/03/2021	11:05	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	05/03/2021	10:35	0.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	05/03/2021	10:40	0.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	05/03/2021	10:55	Completed			
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	05/03/2021	09:55	<1	MPN/100mL	(0 - 0)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	05/03/2021	10:10	<1	MPN/100mL	(0 - 0)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	05/03/2021	09:55	<1	MPN/100ml	(0 - 0)	
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	05/03/2021	10:10	<1	MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	05/03/2021	12:50	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	05/03/2021	12:10	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	05/03/2021	11:40	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	05/03/2021	10:55	Completed			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	05/03/2021	11:00	Completed			
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	05/03/2021	09:55	Completed			
Tap not sanitised for micro sample	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	05/03/2021	10:10	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	05/03/2021	12:45	Completed			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	05/03/2021	11:35	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	05/03/2021	12:50	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	05/03/2021	12:10	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	05/03/2021	12:00	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	05/03/2021	12:35	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	05/03/2021	11:55	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	05/03/2021	11:40	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	05/03/2021	11:00	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	05/03/2021	11:05	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	05/03/2021	10:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	05/03/2021	10:40	Completed			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	05/03/2021	12:20	Completed			
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	1	pH	05/03/2021	09:59	7.9		(1 - 14)	
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	52	Alkalinity - Total	05/03/2021	09:59	73	g CaCO3/m³		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	55	Conductivity at 25°C - mS/m unit	05/03/2021	09:59	25.8	mS/m (257.7 x .1)		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	0440D	Dissolved Inorganic Carbon	05/03/2021	09:59	18.6	g/m³		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	702	Chloride - Ultra Trace	05/03/2021	09:59	16.1	g/m³		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	707	Sulphate - Ultra Trace	05/03/2021	09:59	24.3	g/m³		
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:49	0.012	g/m³		
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:50	0.012	g/m³		
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:51	0.011	g/m³		
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:52	0.011	g/m³		
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:53	0.012	g/m³		
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:54	0.011	g/m³		
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:55	0.011	g/m³		
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:56	0.011	g/m³		
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:57	0.012	g/m³		
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:58	0.012	g/m³		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6001	Aluminium - Acid Soluble	05/03/2021	09:59	0.012	g/m³		
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:49	0.0033	g/m³	(2 - 2)	
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:50	0.0008	g/m³	(2 - 2)	
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:51	0.0009	g/m³	(2 - 2)	
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:52	0.0007	g/m³	(2 - 2)	
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:53	0.0008	g/m³	(2 - 2)	
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:54	0.0007	g/m³	(2 - 2)	

#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:55	0.0007	g/m³	(2 - 2)
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:56	0.0014	g/m³	(2 - 2)
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:57	0.0007	g/m³	(2 - 2)
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:58	0.0007	g/m³	(2 - 2)
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6013	Copper - Acid Soluble	05/03/2021	09:59	0.0006	g/m³	(2 - 2)
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:49	0.01	g/m³	
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:50	0.01	g/m³	
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:51	0.01	g/m³	
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:52	0.01	g/m³	
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:53	0.01	g/m³	
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:54	0.01	g/m³	
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:55	0.01	g/m³	
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:56	0.01	g/m³	
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:57	0.01	g/m³	
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:58	0.01	g/m³	
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6017	Iron - Acid Soluble	05/03/2021	09:59	0.01	g/m³	
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:49	0.0013	g/m³	(.005 - .01)
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:50	<0.0005	g/m³	(.005 - .01)
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:51	<0.0005	g/m³	(.005 - .01)
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:52	<0.0005	g/m³	(.005 - .01)
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:53	<0.0005	g/m³	(.005 - .01)
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:54	<0.0005	g/m³	(.005 - .01)
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:55	<0.0005	g/m³	(.005 - .01)
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:56	<0.0005	g/m³	(.005 - .01)
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:57	<0.0005	g/m³	(.005 - .01)
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:58	<0.0005	g/m³	(.005 - .01)
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6018	Lead - Acid Soluble	05/03/2021	09:59	<0.0005	g/m³	(.005 - .01)
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:49	0.0009	g/m³	(.4 - .4)
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:50	<0.0005	g/m³	(.4 - .4)
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:51	<0.0005	g/m³	(.4 - .4)
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:52	<0.0005	g/m³	(.4 - .4)
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:53	<0.0005	g/m³	(.4 - .4)
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:54	<0.0005	g/m³	(.4 - .4)
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:55	<0.0005	g/m³	(.4 - .4)
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:56	<0.0005	g/m³	(.4 - .4)
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:57	<0.0005	g/m³	(.4 - .4)
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:58	<0.0005	g/m³	(.4 - .4)
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6021	Manganese - Acid Soluble	05/03/2021	09:59	<0.0005	g/m³	(.4 - .4)
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:49	<0.0005	g/m³	(.08 - .08)
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:50	<0.0005	g/m³	(.08 - .08)
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:51	<0.0005	g/m³	(.08 - .08)
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:52	<0.0005	g/m³	(.08 - .08)
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:53	<0.0005	g/m³	(.08 - .08)
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:54	<0.0005	g/m³	(.08 - .08)
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:55	<0.0005	g/m³	(.08 - .08)
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:56	<0.0005	g/m³	(.08 - .08)
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:57	<0.0005	g/m³	(.08 - .08)
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:58	<0.0005	g/m³	(.08 - .08)
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6024	Nickel - Acid Soluble	05/03/2021	09:59	<0.0005	g/m³	(.08 - .08)
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:49	0.023	g/m³	
#1 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:50	<0.002	g/m³	
#2 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:51	<0.002	g/m³	
#3 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:52	<0.002	g/m³	
#4 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:53	<0.002	g/m³	
#5 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:54	<0.002	g/m³	
#6 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:55	<0.002	g/m³	
#7 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:56	<0.002	g/m³	
#8 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:57	<0.002	g/m³	
#9 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:58	<0.002	g/m³	
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	6038	Zinc - Acid Soluble	05/03/2021	09:59	<0.002	g/m³	
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	D-0056F	Dissolved Oxygen - Field	05/03/2021	09:59	5.9	g O2/m³	
#0	Waikouaiti SS - 210 Edinburgh St - Profile sample	D-1202	Sampling / Inspection 30 Mins	05/03/2021	09:49	Completed		
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	O0994b	Flow Rate performed by ELS	05/03/2021	09:59	0.3	litres/sec	
#10 minute	Waikouaiti SS - 210 Edinburgh St - Profile sample	P1859	Sample Filtration	05/03/2021	09:59	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	05/03/2021	13:00	0.56	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	05/03/2021	13:00	0.7	g/m³	
	Karitane Bowls	D-0084	Turbidity	05/03/2021	13:00	0.09	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	05/03/2021	13:00	11.6	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	05/03/2021	13:00	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	05/03/2021	13:00	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	06/03/2021	13:50	7.9		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1	pH	06/03/2021	13:55	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	06/03/2021	12:57	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1	pH	06/03/2021	13:04	8		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1	pH	06/03/2021	11:42	8		(1 - 14)
	Karitane SS - 99 Stornoway St	1	pH	06/03/2021	11:48	8		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	06/03/2021	14:45	8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	06/03/2021	14:16	8.1		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	06/03/2021	14:30	7.8		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	06/03/2021	14:20	7.9		(1 - 14)

	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	06/03/2021	14:10	7.9		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	06/03/2021	14:55	8		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	06/03/2021	12:11	8		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	06/03/2021	12:17	8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	06/03/2021	12:36	8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	06/03/2021	12:43	8		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	06/03/2021	13:50	<6	g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	06/03/2021	13:55	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	06/03/2021	12:57	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	06/03/2021	13:04	<6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	06/03/2021	11:42	<6	g/m³		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	06/03/2021	11:48	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	06/03/2021	14:45	<6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	06/03/2021	14:16	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	06/03/2021	14:30	<6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	06/03/2021	14:20	83	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	06/03/2021	14:10	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	06/03/2021	14:55	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	06/03/2021	12:11	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	06/03/2021	12:17	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	06/03/2021	12:36	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	06/03/2021	12:43	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	06/03/2021	13:50	72	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	06/03/2021	13:55	72	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	06/03/2021	12:57	73	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	06/03/2021	13:04	74	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	06/03/2021	11:42	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	06/03/2021	11:48	73	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	06/03/2021	14:45	73	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	06/03/2021	14:16	73	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	06/03/2021	14:30	72	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	06/03/2021	14:20	74	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	06/03/2021	14:10	73	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	06/03/2021	14:55	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	06/03/2021	12:11	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	06/03/2021	12:17	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	06/03/2021	12:36	76	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	06/03/2021	12:43	73	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	06/03/2021	13:50	19.6	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	06/03/2021	13:55	19.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	06/03/2021	12:57	19.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	06/03/2021	13:04	19.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	06/03/2021	11:42	19.5	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	06/03/2021	11:48	19.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	06/03/2021	14:45	19.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	06/03/2021	14:16	19.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	06/03/2021	14:30	19.5	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	06/03/2021	14:20	18.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	06/03/2021	14:10	19.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	06/03/2021	14:55	19.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	06/03/2021	12:11	19.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	06/03/2021	12:17	19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	06/03/2021	12:36	20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	06/03/2021	12:43	19.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	06/03/2021	13:50	15.4	g/m³		
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	06/03/2021	13:55	15.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	06/03/2021	12:57	15.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	06/03/2021	13:04	15.6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	06/03/2021	11:42	15.4	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	06/03/2021	11:48	15.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	06/03/2021	14:45	12.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	06/03/2021	14:16	12.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	06/03/2021	14:30	14	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	06/03/2021	14:20	14.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	06/03/2021	14:10	15.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	06/03/2021	14:55	12.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	06/03/2021	12:11	15.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	06/03/2021	12:17	15.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	06/03/2021	12:36	15.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	06/03/2021	12:43	15.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	06/03/2021	13:50	23.8	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	06/03/2021	13:55	23.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	06/03/2021	12:57	24	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	06/03/2021	13:04	23.9	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	06/03/2021	11:42	24	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	06/03/2021	11:48	23.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	06/03/2021	14:45	21.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	06/03/2021	14:16	23.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	06/03/2021	14:30	23.3	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	06/03/2021	14:20	24.2	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	06/03/2021	14:10	23.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	06/03/2021	14:55	21.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	06/03/2021	12:11	24.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	06/03/2021	12:17	23.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	06/03/2021	12:36	23.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	06/03/2021	12:43	23.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	06/03/2021	13:50	148	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	06/03/2021	13:55	148	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	06/03/2021	12:57	141	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	06/03/2021	13:04	146	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	06/03/2021	11:42	145	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	06/03/2021	11:48	133	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:45	133	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:16	133	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:30	133	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:20	138	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:10	136	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	06/03/2021	14:55	136	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	06/03/2021	12:11	134	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	06/03/2021	12:17	134	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	06/03/2021	12:36	107	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	06/03/2021	12:43	130	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	06/03/2021	13:50	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	06/03/2021	13:50	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	06/03/2021	13:55	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	06/03/2021	12:57	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	06/03/2021	13:04	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	06/03/2021	11:42	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	06/03/2021	11:48	0.017	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	06/03/2021	14:30	0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	06/03/2021	14:20	16.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	06/03/2021	14:10	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	06/03/2021	12:11	0.011	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	06/03/2021	12:17	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	06/03/2021	12:36	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	06/03/2021	12:43	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	06/03/2021	13:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	06/03/2021	13:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	06/03/2021	12:57	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	06/03/2021	13:04	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	06/03/2021	11:42	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	06/03/2021	11:48	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	06/03/2021	14:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	06/03/2021	14:20	0.005	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	06/03/2021	14:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	06/03/2021	12:11	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	06/03/2021	12:17	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	06/03/2021	12:36	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	06/03/2021	12:43	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	06/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	06/03/2021	13:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	06/03/2021	12:57	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	06/03/2021	13:04	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	06/03/2021	11:42	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	06/03/2021	11:48	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	06/03/2021	14:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	06/03/2021	14:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	06/03/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	06/03/2021	12:11	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	06/03/2021	12:17	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	06/03/2021	12:36	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	06/03/2021	12:43	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	06/03/2021	13:50	22.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	06/03/2021	13:55	21.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	06/03/2021	12:57	22.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	06/03/2021	13:04	22.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	06/03/2021	11:42	22.2	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	06/03/2021	11:48	21.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	06/03/2021	14:30	21.5	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	06/03/2021	14:20	21.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	06/03/2021	14:10	21.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	06/03/2021	12:11	21.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	06/03/2021	12:17	21.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	06/03/2021	12:36	21.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	06/03/2021	12:43	21.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	06/03/2021	13:50	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	06/03/2021	13:55	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	06/03/2021	12:57	0.002	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	06/03/2021	13:04	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	06/03/2021	11:42	0.0011	g/m³	(2 - 2)	

	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	06/03/2021	11:48	0.0011	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	06/03/2021	14:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6013 Copper - Acid Soluble	06/03/2021	14:20	0.0029	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	06/03/2021	14:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	06/03/2021	12:11	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	06/03/2021	12:17	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	06/03/2021	12:36	0.0049	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	06/03/2021	12:43	0.0038	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	06/03/2021	13:50	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	06/03/2021	13:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	06/03/2021	12:57	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	06/03/2021	13:04	0.02	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	06/03/2021	11:42	0.05	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	06/03/2021	11:48	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	06/03/2021	14:30	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6017 Iron - Acid Soluble	06/03/2021	14:20	2.07	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	06/03/2021	14:10	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	06/03/2021	12:11	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	06/03/2021	12:17	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	06/03/2021	12:36	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	06/03/2021	12:43	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	06/03/2021	13:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	06/03/2021	13:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	06/03/2021	12:57	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	06/03/2021	13:04	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	06/03/2021	11:42	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	06/03/2021	11:48	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	06/03/2021	14:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6018 Lead - Acid Soluble	06/03/2021	14:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	06/03/2021	14:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	06/03/2021	12:11	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	06/03/2021	12:17	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	06/03/2021	12:36	0.0023	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	06/03/2021	12:43	0.0011	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	06/03/2021	13:50	10	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	06/03/2021	13:55	9.81	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	06/03/2021	12:57	10.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	06/03/2021	13:04	9.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	06/03/2021	11:42	9.88	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	06/03/2021	11:48	9.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	06/03/2021	14:30	9.8	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6020 Magnesium - Acid Soluble	06/03/2021	14:20	9.74	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	06/03/2021	14:10	9.88	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	06/03/2021	12:11	10.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	06/03/2021	12:17	10.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	06/03/2021	12:36	10.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	06/03/2021	12:43	9.96	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	06/03/2021	13:50	0.0021	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	06/03/2021	13:55	0.0019	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	06/03/2021	12:57	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	06/03/2021	13:04	0.0008	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	06/03/2021	11:42	0.0027	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	06/03/2021	11:48	0.035	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	06/03/2021	14:30	0.0009	g/m³	(.4 - .4)	
	Waikouaiti WTP - Supernatant Tube Settler	6021 Manganese - Acid Soluble	06/03/2021	14:20	0.212	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	06/03/2021	14:10	0.0026	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	06/03/2021	12:11	0.0019	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	06/03/2021	12:17	0.0023	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	06/03/2021	12:36	0.0022	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	06/03/2021	12:43	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	06/03/2021	13:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	06/03/2021	13:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	06/03/2021	12:57	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	06/03/2021	13:04	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	06/03/2021	11:42	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	06/03/2021	11:48	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	06/03/2021	14:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Supernatant Tube Settler	6022 Mercury - Acid Soluble	06/03/2021	14:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	06/03/2021	14:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	06/03/2021	12:11	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	06/03/2021	12:17	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	06/03/2021	12:36	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	06/03/2021	12:43	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	06/03/2021	13:50	0.002	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	06/03/2021	13:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	06/03/2021	12:57	0.0022	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	06/03/2021	13:04	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	06/03/2021	11:42	0.0145	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	06/03/2021	11:48	0.0006	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	06/03/2021	14:30	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	06/03/2021	14:20	0.0016	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	06/03/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	06/03/2021	12:11	0.0009	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	06/03/2021	12:17	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	06/03/2021	12:36	0.0089	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	06/03/2021	12:43	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	06/03/2021	13:50	0.006	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	06/03/2021	13:55	0.003	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	06/03/2021	12:57	0.003	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	06/03/2021	13:04	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	06/03/2021	11:42	0.003	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	06/03/2021	11:48	0.004	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	06/03/2021	14:30	<0.002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	06/03/2021	14:20	0.003	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	06/03/2021	14:10	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	06/03/2021	12:11	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	06/03/2021	12:17	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	06/03/2021	12:36	0.046	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	06/03/2021	12:43	0.016	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	06/03/2021	14:38	170,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	06/03/2021	14:38	42.5	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	06/03/2021	14:38	<0.10	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	06/03/2021	14:38	4,630	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	06/03/2021	14:38	29.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	06/03/2021	14:38	27,800	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	06/03/2021	14:38	4.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	06/03/2021	14:38	1,350	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	06/03/2021	14:38	416	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	06/03/2021	14:38	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	06/03/2021	14:38	12.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	06/03/2021	14:38	34	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	06/03/2021	14:45	0.012	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	06/03/2021	14:16	0.011	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	06/03/2021	14:55	0.015	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	06/03/2021	14:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	06/03/2021	14:16	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	06/03/2021	14:55	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	06/03/2021	14:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	06/03/2021	14:16	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	06/03/2021	14:55	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	06/03/2021	14:45	19.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	06/03/2021	14:16	20.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	06/03/2021	14:55	20.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	06/03/2021	14:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	06/03/2021	14:16	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	06/03/2021	14:55	0.003	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	06/03/2021	14:45	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	06/03/2021	14:16	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	06/03/2021	14:55	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	06/03/2021	14:45	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	06/03/2021	14:16	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	06/03/2021	14:55	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	06/03/2021	14:45	9.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	06/03/2021	14:16	10.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	06/03/2021	14:55	9.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	06/03/2021	14:45	0.026	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	06/03/2021	14:16	0.022	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	06/03/2021	14:55	0.027	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	06/03/2021	14:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	06/03/2021	14:16	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	06/03/2021	14:55	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	06/03/2021	14:45	0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	06/03/2021	14:16	0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	06/03/2021	14:55	0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	06/03/2021	14:45	0.008	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	06/03/2021	14:16	0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	06/03/2021	14:55	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	06/03/2021	13:50	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	06/03/2021	13:55	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	06/03/2021	12:57	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	06/03/2021	13:04	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	06/03/2021	11:42	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	06/03/2021	11:48	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	06/03/2021	14:45	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	06/03/2021	14:16	0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	06/03/2021	14:30	0.011	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	06/03/2021	14:20	0.221	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	06/03/2021	14:10	0.011	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	06/03/2021	14:55	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	06/03/2021	12:11	0.011	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	06/03/2021	12:17	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	06/03/2021	12:36	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	06/03/2021	12:43	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	06/03/2021	13:50	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	06/03/2021	13:55	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	06/03/2021	12:57	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	06/03/2021	13:04	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	06/03/2021	11:42	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	06/03/2021	11:48	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	06/03/2021	14:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	06/03/2021	14:16	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	06/03/2021	14:30	<0.001	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	06/03/2021	14:20	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	06/03/2021	14:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	06/03/2021	14:55	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	06/03/2021	12:11	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	06/03/2021	12:17	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	06/03/2021	12:36	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	06/03/2021	12:43	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	06/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	06/03/2021	13:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	06/03/2021	12:57	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	06/03/2021	13:04	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	06/03/2021	11:42	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	06/03/2021	11:48	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	06/03/2021	14:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	06/03/2021	14:16	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	06/03/2021	14:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	06/03/2021	14:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	06/03/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	06/03/2021	14:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	06/03/2021	12:11	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	06/03/2021	12:17	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	06/03/2021	12:36	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	06/03/2021	12:43	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	06/03/2021	13:50	21.5	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	06/03/2021	13:55	21.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	06/03/2021	12:57	21.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	06/03/2021	13:04	21.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	06/03/2021	11:42	21.5	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	06/03/2021	11:48	22	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	06/03/2021	14:45	20.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	06/03/2021	14:16	20.5	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	06/03/2021	14:30	22	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	06/03/2021	14:20	20.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	06/03/2021	14:10	20.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	06/03/2021	14:55	22.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	06/03/2021	12:11	21.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	06/03/2021	12:17	21.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	06/03/2021	12:36	21.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	06/03/2021	12:43	21.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	06/03/2021	13:50	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	06/03/2021	13:55	0.0017	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	06/03/2021	12:57	0.0034	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	06/03/2021	13:04	0.0013	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	06/03/2021	11:42	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	06/03/2021	11:48	0.008	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	06/03/2021	14:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	06/03/2021	14:16	0.0011	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	06/03/2021	14:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	06/03/2021	14:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	06/03/2021	14:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	06/03/2021	14:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	06/03/2021	12:11	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	06/03/2021	12:17	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	06/03/2021	12:36	0.0168	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	06/03/2021	12:43	0.004	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	06/03/2021	13:50	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	06/03/2021	13:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	06/03/2021	12:57	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	06/03/2021	13:04	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	06/03/2021	11:42	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	06/03/2021	11:48	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	06/03/2021	14:45	0.11	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	06/03/2021	14:16	0.08	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	06/03/2021	14:30	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	06/03/2021	14:20	0.02	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	06/03/2021	14:10	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	06/03/2021	14:55	0.11	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	06/03/2021	12:11	<0.01	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	06/03/2021	12:17	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	06/03/2021	12:36	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	06/03/2021	12:43	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	06/03/2021	13:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	06/03/2021	13:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	06/03/2021	12:57	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	06/03/2021	13:04	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	06/03/2021	11:42	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	06/03/2021	11:48	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	06/03/2021	14:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	06/03/2021	14:16	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	06/03/2021	14:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	06/03/2021	14:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	06/03/2021	14:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	06/03/2021	14:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	06/03/2021	12:11	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	06/03/2021	12:17	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	06/03/2021	12:36	0.0297	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	06/03/2021	12:43	0.0008	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	06/03/2021	13:50	9.86	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	06/03/2021	13:55	9.87	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	06/03/2021	12:57	9.62	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	06/03/2021	13:04	9.63	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	06/03/2021	11:42	9.73	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	06/03/2021	11:48	9.97	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	06/03/2021	14:45	9.56	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	06/03/2021	14:16	9.69	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	06/03/2021	14:30	10.1	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	06/03/2021	14:20	9.75	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	06/03/2021	14:10	9.68	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	06/03/2021	14:55	10	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	06/03/2021	12:11	10.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	06/03/2021	12:17	9.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	06/03/2021	12:36	9.58	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	06/03/2021	12:43	9.72	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	06/03/2021	13:50	0.0011	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	06/03/2021	13:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	06/03/2021	12:57	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	06/03/2021	13:04	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	06/03/2021	11:42	0.0007	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	06/03/2021	11:48	0.0029	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	06/03/2021	14:45	0.0084	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	06/03/2021	14:16	0.0042	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	06/03/2021	14:30	0.001	g/m³	(.4 - .4)	
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	06/03/2021	14:20	0.0015	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	06/03/2021	14:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	06/03/2021	14:55	0.0121	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	06/03/2021	12:11	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	06/03/2021	12:17	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	06/03/2021	12:36	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	06/03/2021	12:43	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	06/03/2021	13:50	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	06/03/2021	13:55	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	06/03/2021	12:57	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	06/03/2021	13:04	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	06/03/2021	11:42	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	06/03/2021	11:48	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	06/03/2021	14:45	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	06/03/2021	14:16	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	06/03/2021	14:30	<0.0005	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	06/03/2021	14:20	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	06/03/2021	14:10	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	06/03/2021	14:55	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	06/03/2021	12:11	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	06/03/2021	12:17	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	06/03/2021	12:36	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	06/03/2021	12:43	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	06/03/2021	13:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	06/03/2021	13:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	06/03/2021	12:57	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	06/03/2021	13:04	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	06/03/2021	11:42	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	06/03/2021	11:48	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	06/03/2021	14:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	06/03/2021	14:16	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	06/03/2021	14:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	06/03/2021	14:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	06/03/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	06/03/2021	14:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	06/03/2021	12:11	0.0012	g/m³	(.08 - .08)	

	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	06/03/2021	12:17	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	06/03/2021	12:36	0.0073	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	06/03/2021	12:43	0.0009	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	06/03/2021	13:50	0.006	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	06/03/2021	13:55	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	06/03/2021	12:57	0.045	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	06/03/2021	13:04	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	06/03/2021	11:42	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	06/03/2021	11:48	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	06/03/2021	14:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	06/03/2021	14:16	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	06/03/2021	14:30	<0.002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	06/03/2021	14:20	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	06/03/2021	14:10	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	06/03/2021	14:55	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	06/03/2021	12:11	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	06/03/2021	12:17	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	06/03/2021	12:36	0.671	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	06/03/2021	12:43	0.015	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	06/03/2021	13:50	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	06/03/2021	13:55	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	06/03/2021	12:57	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	06/03/2021	13:04	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	06/03/2021	11:42	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	06/03/2021	11:48	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	06/03/2021	14:45	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	06/03/2021	14:16	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	06/03/2021	14:30	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	06/03/2021	14:20	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	06/03/2021	14:10	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	06/03/2021	14:55	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	06/03/2021	12:11	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	06/03/2021	12:17	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	06/03/2021	12:36	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	06/03/2021	12:43	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	06/03/2021	13:50	7.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	06/03/2021	13:55	6.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	06/03/2021	12:57	5.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	06/03/2021	13:04	7.4	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	06/03/2021	11:42	7.1	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	06/03/2021	11:48	7.7	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:45	7.6	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:16	7.4	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:30	7.6	g O2/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:20	7.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:10	7.4	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	06/03/2021	14:55	7.5	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	06/03/2021	12:11	7	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	06/03/2021	12:17	7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	06/03/2021	12:36	7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	06/03/2021	12:43	7.4	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	06/03/2021	13:50	0.81	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	06/03/2021	13:55	0.84	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	06/03/2021	12:57	0.36	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	06/03/2021	13:04	0.44	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	06/03/2021	11:42	0.66	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	06/03/2021	11:48	0.79	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	06/03/2021	14:30	<0.05	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	06/03/2021	14:20	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	06/03/2021	14:10	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	06/03/2021	12:11	0.73	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	06/03/2021	12:17	0.74	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	06/03/2021	12:36	0.71	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	06/03/2021	12:43	0.71	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	06/03/2021	13:50	0.9	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	06/03/2021	13:55	1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	06/03/2021	12:57	0.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	06/03/2021	13:04	0.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	06/03/2021	11:42	0.8	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	06/03/2021	11:48	0.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	06/03/2021	14:30	<0.05	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	06/03/2021	14:20	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	06/03/2021	14:10	1.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	06/03/2021	12:11	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	06/03/2021	12:17	0.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	06/03/2021	12:36	0.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	06/03/2021	12:43	0.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	06/03/2021	13:50	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	06/03/2021	12:57	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	06/03/2021	13:04	<1	MPN/100mL	(0 - 0)	

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	06/03/2021	12:57	<1		MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	06/03/2021	13:04	<1		MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	06/03/2021	14:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	06/03/2021	14:16	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	06/03/2021	14:55	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	06/03/2021	13:50	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	06/03/2021	13:55	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	06/03/2021	12:57	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	06/03/2021	13:04	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	06/03/2021	11:42	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	06/03/2021	11:48	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	06/03/2021	14:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	06/03/2021	14:16	Completed				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	06/03/2021	14:30	Completed				
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	06/03/2021	14:20	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	06/03/2021	14:10	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	06/03/2021	14:55	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	06/03/2021	12:11	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	06/03/2021	12:17	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	06/03/2021	12:36	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	06/03/2021	12:43	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	06/03/2021	14:38	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	07/03/2021	08:40	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	07/03/2021	08:45	7.8			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	07/03/2021	09:00	7.9			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	07/03/2021	09:05	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	07/03/2021	08:10	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	07/03/2021	08:15	7.9			(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	07/03/2021	07:55	7.8			(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	07/03/2021	07:40	7.8			(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	07/03/2021	07:20	7.8			(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	07/03/2021	07:30	7.8			(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	07/03/2021	07:50	7.7			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	07/03/2021	08:25	7.9			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	07/03/2021	08:30	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	07/03/2021	09:15	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	07/03/2021	09:20	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	07/03/2021	08:40	<6		g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	07/03/2021	08:45	<6		g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	07/03/2021	09:00	<6		g/m³		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	07/03/2021	09:05	<6		g/m³		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	07/03/2021	08:10	<6		g/m³		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	07/03/2021	08:15	<6		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	07/03/2021	07:55	<6		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	07/03/2021	07:40	<6		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	07/03/2021	07:20	<6		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	07/03/2021	07:30	<6		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	07/03/2021	07:50	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	07/03/2021	08:25	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	07/03/2021	08:30	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	07/03/2021	09:15	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	07/03/2021	09:20	<6		g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	07/03/2021	08:40	74		g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	07/03/2021	08:45	72		g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	07/03/2021	09:00	74		g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	07/03/2021	09:05	73		g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	07/03/2021	08:10	75		g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	07/03/2021	08:15	72		g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	07/03/2021	07:55	72		g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	07/03/2021	07:40	71		g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	07/03/2021	07:20	71		g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	07/03/2021	07:30	72		g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	07/03/2021	07:50	71		g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	07/03/2021	08:25	74		g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	07/03/2021	08:30	73		g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	07/03/2021	09:15	76		g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	07/03/2021	09:20	73		g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	07/03/2021	08:40	19.9		g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	07/03/2021	08:45	19.7		g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	07/03/2021	09:00	20		g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	07/03/2021	09:05	19.7		g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	07/03/2021	08:10	20		g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	07/03/2021	08:15	19.8		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	07/03/2021	07:55	20.2		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	07/03/2021	07:40	19.9		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	07/03/2021	07:20	19.7		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	07/03/2021	07:30	19.6		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	07/03/2021	07:50	20.5		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	07/03/2021	08:25	20.1		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	07/03/2021	08:30	19.9		g/m³		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	07/03/2021	09:15	19.8	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	07/03/2021	09:20	19.9	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	07/03/2021	08:40	15.7	g/m³			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	07/03/2021	08:45	15.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	07/03/2021	09:00	15.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	07/03/2021	09:05	16	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	07/03/2021	08:10	16.2	g/m³			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	07/03/2021	08:15	16.2	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	07/03/2021	07:55	13	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	07/03/2021	07:40	12.8	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	07/03/2021	07:20	14.4	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	07/03/2021	07:30	14.4	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	07/03/2021	07:50	13.1	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	07/03/2021	08:25	14.3	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	07/03/2021	08:30	15.9	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	07/03/2021	09:15	16.2	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	07/03/2021	09:20	15.9	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	07/03/2021	08:40	23.6	g/m³			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	07/03/2021	08:45	23.4	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	07/03/2021	09:00	23.6	g/m³			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	07/03/2021	09:05	24	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	07/03/2021	08:10	23.8	g/m³			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	07/03/2021	08:15	23.8	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	07/03/2021	07:55	21.3	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	07/03/2021	07:40	22.1	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	07/03/2021	07:20	22.5	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	07/03/2021	07:30	22.5	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	07/03/2021	07:50	21.4	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	07/03/2021	08:25	21.9	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	07/03/2021	08:30	23.4	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	07/03/2021	09:15	24.3	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	07/03/2021	09:20	23.4	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:40	149	g/m³			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:45	148	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	07/03/2021	09:00	147	g/m³			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	07/03/2021	09:05	144	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:10	147	g/m³			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:15	140	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	07/03/2021	07:55	108	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	07/03/2021	07:40	122	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	07/03/2021	07:20	96	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	07/03/2021	07:30	111	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	07/03/2021	07:50	108	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:25	137	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	07/03/2021	08:30	127	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	07/03/2021	09:15	137	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	07/03/2021	09:20	135	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	07/03/2021	08:40	$100				
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	07/03/2021	08:40	0.01	g/m³			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	07/03/2021	08:45	0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	07/03/2021	09:00	0.011	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	07/03/2021	09:05	0.011	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	07/03/2021	08:10	0.012	g/m³			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	07/03/2021	08:15	0.011	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	07/03/2021	07:20	0.008	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	07/03/2021	07:30	0.01	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	07/03/2021	08:25	0.01	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	07/03/2021	08:30	0.011	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	07/03/2021	09:15	0.008	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	07/03/2021	09:20	0.01	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	07/03/2021	08:40	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	07/03/2021	08:45	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	07/03/2021	09:00	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	07/03/2021	09:05	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	07/03/2021	08:10	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	07/03/2021	08:15	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	07/03/2021	07:20	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	07/03/2021	07:30	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	07/03/2021	08:25	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	07/03/2021	08:30	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	07/03/2021	09:15	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	07/03/2021	09:20	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	07/03/2021	08:40	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	07/03/2021	08:45	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	07/03/2021	09:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	07/03/2021	09:05	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	07/03/2021	08:10	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	07/03/2021	08:15	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	07/03/2021	07:20	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	07/03/2021	07:30	<0.0002	g/m³		(.004 - .004)	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008 Cadmium - Acid Soluble	07/03/2021	08:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008 Cadmium - Acid Soluble	07/03/2021	08:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008 Cadmium - Acid Soluble	07/03/2021	09:15	0.0004	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	07/03/2021	09:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	07/03/2021	08:40	21.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	07/03/2021	08:45	21	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	07/03/2021	09:00	21.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	07/03/2021	09:05	21.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	07/03/2021	08:10	21.8	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	07/03/2021	08:15	21.8	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	07/03/2021	07:20	20.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	07/03/2021	07:30	21	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	07/03/2021	08:25	21.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	07/03/2021	08:30	21.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	07/03/2021	09:15	21.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	07/03/2021	09:20	21.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	07/03/2021	08:40	0.0025	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	07/03/2021	08:45	0.0015	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	07/03/2021	09:00	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	07/03/2021	09:05	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	07/03/2021	08:10	0.0008	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	07/03/2021	08:15	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	07/03/2021	07:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	07/03/2021	07:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	07/03/2021	08:25	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	07/03/2021	08:30	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	07/03/2021	09:15	0.0287	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	07/03/2021	09:20	0.0045	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	07/03/2021	08:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	07/03/2021	08:45	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	07/03/2021	09:00	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	07/03/2021	09:05	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	07/03/2021	08:10	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	07/03/2021	08:15	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	07/03/2021	07:20	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	07/03/2021	07:30	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	07/03/2021	08:25	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	07/03/2021	08:30	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	07/03/2021	09:15	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	07/03/2021	09:20	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	07/03/2021	08:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	07/03/2021	08:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	07/03/2021	09:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	07/03/2021	09:05	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	07/03/2021	08:10	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	07/03/2021	08:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	07/03/2021	07:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	07/03/2021	07:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	07/03/2021	08:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	07/03/2021	08:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	07/03/2021	09:15	0.0708	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	07/03/2021	09:20	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	07/03/2021	08:40	10.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	07/03/2021	08:45	10.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	07/03/2021	09:00	10	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	07/03/2021	09:05	9.9	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	07/03/2021	08:10	10.1	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	07/03/2021	08:15	10	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	07/03/2021	07:20	10	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	07/03/2021	07:30	10.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	07/03/2021	08:25	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	07/03/2021	08:30	10.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	07/03/2021	09:15	10.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	07/03/2021	09:20	9.96	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	07/03/2021	08:40	0.0023	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	07/03/2021	08:45	0.0012	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	07/03/2021	09:00	0.0008	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	07/03/2021	09:05	0.0006	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	07/03/2021	08:10	0.0008	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	07/03/2021	08:15	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	07/03/2021	07:20	0.0012	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	07/03/2021	07:30	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	07/03/2021	08:25	0.0031	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	07/03/2021	08:30	0.0015	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	07/03/2021	09:15	0.0014	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	07/03/2021	09:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	07/03/2021	08:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	07/03/2021	08:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	07/03/2021	09:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	07/03/2021	09:05	<0.0005	g/m³	(.007 - .007)	

	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	07/03/2021	08:10	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	07/03/2021	08:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	07/03/2021	07:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	07/03/2021	07:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	07/03/2021	08:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	07/03/2021	08:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	07/03/2021	09:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	07/03/2021	09:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	07/03/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	07/03/2021	08:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	07/03/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	07/03/2021	09:05	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	07/03/2021	08:10	0.0006	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	07/03/2021	08:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	07/03/2021	07:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	07/03/2021	07:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	07/03/2021	08:25	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	07/03/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	07/03/2021	09:15	0.0061	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	07/03/2021	09:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	07/03/2021	08:40	0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	07/03/2021	08:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	07/03/2021	09:00	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	07/03/2021	09:05	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	07/03/2021	08:10	0.006	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	07/03/2021	08:15	0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	07/03/2021	07:20	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	07/03/2021	07:30	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	07/03/2021	08:25	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	07/03/2021	08:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	07/03/2021	09:15	1.89	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	07/03/2021	09:20	0.01	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	07/03/2021	07:45	91,800	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	07/03/2021	07:45	15.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	07/03/2021	07:45	<0.10	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	07/03/2021	07:45	4,210	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	07/03/2021	07:45	16.2	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	07/03/2021	07:45	16,700	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	07/03/2021	07:45	7.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	07/03/2021	07:45	1,870	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	07/03/2021	07:45	892	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	07/03/2021	07:45	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	07/03/2021	07:45	10.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	07/03/2021	07:45	62	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	07/03/2021	07:55	0.022	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	07/03/2021	07:40	0.008	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	07/03/2021	07:50	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	07/03/2021	07:55	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	07/03/2021	07:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	07/03/2021	07:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	07/03/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	07/03/2021	07:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	07/03/2021	07:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	07/03/2021	07:55	20.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	07/03/2021	07:40	19.1	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	07/03/2021	07:50	21	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	07/03/2021	07:55	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	07/03/2021	07:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	07/03/2021	07:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	07/03/2021	07:55	0.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	07/03/2021	07:40	0.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	07/03/2021	07:50	0.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	07/03/2021	07:55	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	07/03/2021	07:40	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	07/03/2021	07:50	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	07/03/2021	07:55	9.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	07/03/2021	07:40	9.2	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	07/03/2021	07:50	9.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	07/03/2021	07:55	0.037	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	07/03/2021	07:40	0.013	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	07/03/2021	07:50	0.035	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	07/03/2021	07:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	07/03/2021	07:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	07/03/2021	07:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	07/03/2021	07:55	0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	07/03/2021	07:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	07/03/2021	07:50	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	07/03/2021	07:55	<0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	07/03/2021	07:40	<0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	07/03/2021	07:50	<0.005	g/m³	

	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	07/03/2021	08:40		0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	07/03/2021	08:45		0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	07/03/2021	09:00		0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	07/03/2021	09:05		0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	07/03/2021	08:10		0.012	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	07/03/2021	08:15		0.011	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	07/03/2021	07:55		0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	07/03/2021	07:40		0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	07/03/2021	07:20		0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	07/03/2021	07:30		0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	07/03/2021	07:50		0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	07/03/2021	08:25		0.011	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	07/03/2021	08:30		0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	07/03/2021	09:15		0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	07/03/2021	09:20		0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	07/03/2021	08:40	<0.001		g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	07/03/2021	08:45	<0.001		g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	07/03/2021	09:00	<0.001		g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	07/03/2021	09:05	<0.001		g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	07/03/2021	08:10	<0.001		g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	07/03/2021	08:15	<0.001		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	07/03/2021	07:55	<0.001		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	07/03/2021	07:40	<0.001		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	07/03/2021	07:20	<0.001		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	07/03/2021	07:30	<0.001		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	07/03/2021	07:50	<0.001		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	07/03/2021	08:25	<0.001		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	07/03/2021	08:30	<0.001		g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	07/03/2021	09:15	<0.001		g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	07/03/2021	09:20	<0.001		g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	07/03/2021	08:40	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	07/03/2021	08:45	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	07/03/2021	09:00	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	07/03/2021	09:05	<0.0002		g/m³		(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	07/03/2021	08:10	<0.0002		g/m³		(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	07/03/2021	08:15	<0.0002		g/m³		(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	07/03/2021	07:55	<0.0002		g/m³		(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	07/03/2021	07:40	<0.0002		g/m³		(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	07/03/2021	07:20	<0.0002		g/m³		(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	07/03/2021	07:30	<0.0002		g/m³		(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	07/03/2021	07:50	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	07/03/2021	08:25	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	07/03/2021	08:30	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	07/03/2021	09:15	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	07/03/2021	09:20	<0.0002		g/m³		(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	07/03/2021	08:40		21	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	07/03/2021	08:45		19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	07/03/2021	09:00		19.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	07/03/2021	09:05		18.6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	07/03/2021	08:10		19.3	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	07/03/2021	08:15		19.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	07/03/2021	07:55		19.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	07/03/2021	07:40		21	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	07/03/2021	07:20		20.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	07/03/2021	07:30		19.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	07/03/2021	07:50		19.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	07/03/2021	08:25		20.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	07/03/2021	08:30		20.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	07/03/2021	09:15		21.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	07/03/2021	09:20		21.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	07/03/2021	08:40		0.0019	g/m³		(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	07/03/2021	08:45		0.0014	g/m³		(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	07/03/2021	09:00		0.0013	g/m³		(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	07/03/2021	09:05		0.0007	g/m³		(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	07/03/2021	08:10		0.0007	g/m³		(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	07/03/2021	08:15		0.0005	g/m³		(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	07/03/2021	07:55	<0.0005		g/m³		(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	07/03/2021	07:40	<0.0005		g/m³		(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	07/03/2021	07:20	<0.0005		g/m³		(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	07/03/2021	07:30	<0.0005		g/m³		(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	07/03/2021	07:50	<0.0005		g/m³		(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	07/03/2021	08:25		0.0007	g/m³		(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	07/03/2021	08:30		0.0006	g/m³		(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	07/03/2021	09:15		0.0057	g/m³		(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	07/03/2021	09:20		0.0037	g/m³		(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	07/03/2021	08:40	<0.01		g/m³		(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	07/03/2021	08:45	<0.01		g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	07/03/2021	09:00	<0.01		g/m³		(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	07/03/2021	09:05	<0.01		g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	07/03/2021	08:10	<0.01		g/m³		(.2 - .2)

	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	07/03/2021	08:15	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	07/03/2021	07:55	0.12	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	07/03/2021	07:40	0.09	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	07/03/2021	07:20	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	07/03/2021	07:30	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	07/03/2021	07:50	0.12	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	07/03/2021	08:25	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	07/03/2021	08:30	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	07/03/2021	09:15	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	07/03/2021	09:20	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	07/03/2021	08:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	07/03/2021	08:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	07/03/2021	09:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	07/03/2021	09:05	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	07/03/2021	08:10	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	07/03/2021	08:15	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	07/03/2021	07:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	07/03/2021	07:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	07/03/2021	07:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	07/03/2021	07:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	07/03/2021	07:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	07/03/2021	08:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	07/03/2021	08:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	07/03/2021	09:15	0.0021	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	07/03/2021	09:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	07/03/2021	08:40	9.77	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	07/03/2021	08:45	9.46	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	07/03/2021	09:00	8.85	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	07/03/2021	09:05	8.43	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	07/03/2021	08:10	8.84	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	07/03/2021	08:15	8.88	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	07/03/2021	07:55	9.21	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	07/03/2021	07:40	9.71	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	07/03/2021	07:20	9.54	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	07/03/2021	07:30	9.45	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	07/03/2021	07:50	8.91	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	07/03/2021	08:25	9.78	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	07/03/2021	08:30	9.57	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	07/03/2021	09:15	9.72	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	07/03/2021	09:20	9.74	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	07/03/2021	08:40	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	07/03/2021	08:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	07/03/2021	09:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	07/03/2021	09:05	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	07/03/2021	08:10	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	07/03/2021	08:15	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	07/03/2021	07:55	0.0132	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	07/03/2021	07:40	0.0036	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	07/03/2021	07:20	0.0011	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	07/03/2021	07:30	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	07/03/2021	07:50	0.0183	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	07/03/2021	08:25	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	07/03/2021	08:30	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	07/03/2021	09:15	0.0014	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	07/03/2021	09:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	07/03/2021	08:40	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	07/03/2021	08:45	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	07/03/2021	09:00	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	07/03/2021	09:05	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	07/03/2021	08:10	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	07/03/2021	08:15	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	07/03/2021	07:55	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	07/03/2021	07:40	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	07/03/2021	07:20	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	07/03/2021	07:30	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	07/03/2021	07:50	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	07/03/2021	08:25	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	07/03/2021	08:30	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	07/03/2021	09:15	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	07/03/2021	09:20	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	07/03/2021	08:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	07/03/2021	08:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	07/03/2021	09:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	07/03/2021	09:05	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	07/03/2021	08:10	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	07/03/2021	08:15	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	07/03/2021	07:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	07/03/2021	07:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	07/03/2021	07:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	07/03/2021	07:30	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	07/03/2021	07:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	07/03/2021	08:25	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	07/03/2021	08:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	07/03/2021	09:15	0.0078	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	07/03/2021	09:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	07/03/2021	08:40	0.003	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	07/03/2021	08:45	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	07/03/2021	09:00	0.005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	07/03/2021	09:05	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	07/03/2021	08:10	0.004	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	07/03/2021	08:15	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	07/03/2021	07:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	07/03/2021	07:40	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	07/03/2021	07:20	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	07/03/2021	07:30	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	07/03/2021	07:50	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	07/03/2021	08:25	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	07/03/2021	08:30	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	07/03/2021	09:15	0.066	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	07/03/2021	09:20	0.006	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	07/03/2021	08:40	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	07/03/2021	08:45	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	07/03/2021	09:00	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	07/03/2021	09:05	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	07/03/2021	08:10	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	07/03/2021	08:15	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	07/03/2021	07:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	07/03/2021	07:40	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	07/03/2021	07:20	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	07/03/2021	07:30	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	07/03/2021	07:50	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	07/03/2021	08:25	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	07/03/2021	08:30	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	07/03/2021	09:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	07/03/2021	09:20	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	07/03/2021	07:20	No	Water		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:40	6.6	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:45	6.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	07/03/2021	09:00	6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	07/03/2021	09:05	6.2	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:10	7.2	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:15	6.8	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	07/03/2021	07:55	4.7	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	07/03/2021	07:40	5.6	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	07/03/2021	07:20	7.4	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	07/03/2021	07:30	6.3	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	07/03/2021	07:50	4.8	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:25	7.5	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	07/03/2021	08:30	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	07/03/2021	09:15	6.3	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	07/03/2021	09:20	6.5	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	07/03/2021	08:40	0.07	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	07/03/2021	08:45	0.79	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	07/03/2021	09:00	0.11	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	07/03/2021	09:05	0.16	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	07/03/2021	08:10	0.15	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	07/03/2021	08:15	1	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	07/03/2021	07:20	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	07/03/2021	07:30	0.22	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	07/03/2021	08:25	0.07	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	07/03/2021	08:30	1	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	07/03/2021	09:15	0.06	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	07/03/2021	09:20	0.86	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	07/03/2021	08:40	0.1	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	07/03/2021	08:45	0.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	07/03/2021	09:00	0.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	07/03/2021	09:05	0.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	07/03/2021	08:10	0.2	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	07/03/2021	08:15	1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	07/03/2021	07:20	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	07/03/2021	07:30	0.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	07/03/2021	08:25	0.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	07/03/2021	08:30	1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	07/03/2021	09:15	0.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	07/03/2021	09:20	0.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	07/03/2021	08:40	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	07/03/2021	09:00	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	07/03/2021	09:05	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	07/03/2021	09:00	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	07/03/2021	09:05	<1	MPN/100ml	(0 - 0)	

	Catchment - Waikouaiti River - Pump Station Intake	P1855		Aqueous Total Metal Digestion for ICPMS codes	07/03/2021	07:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855		Aqueous Total Metal Digestion for ICPMS codes	07/03/2021	07:40	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855		Aqueous Total Metal Digestion for ICPMS codes	07/03/2021	07:50	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859		Sample Filtration	07/03/2021	08:40	Completed			
	Waikouaiti SS - 192 Main Rd	P1859		Sample Filtration	07/03/2021	08:45	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859		Sample Filtration	07/03/2021	09:00	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859		Sample Filtration	07/03/2021	09:05	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859		Sample Filtration	07/03/2021	08:10	Completed			
	Karitane SS - 99 Stornoway St	P1859		Sample Filtration	07/03/2021	08:15	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859		Sample Filtration	07/03/2021	07:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859		Sample Filtration	07/03/2021	07:40	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859		Sample Filtration	07/03/2021	07:20	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859		Sample Filtration	07/03/2021	07:30	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859		Sample Filtration	07/03/2021	07:50	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859		Sample Filtration	07/03/2021	08:25	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859		Sample Filtration	07/03/2021	08:30	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859		Sample Filtration	07/03/2021	09:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859		Sample Filtration	07/03/2021	09:20	Completed			
	Waikouaiti WTP - Settling Ponds Sediment	P1861		Metals Digestion - Soil/Sludge	07/03/2021	07:45	Completed			
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		1	pH	08/03/2021	10:45	7.9		(1 - 14)	
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		52	Alkalinity - Total	08/03/2021	10:45	75	g CaCO3/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		55	Conductivity at 25°C - mS/m unit	08/03/2021	10:45	25.9	mS/m (258.6 x .1)		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	0440D		Dissolved Inorganic Carbon	08/03/2021	10:45	19.4	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		702	Chloride - Ultra Trace	08/03/2021	10:45	15.9	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		707	Sulphate - Ultra Trace	08/03/2021	10:45	23.4	g/m³		
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:35	0.046	g/m³		
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:36	0.011	g/m³		
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:37	0.01	g/m³		
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:38	0.021	g/m³		
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:39	0.012	g/m³		
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:40	0.011	g/m³		
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:41	0.012	g/m³		
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:42	0.011	g/m³		
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:43	0.011	g/m³		
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:44	0.01	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6001	Aluminium - Acid Soluble	08/03/2021	10:45	0.011	g/m³		
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:35	0.088	g/m³	(2 - 2)	
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:36	0.0255	g/m³	(2 - 2)	
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:37	0.0249	g/m³	(2 - 2)	
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:38	0.0202	g/m³	(2 - 2)	
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:39	0.0194	g/m³	(2 - 2)	
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:40	0.0185	g/m³	(2 - 2)	
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:41	0.0194	g/m³	(2 - 2)	
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:42	0.0201	g/m³	(2 - 2)	
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:43	0.0198	g/m³	(2 - 2)	
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:44	0.0209	g/m³	(2 - 2)	
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6013	Copper - Acid Soluble	08/03/2021	10:45	0.031	g/m³	(2 - 2)	
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:35	1.99	g/m³		
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:36	0.09	g/m³		
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:37	0.03	g/m³		
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:38	0.05	g/m³		
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:39	0.05	g/m³		
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:40	0.03	g/m³		
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:41	0.03	g/m³		
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:42	0.04	g/m³		
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:43	0.05	g/m³		
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:44	0.04	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6017	Iron - Acid Soluble	08/03/2021	10:45	0.05	g/m³		
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:35	0.0261	g/m³	(.005 - .01)	
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:36	0.0043	g/m³	(.005 - .01)	
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:37	0.003	g/m³	(.005 - .01)	
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:38	0.0025	g/m³	(.005 - .01)	
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:39	0.0024	g/m³	(.005 - .01)	
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:40	0.0018	g/m³	(.005 - .01)	
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:41	0.0022	g/m³	(.005 - .01)	
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:42	0.0022	g/m³	(.005 - .01)	
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:43	0.0019	g/m³	(.005 - .01)	
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:44	0.0018	g/m³	(.005 - .01)	
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6018	Lead - Acid Soluble	08/03/2021	10:45	0.0034	g/m³	(.005 - .01)	
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:35	0.0485	g/m³	(.4 - .4)	
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:36	0.0025	g/m³	(.4 - .4)	
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:37	0.0009	g/m³	(.4 - .4)	
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:38	0.0053	g/m³	(.4 - .4)	
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:39	0.0027	g/m³	(.4 - .4)	
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:40	0.0016	g/m³	(.4 - .4)	
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:41	0.0016	g/m³	(.4 - .4)	
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:42	0.0018	g/m³	(.4 - .4)	
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:43	0.002	g/m³	(.4 - .4)	
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:44	0.0017	g/m³	(.4 - .4)	
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample		6021	Manganese - Acid Soluble	08/03/2021	10:45	0.0022	g/m³	(.4 - .4)	

#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:35	0.0013	g/m³	(.08 - .08)	
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:36	0.0008	g/m³	(.08 - .08)	
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:37	0.0008	g/m³	(.08 - .08)	
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:38	0.0008	g/m³	(.08 - .08)	
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:39	0.0007	g/m³	(.08 - .08)	
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:40	0.0007	g/m³	(.08 - .08)	
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:41	0.0007	g/m³	(.08 - .08)	
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:42	0.0007	g/m³	(.08 - .08)	
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:43	0.0006	g/m³	(.08 - .08)	
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:44	0.0005	g/m³	(.08 - .08)	
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6024	Nickel - Acid Soluble	08/03/2021	10:45	0.0006	g/m³	(.08 - .08)	
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:35	0.205	g/m³		
#1 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:36	0.164	g/m³		
#2 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:37	0.163	g/m³		
#3 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:38	0.124	g/m³		
#4 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:39	0.123	g/m³		
#5 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:40	0.12	g/m³		
#6 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:41	0.129	g/m³		
#7 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:42	0.125	g/m³		
#8 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:43	0.114	g/m³		
#9 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:44	0.121	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	6038	Zinc - Acid Soluble	08/03/2021	10:45	0.157	g/m³		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	D-0056F	Dissolved Oxygen - Field	08/03/2021	10:45	6.6	g O2/m³		
#0	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	D-1202	Sampling / Inspection 30 Mins	08/03/2021	10:35	Completed			
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	O0994b	Flow Rate performed by ELS	08/03/2021	10:45	0.3	litres/sec		
#10 minute	Waikouaiti Golf Club - Alternate Tap 1 - Profile sample	P1859	Sample Filtration	08/03/2021	10:45	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	08/03/2021	11:30	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	08/03/2021	11:35	7.9		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	08/03/2021	10:55	8		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	08/03/2021	11:05	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	08/03/2021	13:35	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	08/03/2021	13:40	8		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	08/03/2021	13:10	7.9		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	08/03/2021	12:40	7.8		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	08/03/2021	12:50	7.9		(1 - 14)	
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	08/03/2021	12:55	7.8		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	08/03/2021	12:35	7.8		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	08/03/2021	13:15	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	08/03/2021	11:45	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	08/03/2021	11:50	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	08/03/2021	11:15	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	08/03/2021	11:20	7.8		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	08/03/2021	11:30	<6	g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	08/03/2021	11:35	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	08/03/2021	10:55	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	08/03/2021	11:05	<6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	08/03/2021	13:35	<6	g/m³		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	08/03/2021	13:40	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	08/03/2021	13:10	<6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	08/03/2021	12:40	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	08/03/2021	12:50	<6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	08/03/2021	12:55	100	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	08/03/2021	12:35	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	08/03/2021	13:15	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	08/03/2021	11:45	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	08/03/2021	11:50	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	08/03/2021	11:15	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	08/03/2021	11:20	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	08/03/2021	11:30	72	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	08/03/2021	11:35	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	08/03/2021	10:55	73	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	08/03/2021	11:05	74	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	08/03/2021	13:35	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	08/03/2021	13:40	73	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	08/03/2021	13:10	72	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	08/03/2021	12:40	72	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	08/03/2021	12:50	70	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	08/03/2021	12:55	78	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	08/03/2021	12:35	73	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	08/03/2021	13:15	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	08/03/2021	11:45	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	08/03/2021	11:50	74	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	08/03/2021	11:15	77	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	08/03/2021	11:20	74	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	08/03/2021	11:30	19.7	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	08/03/2021	11:35	19.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	08/03/2021	10:55	20.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	08/03/2021	11:05	20.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	08/03/2021	13:35	19.8	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	08/03/2021	13:40	19.7	g/m³		

	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	08/03/2021	13:10	19.8	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	08/03/2021	12:40	19.8	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	08/03/2021	12:50	19.5	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	08/03/2021	12:55	19	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	08/03/2021	12:35	19.5	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	08/03/2021	13:15	19.9	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	08/03/2021	11:45	19.7	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	08/03/2021	11:50	19.6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	08/03/2021	11:15	20.1	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	08/03/2021	11:20	19.9	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	08/03/2021	11:30	15.9	g/m³			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	08/03/2021	11:35	15.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	08/03/2021	10:55	16	g/m³			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	08/03/2021	11:05	16.1	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	08/03/2021	13:35	16	g/m³			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	08/03/2021	13:40	16.1	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	08/03/2021	13:10	13.2	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	08/03/2021	12:40	13.1	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	08/03/2021	12:50	14.5	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	08/03/2021	12:55	14.6	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	08/03/2021	12:35	16	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	08/03/2021	13:15	13.2	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	08/03/2021	11:45	15.9	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	08/03/2021	11:50	16	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	08/03/2021	11:15	16.1	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	08/03/2021	11:20	16	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	08/03/2021	11:30	23.6	g/m³			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	08/03/2021	11:35	23.2	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	08/03/2021	10:55	23.8	g/m³			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	08/03/2021	11:05	23.5	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	08/03/2021	13:35	23.7	g/m³			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	08/03/2021	13:40	23.3	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	08/03/2021	13:10	22.4	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	08/03/2021	12:40	22.6	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	08/03/2021	12:50	22.5	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	08/03/2021	12:55	23.5	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	08/03/2021	12:35	23.3	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	08/03/2021	13:15	22.5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	08/03/2021	11:45	23.9	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	08/03/2021	11:50	23.5	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	08/03/2021	11:15	23.8	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	08/03/2021	11:20	23.6	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:30	138	g/m³			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:35	121	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	08/03/2021	10:55	125	g/m³			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:05	137	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	08/03/2021	13:35	137	g/m³			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	08/03/2021	13:40	136	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	08/03/2021	13:10	136	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	08/03/2021	12:40	137	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	08/03/2021	12:50	140	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	08/03/2021	12:55	137	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	08/03/2021	12:35	136	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	08/03/2021	13:15	108	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:45	134	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:50	139	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:15	147	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	08/03/2021	11:20	149	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	08/03/2021	11:30	$100				
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	08/03/2021	11:30	0.01	g/m³			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	08/03/2021	11:35	0.011	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	08/03/2021	10:55	0.011	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	08/03/2021	11:05	0.012	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	08/03/2021	13:35	0.014	g/m³			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	08/03/2021	13:40	0.011	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	08/03/2021	12:50	0.007	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	08/03/2021	12:55	21.4	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	08/03/2021	12:35	0.012	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	08/03/2021	11:45	0.013	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	08/03/2021	11:50	0.011	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	08/03/2021	11:15	0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	08/03/2021	11:20	0.011	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	08/03/2021	11:30	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	08/03/2021	11:35	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	08/03/2021	10:55	<0.001	g/m³		(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	08/03/2021	11:05	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	08/03/2021	13:35	<0.001	g/m³		(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	08/03/2021	13:40	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	08/03/2021	12:50	<0.001	g/m³		(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	08/03/2021	12:55	0.004	g/m³		(.01 - .01)	

	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	08/03/2021	12:35	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	08/03/2021	11:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	08/03/2021	11:50	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	08/03/2021	11:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	08/03/2021	11:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	08/03/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	08/03/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	08/03/2021	10:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	08/03/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	08/03/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	08/03/2021	13:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	08/03/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	08/03/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	08/03/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	08/03/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	08/03/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	08/03/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	08/03/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	08/03/2021	11:30	21.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	08/03/2021	11:35	21.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	08/03/2021	10:55	22	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	08/03/2021	11:05	22	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	08/03/2021	13:35	22.8	g/m³	
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	08/03/2021	13:40	22.1	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	08/03/2021	12:50	21.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	08/03/2021	12:55	21.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	08/03/2021	12:35	21.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	08/03/2021	11:45	21.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	08/03/2021	11:50	21.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	08/03/2021	11:15	22	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	08/03/2021	11:20	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	08/03/2021	11:30	0.0053	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	08/03/2021	11:35	0.0012	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	08/03/2021	10:55	0.0061	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	08/03/2021	11:05	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	08/03/2021	13:35	0.0056	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	08/03/2021	13:40	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	08/03/2021	12:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	08/03/2021	12:55	0.0032	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	08/03/2021	12:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	08/03/2021	11:45	0.0017	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	08/03/2021	11:50	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	08/03/2021	11:15	0.0165	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	08/03/2021	11:20	0.0038	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	08/03/2021	11:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	08/03/2021	11:35	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	08/03/2021	10:55	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	08/03/2021	11:05	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	08/03/2021	13:35	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	08/03/2021	13:40	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	08/03/2021	12:50	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	08/03/2021	12:55	2.02	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	08/03/2021	12:35	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	08/03/2021	11:45	0.58	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	08/03/2021	11:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	08/03/2021	11:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	08/03/2021	11:20	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	08/03/2021	11:30	0.0024	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	08/03/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	08/03/2021	10:55	0.0025	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	08/03/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	08/03/2021	13:35	0.0012	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	08/03/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	08/03/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	08/03/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	08/03/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	08/03/2021	11:45	0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	08/03/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	08/03/2021	11:15	0.0302	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	08/03/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	08/03/2021	11:30	9.9	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	08/03/2021	11:35	9.94	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	08/03/2021	10:55	9.83	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	08/03/2021	11:05	9.73	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	08/03/2021	13:35	10	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	08/03/2021	13:40	9.81	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	08/03/2021	12:50	9.83	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	08/03/2021	12:55	9.69	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	08/03/2021	12:35	9.86	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	08/03/2021	11:45	9.95	g/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	08/03/2021	11:50	10	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	08/03/2021	11:15	9.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	08/03/2021	11:20	9.74	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	08/03/2021	11:30	0.004	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	08/03/2021	11:35	0.0029	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	08/03/2021	10:55	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	08/03/2021	11:05	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	08/03/2021	13:35	0.0045	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	08/03/2021	13:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	08/03/2021	12:50	0.0013	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	08/03/2021	12:55	0.196	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	08/03/2021	12:35	0.0015	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	08/03/2021	11:45	0.0066	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	08/03/2021	11:50	0.0011	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	08/03/2021	11:15	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	08/03/2021	11:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	08/03/2021	11:30	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	08/03/2021	11:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	08/03/2021	10:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	08/03/2021	11:05	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	08/03/2021	13:35	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	08/03/2021	13:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	08/03/2021	12:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	08/03/2021	12:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	08/03/2021	12:35	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	08/03/2021	11:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	08/03/2021	11:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	08/03/2021	11:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	08/03/2021	11:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	08/03/2021	11:30	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	08/03/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	08/03/2021	10:55	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	08/03/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	08/03/2021	13:35	0.0012	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	08/03/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	08/03/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	08/03/2021	12:55	0.0017	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	08/03/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	08/03/2021	11:45	0.0143	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	08/03/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	08/03/2021	11:15	0.0036	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	08/03/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	08/03/2021	11:30	0.055	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	08/03/2021	11:35	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	08/03/2021	10:55	0.038	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	08/03/2021	11:05	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	08/03/2021	13:35	0.044	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	08/03/2021	13:40	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	08/03/2021	12:50	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	08/03/2021	12:55	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	08/03/2021	12:35	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	08/03/2021	11:45	0.004	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	08/03/2021	11:50	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	08/03/2021	11:15	0.862	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	08/03/2021	11:20	0.008	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	08/03/2021	13:00	136,000	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	08/03/2021	13:00	25	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	08/03/2021	13:00	0.11	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	08/03/2021	13:00	7,150	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	08/03/2021	13:00	25.3	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	08/03/2021	13:00	23,100	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	08/03/2021	13:00	6.5	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	08/03/2021	13:00	2,220	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	08/03/2021	13:00	1,580	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	08/03/2021	13:00	<0.1	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	08/03/2021	13:00	11.8	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	08/03/2021	13:00	48	mg/Kg	
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	08/03/2021	13:10	0.012	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	08/03/2021	12:40	0.016	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	08/03/2021	13:15	0.066	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	08/03/2021	13:10	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	08/03/2021	12:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	08/03/2021	13:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	08/03/2021	13:10	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	08/03/2021	12:40	<0.001	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	08/03/2021	13:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	08/03/2021	13:10	20.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	08/03/2021	12:40	20.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	08/03/2021	13:15	20.7	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	08/03/2021	13:10	<0.002	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	08/03/2021	12:40	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	08/03/2021	13:15	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	08/03/2021	13:10	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	08/03/2021	12:40	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	08/03/2021	13:15	0.4	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	08/03/2021	13:10	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	08/03/2021	12:40	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	08/03/2021	13:15	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	08/03/2021	13:10	9.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	08/03/2021	12:40	10	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	08/03/2021	13:15	10.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	08/03/2021	13:10	0.029	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	08/03/2021	12:40	0.02	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	08/03/2021	13:15	0.054	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	08/03/2021	13:10	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	08/03/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	08/03/2021	13:15	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	08/03/2021	13:10	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	08/03/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	08/03/2021	13:15	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	08/03/2021	13:10	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	08/03/2021	12:40	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	08/03/2021	13:15	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	08/03/2021	11:30	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	08/03/2021	11:35	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	08/03/2021	10:55	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	08/03/2021	11:05	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	08/03/2021	13:35	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	08/03/2021	13:40	0.011	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	08/03/2021	13:10	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	08/03/2021	12:40	0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	08/03/2021	12:50	0.008	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	08/03/2021	12:55	0.293	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	08/03/2021	12:35	0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	08/03/2021	13:15	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	08/03/2021	11:45	0.007	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	08/03/2021	11:50	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	08/03/2021	11:15	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	08/03/2021	11:20	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	08/03/2021	11:30	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	08/03/2021	11:35	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	08/03/2021	10:55	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	08/03/2021	11:05	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	08/03/2021	13:35	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	08/03/2021	13:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	08/03/2021	13:10	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	08/03/2021	12:40	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	08/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	08/03/2021	12:55	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	08/03/2021	12:35	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	08/03/2021	13:15	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	08/03/2021	11:45	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	08/03/2021	11:50	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	08/03/2021	11:15	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	08/03/2021	11:20	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	08/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	08/03/2021	11:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	08/03/2021	10:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	08/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	08/03/2021	13:35	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	08/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	08/03/2021	13:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	08/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	08/03/2021	12:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	08/03/2021	12:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	08/03/2021	12:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	08/03/2021	13:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	08/03/2021	11:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	08/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	08/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	08/03/2021	11:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	08/03/2021	11:30	21.5	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	08/03/2021	11:35	21	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	08/03/2021	10:55	22	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	08/03/2021	11:05	21.9	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	08/03/2021	13:35	21	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	08/03/2021	13:40	21.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	08/03/2021	13:10	20	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	08/03/2021	12:40	20.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	08/03/2021	12:50	21.9	g/m³		

	Waikouaiti WTP - Supernatant Tube Settler	6710 Calcium - Dissolved	08/03/2021	12:55	21.6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710 Calcium - Dissolved	08/03/2021	12:35	21.1	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710 Calcium - Dissolved	08/03/2021	13:15	20.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710 Calcium - Dissolved	08/03/2021	11:45	21	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710 Calcium - Dissolved	08/03/2021	11:50	21.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710 Calcium - Dissolved	08/03/2021	11:15	22.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710 Calcium - Dissolved	08/03/2021	11:20	22.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713 Copper - Dissolved	08/03/2021	11:30	0.005	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713 Copper - Dissolved	08/03/2021	11:35	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713 Copper - Dissolved	08/03/2021	10:55	0.0055	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713 Copper - Dissolved	08/03/2021	11:05	0.0008	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713 Copper - Dissolved	08/03/2021	13:35	0.0036	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713 Copper - Dissolved	08/03/2021	13:40	0.0007	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713 Copper - Dissolved	08/03/2021	13:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713 Copper - Dissolved	08/03/2021	12:40	0.0006	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713 Copper - Dissolved	08/03/2021	12:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6713 Copper - Dissolved	08/03/2021	12:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713 Copper - Dissolved	08/03/2021	12:35	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713 Copper - Dissolved	08/03/2021	13:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713 Copper - Dissolved	08/03/2021	11:45	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713 Copper - Dissolved	08/03/2021	11:50	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713 Copper - Dissolved	08/03/2021	11:15	0.0157	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713 Copper - Dissolved	08/03/2021	11:20	0.0037	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717 Iron - Dissolved	08/03/2021	11:30	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717 Iron - Dissolved	08/03/2021	11:35	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717 Iron - Dissolved	08/03/2021	10:55	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717 Iron - Dissolved	08/03/2021	11:05	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717 Iron - Dissolved	08/03/2021	13:35	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717 Iron - Dissolved	08/03/2021	13:40	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717 Iron - Dissolved	08/03/2021	13:10	0.11	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717 Iron - Dissolved	08/03/2021	12:40	0.06	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717 Iron - Dissolved	08/03/2021	12:50	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6717 Iron - Dissolved	08/03/2021	12:55	0.02	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717 Iron - Dissolved	08/03/2021	12:35	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717 Iron - Dissolved	08/03/2021	13:15	0.14	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717 Iron - Dissolved	08/03/2021	11:45	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717 Iron - Dissolved	08/03/2021	11:50	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717 Iron - Dissolved	08/03/2021	11:15	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717 Iron - Dissolved	08/03/2021	11:20	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718 Lead - Dissolved	08/03/2021	11:30	0.0013	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718 Lead - Dissolved	08/03/2021	11:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718 Lead - Dissolved	08/03/2021	10:55	0.0013	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718 Lead - Dissolved	08/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718 Lead - Dissolved	08/03/2021	13:35	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718 Lead - Dissolved	08/03/2021	13:40	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718 Lead - Dissolved	08/03/2021	13:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718 Lead - Dissolved	08/03/2021	12:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718 Lead - Dissolved	08/03/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6718 Lead - Dissolved	08/03/2021	12:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718 Lead - Dissolved	08/03/2021	12:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718 Lead - Dissolved	08/03/2021	13:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718 Lead - Dissolved	08/03/2021	11:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718 Lead - Dissolved	08/03/2021	11:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718 Lead - Dissolved	08/03/2021	11:15	0.028	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718 Lead - Dissolved	08/03/2021	11:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720 Magnesium - Dissolved	08/03/2021	11:30	9.99	g/m³		
	Waikouaiti SS - 192 Main Rd	6720 Magnesium - Dissolved	08/03/2021	11:35	9.72	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720 Magnesium - Dissolved	08/03/2021	10:55	9.75	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720 Magnesium - Dissolved	08/03/2021	11:05	9.61	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720 Magnesium - Dissolved	08/03/2021	13:35	9.4	g/m³		
	Karitane SS - 99 Stornoway St	6720 Magnesium - Dissolved	08/03/2021	13:40	9.69	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720 Magnesium - Dissolved	08/03/2021	13:10	9.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720 Magnesium - Dissolved	08/03/2021	12:40	9.35	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720 Magnesium - Dissolved	08/03/2021	12:50	9.92	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6720 Magnesium - Dissolved	08/03/2021	12:55	10	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720 Magnesium - Dissolved	08/03/2021	12:35	9.85	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720 Magnesium - Dissolved	08/03/2021	13:15	9.68	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720 Magnesium - Dissolved	08/03/2021	11:45	9.75	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720 Magnesium - Dissolved	08/03/2021	11:50	9.92	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720 Magnesium - Dissolved	08/03/2021	11:15	9.93	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720 Magnesium - Dissolved	08/03/2021	11:20	10	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721 Manganese - Dissolved	08/03/2021	11:30	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721 Manganese - Dissolved	08/03/2021	11:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721 Manganese - Dissolved	08/03/2021	10:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721 Manganese - Dissolved	08/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721 Manganese - Dissolved	08/03/2021	13:35	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721 Manganese - Dissolved	08/03/2021	13:40	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721 Manganese - Dissolved	08/03/2021	13:10	0.0196	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721 Manganese - Dissolved	08/03/2021	12:40	0.0018	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721 Manganese - Dissolved	08/03/2021	12:50	0.0013	g/m³	(.4 - .4)	

	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	08/03/2021	12:55	0.0016	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	08/03/2021	12:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	08/03/2021	13:15	0.0173	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	08/03/2021	11:45	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	08/03/2021	11:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	08/03/2021	11:15	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	08/03/2021	11:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	08/03/2021	11:30	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	08/03/2021	11:35	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	08/03/2021	10:55	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	08/03/2021	11:05	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	08/03/2021	13:35	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	08/03/2021	13:40	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	08/03/2021	13:10	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	08/03/2021	12:40	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	08/03/2021	12:50	<0.0005	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	08/03/2021	12:55	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	08/03/2021	12:35	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	08/03/2021	13:15	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	08/03/2021	11:45	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	08/03/2021	11:50	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	08/03/2021	11:15	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	08/03/2021	11:20	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	08/03/2021	11:30	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	08/03/2021	11:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	08/03/2021	10:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	08/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	08/03/2021	13:35	0.0008	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	08/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	08/03/2021	13:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	08/03/2021	12:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	08/03/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	08/03/2021	12:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	08/03/2021	12:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	08/03/2021	13:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	08/03/2021	11:45	0.0129	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	08/03/2021	11:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	08/03/2021	11:15	0.0034	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	08/03/2021	11:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	08/03/2021	11:30	0.054	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	08/03/2021	11:35	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	08/03/2021	10:55	0.037	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	08/03/2021	11:05	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	08/03/2021	13:35	0.041	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	08/03/2021	13:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	08/03/2021	13:10	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	08/03/2021	12:40	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	08/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	08/03/2021	12:55	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	08/03/2021	12:35	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	08/03/2021	13:15	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	08/03/2021	11:45	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	08/03/2021	11:50	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	08/03/2021	11:15	0.885	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	08/03/2021	11:20	0.006	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	08/03/2021	11:30	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	08/03/2021	11:35	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	08/03/2021	10:55	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	08/03/2021	11:05	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	08/03/2021	13:35	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	08/03/2021	13:40	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	08/03/2021	13:10	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	08/03/2021	12:40	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	08/03/2021	12:50	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	08/03/2021	12:55	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	08/03/2021	12:35	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	08/03/2021	13:15	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	08/03/2021	11:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	08/03/2021	11:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	08/03/2021	11:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	08/03/2021	11:20	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:30	6.5	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:35	5.5	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	08/03/2021	10:55	6.4	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:05	5.5	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	08/03/2021	13:35	7	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	08/03/2021	13:40	6.6	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	08/03/2021	13:10	7.5	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	08/03/2021	12:40	6.7	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	08/03/2021	12:50	6.8	g O2/m³		

	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	08/03/2021	12:55	6.5	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	08/03/2021	12:35	7.4	g O2/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	08/03/2021	13:15	7.8	g O2/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:45	7	g O2/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:50	6.6	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:15	6.4	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	08/03/2021	11:20	5.8	g O2/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	08/03/2021	11:30	0.74	g/m³		(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	08/03/2021	11:35	0.92	g/m³		(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	08/03/2021	10:55	0.41	g/m³		(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	08/03/2021	11:05	0.36	g/m³		(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	08/03/2021	13:35	0.61	g/m³		(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	08/03/2021	13:40	0.66	g/m³		(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	08/03/2021	12:50	<0.05	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	08/03/2021	12:55	0.16	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	08/03/2021	12:35	0.84	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	08/03/2021	11:45	0.65	g/m³		(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	08/03/2021	11:50	0.8	g/m³		(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	08/03/2021	11:15	0.59	g/m³		(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	08/03/2021	11:20	0.81	g/m³		(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	08/03/2021	11:30	0.9	g/m³			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	08/03/2021	11:35	1	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	08/03/2021	10:55	0.6	g/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	08/03/2021	11:05	0.5	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	08/03/2021	13:35	0.7	g/m³			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	08/03/2021	13:40	1	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	08/03/2021	12:50	<0.05	g/m³			
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	08/03/2021	12:55	0.2	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	08/03/2021	12:35	1	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	08/03/2021	11:45	0.8	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	08/03/2021	11:50	1	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	08/03/2021	11:15	0.7	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	08/03/2021	11:20	0.9	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	08/03/2021	11:30	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	08/03/2021	10:55	<1	MPN/100mL		(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	08/03/2021	11:05	<1	MPN/100mL		(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	08/03/2021	10:55	<1	MPN/100ml		(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	08/03/2021	11:05	<1	MPN/100ml		(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/03/2021	13:10	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/03/2021	12:40	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	08/03/2021	13:15	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	08/03/2021	11:30	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	08/03/2021	11:35	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	08/03/2021	10:55	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	08/03/2021	11:05	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	08/03/2021	13:35	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	08/03/2021	13:40	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	08/03/2021	13:10	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	08/03/2021	12:40	Completed				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	08/03/2021	12:50	Completed				
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	08/03/2021	12:55	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	08/03/2021	12:35	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	08/03/2021	13:15	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	08/03/2021	11:45	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	08/03/2021	11:50	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	08/03/2021	11:15	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	08/03/2021	11:20	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	08/03/2021	13:00	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	09/03/2021	13:17	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	09/03/2021	13:22	7.9			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	09/03/2021	12:24	7.9			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	09/03/2021	12:30	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	09/03/2021	11:26	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	09/03/2021	11:35	8			(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	09/03/2021	14:35	8.2			(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	09/03/2021	14:05	8			(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	09/03/2021	14:03	8.1			(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	09/03/2021	14:40	8.2			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	09/03/2021	13:32	8.1			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	09/03/2021	13:40	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	09/03/2021	12:04	8.1			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	09/03/2021	12:08	8			(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	09/03/2021	13:17	<6	g/m³			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	09/03/2021	13:22	<6	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	09/03/2021	12:24	<6	g/m³			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	09/03/2021	12:30	<6	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	09/03/2021	11:26	<6	g/m³			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	09/03/2021	11:35	<6	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	09/03/2021	14:35	<6	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	09/03/2021	14:05	<6	g/m³			

	Waikouaiti WTP - Post Treated Water Reservoir		2	Suspended Solids - Total	09/03/2021	14:03	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		2	Suspended Solids - Total	09/03/2021	14:40	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2	Suspended Solids - Total	09/03/2021	13:32	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		2	Suspended Solids - Total	09/03/2021	13:40	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2	Suspended Solids - Total	09/03/2021	12:04	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		2	Suspended Solids - Total	09/03/2021	12:08	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		52	Alkalinity - Total	09/03/2021	13:17	69	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd		52	Alkalinity - Total	09/03/2021	13:22	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		52	Alkalinity - Total	09/03/2021	12:24	71	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St		52	Alkalinity - Total	09/03/2021	12:30	69	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush		52	Alkalinity - Total	09/03/2021	11:26	71	g CaCO3/m³		
	Karitane SS - 99 Stornoway St		52	Alkalinity - Total	09/03/2021	11:35	71	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake		52	Alkalinity - Total	09/03/2021	14:35	72	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	09/03/2021	14:05	70	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	09/03/2021	14:03	71	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		52	Alkalinity - Total	09/03/2021	14:40	71	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52	Alkalinity - Total	09/03/2021	13:32	72	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		52	Alkalinity - Total	09/03/2021	13:40	71	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52	Alkalinity - Total	09/03/2021	12:04	75	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	09/03/2021	12:08	71	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D		Dissolved Inorganic Carbon	09/03/2021	13:17	19.8	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D		Dissolved Inorganic Carbon	09/03/2021	13:22	19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D		Dissolved Inorganic Carbon	09/03/2021	12:24	20.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D		Dissolved Inorganic Carbon	09/03/2021	12:30	20.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D		Dissolved Inorganic Carbon	09/03/2021	11:26	19.8	g/m³		
	Karitane SS - 99 Stornoway St	0440D		Dissolved Inorganic Carbon	09/03/2021	11:35	20.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D		Dissolved Inorganic Carbon	09/03/2021	14:35	19.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D		Dissolved Inorganic Carbon	09/03/2021	14:05	19.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D		Dissolved Inorganic Carbon	09/03/2021	14:03	20	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D		Dissolved Inorganic Carbon	09/03/2021	14:40	19.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D		Dissolved Inorganic Carbon	09/03/2021	13:32	20.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D		Dissolved Inorganic Carbon	09/03/2021	13:40	19.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D		Dissolved Inorganic Carbon	09/03/2021	12:04	20.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D		Dissolved Inorganic Carbon	09/03/2021	12:08	20.1	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		602	Chloride - Add P1859 Filtration	09/03/2021	13:17	16.2	g/m³		
	Waikouaiti SS - 192 Main Rd		602	Chloride - Add P1859 Filtration	09/03/2021	13:22	16.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		602	Chloride - Add P1859 Filtration	09/03/2021	12:24	16.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St		602	Chloride - Add P1859 Filtration	09/03/2021	12:30	16.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		602	Chloride - Add P1859 Filtration	09/03/2021	11:26	16.4	g/m³		
	Karitane SS - 99 Stornoway St		602	Chloride - Add P1859 Filtration	09/03/2021	11:35	16.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		602	Chloride - Add P1859 Filtration	09/03/2021	14:35	13.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		602	Chloride - Add P1859 Filtration	09/03/2021	14:05	13.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		602	Chloride - Add P1859 Filtration	09/03/2021	14:03	16.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		602	Chloride - Add P1859 Filtration	09/03/2021	14:40	13.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		602	Chloride - Add P1859 Filtration	09/03/2021	13:32	15.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		602	Chloride - Add P1859 Filtration	09/03/2021	13:40	16.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		602	Chloride - Add P1859 Filtration	09/03/2021	12:04	16.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		602	Chloride - Add P1859 Filtration	09/03/2021	12:08	16.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		607	Sulphate - Add P1859 Filtration	09/03/2021	13:17	23.2	g/m³		
	Waikouaiti SS - 192 Main Rd		607	Sulphate - Add P1859 Filtration	09/03/2021	13:22	22.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		607	Sulphate - Add P1859 Filtration	09/03/2021	12:24	23.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St		607	Sulphate - Add P1859 Filtration	09/03/2021	12:30	23.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		607	Sulphate - Add P1859 Filtration	09/03/2021	11:26	23.3	g/m³		
	Karitane SS - 99 Stornoway St		607	Sulphate - Add P1859 Filtration	09/03/2021	11:35	22.9	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		607	Sulphate - Add P1859 Filtration	09/03/2021	14:35	22.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		607	Sulphate - Add P1859 Filtration	09/03/2021	14:05	22.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		607	Sulphate - Add P1859 Filtration	09/03/2021	14:03	22.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		607	Sulphate - Add P1859 Filtration	09/03/2021	14:40	22	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		607	Sulphate - Add P1859 Filtration	09/03/2021	13:32	23.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		607	Sulphate - Add P1859 Filtration	09/03/2021	13:40	23.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		607	Sulphate - Add P1859 Filtration	09/03/2021	12:04	23.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		607	Sulphate - Add P1859 Filtration	09/03/2021	12:08	23.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		1024	Total Dissolved Solids by Evaporation	09/03/2021	13:17	135	g/m³		
	Waikouaiti SS - 192 Main Rd		1024	Total Dissolved Solids by Evaporation	09/03/2021	13:22	136	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		1024	Total Dissolved Solids by Evaporation	09/03/2021	12:24	140	g/m³		
	Waikouaiti SS - 210 Edinburgh St		1024	Total Dissolved Solids by Evaporation	09/03/2021	12:30	143	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		1024	Total Dissolved Solids by Evaporation	09/03/2021	11:26	147	g/m³		
	Karitane SS - 99 Stornoway St		1024	Total Dissolved Solids by Evaporation	09/03/2021	11:35	157	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		1024	Total Dissolved Solids by Evaporation	09/03/2021	14:35	138	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		1024	Total Dissolved Solids by Evaporation	09/03/2021	14:05	142	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		1024	Total Dissolved Solids by Evaporation	09/03/2021	14:03	157	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		1024	Total Dissolved Solids by Evaporation	09/03/2021	14:40	133	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		1024	Total Dissolved Solids by Evaporation	09/03/2021	13:32	149	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		1024	Total Dissolved Solids by Evaporation	09/03/2021	13:40	147	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		1024	Total Dissolved Solids by Evaporation	09/03/2021	12:04	139	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		1024	Total Dissolved Solids by Evaporation	09/03/2021	12:08	138	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		1214	Surcharge Fee	09/03/2021	13:17	$100			
	Waikouaiti SS - 192 Main Rd - Preflush		6001	Aluminium - Acid Soluble	09/03/2021	13:17	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd		6001	Aluminium - Acid Soluble	09/03/2021	13:22	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		6001	Aluminium - Acid Soluble	09/03/2021	12:24	0.012	g/m³		

	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	09/03/2021	12:30	0.012	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	09/03/2021	11:26	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	09/03/2021	11:35	0.012	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	09/03/2021	14:03	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	09/03/2021	13:32	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	09/03/2021	13:40	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	09/03/2021	12:04	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	09/03/2021	12:08	0.022	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	09/03/2021	13:17	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	09/03/2021	13:22	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	09/03/2021	12:24	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	09/03/2021	12:30	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	09/03/2021	11:26	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	09/03/2021	11:35	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	09/03/2021	14:03	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	09/03/2021	13:32	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	09/03/2021	13:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	09/03/2021	12:04	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	09/03/2021	12:08	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	09/03/2021	13:17	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	09/03/2021	13:22	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	09/03/2021	12:24	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	09/03/2021	12:30	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	09/03/2021	11:26	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	09/03/2021	11:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	09/03/2021	14:03	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	09/03/2021	13:32	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	09/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	09/03/2021	12:04	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	09/03/2021	12:08	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	09/03/2021	13:17	21.3	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	09/03/2021	13:22	22.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	09/03/2021	12:24	22.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	09/03/2021	12:30	22.1	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	09/03/2021	11:26	22.2	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	09/03/2021	11:35	22.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	09/03/2021	14:03	21.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	09/03/2021	13:32	22.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	09/03/2021	13:40	22.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	09/03/2021	12:04	23	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	09/03/2021	12:08	22.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	09/03/2021	13:17	0.0016	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	09/03/2021	13:22	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	09/03/2021	12:24	0.0026	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	09/03/2021	12:30	0.0014	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	09/03/2021	11:26	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	09/03/2021	11:35	0.0007	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	09/03/2021	14:03	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	09/03/2021	13:32	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	09/03/2021	13:40	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	09/03/2021	12:04	0.0059	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	09/03/2021	12:08	0.0035	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	09/03/2021	13:17	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	09/03/2021	13:22	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	09/03/2021	12:24	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	09/03/2021	12:30	0.03	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	09/03/2021	11:26	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	09/03/2021	11:35	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	09/03/2021	14:03	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	09/03/2021	13:32	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	09/03/2021	13:40	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	09/03/2021	12:04	0.02	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	09/03/2021	12:08	0.03	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	09/03/2021	13:17	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	09/03/2021	13:22	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	09/03/2021	12:24	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	09/03/2021	12:30	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	09/03/2021	11:26	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	09/03/2021	11:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	09/03/2021	14:03	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	09/03/2021	13:32	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	09/03/2021	13:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	09/03/2021	12:04	0.0023	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	09/03/2021	12:08	0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	09/03/2021	13:17	9.64	g/m³		
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	09/03/2021	13:22	9.97	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	09/03/2021	12:24	9.93	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	09/03/2021	12:30	9.92	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	09/03/2021	11:26	9.86	g/m³		
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	09/03/2021	11:35	9.95	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	09/03/2021	14:03	9.99	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	09/03/2021	13:32	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	09/03/2021	13:40	10	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	09/03/2021	12:04	10.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	09/03/2021	12:08	9.92	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	09/03/2021	13:17	0.0024	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	09/03/2021	13:22	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	09/03/2021	12:24	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	09/03/2021	12:30	0.029	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	09/03/2021	11:26	0.0006	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	09/03/2021	11:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	09/03/2021	14:03	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	09/03/2021	13:32	0.002	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	09/03/2021	13:40	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	09/03/2021	12:04	0.0015	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	09/03/2021	12:08	0.0344	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	09/03/2021	13:17	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	09/03/2021	13:22	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	09/03/2021	12:24	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	09/03/2021	12:30	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	09/03/2021	11:26	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	09/03/2021	11:35	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	09/03/2021	14:03	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	09/03/2021	13:32	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	09/03/2021	13:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	09/03/2021	12:04	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	09/03/2021	12:08	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	09/03/2021	13:17	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	09/03/2021	13:22	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	09/03/2021	12:24	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	09/03/2021	12:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	09/03/2021	11:26	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	09/03/2021	11:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024 Nickel - Acid Soluble	09/03/2021	14:03	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024 Nickel - Acid Soluble	09/03/2021	13:32	0.0009	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024 Nickel - Acid Soluble	09/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024 Nickel - Acid Soluble	09/03/2021	12:04	0.013	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024 Nickel - Acid Soluble	09/03/2021	12:08	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038 Zinc - Acid Soluble	09/03/2021	13:17	0.002	g/m³		
	Waikouaiti SS - 192 Main Rd	6038 Zinc - Acid Soluble	09/03/2021	13:22	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038 Zinc - Acid Soluble	09/03/2021	12:24	0.007	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038 Zinc - Acid Soluble	09/03/2021	12:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038 Zinc - Acid Soluble	09/03/2021	11:26	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6038 Zinc - Acid Soluble	09/03/2021	11:35	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038 Zinc - Acid Soluble	09/03/2021	14:03	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038 Zinc - Acid Soluble	09/03/2021	13:32	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038 Zinc - Acid Soluble	09/03/2021	13:40	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038 Zinc - Acid Soluble	09/03/2021	12:04	0.049	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038 Zinc - Acid Soluble	09/03/2021	12:08	0.008	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201 Aluminium - Total	09/03/2021	14:20	153,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203 Arsenic - Total	09/03/2021	14:20	35.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208 Cadmium - Total	09/03/2021	14:20	0.06	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210 Calcium - Total	09/03/2021	14:20	6,480	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213 Copper - Total	09/03/2021	14:20	21.9	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217 Iron - Total	09/03/2021	14:20	20,900	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218 Lead - Total	09/03/2021	14:20	3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220 Magnesium - Total	09/03/2021	14:20	203	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221 Manganese - Total	09/03/2021	14:20	1,210	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222 Mercury - Total	09/03/2021	14:20	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224 Nickel - Total	09/03/2021	14:20	9.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238 Zinc - Total	09/03/2021	14:20	32	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601 Aluminium - Total	09/03/2021	14:35	0.016	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601 Aluminium - Total	09/03/2021	14:05	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601 Aluminium - Total	09/03/2021	14:40	0.013	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603 Arsenic - Total	09/03/2021	14:35	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603 Arsenic - Total	09/03/2021	14:05	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603 Arsenic - Total	09/03/2021	14:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608 Cadmium - Total	09/03/2021	14:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608 Cadmium - Total	09/03/2021	14:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608 Cadmium - Total	09/03/2021	14:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610 Calcium - Total	09/03/2021	14:35	20.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610 Calcium - Total	09/03/2021	14:05	20.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610 Calcium - Total	09/03/2021	14:40	20.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613 Copper - Total	09/03/2021	14:35	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613 Copper - Total	09/03/2021	14:05	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613 Copper - Total	09/03/2021	14:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617 Iron - Total	09/03/2021	14:35	0.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617 Iron - Total	09/03/2021	14:05	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617 Iron - Total	09/03/2021	14:40	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618 Lead - Total	09/03/2021	14:35	<0.001	g/m³	(.005 - .01)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	09/03/2021	14:05	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	09/03/2021	14:40	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	09/03/2021	14:35	10.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	09/03/2021	14:05	10.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	09/03/2021	14:40	10.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	09/03/2021	14:35	0.028	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	09/03/2021	14:05	0.02	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	09/03/2021	14:40	0.029	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	09/03/2021	14:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	09/03/2021	14:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	09/03/2021	14:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	09/03/2021	14:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	09/03/2021	14:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	09/03/2021	14:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	09/03/2021	14:35	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	09/03/2021	14:05	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	09/03/2021	14:40	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	09/03/2021	13:17	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	09/03/2021	13:22	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	09/03/2021	12:24	0.013	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	09/03/2021	12:30	0.009	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	09/03/2021	11:26	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	09/03/2021	11:35	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	09/03/2021	14:35	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	09/03/2021	14:05	0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	09/03/2021	14:03	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	09/03/2021	14:40	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	09/03/2021	13:32	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	09/03/2021	13:40	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	09/03/2021	12:04	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	09/03/2021	12:08	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	09/03/2021	13:17	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	09/03/2021	13:22	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	09/03/2021	12:24	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	09/03/2021	12:30	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	09/03/2021	11:26	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	09/03/2021	11:35	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	09/03/2021	14:35	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	09/03/2021	14:05	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	09/03/2021	14:03	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	09/03/2021	14:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	09/03/2021	13:32	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	09/03/2021	13:40	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	09/03/2021	12:04	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	09/03/2021	12:08	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	09/03/2021	13:17	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	09/03/2021	13:22	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	09/03/2021	12:24	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	09/03/2021	12:30	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	09/03/2021	11:26	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	09/03/2021	11:35	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	09/03/2021	14:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	09/03/2021	14:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	09/03/2021	14:03	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	09/03/2021	14:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	09/03/2021	13:32	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	09/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	09/03/2021	12:04	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	09/03/2021	12:08	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	09/03/2021	13:17	22.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	09/03/2021	13:22	21.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	09/03/2021	12:24	23.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	09/03/2021	12:30	22.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	09/03/2021	11:26	22.9	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	09/03/2021	11:35	22.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	09/03/2021	14:35	21.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	09/03/2021	14:05	21.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	09/03/2021	14:03	21.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	09/03/2021	14:40	21.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	09/03/2021	13:32	22.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	09/03/2021	13:40	22	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	09/03/2021	12:04	22.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	09/03/2021	12:08	22.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	09/03/2021	13:17	0.0015	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	09/03/2021	13:22	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	09/03/2021	12:24	0.0017	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	09/03/2021	12:30	0.0008	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	09/03/2021	11:26	0.001	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	09/03/2021	11:35	0.0014	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	09/03/2021	14:35	<0.0005	g/m³	(2 - 2)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	09/03/2021	14:05	0.0011	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	09/03/2021	14:03	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	09/03/2021	14:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	09/03/2021	13:32	0.001	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	09/03/2021	13:40	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	09/03/2021	12:04	0.0403	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	09/03/2021	12:08	0.0021	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	09/03/2021	13:17	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	09/03/2021	13:22	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	09/03/2021	12:24	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	09/03/2021	12:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	09/03/2021	11:26	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	09/03/2021	11:35	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	09/03/2021	14:35	0.08	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	09/03/2021	14:05	0.07	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	09/03/2021	14:03	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	09/03/2021	14:40	0.08	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	09/03/2021	13:32	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	09/03/2021	13:40	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	09/03/2021	12:04	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	09/03/2021	12:08	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	09/03/2021	13:17	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	09/03/2021	13:22	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	09/03/2021	12:24	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	09/03/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	09/03/2021	11:26	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	09/03/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	09/03/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	09/03/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	09/03/2021	14:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	09/03/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	09/03/2021	13:32	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	09/03/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	09/03/2021	12:04	0.0427	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	09/03/2021	12:08	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	09/03/2021	13:17	10.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	09/03/2021	13:22	10	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	09/03/2021	12:24	10.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	09/03/2021	12:30	10.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	09/03/2021	11:26	10.1	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	09/03/2021	11:35	9.96	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	09/03/2021	14:35	9.83	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	09/03/2021	14:05	9.86	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	09/03/2021	14:03	9.95	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	09/03/2021	14:40	9.76	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	09/03/2021	13:32	10.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	09/03/2021	13:40	9.89	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	09/03/2021	12:04	9.94	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	09/03/2021	12:08	9.86	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	09/03/2021	13:17	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	09/03/2021	13:22	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	09/03/2021	12:24	0.0011	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	09/03/2021	12:30	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	09/03/2021	11:26	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	09/03/2021	11:35	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	09/03/2021	14:35	0.0197	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	09/03/2021	14:05	0.0033	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	09/03/2021	14:03	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	09/03/2021	14:40	0.0196	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	09/03/2021	13:32	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	09/03/2021	13:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	09/03/2021	12:04	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	09/03/2021	12:08	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	09/03/2021	13:17	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	09/03/2021	13:22	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	09/03/2021	12:24	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	09/03/2021	12:30	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	09/03/2021	11:26	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	09/03/2021	11:35	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	09/03/2021	14:35	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	09/03/2021	14:05	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	09/03/2021	14:03	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	09/03/2021	14:40	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	09/03/2021	13:32	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	09/03/2021	13:40	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	09/03/2021	12:04	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	09/03/2021	12:08	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	09/03/2021	13:17	0.0018	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	09/03/2021	13:22	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	09/03/2021	12:24	0.0052	g/m³	(.08 - .08)

	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	09/03/2021	12:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	09/03/2021	11:26	0.002	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	09/03/2021	11:35	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	09/03/2021	14:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	09/03/2021	14:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	09/03/2021	14:03	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	09/03/2021	14:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	09/03/2021	13:32	0.0074	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	09/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	09/03/2021	12:04	0.007	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	09/03/2021	12:08	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	09/03/2021	13:17	<0.002	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	09/03/2021	13:22	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	09/03/2021	12:24	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	09/03/2021	12:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	09/03/2021	11:26	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	09/03/2021	11:35	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	09/03/2021	14:35	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	09/03/2021	14:05	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	09/03/2021	14:03	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	09/03/2021	14:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	09/03/2021	13:32	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	09/03/2021	13:40	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	09/03/2021	12:04	0.885	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	09/03/2021	12:08	0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	09/03/2021	13:17	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	09/03/2021	13:22	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	09/03/2021	12:24	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	09/03/2021	12:30	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	09/03/2021	11:26	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	09/03/2021	11:35	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	09/03/2021	14:35	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	09/03/2021	14:05	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	09/03/2021	14:03	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	09/03/2021	14:40	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	09/03/2021	13:32	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	09/03/2021	13:40	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	09/03/2021	12:04	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	09/03/2021	12:08	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	09/03/2021	13:17	6.5	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	09/03/2021	13:22	7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	09/03/2021	12:24	6.9	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	09/03/2021	12:30	6.3	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	09/03/2021	11:26	6.4	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	09/03/2021	11:35	6.9	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	09/03/2021	14:35	7.5	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	09/03/2021	14:05	6.9	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	09/03/2021	14:03	6.8	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	09/03/2021	14:40	7.3	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	09/03/2021	13:32	7	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	09/03/2021	13:40	7.3	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	09/03/2021	12:04	7.4	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	09/03/2021	12:08	8.6	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	09/03/2021	13:17	0.91	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	09/03/2021	13:22	0.92	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	09/03/2021	12:24	0.59	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	09/03/2021	12:30	0.64	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	09/03/2021	11:26	0.77	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	09/03/2021	11:35	0.87	g/m³	(.2 - 5)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	09/03/2021	14:03	0.94	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	09/03/2021	13:32	0.87	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	09/03/2021	13:40	0.91	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	09/03/2021	12:04	0.79	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	09/03/2021	12:08	0.8	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	09/03/2021	13:17	1	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	09/03/2021	13:22	1.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	09/03/2021	12:24	0.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	09/03/2021	12:30	0.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	09/03/2021	11:26	0.9	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	09/03/2021	11:35	1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	09/03/2021	14:03	1.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	09/03/2021	13:32	1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	09/03/2021	13:40	1.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	09/03/2021	12:04	0.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	09/03/2021	12:08	0.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	09/03/2021	13:17	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/03/2021	12:24	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/03/2021	12:30	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/03/2021	12:24	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/03/2021	12:30	<1	MPN/100ml	(0 - 0)	

	Waikouaiti WTP - Containerised Plant Filtrate	O1420		Sampler Observation	09/03/2021	14:14	No		Water Plant off		
	Waikouaiti WTP - Supernatant Tube Settler	O1420		Sampler Observation	09/03/2021	14:12	No		Water Plant off		
	Catchment - Waikouaiti River - Pump Station Intake	P1855		Aqueous Total Metal Digestion for ICPMS codes	09/03/2021	14:35	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855		Aqueous Total Metal Digestion for ICPMS codes	09/03/2021	14:05	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855		Aqueous Total Metal Digestion for ICPMS codes	09/03/2021	14:40	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859		Sample Filtration	09/03/2021	13:17	Completed				
	Waikouaiti SS - 192 Main Rd	P1859		Sample Filtration	09/03/2021	13:22	Completed				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859		Sample Filtration	09/03/2021	12:24	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859		Sample Filtration	09/03/2021	12:30	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859		Sample Filtration	09/03/2021	11:26	Completed				
	Karitane SS - 99 Stornoway St	P1859		Sample Filtration	09/03/2021	11:35	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859		Sample Filtration	09/03/2021	14:35	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859		Sample Filtration	09/03/2021	14:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859		Sample Filtration	09/03/2021	14:03	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859		Sample Filtration	09/03/2021	14:40	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859		Sample Filtration	09/03/2021	13:32	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859		Sample Filtration	09/03/2021	13:40	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859		Sample Filtration	09/03/2021	12:04	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859		Sample Filtration	09/03/2021	12:08	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861		Metals Digestion - Soil/Sludge	09/03/2021	14:20	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush		1	pH	10/03/2021	13:40	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd		1	pH	10/03/2021	13:45	7.8			(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush		1	pH	10/03/2021	13:00	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St		1	pH	10/03/2021	13:05	7.9			(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake		1	pH	10/03/2021	12:45	7.9			(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		1	pH	10/03/2021	12:25	7.9			(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate		1	pH	10/03/2021	12:10	7.9			(1 - 14)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler		1	pH	10/03/2021	12:05	7.9			(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir		1	pH	10/03/2021	12:15	7.8			(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream		1	pH	10/03/2021	12:40	7.9			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		1	pH	10/03/2021	13:20	7.9			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St		1	pH	10/03/2021	13:25	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		1	pH	10/03/2021	14:50	8			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd		1	pH	10/03/2021	14:55	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush		2	Suspended Solids - Total	10/03/2021	13:40	<6		g/m³		
	Waikouaiti SS - 192 Main Rd		2	Suspended Solids - Total	10/03/2021	13:45	<6		g/m³		
	Karitane SS - 99 Stornoway St - Preflush		2	Suspended Solids - Total	10/03/2021	13:00	<6		g/m³		
	Karitane SS - 99 Stornoway St		2	Suspended Solids - Total	10/03/2021	13:05	<6		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		2	Suspended Solids - Total	10/03/2021	12:45	<6		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		2	Suspended Solids - Total	10/03/2021	12:25	<6		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		2	Suspended Solids - Total	10/03/2021	12:10	<6		g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler		2	Suspended Solids - Total	10/03/2021	12:05	83		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		2	Suspended Solids - Total	10/03/2021	12:15	<6		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		2	Suspended Solids - Total	10/03/2021	12:40	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2	Suspended Solids - Total	10/03/2021	13:20	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		2	Suspended Solids - Total	10/03/2021	13:25	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2	Suspended Solids - Total	10/03/2021	14:50	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd		2	Suspended Solids - Total	10/03/2021	14:55	<6		g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		52	Alkalinity - Total	10/03/2021	13:40	74		g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd		52	Alkalinity - Total	10/03/2021	13:45	71		g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush		52	Alkalinity - Total	10/03/2021	13:00	73		g CaCO3/m³		
	Karitane SS - 99 Stornoway St		52	Alkalinity - Total	10/03/2021	13:05	73		g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake		52	Alkalinity - Total	10/03/2021	12:45	71		g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	10/03/2021	12:25	72		g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		52	Alkalinity - Total	10/03/2021	12:10	72		g CaCO3/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler		52	Alkalinity - Total	10/03/2021	12:05	76		g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	10/03/2021	12:15	72		g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		52	Alkalinity - Total	10/03/2021	12:40	72		g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52	Alkalinity - Total	10/03/2021	13:20	74		g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		52	Alkalinity - Total	10/03/2021	13:25	73		g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52	Alkalinity - Total	10/03/2021	14:50	79		g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	10/03/2021	14:55	70		g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D		Dissolved Inorganic Carbon	10/03/2021	13:40	19.9		g/m³		
	Waikouaiti SS - 192 Main Rd	0440D		Dissolved Inorganic Carbon	10/03/2021	13:45	19.8		g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D		Dissolved Inorganic Carbon	10/03/2021	13:00	20		g/m³		
	Karitane SS - 99 Stornoway St	0440D		Dissolved Inorganic Carbon	10/03/2021	13:05	19.8		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D		Dissolved Inorganic Carbon	10/03/2021	12:45	19.8		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D		Dissolved Inorganic Carbon	10/03/2021	12:25	19.7		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D		Dissolved Inorganic Carbon	10/03/2021	12:10	19.2		g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	0440D		Dissolved Inorganic Carbon	10/03/2021	12:05	19.2		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D		Dissolved Inorganic Carbon	10/03/2021	12:15	19.4		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D		Dissolved Inorganic Carbon	10/03/2021	12:40	9.6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D		Dissolved Inorganic Carbon	10/03/2021	13:20	19.7		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D		Dissolved Inorganic Carbon	10/03/2021	13:25	20		g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D		Dissolved Inorganic Carbon	10/03/2021	14:50	19.8		g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D		Dissolved Inorganic Carbon	10/03/2021	14:55	19.8		g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		602	Chloride - Add P1859 Filtration	10/03/2021	13:40	16.5		g/m³		
	Waikouaiti SS - 192 Main Rd		602	Chloride - Add P1859 Filtration	10/03/2021	13:45	16.4		g/m³		
	Karitane SS - 99 Stornoway St - Preflush		602	Chloride - Add P1859 Filtration	10/03/2021	13:00	16.5		g/m³		
	Karitane SS - 99 Stornoway St		602	Chloride - Add P1859 Filtration	10/03/2021	13:05	16.5		g/m³		

	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	10/03/2021	12:45	13.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	10/03/2021	12:25	13.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	10/03/2021	12:10	14.5	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	10/03/2021	12:05	14.6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	10/03/2021	12:15	14.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	10/03/2021	12:40	13.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	10/03/2021	13:20	16.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	10/03/2021	13:25	16.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	10/03/2021	14:50	16.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	10/03/2021	14:55	16.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	10/03/2021	13:40	23.4	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	10/03/2021	13:45	23.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	10/03/2021	13:00	23.1	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	10/03/2021	13:05	23.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	10/03/2021	12:45	21.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	10/03/2021	12:25	22.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	10/03/2021	12:10	22.4	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	10/03/2021	12:05	23.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	10/03/2021	12:15	22.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	10/03/2021	12:40	21.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	10/03/2021	13:20	23.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	10/03/2021	13:25	23.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	10/03/2021	14:50	23.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	10/03/2021	14:55	23.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:40	136	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:45	135	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:00	130	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:05	136	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:45	124	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:25	128	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:10	139	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:05	137	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:15	120	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	10/03/2021	12:40	125	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:20	145	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	10/03/2021	13:25	135	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	10/03/2021	14:50	145	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	10/03/2021	14:55	127	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	10/03/2021	13:40	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	10/03/2021	13:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	10/03/2021	13:45	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	10/03/2021	13:00	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	10/03/2021	13:05	0.012	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	10/03/2021	12:10	0.007	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	10/03/2021	12:05	17.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	10/03/2021	12:15	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	10/03/2021	13:20	0.013	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	10/03/2021	13:25	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	10/03/2021	14:50	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	10/03/2021	14:55	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	10/03/2021	13:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	10/03/2021	13:45	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	10/03/2021	13:00	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	10/03/2021	13:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	10/03/2021	12:10	<0.001	g/m³	(.01 - .01)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	10/03/2021	12:05	0.003	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	10/03/2021	12:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	10/03/2021	13:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	10/03/2021	13:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	10/03/2021	14:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	10/03/2021	14:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	10/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	10/03/2021	13:45	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	10/03/2021	13:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	10/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	10/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	10/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	10/03/2021	12:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	10/03/2021	13:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	10/03/2021	13:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	10/03/2021	14:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	10/03/2021	14:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	10/03/2021	13:40	22.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	10/03/2021	13:45	22.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	10/03/2021	13:00	22.5	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	10/03/2021	13:05	22.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	10/03/2021	12:10	21.9	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	10/03/2021	12:05	22.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	10/03/2021	12:15	22.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	10/03/2021	13:20	22.5	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	10/03/2021	13:25	22	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	10/03/2021	14:50	22.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	10/03/2021	14:55	22.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	10/03/2021	13:40	0.0019	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	10/03/2021	13:45	0.0017	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	10/03/2021	13:00	0.0007	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	10/03/2021	13:05	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	10/03/2021	12:10	<0.0005	g/m³	(2 - 2)
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6013 Copper - Acid Soluble	10/03/2021	12:05	0.0024	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	10/03/2021	12:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	10/03/2021	13:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	10/03/2021	13:25	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	10/03/2021	14:50	0.0055	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	10/03/2021	14:55	0.0039	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	10/03/2021	13:40	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	10/03/2021	13:45	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	10/03/2021	13:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	10/03/2021	13:05	<0.01	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	10/03/2021	12:10	<0.01	g/m³	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6017 Iron - Acid Soluble	10/03/2021	12:05	2.04	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	10/03/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	10/03/2021	13:20	0.02	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	10/03/2021	13:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	10/03/2021	14:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	10/03/2021	14:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	10/03/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	10/03/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	10/03/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	10/03/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	10/03/2021	12:10	<0.0005	g/m³	(.005 - .01)
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6018 Lead - Acid Soluble	10/03/2021	12:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	10/03/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	10/03/2021	13:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	10/03/2021	13:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	10/03/2021	14:50	0.0022	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	10/03/2021	14:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	10/03/2021	13:40	10.3	g/m³	
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	10/03/2021	13:45	10.2	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	10/03/2021	13:00	10	g/m³	
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	10/03/2021	13:05	10	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	10/03/2021	12:10	10.1	g/m³	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6020 Magnesium - Acid Soluble	10/03/2021	12:05	10	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	10/03/2021	12:15	10.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	10/03/2021	13:20	10.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	10/03/2021	13:25	10.2	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	10/03/2021	14:50	10	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	10/03/2021	14:55	9.99	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	10/03/2021	13:40	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	10/03/2021	13:45	0.001	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	10/03/2021	13:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	10/03/2021	13:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	10/03/2021	12:10	0.0021	g/m³	(.4 - .4)
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6021 Manganese - Acid Soluble	10/03/2021	12:05	0.19	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	10/03/2021	12:15	0.0019	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	10/03/2021	13:20	0.005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	10/03/2021	13:25	0.0042	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	10/03/2021	14:50	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	10/03/2021	14:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	10/03/2021	13:40	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	10/03/2021	13:45	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	10/03/2021	13:00	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	10/03/2021	13:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	10/03/2021	12:10	<0.0005	g/m³	(.007 - .007)
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6022 Mercury - Acid Soluble	10/03/2021	12:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	10/03/2021	12:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	10/03/2021	13:20	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	10/03/2021	13:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	10/03/2021	14:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	10/03/2021	14:55	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	10/03/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	10/03/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	10/03/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	10/03/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	10/03/2021	12:10	<0.0005	g/m³	(.08 - .08)
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6024 Nickel - Acid Soluble	10/03/2021	12:05	0.0013	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024 Nickel - Acid Soluble	10/03/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024 Nickel - Acid Soluble	10/03/2021	13:20	0.0023	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024 Nickel - Acid Soluble	10/03/2021	13:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024 Nickel - Acid Soluble	10/03/2021	14:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6024 Nickel - Acid Soluble	10/03/2021	14:55	<0.0005	g/m³	(.08 - .08)

	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	10/03/2021	13:40	0.004	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	10/03/2021	13:45	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	10/03/2021	13:00	0.007	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	10/03/2021	13:05	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	10/03/2021	12:10	<0.002	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	10/03/2021	12:05	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	10/03/2021	12:15	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	10/03/2021	13:20	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	10/03/2021	13:25	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	10/03/2021	14:50	0.066	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	10/03/2021	14:55	0.008	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	10/03/2021	12:30	93,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	10/03/2021	12:30	17.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	10/03/2021	12:30	0.05	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	10/03/2021	12:30	3,210	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	10/03/2021	12:30	9.6	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	10/03/2021	12:30	27,300	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	10/03/2021	12:30	14	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	10/03/2021	12:30	1,520	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	10/03/2021	12:30	717	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	10/03/2021	12:30	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	10/03/2021	12:30	10.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	10/03/2021	12:30	39	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	10/03/2021	12:45	0.027	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	10/03/2021	12:25	0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	10/03/2021	12:40	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	10/03/2021	12:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	10/03/2021	12:25	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	10/03/2021	12:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	10/03/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	10/03/2021	12:25	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	10/03/2021	12:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	10/03/2021	12:45	18.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	10/03/2021	12:25	19.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	10/03/2021	12:40	18.9	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	10/03/2021	12:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	10/03/2021	12:25	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	10/03/2021	12:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	10/03/2021	12:45	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	10/03/2021	12:25	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	10/03/2021	12:40	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	10/03/2021	12:45	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	10/03/2021	12:25	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	10/03/2021	12:40	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	10/03/2021	12:45	9.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	10/03/2021	12:25	9.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	10/03/2021	12:40	9.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	10/03/2021	12:45	0.031	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	10/03/2021	12:25	0.017	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	10/03/2021	12:40	0.032	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	10/03/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	10/03/2021	12:25	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	10/03/2021	12:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	10/03/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	10/03/2021	12:25	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	10/03/2021	12:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	10/03/2021	12:45	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	10/03/2021	12:25	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	10/03/2021	12:40	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	10/03/2021	13:40	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	10/03/2021	13:45	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	10/03/2021	13:00	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	10/03/2021	13:05	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	10/03/2021	12:45	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	10/03/2021	12:25	0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	10/03/2021	12:10	0.007	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	10/03/2021	12:05	0.083	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	10/03/2021	12:15	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	10/03/2021	12:40	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	10/03/2021	13:20	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	10/03/2021	13:25	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	10/03/2021	14:50	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	10/03/2021	14:55	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	10/03/2021	13:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	10/03/2021	13:45	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	10/03/2021	13:00	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	10/03/2021	13:05	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	10/03/2021	12:45	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	10/03/2021	12:25	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	10/03/2021	12:10	<0.001	g/m³		

Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	10/03/2021	12:05	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	10/03/2021	12:15	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	10/03/2021	12:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	10/03/2021	13:20	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	10/03/2021	13:25	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	10/03/2021	14:50	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	10/03/2021	14:55	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	10/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	10/03/2021	13:45	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	10/03/2021	13:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	10/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	10/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	10/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	10/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	10/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	10/03/2021	12:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	10/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	10/03/2021	13:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	10/03/2021	13:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	10/03/2021	14:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	10/03/2021	14:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	10/03/2021	13:40	22.7	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	10/03/2021	13:45	22.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	10/03/2021	13:00	23	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	10/03/2021	13:05	23	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	10/03/2021	12:45	21.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	10/03/2021	12:25	22	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	10/03/2021	12:10	22.1	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	10/03/2021	12:05	21.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	10/03/2021	12:15	22.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	10/03/2021	12:40	21.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	10/03/2021	13:20	22.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	10/03/2021	13:25	22.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	10/03/2021	14:50	22.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	10/03/2021	14:55	22.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	10/03/2021	13:40	0.0035	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	10/03/2021	13:45	0.0017	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	10/03/2021	13:00	0.0007	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	10/03/2021	13:05	0.0005	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	10/03/2021	12:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	10/03/2021	12:25	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	10/03/2021	12:10	<0.0005	g/m³	(2 - 2)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	10/03/2021	12:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	10/03/2021	12:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	10/03/2021	12:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	10/03/2021	13:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	10/03/2021	13:25	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	10/03/2021	14:50	0.0036	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	10/03/2021	14:55	0.004	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	10/03/2021	13:40	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	10/03/2021	13:45	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	10/03/2021	13:00	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	10/03/2021	13:05	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	10/03/2021	12:45	0.09	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	10/03/2021	12:25	0.07	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	10/03/2021	12:10	<0.01	g/m³		
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	10/03/2021	12:05	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	10/03/2021	12:15	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	10/03/2021	12:40	0.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	10/03/2021	13:20	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	10/03/2021	13:25	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	10/03/2021	14:50	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	10/03/2021	14:55	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	10/03/2021	13:40	0.0013	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	10/03/2021	13:45	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	10/03/2021	13:00	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	10/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	10/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	10/03/2021	12:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	10/03/2021	12:10	<0.0005	g/m³	(.005 - .01)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	10/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	10/03/2021	12:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	10/03/2021	12:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	10/03/2021	13:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	10/03/2021	13:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	10/03/2021	14:50	0.002	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	10/03/2021	14:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	10/03/2021	13:40	10.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	10/03/2021	13:45	9.96	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	10/03/2021	13:00	9.96	g/m³		

	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	10/03/2021	13:05	10	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	10/03/2021	12:45	9.94	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	10/03/2021	12:25	9.85	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	10/03/2021	12:10	9.92	g/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	10/03/2021	12:05	9.88	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	10/03/2021	12:15	10	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	10/03/2021	12:40	9.85	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	10/03/2021	13:20	10.1	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	10/03/2021	13:25	10.3	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	10/03/2021	14:50	9.99	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	10/03/2021	14:55	10	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	10/03/2021	13:40	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	10/03/2021	13:45	<0.0005	g/m³		(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	10/03/2021	13:00	<0.0005	g/m³		(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	10/03/2021	13:05	<0.0005	g/m³		(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	10/03/2021	12:45	0.0224	g/m³		(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	10/03/2021	12:25	0.002	g/m³		(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	10/03/2021	12:10	0.0021	g/m³		(.4 - .4)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	10/03/2021	12:05	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	10/03/2021	12:15	0.0016	g/m³		(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	10/03/2021	12:40	0.0243	g/m³		(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	10/03/2021	13:20	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	10/03/2021	13:25	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	10/03/2021	14:50	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	10/03/2021	14:55	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	10/03/2021	13:40	<0.0005	g/m³			
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	10/03/2021	13:45	<0.0005	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	10/03/2021	13:00	<0.0005	g/m³			
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	10/03/2021	13:05	<0.0005	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	10/03/2021	12:45	<0.0005	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	10/03/2021	12:25	<0.0005	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	10/03/2021	12:10	<0.0005	g/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	10/03/2021	12:05	<0.0005	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	10/03/2021	12:15	<0.0005	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	10/03/2021	12:40	<0.0005	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	10/03/2021	13:20	<0.0005	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	10/03/2021	13:25	<0.0005	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	10/03/2021	14:50	<0.0005	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	10/03/2021	14:55	<0.0005	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	10/03/2021	13:40	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	10/03/2021	13:45	<0.0005	g/m³		(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	10/03/2021	13:00	<0.0005	g/m³		(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	10/03/2021	13:05	<0.0005	g/m³		(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	10/03/2021	12:45	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	10/03/2021	12:25	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	10/03/2021	12:10	<0.0005	g/m³		(.08 - .08)	
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	10/03/2021	12:05	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	10/03/2021	12:15	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	10/03/2021	12:40	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	10/03/2021	13:20	0.0025	g/m³		(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	10/03/2021	13:25	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	10/03/2021	14:50	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	10/03/2021	14:55	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	10/03/2021	13:40	0.039	g/m³			
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	10/03/2021	13:45	<0.002	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	10/03/2021	13:00	0.008	g/m³			
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	10/03/2021	13:05	<0.002	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	10/03/2021	12:45	<0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	10/03/2021	12:25	<0.002	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	10/03/2021	12:10	<0.002	g/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	10/03/2021	12:05	<0.002	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	10/03/2021	12:15	<0.002	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	10/03/2021	12:40	<0.002	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	10/03/2021	13:20	<0.002	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	10/03/2021	13:25	<0.002	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	10/03/2021	14:50	0.078	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	10/03/2021	14:55	0.009	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	10/03/2021	13:40	Completed				
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	10/03/2021	13:45	Completed				
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	10/03/2021	13:00	Completed				
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	10/03/2021	13:05	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	10/03/2021	12:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	10/03/2021	12:25	Completed				
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	10/03/2021	12:10	Completed				
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	10/03/2021	12:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	10/03/2021	12:15	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	10/03/2021	12:40	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	10/03/2021	13:20	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	10/03/2021	13:25	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	10/03/2021	14:50	Completed				

	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	10/03/2021	14:55	Completed				
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St - Preflush	C-O1420	Sampler Observation	10/03/2021	14:20	No	Sample			
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St	C-O1420	Sampler Observation	10/03/2021	14:25	No	Sample			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:40	5.9	g O2/m³			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:45	7	g O2/m³			
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	10/03/2021	14:20	7.1	g O2/m³			
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	10/03/2021	14:25	7.2	g O2/m³			
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:00	5.9	g O2/m³			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:05	7.6	g O2/m³			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:45	7.6	g O2/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:25	6.8	g O2/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:10	7	g O2/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:05	7.1	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:15	6.4	g O2/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	10/03/2021	12:40	7.6	g O2/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:20	6.1	g O2/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	10/03/2021	13:25	6.7	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	10/03/2021	14:50	8	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	10/03/2021	14:55	7.7	g O2/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	10/03/2021	13:40	<0.05	g/m³	(0 - 5)		
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	10/03/2021	13:45	0.92	g/m³	(.2 - 5)		
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	10/03/2021	14:20	<0.05	g/m³	(0 - 5)		
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	10/03/2021	14:25	0.2	g/m³	(.2 - 5)		
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	10/03/2021	13:00	0.35	g/m³	(0 - 5)		
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	10/03/2021	13:05	0.88	g/m³	(.2 - 5)		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	10/03/2021	12:10	<0.05	g/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	10/03/2021	12:05	0.15	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	10/03/2021	12:15	<0.05	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	10/03/2021	13:20	<0.05	g/m³	(0 - 5)		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	10/03/2021	13:25	0.83	g/m³	(.2 - 5)		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	10/03/2021	14:50	0.12	g/m³	(0 - 5)		
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	10/03/2021	14:55	0.86	g/m³	(.2 - 5)		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	10/03/2021	13:40	<0.05	g/m³			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	10/03/2021	13:45	1.1	g/m³			
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	10/03/2021	14:20	<0.05	g/m³			
Taken from old sample point by golf club	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	10/03/2021	14:25	0.2	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	10/03/2021	13:00	0.4	g/m³			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	10/03/2021	13:05	0.9	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	10/03/2021	12:10	<0.05	g/m³			
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	10/03/2021	12:05	0.2	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	10/03/2021	12:15	<0.05	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	10/03/2021	13:20	<0.05	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	10/03/2021	13:25	0.9	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	10/03/2021	14:50	0.2	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	10/03/2021	14:55	0.9	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	10/03/2021	13:40	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	10/03/2021	12:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	10/03/2021	12:25	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	10/03/2021	12:40	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	10/03/2021	13:40	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	10/03/2021	13:45	Completed				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	10/03/2021	13:00	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	10/03/2021	13:05	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	10/03/2021	12:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	10/03/2021	12:25	Completed				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	10/03/2021	12:10	Completed				
Murky brown	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	10/03/2021	12:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	10/03/2021	12:15	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	10/03/2021	12:40	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	10/03/2021	13:20	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	10/03/2021	13:25	Completed				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	10/03/2021	14:50	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	10/03/2021	14:55	Completed				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	10/03/2021	12:30	Completed				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	11/03/2021	11:00	7.9		(1 - 14)		
	Waikouaiti SS - 192 Main Rd	1	pH	11/03/2021	11:05	7.8		(1 - 14)		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	11/03/2021	11:25	8		(1 - 14)		
	Waikouaiti SS - 210 Edinburgh St	1	pH	11/03/2021	11:30	7.9		(1 - 14)		
	Karitane SS - 99 Stornoway St - Preflush	1	pH	11/03/2021	12:20	7.9		(1 - 14)		
	Karitane SS - 99 Stornoway St	1	pH	11/03/2021	12:25	8		(1 - 14)		
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	11/03/2021	08:55	7.9		(1 - 14)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	11/03/2021	08:35	7.8		(1 - 14)		

	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	11/03/2021	08:15	7.9		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	11/03/2021	08:25	7.8		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	11/03/2021	08:50	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	11/03/2021	10:15	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	11/03/2021	10:20	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	11/03/2021	11:50	8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	11/03/2021	11:55	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	11/03/2021	11:00	<6	g/m^3		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	11/03/2021	11:05	<6	g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	11/03/2021	11:25	<6	g/m^3		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	11/03/2021	11:30	<6	g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	11/03/2021	12:20	<6	g/m^3		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	11/03/2021	12:25	<6	g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	11/03/2021	08:55	<6	g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	11/03/2021	08:35	<6	g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	11/03/2021	08:15	<6	g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	11/03/2021	08:25	<6	g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	11/03/2021	08:50	<6	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	11/03/2021	10:15	<6	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	11/03/2021	10:20	<6	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	11/03/2021	11:50	<6	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	11/03/2021	11:55	<6	g/m^3		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	11/03/2021	11:00	71	$g\ CaCO3/m^3$		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	11/03/2021	11:05	70	$g\ CaCO3/m^3$		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	11/03/2021	11:25	73	$g\ CaCO3/m^3$		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	11/03/2021	11:30	72	$g\ CaCO3/m^3$		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	11/03/2021	12:20	73	$g\ CaCO3/m^3$		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	11/03/2021	12:25	71	$g\ CaCO3/m^3$		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	11/03/2021	08:55	70	$g\ CaCO3/m^3$		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	11/03/2021	08:35	70	$g\ CaCO3/m^3$		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	11/03/2021	08:15	69	$g\ CaCO3/m^3$		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	11/03/2021	08:25	70	$g\ CaCO3/m^3$		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	11/03/2021	08:50	72	$g\ CaCO3/m^3$		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	11/03/2021	10:15	72	$g\ CaCO3/m^3$		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	11/03/2021	10:20	71	$g\ CaCO3/m^3$		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	11/03/2021	11:50	77	$g\ CaCO3/m^3$		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	11/03/2021	11:55	72	$g\ CaCO3/m^3$		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	11:00	20.4	g/m^3		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	11/03/2021	11:05	20.7	g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	11:25	21	g/m^3		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	11/03/2021	11:30	20.9	g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	12:20	20.9	g/m^3		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	11/03/2021	12:25	20.8	g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	11/03/2021	08:55	20.7	g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	11/03/2021	08:35	20.6	g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	11/03/2021	08:15	20.1	g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	11/03/2021	08:25	20.3	g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	11/03/2021	08:50	20.4	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	10:15	20.6	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	11/03/2021	10:20	20.7	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	11:50	20.9	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	11/03/2021	11:55	20.8	g/m^3		
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	11:00	16.5	g/m^3		
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	11/03/2021	11:05	16.3	g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	11:25	16.6	g/m^3		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	11/03/2021	11:30	16.5	g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	12:20	16.6	g/m^3		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	11/03/2021	12:25	16.5	g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	11/03/2021	08:55	13.4	g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	11/03/2021	08:35	13.4	g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	11/03/2021	08:15	14.8	g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	11/03/2021	08:25	14.8	g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	11/03/2021	08:50	13.5	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	10:15	16.4	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	11/03/2021	10:20	16.7	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	11:50	16.5	g/m^3		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	11/03/2021	11:55	16.5	g/m^3		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	11:00	23.5	g/m^3		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	11/03/2021	11:05	23.1	g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	11:25	23	g/m^3		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	11/03/2021	11:30	23.5	g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	12:20	23	g/m^3		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	11/03/2021	12:25	22.9	g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	11/03/2021	08:55	21.3	g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	11/03/2021	08:35	22.3	g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	11/03/2021	08:15	22.3	g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	11/03/2021	08:25	22.2	g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	11/03/2021	08:50	21.3	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	10:15	23.1	g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	11/03/2021	10:20	23.2	g/m^3		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	11:50	22.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	11/03/2021	11:55	22.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:00	121	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:05	125	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:25	127	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:30	141	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	12:20	144	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	11/03/2021	12:25	150	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	11/03/2021	08:55	132	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	11/03/2021	08:35	140	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	11/03/2021	08:15	137	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	11/03/2021	08:25	132	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	11/03/2021	08:50	137	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	10:15	125	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	11/03/2021	10:20	125	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:50	137	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	11/03/2021	11:55	129	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	11/03/2021	11:00	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	11:00	0.018	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	11/03/2021	11:05	0.014	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	11:25	0.027	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	11/03/2021	11:30	0.035	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	12:20	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	11/03/2021	12:25	0.012	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	11/03/2021	08:15	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	11/03/2021	08:25	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	10:15	0.012	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	11/03/2021	10:20	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	11:50	0.02	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	11/03/2021	11:55	0.02	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	11/03/2021	11:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	11:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	11/03/2021	11:30	0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	12:20	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	11/03/2021	12:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	11/03/2021	08:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	11/03/2021	08:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	10:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	11/03/2021	10:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	11:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	11/03/2021	11:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	11/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	11:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	11/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	12:20	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	11/03/2021	12:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	11/03/2021	08:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	11/03/2021	08:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	10:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	11/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	11/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	11/03/2021	11:00	0.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	11/03/2021	11:05	20.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	11/03/2021	11:25	21.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	11/03/2021	11:30	21	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	11/03/2021	12:20	21	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	11/03/2021	12:25	20.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	11/03/2021	08:15	19.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	11/03/2021	08:25	19.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	11/03/2021	10:15	19.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	11/03/2021	10:20	20.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	11/03/2021	11:50	20.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	11/03/2021	11:55	20.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	11/03/2021	11:00	0.0023	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	11/03/2021	11:05	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	11/03/2021	11:25	0.006	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	11/03/2021	11:30	0.0015	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	11/03/2021	12:20	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	11/03/2021	12:25	0.0011	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	11/03/2021	08:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	11/03/2021	08:25	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	11/03/2021	10:15	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	11/03/2021	10:20	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	11/03/2021	11:50	0.0042	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	11/03/2021	11:55	0.004	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	11/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	11/03/2021	11:05	0.02	g/m³		

	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	11/03/2021	11:25	0.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	11/03/2021	11:30	0.69	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	11/03/2021	12:20	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	11/03/2021	12:25	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	11/03/2021	08:15	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	11/03/2021	08:25	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	11/03/2021	10:15	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	11/03/2021	10:20	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	11/03/2021	11:50	0.02	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	11/03/2021	11:55	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	11/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	11/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	11/03/2021	11:25	0.0029	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	11/03/2021	11:30	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	11/03/2021	12:20	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	11/03/2021	12:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	11/03/2021	08:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	11/03/2021	08:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	11/03/2021	10:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	11/03/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	11/03/2021	11:50	0.0025	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	11/03/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	11/03/2021	11:00	10.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	11/03/2021	11:05	10.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	11/03/2021	11:25	9.84	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	11/03/2021	11:30	9.77	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	11/03/2021	12:20	9.92	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	11/03/2021	12:25	9.73	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	11/03/2021	08:15	9.89	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	11/03/2021	08:25	9.86	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	11/03/2021	10:15	9.88	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	11/03/2021	10:20	10	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	11/03/2021	11:50	9.86	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	11/03/2021	11:55	9.87	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	11/03/2021	11:00	0.0016	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	11/03/2021	11:05	0.0074	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	11/03/2021	11:25	0.0191	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	11/03/2021	11:30	0.0476	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	11/03/2021	12:20	0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	11/03/2021	12:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	11/03/2021	08:15	0.0014	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	11/03/2021	08:25	0.0012	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	11/03/2021	10:15	0.0135	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	11/03/2021	10:20	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	11/03/2021	11:50	0.028	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	11/03/2021	11:55	0.0255	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	11/03/2021	11:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	11/03/2021	11:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	11/03/2021	11:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	11/03/2021	11:30	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	11/03/2021	12:20	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	11/03/2021	12:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	11/03/2021	08:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	11/03/2021	08:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	11/03/2021	10:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	11/03/2021	10:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	11/03/2021	11:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	11/03/2021	11:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	11/03/2021	11:00	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	11/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	11/03/2021	11:25	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	11/03/2021	11:30	0.0006	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	11/03/2021	12:20	0.001	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	11/03/2021	12:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	11/03/2021	08:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024 Nickel - Acid Soluble	11/03/2021	08:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024 Nickel - Acid Soluble	11/03/2021	10:15	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024 Nickel - Acid Soluble	11/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024 Nickel - Acid Soluble	11/03/2021	11:50	0.0007	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024 Nickel - Acid Soluble	11/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038 Zinc - Acid Soluble	11/03/2021	11:00	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd	6038 Zinc - Acid Soluble	11/03/2021	11:05	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038 Zinc - Acid Soluble	11/03/2021	11:25	0.015	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038 Zinc - Acid Soluble	11/03/2021	11:30	0.003	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038 Zinc - Acid Soluble	11/03/2021	12:20	0.006	g/m³		
	Karitane SS - 99 Stornoway St	6038 Zinc - Acid Soluble	11/03/2021	12:25	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038 Zinc - Acid Soluble	11/03/2021	08:15	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038 Zinc - Acid Soluble	11/03/2021	08:25	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038 Zinc - Acid Soluble	11/03/2021	10:15	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038 Zinc - Acid Soluble	11/03/2021	10:20	<0.002	g/m³		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	11/03/2021	11:50	0.084	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	11/03/2021	11:55	0.007	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	11/03/2021	08:40	38,600	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	11/03/2021	08:40	11.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	11/03/2021	08:40	0.03	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	11/03/2021	08:40	5,280	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	11/03/2021	08:40	7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	11/03/2021	08:40	50,200	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	11/03/2021	08:40	28.6	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	11/03/2021	08:40	4,620	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	11/03/2021	08:40	813	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	11/03/2021	08:40	0.2	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	11/03/2021	08:40	10	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	11/03/2021	08:40	75	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	11/03/2021	08:55	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	11/03/2021	08:35	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	11/03/2021	08:50	0.007	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	11/03/2021	08:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	11/03/2021	08:35	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	11/03/2021	08:50	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	11/03/2021	08:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	11/03/2021	08:35	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	11/03/2021	08:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	11/03/2021	08:55	18.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	11/03/2021	08:35	18.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	11/03/2021	08:50	18.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	11/03/2021	08:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	11/03/2021	08:35	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	11/03/2021	08:50	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	11/03/2021	08:55	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	11/03/2021	08:35	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	11/03/2021	08:50	0.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	11/03/2021	08:55	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	11/03/2021	08:35	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	11/03/2021	08:50	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	11/03/2021	08:55	10.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	11/03/2021	08:35	10.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	11/03/2021	08:50	10.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	11/03/2021	08:55	0.032	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	11/03/2021	08:35	0.015	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	11/03/2021	08:50	0.034	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	11/03/2021	08:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	11/03/2021	08:35	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	11/03/2021	08:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	11/03/2021	08:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	11/03/2021	08:35	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	11/03/2021	08:50	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	11/03/2021	08:55	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	11/03/2021	08:35	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	11/03/2021	08:50	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	11/03/2021	11:00	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	11/03/2021	11:05	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	11/03/2021	11:25	0.013	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	11/03/2021	11:30	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	11/03/2021	12:20	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	11/03/2021	12:25	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	11/03/2021	08:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	11/03/2021	08:35	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	11/03/2021	08:15	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	11/03/2021	08:25	0.007	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	11/03/2021	08:50	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	11/03/2021	10:15	0.011	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	11/03/2021	10:20	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	11/03/2021	11:50	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	11/03/2021	11:55	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	11/03/2021	11:00	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	11/03/2021	11:05	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	11/03/2021	11:25	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	11/03/2021	11:30	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	11/03/2021	12:20	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	11/03/2021	12:25	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	11/03/2021	08:55	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	11/03/2021	08:35	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	11/03/2021	08:15	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	11/03/2021	08:25	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	11/03/2021	08:50	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	11/03/2021	10:15	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	11/03/2021	10:20	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	11/03/2021	11:50	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	11/03/2021	11:55	<0.001	g/m³		

	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	11/03/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	11/03/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	11/03/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	11/03/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	11/03/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	11/03/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	11/03/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	11/03/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	11/03/2021	08:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	11/03/2021	08:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	11/03/2021	08:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	11/03/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	11/03/2021	10:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	11/03/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	11/03/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	11/03/2021	11:00	19.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	11/03/2021	11:05	19.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	11/03/2021	11:25	21	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	11/03/2021	11:30	20.5	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	11/03/2021	12:20	20.5	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	11/03/2021	12:25	20.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	11/03/2021	08:55	19.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	11/03/2021	08:35	19.4	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	11/03/2021	08:15	19.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	11/03/2021	08:25	19.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	11/03/2021	08:50	19.2	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	11/03/2021	10:15	19.8	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	11/03/2021	10:20	20.1	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	11/03/2021	11:50	20.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	11/03/2021	11:55	20.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	11/03/2021	11:00	0.0017	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	11/03/2021	11:05	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	11/03/2021	11:25	0.0123	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	11/03/2021	11:30	<0.0005	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	11/03/2021	12:20	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	11/03/2021	12:25	0.0006	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	11/03/2021	08:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	11/03/2021	08:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	11/03/2021	08:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	11/03/2021	08:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	11/03/2021	08:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	11/03/2021	10:15	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	11/03/2021	10:20	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	11/03/2021	11:50	0.0043	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	11/03/2021	11:55	0.0029	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	11/03/2021	11:00	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	11/03/2021	11:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	11/03/2021	11:25	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	11/03/2021	11:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	11/03/2021	12:20	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	11/03/2021	12:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	11/03/2021	08:55	0.12	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	11/03/2021	08:35	0.09	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	11/03/2021	08:15	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	11/03/2021	08:25	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	11/03/2021	08:50	0.13	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	11/03/2021	10:15	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	11/03/2021	10:20	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	11/03/2021	11:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	11/03/2021	11:55	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	11/03/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	11/03/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	11/03/2021	11:25	0.0008	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	11/03/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	11/03/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	11/03/2021	12:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	11/03/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	11/03/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	11/03/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	11/03/2021	08:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	11/03/2021	08:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	11/03/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	11/03/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	11/03/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	11/03/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	11/03/2021	11:00	10.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	11/03/2021	11:05	10.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	11/03/2021	11:25	10	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	11/03/2021	11:30	10.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	11/03/2021	12:20	10.1	g/m³	

	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	11/03/2021	12:25	10	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	11/03/2021	08:55	9.86	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	11/03/2021	08:35	10	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	11/03/2021	08:15	10	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	11/03/2021	08:25	10	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	11/03/2021	08:50	9.73	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	11/03/2021	10:15	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	11/03/2021	10:20	10.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	11/03/2021	11:50	10.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	11/03/2021	11:55	10	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	11/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	11/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	11/03/2021	11:25	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	11/03/2021	11:30	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	11/03/2021	12:20	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	11/03/2021	12:25	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	11/03/2021	08:55	0.0196	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	11/03/2021	08:35	0.0039	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	11/03/2021	08:15	0.0013	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	11/03/2021	08:25	0.001	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	11/03/2021	08:50	0.0196	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	11/03/2021	10:15	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	11/03/2021	10:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	11/03/2021	11:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	11/03/2021	11:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	11/03/2021	11:00	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	11/03/2021	11:05	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	11/03/2021	11:25	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	11/03/2021	11:30	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	11/03/2021	12:20	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	11/03/2021	12:25	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	11/03/2021	08:55	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	11/03/2021	08:35	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	11/03/2021	08:15	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	11/03/2021	08:25	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	11/03/2021	08:50	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	11/03/2021	10:15	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	11/03/2021	10:20	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	11/03/2021	11:50	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	11/03/2021	11:55	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	11/03/2021	11:00	0.0006	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	11/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	11/03/2021	11:25	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	11/03/2021	11:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	11/03/2021	12:20	0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	11/03/2021	12:25	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	11/03/2021	08:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	11/03/2021	08:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	11/03/2021	08:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	11/03/2021	08:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	11/03/2021	08:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	11/03/2021	10:15	0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	11/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	11/03/2021	11:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	11/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	11/03/2021	11:00	0.004	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	11/03/2021	11:05	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	11/03/2021	11:25	0.044	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	11/03/2021	11:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	11/03/2021	12:20	0.01	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	11/03/2021	12:25	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	11/03/2021	08:55	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	11/03/2021	08:35	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	11/03/2021	08:15	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	11/03/2021	08:25	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	11/03/2021	08:50	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	11/03/2021	10:15	0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	11/03/2021	10:20	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	11/03/2021	11:50	0.059	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	11/03/2021	11:55	0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	11:00	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	11/03/2021	11:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	11:25	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	11/03/2021	11:30	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	12:20	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	11/03/2021	12:25	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	11/03/2021	08:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	11/03/2021	08:35	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	11/03/2021	08:15	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	11/03/2021	08:25	Completed			

	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	11/03/2021	08:50	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	10:15	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	11/03/2021	10:20	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	11:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	11/03/2021	11:55	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	11/03/2021	08:15	No	water		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:00	7.8	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:05	7.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:25	6.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:30	6.7	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	12:20	6.3	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	11/03/2021	12:25	7.4	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	11/03/2021	08:55	6.6	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	11/03/2021	08:35	7.1	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	11/03/2021	08:15	7.3	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	11/03/2021	08:25	6.6	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	11/03/2021	08:50	6.7	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	10:15	6.9	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	11/03/2021	10:20	4.8	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:50	6.9	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	11/03/2021	11:55	6.9	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	11/03/2021	11:00	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	11/03/2021	11:05	0.82	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	11/03/2021	11:25	0.11	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	11/03/2021	11:30	0.45	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	11/03/2021	12:20	<0.05	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	11/03/2021	12:25	0.8	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	11/03/2021	08:15	0.15	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	11/03/2021	08:25	<0.05	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	11/03/2021	10:15	0.14	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	11/03/2021	10:20	0.8	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	11/03/2021	11:50	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	11/03/2021	11:55	1	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	11/03/2021	11:00	<0.05	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	11/03/2021	11:05	0.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	11/03/2021	11:25	0.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	11/03/2021	11:30	0.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	11/03/2021	12:20	<0.05	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	11/03/2021	12:25	0.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	11/03/2021	08:15	0.2	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	11/03/2021	08:25	<0.05	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	11/03/2021	10:15	0.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	11/03/2021	10:20	0.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	11/03/2021	11:50	<0.05	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	11/03/2021	11:55	1	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	11/03/2021	11:00	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	11/03/2021	11:25	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	11/03/2021	11:30	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	11/03/2021	11:25	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	11/03/2021	11:30	<1	MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	11/03/2021	08:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	11/03/2021	08:35	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	11/03/2021	08:50	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	11/03/2021	11:00	Completed			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	11/03/2021	11:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	11/03/2021	11:25	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	11/03/2021	11:30	Completed			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	11/03/2021	12:20	Completed			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	11/03/2021	12:25	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	11/03/2021	08:55	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	11/03/2021	08:35	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	11/03/2021	08:15	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	11/03/2021	08:25	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	11/03/2021	08:50	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	11/03/2021	10:15	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	11/03/2021	10:20	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	11/03/2021	11:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	11/03/2021	11:55	Completed			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	11/03/2021	08:40	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1	pH	11/03/2021	09:30	8		(1 - 14)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1	pH	11/03/2021	09:35	8		(1 - 14)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	2	Suspended Solids - Total	11/03/2021	09:30	<6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	2	Suspended Solids - Total	11/03/2021	09:35	<6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	52	Alkalinity - Total	11/03/2021	09:30	72	g CaCO3/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	11/03/2021	09:35	72	g CaCO3/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	0440D	Dissolved Inorganic Carbon	11/03/2021	09:30	19.7	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	11/03/2021	09:35	19.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	602	Chloride - Add P1859 Filtration	11/03/2021	09:30	16.7	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	602	Chloride - Add P1859 Filtration	11/03/2021	09:35	16.6	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	607	Sulphate - Add P1859 Filtration	11/03/2021	09:30	25.2	g/m³		

	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	607	Sulphate - Add P1859 Filtration	11/03/2021	09:35	24.1	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1024	Total Dissolved Solids by Evaporation	11/03/2021	09:30	159	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1024	Total Dissolved Solids by Evaporation	11/03/2021	09:35	156	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6001	Aluminium - Acid Soluble	11/03/2021	09:30	0.019	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6001	Aluminium - Acid Soluble	11/03/2021	09:35	0.015	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6003	Arsenic - Acid Soluble	11/03/2021	09:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6003	Arsenic - Acid Soluble	11/03/2021	09:35	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6008	Cadmium - Acid Soluble	11/03/2021	09:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6008	Cadmium - Acid Soluble	11/03/2021	09:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6010	Calcium - Acid Soluble	11/03/2021	09:30	20.3	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6010	Calcium - Acid Soluble	11/03/2021	09:35	20.4	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6013	Copper - Acid Soluble	11/03/2021	09:30	0.0114	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6013	Copper - Acid Soluble	11/03/2021	09:35	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6017	Iron - Acid Soluble	11/03/2021	09:30	0.02	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6017	Iron - Acid Soluble	11/03/2021	09:35	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6018	Lead - Acid Soluble	11/03/2021	09:30	0.0054	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6018	Lead - Acid Soluble	11/03/2021	09:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6020	Magnesium - Acid Soluble	11/03/2021	09:30	9.92	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6020	Magnesium - Acid Soluble	11/03/2021	09:35	9.96	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6021	Manganese - Acid Soluble	11/03/2021	09:30	0.0614	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6021	Manganese - Acid Soluble	11/03/2021	09:35	0.0016	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6022	Mercury - Acid Soluble	11/03/2021	09:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6022	Mercury - Acid Soluble	11/03/2021	09:35	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6024	Nickel - Acid Soluble	11/03/2021	09:30	0.0138	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6024	Nickel - Acid Soluble	11/03/2021	09:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6038	Zinc - Acid Soluble	11/03/2021	09:30	0.056	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6038	Zinc - Acid Soluble	11/03/2021	09:35	<0.002	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6701	Aluminium - Dissolved	11/03/2021	09:30	0.007	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	11/03/2021	09:35	0.013	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6703	Arsenic - Dissolved	11/03/2021	09:30	<0.001	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6703	Arsenic - Dissolved	11/03/2021	09:35	<0.001	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6708	Cadmium - Dissolved	11/03/2021	09:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	11/03/2021	09:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6710	Calcium - Dissolved	11/03/2021	09:30	19.8	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6710	Calcium - Dissolved	11/03/2021	09:35	20.2	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6713	Copper - Dissolved	11/03/2021	09:30	0.002	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	11/03/2021	09:35	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6717	Iron - Dissolved	11/03/2021	09:30	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	11/03/2021	09:35	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6718	Lead - Dissolved	11/03/2021	09:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	11/03/2021	09:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6720	Magnesium - Dissolved	11/03/2021	09:30	10.3	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6720	Magnesium - Dissolved	11/03/2021	09:35	10.2	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6721	Manganese - Dissolved	11/03/2021	09:30	0.0061	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	11/03/2021	09:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6722	Mercury - Dissolved	11/03/2021	09:30	<0.0005	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6722	Mercury - Dissolved	11/03/2021	09:35	<0.0005	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6724	Nickel - Dissolved	11/03/2021	09:30	0.0096	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	11/03/2021	09:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6738	Zinc - Dissolved	11/03/2021	09:30	0.026	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	11/03/2021	09:35	<0.002	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	9402	ICP-MS - 2 Elements	11/03/2021	09:30	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	9402	ICP-MS - 2 Elements	11/03/2021	09:35	Completed			
	Karitane School	C-O1420	Sampler Observation	11/03/2021	00:00	No	Sample		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0056F	Dissolved Oxygen - Field	11/03/2021	09:30	6.4	g O2/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	11/03/2021	09:35	7.3	g O2/m³		
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	11/03/2021	12:45	0.25	g/m³	(.2 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0058H	Free Available Chlorine	11/03/2021	09:30	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	11/03/2021	09:35	0.5	g/m³	(.2 - 5)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0066H	Total Chlorine	11/03/2021	09:30	<0.05	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0066H	Total Chlorine	11/03/2021	09:35	0.6	g/m³		
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	11/03/2021	12:45	0.14	NTU		
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	11/03/2021	12:45	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-1201	Sampling / Inspection 15 Mins	11/03/2021	09:30	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-1201	Sampling / Inspection 15 Mins	11/03/2021	09:35	Completed			
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	11/03/2021	12:45	8.4	Deg C		
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	11/03/2021	12:45	<1	MPN/100mL	(0 - 0)	
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	11/03/2021	12:45	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	P1859	Sample Filtration	11/03/2021	09:30	Completed			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	11/03/2021	09:35	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	12/03/2021	11:50	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	12/03/2021	11:55	7.9		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	12/03/2021	11:10	8		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	12/03/2021	11:15	8.1		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	12/03/2021	12:10	8		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	12/03/2021	12:15	8		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	12/03/2021	10:20	7.8		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	12/03/2021	09:45	7.9		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	12/03/2021	09:50	8.1		(1 - 14)	
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	12/03/2021	09:55	7.9		(1 - 14)	

	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	12/03/2021	09:40	7.9		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	12/03/2021	10:25	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	12/03/2021	10:45	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	12/03/2021	10:50	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	12/03/2021	11:25	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	12/03/2021	11:30	8		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	12/03/2021	11:50	<6	g/m³		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	12/03/2021	11:55	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	12/03/2021	11:10	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	12/03/2021	11:15	<6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	12/03/2021	12:10	<6	g/m³		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	12/03/2021	12:15	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	12/03/2021	10:20	<6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	12/03/2021	09:45	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	12/03/2021	09:50	<6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	12/03/2021	09:55	103	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	12/03/2021	09:40	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	12/03/2021	10:25	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	12/03/2021	10:45	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	12/03/2021	10:50	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	12/03/2021	11:25	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	12/03/2021	11:30	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	12/03/2021	11:50	71	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	12/03/2021	11:55	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	12/03/2021	11:10	73	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	12/03/2021	11:15	74	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	12/03/2021	12:10	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	12/03/2021	12:15	72	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	12/03/2021	10:20	71	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	12/03/2021	09:45	72	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	12/03/2021	09:50	71	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	12/03/2021	09:55	77	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	12/03/2021	09:40	72	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	12/03/2021	10:25	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	12/03/2021	10:45	72	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	12/03/2021	10:50	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	12/03/2021	11:25	76	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	12/03/2021	11:30	74	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	12/03/2021	11:50	20.4	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	12/03/2021	11:55	20.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	12/03/2021	11:10	21.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	12/03/2021	11:15	21.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	12/03/2021	12:10	20.5	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	12/03/2021	12:15	20.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	12/03/2021	10:20	20.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	12/03/2021	09:45	20.5	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	12/03/2021	09:50	20.4	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	12/03/2021	09:55	19.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	12/03/2021	09:40	20.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	12/03/2021	10:25	20.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	12/03/2021	10:45	20.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	12/03/2021	10:50	20.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	12/03/2021	11:25	20.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	12/03/2021	11:30	20.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	12/03/2021	11:50	16.2	g/m³		
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	12/03/2021	11:55	16.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	12/03/2021	11:10	16.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	12/03/2021	11:15	16.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	12/03/2021	12:10	16.3	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	12/03/2021	12:15	16.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	12/03/2021	10:20	13.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	12/03/2021	09:45	13.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	12/03/2021	09:50	14.7	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	12/03/2021	09:55	14.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	12/03/2021	09:40	16.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	12/03/2021	10:25	13.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	12/03/2021	10:45	16.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	12/03/2021	10:50	16.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	12/03/2021	11:25	16.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	12/03/2021	11:30	16.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	12/03/2021	11:50	22.6	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	12/03/2021	11:55	22.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	12/03/2021	11:10	22.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	12/03/2021	11:15	22.6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	12/03/2021	12:10	22.7	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	12/03/2021	12:15	22.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	12/03/2021	10:20	22	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	12/03/2021	09:45	21.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	12/03/2021	09:50	21.6	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	12/03/2021	09:55	23	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	607 Sulphate - Add P1859 Filtration	12/03/2021	09:40	22.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607 Sulphate - Add P1859 Filtration	12/03/2021	10:25	22	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607 Sulphate - Add P1859 Filtration	12/03/2021	10:45	22.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607 Sulphate - Add P1859 Filtration	12/03/2021	10:50	22.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607 Sulphate - Add P1859 Filtration	12/03/2021	11:25	22.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607 Sulphate - Add P1859 Filtration	12/03/2021	11:30	22.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:50	125	g/m³		
	Waikouaiti SS - 192 Main Rd	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:55	138	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:10	131	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:15	130	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024 Total Dissolved Solids by Evaporation	12/03/2021	12:10	141	g/m³		
	Karitane SS - 99 Stornoway St	1024 Total Dissolved Solids by Evaporation	12/03/2021	12:15	119	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024 Total Dissolved Solids by Evaporation	12/03/2021	10:20	123	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024 Total Dissolved Solids by Evaporation	12/03/2021	09:45	128	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024 Total Dissolved Solids by Evaporation	12/03/2021	09:50	140	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1024 Total Dissolved Solids by Evaporation	12/03/2021	09:55	119	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024 Total Dissolved Solids by Evaporation	12/03/2021	09:40	139	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024 Total Dissolved Solids by Evaporation	12/03/2021	10:25	116	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024 Total Dissolved Solids by Evaporation	12/03/2021	10:45	139	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024 Total Dissolved Solids by Evaporation	12/03/2021	10:50	127	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:25	112	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024 Total Dissolved Solids by Evaporation	12/03/2021	11:30	131	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214 Surcharge Fee	12/03/2021	11:50	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001 Aluminium - Acid Soluble	12/03/2021	11:50	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6001 Aluminium - Acid Soluble	12/03/2021	11:55	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001 Aluminium - Acid Soluble	12/03/2021	11:10	0.017	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001 Aluminium - Acid Soluble	12/03/2021	11:15	0.012	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001 Aluminium - Acid Soluble	12/03/2021	12:10	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6001 Aluminium - Acid Soluble	12/03/2021	12:15	0.011	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001 Aluminium - Acid Soluble	12/03/2021	09:50	0.007	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001 Aluminium - Acid Soluble	12/03/2021	09:55	21.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001 Aluminium - Acid Soluble	12/03/2021	09:40	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001 Aluminium - Acid Soluble	12/03/2021	10:45	0.016	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001 Aluminium - Acid Soluble	12/03/2021	10:50	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001 Aluminium - Acid Soluble	12/03/2021	11:25	0.013	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001 Aluminium - Acid Soluble	12/03/2021	11:30	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003 Arsenic - Acid Soluble	12/03/2021	11:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003 Arsenic - Acid Soluble	12/03/2021	11:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003 Arsenic - Acid Soluble	12/03/2021	11:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003 Arsenic - Acid Soluble	12/03/2021	11:15	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003 Arsenic - Acid Soluble	12/03/2021	12:10	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003 Arsenic - Acid Soluble	12/03/2021	12:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003 Arsenic - Acid Soluble	12/03/2021	09:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6003 Arsenic - Acid Soluble	12/03/2021	09:55	0.004	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003 Arsenic - Acid Soluble	12/03/2021	09:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003 Arsenic - Acid Soluble	12/03/2021	10:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003 Arsenic - Acid Soluble	12/03/2021	10:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003 Arsenic - Acid Soluble	12/03/2021	11:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003 Arsenic - Acid Soluble	12/03/2021	11:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008 Cadmium - Acid Soluble	12/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008 Cadmium - Acid Soluble	12/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008 Cadmium - Acid Soluble	12/03/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008 Cadmium - Acid Soluble	12/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008 Cadmium - Acid Soluble	12/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008 Cadmium - Acid Soluble	12/03/2021	12:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008 Cadmium - Acid Soluble	12/03/2021	09:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6008 Cadmium - Acid Soluble	12/03/2021	09:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008 Cadmium - Acid Soluble	12/03/2021	09:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008 Cadmium - Acid Soluble	12/03/2021	10:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008 Cadmium - Acid Soluble	12/03/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008 Cadmium - Acid Soluble	12/03/2021	11:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	12/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	12/03/2021	11:50	18	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	12/03/2021	11:55	18	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	12/03/2021	11:10	18.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	12/03/2021	11:15	19	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	12/03/2021	12:10	18.5	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	12/03/2021	12:15	18.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	12/03/2021	09:50	18.1	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6010 Calcium - Acid Soluble	12/03/2021	09:55	18.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	12/03/2021	09:40	17.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	12/03/2021	10:45	17.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	12/03/2021	10:50	17.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	12/03/2021	11:25	18.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	12/03/2021	11:30	18.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	12/03/2021	11:50	0.0057	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	12/03/2021	11:55	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	12/03/2021	11:10	0.0081	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	12/03/2021	11:15	<0.0005	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	12/03/2021	12:10	0.0031	g/m³	(2 - 2)	

	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	12/03/2021	12:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	12/03/2021	09:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6013 Copper - Acid Soluble	12/03/2021	09:55	0.0029	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	12/03/2021	09:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	12/03/2021	10:45	0.0014	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	12/03/2021	10:50	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	12/03/2021	11:25	0.0259	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	12/03/2021	11:30	0.0028	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	12/03/2021	11:50	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	12/03/2021	11:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	12/03/2021	11:10	0.15	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	12/03/2021	11:15	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	12/03/2021	12:10	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	12/03/2021	12:15	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	12/03/2021	09:50	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6017 Iron - Acid Soluble	12/03/2021	09:55	2.26	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	12/03/2021	09:40	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	12/03/2021	10:45	0.56	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	12/03/2021	10:50	0.03	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	12/03/2021	11:25	0.03	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	12/03/2021	11:30	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	12/03/2021	11:50	0.003	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	12/03/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	12/03/2021	11:10	0.0056	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	12/03/2021	11:15	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	12/03/2021	12:10	0.0007	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	12/03/2021	12:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	12/03/2021	09:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Supernatant Tube Settler	6018 Lead - Acid Soluble	12/03/2021	09:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	12/03/2021	09:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	12/03/2021	10:45	0.0008	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	12/03/2021	10:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	12/03/2021	11:25	0.033	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	12/03/2021	11:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	12/03/2021	11:50	9.99	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	12/03/2021	11:55	9.84	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	12/03/2021	11:10	9.83	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	12/03/2021	11:15	9.79	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	12/03/2021	12:10	9.75	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	12/03/2021	12:15	9.72	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	12/03/2021	09:50	9.77	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6020 Magnesium - Acid Soluble	12/03/2021	09:55	9.75	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	12/03/2021	09:40	9.98	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	12/03/2021	10:45	9.92	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	12/03/2021	10:50	10	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	12/03/2021	11:25	9.89	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	12/03/2021	11:30	9.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	12/03/2021	11:50	0.0109	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	12/03/2021	11:55	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	12/03/2021	11:10	0.0139	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	12/03/2021	11:15	0.0006	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	12/03/2021	12:10	0.004	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	12/03/2021	12:15	0.0009	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	12/03/2021	09:50	0.0007	g/m³	(.4 - .4)	
	Waikouaiti WTP - Supernatant Tube Settler	6021 Manganese - Acid Soluble	12/03/2021	09:55	0.22	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	12/03/2021	09:40	0.0012	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	12/03/2021	10:45	0.0181	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	12/03/2021	10:50	0.0026	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	12/03/2021	11:25	0.0175	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	12/03/2021	11:30	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	12/03/2021	11:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	12/03/2021	11:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	12/03/2021	11:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	12/03/2021	11:15	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	12/03/2021	12:10	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	12/03/2021	12:15	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	12/03/2021	09:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Supernatant Tube Settler	6022 Mercury - Acid Soluble	12/03/2021	09:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	12/03/2021	09:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	12/03/2021	10:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	12/03/2021	10:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	12/03/2021	11:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	12/03/2021	11:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	12/03/2021	11:50	0.0008	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	12/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	12/03/2021	11:10	0.001	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	12/03/2021	11:15	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	12/03/2021	12:10	0.001	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	12/03/2021	12:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	12/03/2021	09:50	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	12/03/2021	09:55	0.0017	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	12/03/2021	09:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	12/03/2021	10:45	0.0088	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	12/03/2021	10:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	12/03/2021	11:25	0.004	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	12/03/2021	11:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	12/03/2021	11:50	0.052	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	12/03/2021	11:55	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	12/03/2021	11:10	0.046	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	12/03/2021	11:15	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	12/03/2021	12:10	0.04	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	12/03/2021	12:15	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	12/03/2021	09:50	<0.002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	12/03/2021	09:55	0.003	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	12/03/2021	09:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	12/03/2021	10:45	0.005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	12/03/2021	10:50	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	12/03/2021	11:25	0.813	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	12/03/2021	11:30	0.005	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	12/03/2021	10:05	128,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	12/03/2021	10:05	22.6	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	12/03/2021	10:05	0.12	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	12/03/2021	10:05	5,010	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	12/03/2021	10:05	17.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	12/03/2021	10:05	20,900	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	12/03/2021	10:05	5.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	12/03/2021	10:05	1,400	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	12/03/2021	10:05	2,960	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	12/03/2021	10:05	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	12/03/2021	10:05	8.8	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	12/03/2021	10:05	55	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	12/03/2021	10:20	0.008	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	12/03/2021	09:45	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	12/03/2021	10:25	0.008	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	12/03/2021	10:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	12/03/2021	09:45	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	12/03/2021	10:25	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	12/03/2021	10:20	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	12/03/2021	09:45	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	12/03/2021	10:25	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	12/03/2021	10:20	19.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	12/03/2021	09:45	19.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	12/03/2021	10:25	19.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	12/03/2021	10:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	12/03/2021	09:45	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	12/03/2021	10:25	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	12/03/2021	10:20	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	12/03/2021	09:45	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	12/03/2021	10:25	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	12/03/2021	10:20	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	12/03/2021	09:45	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	12/03/2021	10:25	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	12/03/2021	10:20	9.6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	12/03/2021	09:45	9.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	12/03/2021	10:25	9.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	12/03/2021	10:20	0.027	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	12/03/2021	09:45	0.019	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	12/03/2021	10:25	0.027	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	12/03/2021	10:20	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	12/03/2021	09:45	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	12/03/2021	10:25	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	12/03/2021	10:20	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	12/03/2021	09:45	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	12/03/2021	10:25	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	12/03/2021	10:20	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	12/03/2021	09:45	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	12/03/2021	10:25	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	12/03/2021	11:50	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	12/03/2021	11:55	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	12/03/2021	11:10	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	12/03/2021	11:15	0.014	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	12/03/2021	12:10	0.01	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	12/03/2021	12:15	0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	12/03/2021	10:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	12/03/2021	09:45	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	12/03/2021	09:50	0.006	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	12/03/2021	09:55	0.118	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	12/03/2021	09:40	0.007	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	12/03/2021	10:25	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	12/03/2021	10:45	0.007	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	12/03/2021	10:50	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	12/03/2021	11:25	0.008	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	12/03/2021	11:30	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	12/03/2021	11:50	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	12/03/2021	11:55	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	12/03/2021	11:10	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	12/03/2021	11:15	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	12/03/2021	12:10	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	12/03/2021	12:15	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	12/03/2021	10:20	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	12/03/2021	09:45	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	12/03/2021	09:50	<0.001	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	12/03/2021	09:55	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	12/03/2021	09:40	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	12/03/2021	10:25	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	12/03/2021	10:45	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	12/03/2021	10:50	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	12/03/2021	11:25	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	12/03/2021	11:30	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	12/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	12/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	12/03/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	12/03/2021	11:15	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	12/03/2021	12:10	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	12/03/2021	12:15	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	12/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	12/03/2021	09:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	12/03/2021	09:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	12/03/2021	09:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	12/03/2021	09:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	12/03/2021	10:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	12/03/2021	10:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	12/03/2021	10:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	12/03/2021	11:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	12/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	12/03/2021	11:50	15.7	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	12/03/2021	11:55	17.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	12/03/2021	11:10	17.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	12/03/2021	11:15	16.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	12/03/2021	12:10	16.6	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	12/03/2021	12:15	16.4	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	12/03/2021	10:20	16.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	12/03/2021	09:45	17.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	12/03/2021	09:50	16.3	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	12/03/2021	09:55	15.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	12/03/2021	09:40	16.7	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	12/03/2021	10:25	16.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	12/03/2021	10:45	16.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	12/03/2021	10:50	17.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	12/03/2021	11:25	15	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	12/03/2021	11:30	17.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	12/03/2021	11:50	0.0043	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	12/03/2021	11:55	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	12/03/2021	11:10	0.0046	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	12/03/2021	11:15	<0.0005	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	12/03/2021	12:10	0.0024	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	12/03/2021	12:15	<0.0005	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	12/03/2021	10:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	12/03/2021	09:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	12/03/2021	09:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	12/03/2021	09:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	12/03/2021	09:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	12/03/2021	10:25	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	12/03/2021	10:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	12/03/2021	10:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	12/03/2021	11:25	0.0187	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	12/03/2021	11:30	0.0026	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	12/03/2021	11:50	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	12/03/2021	11:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	12/03/2021	11:10	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	12/03/2021	11:15	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	12/03/2021	12:10	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	12/03/2021	12:15	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	12/03/2021	10:20	0.11	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	12/03/2021	09:45	0.11	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	12/03/2021	09:50	<0.01	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	12/03/2021	09:55	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	12/03/2021	09:40	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	12/03/2021	10:25	0.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	12/03/2021	10:45	<0.01	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	12/03/2021	10:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	12/03/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	12/03/2021	11:30	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	12/03/2021	11:50	0.0007	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	12/03/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	12/03/2021	11:10	0.0006	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	12/03/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	12/03/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	12/03/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	12/03/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	12/03/2021	09:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	12/03/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	12/03/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	12/03/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	12/03/2021	10:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	12/03/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	12/03/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	12/03/2021	11:25	0.0236	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	12/03/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	12/03/2021	11:50	9.64	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	12/03/2021	11:55	9.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	12/03/2021	11:10	9.03	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	12/03/2021	11:15	8.9	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	12/03/2021	12:10	8.98	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	12/03/2021	12:15	8.73	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	12/03/2021	10:20	9.07	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	12/03/2021	09:45	9.19	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	12/03/2021	09:50	8.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	12/03/2021	09:55	8.64	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	12/03/2021	09:40	9.21	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	12/03/2021	10:25	9.04	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	12/03/2021	10:45	9.24	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	12/03/2021	10:50	9.21	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	12/03/2021	11:25	8.56	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	12/03/2021	11:30	9.56	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	12/03/2021	11:50	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	12/03/2021	11:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	12/03/2021	11:10	0.0013	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	12/03/2021	11:15	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	12/03/2021	12:10	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	12/03/2021	12:15	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	12/03/2021	10:20	0.0163	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	12/03/2021	09:45	0.0082	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	12/03/2021	09:50	0.0006	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	12/03/2021	09:55	0.0009	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	12/03/2021	09:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	12/03/2021	10:25	0.0171	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	12/03/2021	10:45	0.0015	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	12/03/2021	10:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	12/03/2021	11:25	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	12/03/2021	11:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	12/03/2021	11:50	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	12/03/2021	11:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	12/03/2021	11:10	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	12/03/2021	11:15	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	12/03/2021	12:10	<0.0005	g/m³	
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	12/03/2021	12:15	<0.0005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	12/03/2021	10:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	12/03/2021	09:45	<0.0005	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	12/03/2021	09:50	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	12/03/2021	09:55	<0.0005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	12/03/2021	09:40	<0.0005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	12/03/2021	10:25	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	12/03/2021	10:45	<0.0005	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	12/03/2021	10:50	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	12/03/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	12/03/2021	11:30	<0.0005	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	12/03/2021	11:50	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	12/03/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	12/03/2021	11:10	0.0008	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	12/03/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	12/03/2021	12:10	0.0009	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	12/03/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	12/03/2021	10:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	12/03/2021	09:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	12/03/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	12/03/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	12/03/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	12/03/2021	10:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	12/03/2021	10:45	0.0075	g/m³	(.08 - .08)

	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	12/03/2021	10:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	12/03/2021	11:25	0.0034	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	12/03/2021	11:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	12/03/2021	11:50	0.044	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	12/03/2021	11:55	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	12/03/2021	11:10	0.036	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	12/03/2021	11:15	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	12/03/2021	12:10	0.035	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	12/03/2021	12:15	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	12/03/2021	10:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	12/03/2021	09:45	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	12/03/2021	09:50	<0.002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	12/03/2021	09:55	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	12/03/2021	09:40	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	12/03/2021	10:25	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	12/03/2021	10:45	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	12/03/2021	10:50	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	12/03/2021	11:25	0.683	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	12/03/2021	11:30	0.004	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	12/03/2021	11:50	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	12/03/2021	11:55	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	12/03/2021	11:10	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	12/03/2021	11:15	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	12/03/2021	12:10	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	12/03/2021	12:15	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	12/03/2021	10:20	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	12/03/2021	09:45	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	12/03/2021	09:50	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	12/03/2021	09:55	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	12/03/2021	09:40	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	12/03/2021	10:25	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	12/03/2021	10:45	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	12/03/2021	10:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	12/03/2021	11:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	12/03/2021	11:30	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:50	6.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:55	6.5	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:10	6.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:15	5.9	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	12/03/2021	12:10	6.2	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	12/03/2021	12:15	6.2	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	12/03/2021	10:20	6.8	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	12/03/2021	09:45	6.3	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	12/03/2021	09:50	6.4	g O2/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	12/03/2021	09:55	7.1	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	12/03/2021	09:40	7.7	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	12/03/2021	10:25	7	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	12/03/2021	10:45	6.6	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	12/03/2021	10:50	6.1	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:25	5.9	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	12/03/2021	11:30	5.8	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	12/03/2021	11:50	0.71	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	12/03/2021	11:55	0.88	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	12/03/2021	11:10	0.21	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	12/03/2021	11:15	0.07	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	12/03/2021	12:10	0.81	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	12/03/2021	12:15	0.92	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	12/03/2021	09:50	<0.05	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	12/03/2021	09:55	0.15	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	12/03/2021	09:40	0.68	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	12/03/2021	10:45	0.65	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	12/03/2021	10:50	0.84	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	12/03/2021	11:25	0.37	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	12/03/2021	11:30	0.88	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	12/03/2021	11:50	0.8	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	12/03/2021	11:55	1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	12/03/2021	11:10	0.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	12/03/2021	11:15	0.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	12/03/2021	12:10	1	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	12/03/2021	12:15	1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	12/03/2021	09:50	<0.05	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	12/03/2021	09:55	0.2	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	12/03/2021	09:40	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	12/03/2021	10:45	0.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	12/03/2021	10:50	1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	12/03/2021	11:25	0.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	12/03/2021	11:30	1	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	12/03/2021	11:50	Complete			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	12/03/2021	11:10	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	12/03/2021	11:15	<1	MPN/100mL	(0 - 0)	

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	12/03/2021	11:10	<1		MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	12/03/2021	11:15	<1		MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/03/2021	10:20	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/03/2021	09:45	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	12/03/2021	10:25	Complete				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	12/03/2021	11:50	Complete				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	12/03/2021	11:55	Complete				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	12/03/2021	11:10	Complete				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	12/03/2021	11:15	Complete				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	12/03/2021	12:10	Complete				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	12/03/2021	12:15	Complete				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	12/03/2021	10:20	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	12/03/2021	09:45	Complete				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	12/03/2021	09:50	Complete				
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	12/03/2021	09:55	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	12/03/2021	09:40	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	12/03/2021	10:25	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	12/03/2021	10:45	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	12/03/2021	10:50	Complete				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	12/03/2021	11:25	Complete				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	12/03/2021	11:30	Complete				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	12/03/2021	10:05	Complete				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	13/03/2021	10:43	7.8			(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	13/03/2021	10:49	7.7			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	13/03/2021	10:22	7.8			(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	13/03/2021	10:30	7.8			(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	13/03/2021	11:53	7.9			(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	13/03/2021	12:00	8			(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	13/03/2021	12:50	7.8			(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	13/03/2021	11:23	7.8			(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	13/03/2021	12:30	7.8			(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	13/03/2021	12:18	7.7			(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	13/03/2021	13:00	7.8			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	13/03/2021	11:00	7.8			(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	13/03/2021	11:06	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	13/03/2021	09:58	7.9			(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	13/03/2021	10:04	7.9			(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	13/03/2021	10:43	<6		g/m^3		
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	13/03/2021	10:49	<6		g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	13/03/2021	10:22	<6		g/m^3		
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	13/03/2021	10:30	<6		g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	13/03/2021	11:53	<6		g/m^3		
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	13/03/2021	12:00	<6		g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	13/03/2021	12:50	<6		g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	13/03/2021	11:23	<6		g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	13/03/2021	12:30	<6		g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	13/03/2021	12:18	<6		g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	13/03/2021	13:00	<6		g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	13/03/2021	11:00	<6		g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	13/03/2021	11:06	<6		g/m^3		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	13/03/2021	09:58	<6		g/m^3		
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	13/03/2021	10:04	<6		g/m^3		
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	13/03/2021	10:43	73		$g\ CaCO3/m^3$		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	13/03/2021	10:49	71		$g\ CaCO3/m^3$		
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	13/03/2021	10:22	73		$g\ CaCO3/m^3$		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	13/03/2021	10:30	73		$g\ CaCO3/m^3$		
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	13/03/2021	11:53	72		$g\ CaCO3/m^3$		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	13/03/2021	12:00	73		$g\ CaCO3/m^3$		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	13/03/2021	12:50	68		$g\ CaCO3/m^3$		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	13/03/2021	11:23	70		$g\ CaCO3/m^3$		
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	13/03/2021	12:30	70		$g\ CaCO3/m^3$		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	13/03/2021	12:18	71		$g\ CaCO3/m^3$		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	13/03/2021	13:00	68		$g\ CaCO3/m^3$		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	13/03/2021	11:00	72		$g\ CaCO3/m^3$		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	13/03/2021	11:06	72		$g\ CaCO3/m^3$		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	13/03/2021	09:58	74		$g\ CaCO3/m^3$		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	13/03/2021	10:04	72		$g\ CaCO3/m^3$		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	13/03/2021	10:43	20.2		g/m^3		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	13/03/2021	10:49	20.4		g/m^3		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	13/03/2021	10:22	20.4		g/m^3		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	13/03/2021	10:30	20.6		g/m^3		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	13/03/2021	11:53	20.6		g/m^3		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	13/03/2021	12:00	20.6		g/m^3		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	13/03/2021	12:50	19		g/m^3		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	13/03/2021	11:23	19.8		g/m^3		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	13/03/2021	12:30	19.4		g/m^3		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	13/03/2021	12:18	20.3		g/m^3		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	13/03/2021	13:00	18.8		g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	13/03/2021	11:00	20.5		g/m^3		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	13/03/2021	11:06	20.3		g/m^3		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	13/03/2021	09:58	20.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	13/03/2021	10:04	20.3	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	13/03/2021	10:43	17.6	g/m³		
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	13/03/2021	10:49	17	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	13/03/2021	10:22	16.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	13/03/2021	10:30	16.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	13/03/2021	11:53	16.5	g/m³		
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	13/03/2021	12:00	16.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	13/03/2021	12:50	13.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	13/03/2021	11:23	13.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	13/03/2021	12:30	14.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	13/03/2021	12:18	16.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	13/03/2021	13:00	13	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	13/03/2021	11:00	16.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	13/03/2021	11:06	16.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	13/03/2021	09:58	16.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	13/03/2021	10:04	16.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	13/03/2021	10:43	22.8	g/m³		
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	13/03/2021	10:49	23.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	13/03/2021	10:22	23.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	13/03/2021	10:30	23	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	13/03/2021	11:53	23.1	g/m³		
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	13/03/2021	12:00	22.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	13/03/2021	12:50	27.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	13/03/2021	11:23	23.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	13/03/2021	12:30	23.5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	13/03/2021	12:18	22.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	13/03/2021	13:00	27.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	13/03/2021	11:00	22.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	13/03/2021	11:06	22.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	13/03/2021	09:58	22.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	13/03/2021	10:04	23.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	13/03/2021	10:43	132	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	13/03/2021	10:49	112	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	13/03/2021	10:22	120	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	13/03/2021	10:30	125	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	13/03/2021	11:53	136	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	13/03/2021	12:00	129	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	13/03/2021	12:50	134	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	13/03/2021	11:23	129	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	13/03/2021	12:30	122	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	13/03/2021	12:18	112	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	13/03/2021	13:00	115	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	13/03/2021	11:00	130	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	13/03/2021	11:06	112	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	13/03/2021	09:58	124	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	13/03/2021	10:04	115	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	13/03/2021	10:43	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	13/03/2021	10:43	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	13/03/2021	10:49	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	13/03/2021	10:22	0.012	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	13/03/2021	10:30	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	13/03/2021	11:53	0.012	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	13/03/2021	12:00	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	13/03/2021	12:30	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	13/03/2021	12:18	0.007	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	13/03/2021	11:00	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	13/03/2021	11:06	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	13/03/2021	09:58	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	13/03/2021	10:04	0.012	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	13/03/2021	10:43	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	13/03/2021	10:49	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	13/03/2021	10:22	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	13/03/2021	10:30	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	13/03/2021	11:53	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	13/03/2021	12:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	13/03/2021	12:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	13/03/2021	12:18	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	13/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	13/03/2021	11:06	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	13/03/2021	09:58	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	13/03/2021	10:04	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	13/03/2021	10:43	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	13/03/2021	10:49	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	13/03/2021	10:22	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	13/03/2021	10:30	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	13/03/2021	11:53	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	13/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	13/03/2021	12:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	13/03/2021	12:18	<0.0002	g/m³	(.004 - .004)	

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008 Cadmium - Acid Soluble	13/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008 Cadmium - Acid Soluble	13/03/2021	11:06	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008 Cadmium - Acid Soluble	13/03/2021	09:58	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008 Cadmium - Acid Soluble	13/03/2021	10:04	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010 Calcium - Acid Soluble	13/03/2021	10:43	18.1	g/m³		
	Waikouaiti SS - 192 Main Rd	6010 Calcium - Acid Soluble	13/03/2021	10:49	18.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010 Calcium - Acid Soluble	13/03/2021	10:22	19.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010 Calcium - Acid Soluble	13/03/2021	10:30	19.9	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010 Calcium - Acid Soluble	13/03/2021	11:53	18.8	g/m³		
	Karitane SS - 99 Stornoway St	6010 Calcium - Acid Soluble	13/03/2021	12:00	18.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010 Calcium - Acid Soluble	13/03/2021	12:30	17.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010 Calcium - Acid Soluble	13/03/2021	12:18	18.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010 Calcium - Acid Soluble	13/03/2021	11:00	18.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010 Calcium - Acid Soluble	13/03/2021	11:06	18.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010 Calcium - Acid Soluble	13/03/2021	09:58	18.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010 Calcium - Acid Soluble	13/03/2021	10:04	18.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013 Copper - Acid Soluble	13/03/2021	10:43	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013 Copper - Acid Soluble	13/03/2021	10:49	0.0015	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013 Copper - Acid Soluble	13/03/2021	10:22	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013 Copper - Acid Soluble	13/03/2021	10:30	0.0013	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013 Copper - Acid Soluble	13/03/2021	11:53	0.0007	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013 Copper - Acid Soluble	13/03/2021	12:00	0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013 Copper - Acid Soluble	13/03/2021	12:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013 Copper - Acid Soluble	13/03/2021	12:18	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013 Copper - Acid Soluble	13/03/2021	11:00	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013 Copper - Acid Soluble	13/03/2021	11:06	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013 Copper - Acid Soluble	13/03/2021	09:58	0.0081	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013 Copper - Acid Soluble	13/03/2021	10:04	0.0024	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017 Iron - Acid Soluble	13/03/2021	10:43	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	13/03/2021	10:49	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	13/03/2021	10:22	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	13/03/2021	10:30	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	13/03/2021	11:53	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	13/03/2021	12:00	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	13/03/2021	12:30	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	13/03/2021	12:18	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	13/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	13/03/2021	11:06	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	13/03/2021	09:58	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	13/03/2021	10:04	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	13/03/2021	10:43	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	13/03/2021	10:49	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	13/03/2021	10:22	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	13/03/2021	10:30	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	13/03/2021	11:53	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	13/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	13/03/2021	12:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	13/03/2021	12:18	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	13/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	13/03/2021	11:06	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	13/03/2021	09:58	0.0058	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	13/03/2021	10:04	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	13/03/2021	10:43	9.91	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	13/03/2021	10:49	9.74	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	13/03/2021	10:22	9.79	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	13/03/2021	10:30	9.74	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	13/03/2021	11:53	9.79	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	13/03/2021	12:00	9.78	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	13/03/2021	12:30	9.94	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	13/03/2021	12:18	9.81	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	13/03/2021	11:00	9.99	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	13/03/2021	11:06	9.85	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	13/03/2021	09:58	9.79	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	13/03/2021	10:04	9.74	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	13/03/2021	10:43	0.0011	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	13/03/2021	10:49	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	13/03/2021	10:22	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	13/03/2021	10:30	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	13/03/2021	11:53	0.001	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	13/03/2021	12:00	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	13/03/2021	12:30	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	13/03/2021	12:18	0.001	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	13/03/2021	11:00	0.0022	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	13/03/2021	11:06	0.0023	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	13/03/2021	09:58	0.0012	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	13/03/2021	10:04	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	13/03/2021	10:43	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	13/03/2021	10:49	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	13/03/2021	10:22	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	13/03/2021	10:30	<0.0005	g/m³	(.007 - .007)	

	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	13/03/2021	11:53	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	13/03/2021	12:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	13/03/2021	12:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	13/03/2021	12:18	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	13/03/2021	11:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	13/03/2021	11:06	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	13/03/2021	09:58	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	13/03/2021	10:04	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	13/03/2021	10:43	0.002	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	13/03/2021	10:49	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	13/03/2021	10:22	0.0012	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	13/03/2021	10:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	13/03/2021	11:53	0.0022	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	13/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	13/03/2021	12:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	13/03/2021	12:18	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	13/03/2021	11:00	0.0068	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	13/03/2021	11:06	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	13/03/2021	09:58	0.0092	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	13/03/2021	10:04	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	13/03/2021	10:43	<0.002	g/m³		
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	13/03/2021	10:49	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	13/03/2021	10:22	0.007	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	13/03/2021	10:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	13/03/2021	11:53	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	13/03/2021	12:00	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	13/03/2021	12:30	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	13/03/2021	12:18	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	13/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	13/03/2021	11:06	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	13/03/2021	09:58	0.128	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	13/03/2021	10:04	0.005	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	13/03/2021	12:38	137,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	13/03/2021	12:38	28.8	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	13/03/2021	12:38	0.03	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	13/03/2021	12:38	3,960	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	13/03/2021	12:38	23.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	13/03/2021	12:38	23,800	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	13/03/2021	12:38	3.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	13/03/2021	12:38	1,320	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	13/03/2021	12:38	495	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	13/03/2021	12:38	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	13/03/2021	12:38	9.8	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	13/03/2021	12:38	29	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	13/03/2021	12:50	0.021	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	13/03/2021	11:23	0.014	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	13/03/2021	13:00	0.021	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	13/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	13/03/2021	11:23	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	13/03/2021	13:00	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	13/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	13/03/2021	11:23	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	13/03/2021	13:00	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	13/03/2021	12:50	18.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	13/03/2021	11:23	19.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	13/03/2021	13:00	19.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	13/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	13/03/2021	11:23	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	13/03/2021	13:00	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	13/03/2021	12:50	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	13/03/2021	11:23	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	13/03/2021	13:00	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	13/03/2021	12:50	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	13/03/2021	11:23	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	13/03/2021	13:00	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	13/03/2021	12:50	10.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	13/03/2021	11:23	10	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	13/03/2021	13:00	10.3	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	13/03/2021	12:50	0.028	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	13/03/2021	11:23	0.02	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	13/03/2021	13:00	0.027	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	13/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	13/03/2021	11:23	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	13/03/2021	13:00	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	13/03/2021	12:50	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	13/03/2021	11:23	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	13/03/2021	13:00	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	13/03/2021	12:50	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	13/03/2021	11:23	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	13/03/2021	13:00	<0.005	g/m³		

	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	13/03/2021	10:43	0.009	g/m³			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	13/03/2021	10:49	0.009	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	13/03/2021	10:22	0.013	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	13/03/2021	10:30	0.011	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	13/03/2021	11:53	0.011	g/m³			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	13/03/2021	12:00	0.01	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	13/03/2021	12:50	0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	13/03/2021	11:23	0.002	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	13/03/2021	12:30	0.007	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	13/03/2021	12:18	0.008	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	13/03/2021	13:00	0.003	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	13/03/2021	11:00	0.011	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	13/03/2021	11:06	0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	13/03/2021	09:58	0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	13/03/2021	10:04	0.012	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	13/03/2021	10:43	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	13/03/2021	10:49	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	13/03/2021	10:22	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	13/03/2021	10:30	<0.001	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	13/03/2021	11:53	<0.001	g/m³			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	13/03/2021	12:00	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	13/03/2021	12:50	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	13/03/2021	11:23	<0.001	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	13/03/2021	12:30	<0.001	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	13/03/2021	12:18	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	13/03/2021	13:00	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	13/03/2021	11:00	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	13/03/2021	11:06	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	13/03/2021	09:58	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	13/03/2021	10:04	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	13/03/2021	10:43	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	13/03/2021	10:49	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	13/03/2021	10:22	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	13/03/2021	10:30	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	13/03/2021	11:53	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	13/03/2021	12:00	<0.0002	g/m³		(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	13/03/2021	12:50	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	13/03/2021	11:23	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	13/03/2021	12:30	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	13/03/2021	12:18	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	13/03/2021	13:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	13/03/2021	11:00	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	13/03/2021	11:06	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	13/03/2021	09:58	0.0003	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	13/03/2021	10:04	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	13/03/2021	10:43	18.9	g/m³			
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	13/03/2021	10:49	18.8	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	13/03/2021	10:22	19.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	13/03/2021	10:30	19.5	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	13/03/2021	11:53	19.2	g/m³			
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	13/03/2021	12:00	19.2	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	13/03/2021	12:50	17.7	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	13/03/2021	11:23	18.3	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	13/03/2021	12:30	18.2	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	13/03/2021	12:18	18.7	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	13/03/2021	13:00	17.5	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	13/03/2021	11:00	18.6	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	13/03/2021	11:06	18.6	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	13/03/2021	09:58	19	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	13/03/2021	10:04	19	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	13/03/2021	10:43	0.0012	g/m³		(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	13/03/2021	10:49	0.0014	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	13/03/2021	10:22	0.0009	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	13/03/2021	10:30	0.0012	g/m³		(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	13/03/2021	11:53	0.0006	g/m³		(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	13/03/2021	12:00	0.0009	g/m³		(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	13/03/2021	12:50	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	13/03/2021	11:23	0.0009	g/m³		(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	13/03/2021	12:30	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	13/03/2021	12:18	<0.0005	g/m³		(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	13/03/2021	13:00	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	13/03/2021	11:00	0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	13/03/2021	11:06	0.0006	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	13/03/2021	09:58	0.0454	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	13/03/2021	10:04	0.0022	g/m³		(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	13/03/2021	10:43	<0.01	g/m³		(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	13/03/2021	10:49	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	13/03/2021	10:22	<0.01	g/m³		(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	13/03/2021	10:30	<0.01	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	13/03/2021	11:53	<0.01	g/m³		(.2 - .2)	

	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	13/03/2021	12:00	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	13/03/2021	12:50	0.06	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	13/03/2021	11:23	0.05	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	13/03/2021	12:30	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	13/03/2021	12:18	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	13/03/2021	13:00	0.05	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	13/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	13/03/2021	11:06	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	13/03/2021	09:58	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	13/03/2021	10:04	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	13/03/2021	10:43	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	13/03/2021	10:49	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	13/03/2021	10:22	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	13/03/2021	10:30	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	13/03/2021	11:53	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	13/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	13/03/2021	12:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	13/03/2021	11:23	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	13/03/2021	12:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	13/03/2021	12:18	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	13/03/2021	13:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	13/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	13/03/2021	11:06	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	13/03/2021	09:58	0.0616	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	13/03/2021	10:04	0.0006	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	13/03/2021	10:43	9.87	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	13/03/2021	10:49	9.72	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	13/03/2021	10:22	9.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	13/03/2021	10:30	9.71	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	13/03/2021	11:53	9.67	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	13/03/2021	12:00	9.59	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	13/03/2021	12:50	9.99	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	13/03/2021	11:23	9.69	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	13/03/2021	12:30	10.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	13/03/2021	12:18	9.91	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	13/03/2021	13:00	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	13/03/2021	11:00	9.91	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	13/03/2021	11:06	9.78	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	13/03/2021	09:58	9.77	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	13/03/2021	10:04	9.55	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	13/03/2021	10:43	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	13/03/2021	10:49	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	13/03/2021	10:22	0.0012	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	13/03/2021	10:30	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	13/03/2021	11:53	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	13/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	13/03/2021	12:50	0.0043	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	13/03/2021	11:23	0.0036	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	13/03/2021	12:30	0.0009	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	13/03/2021	12:18	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	13/03/2021	13:00	0.0039	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	13/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	13/03/2021	11:06	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	13/03/2021	09:58	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	13/03/2021	10:04	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	13/03/2021	10:43	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	13/03/2021	10:49	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	13/03/2021	10:22	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	13/03/2021	10:30	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	13/03/2021	11:53	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	13/03/2021	12:00	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	13/03/2021	12:50	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	13/03/2021	11:23	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	13/03/2021	12:30	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	13/03/2021	12:18	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	13/03/2021	13:00	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	13/03/2021	11:00	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	13/03/2021	11:06	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	13/03/2021	09:58	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	13/03/2021	10:04	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	13/03/2021	10:43	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	13/03/2021	10:49	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	13/03/2021	10:22	0.02	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	13/03/2021	10:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	13/03/2021	11:53	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	13/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	13/03/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	13/03/2021	11:23	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	13/03/2021	12:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	13/03/2021	12:18	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	13/03/2021	13:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	13/03/2021	11:00	0.001	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	13/03/2021	11:06	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	13/03/2021	09:58	0.006	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	13/03/2021	10:04	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	13/03/2021	10:43	0.003	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	13/03/2021	10:49	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	13/03/2021	10:22	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	13/03/2021	10:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	13/03/2021	11:53	0.002	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	13/03/2021	12:00	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	13/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	13/03/2021	11:23	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	13/03/2021	12:30	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	13/03/2021	12:18	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	13/03/2021	13:00	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	13/03/2021	11:00	0.003	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	13/03/2021	11:06	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	13/03/2021	09:58	1.53	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	13/03/2021	10:04	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	13/03/2021	10:43	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	13/03/2021	10:49	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	13/03/2021	10:22	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	13/03/2021	10:30	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	13/03/2021	11:53	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	13/03/2021	12:00	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	13/03/2021	12:50	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	13/03/2021	11:23	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	13/03/2021	12:30	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	13/03/2021	12:18	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	13/03/2021	13:00	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	13/03/2021	11:00	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	13/03/2021	11:06	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	13/03/2021	09:58	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	13/03/2021	10:04	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	13/03/2021	10:43	6.2	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	13/03/2021	10:49	7.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	13/03/2021	10:22	7.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	13/03/2021	10:30	7.7	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	13/03/2021	11:53	7.8	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	13/03/2021	12:00	8	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	13/03/2021	12:50	9.6	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	13/03/2021	11:23	8	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	13/03/2021	12:30	8.4	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	13/03/2021	12:18	8.4	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	13/03/2021	13:00	8.8	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	13/03/2021	11:00	6.5	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	13/03/2021	11:06	9.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	13/03/2021	09:58	7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	13/03/2021	10:04	6.5	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	13/03/2021	10:43	1	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	13/03/2021	10:49	1	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	13/03/2021	10:22	0.61	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	13/03/2021	10:30	0.62	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	13/03/2021	11:53	0.92	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	13/03/2021	12:00	0.92	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	13/03/2021	12:30	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	13/03/2021	12:18	1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	13/03/2021	11:00	0.91	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	13/03/2021	11:06	0.91	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	13/03/2021	09:58	0.53	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	13/03/2021	10:04	0.59	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	13/03/2021	10:43	1.1	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	13/03/2021	10:49	1.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	13/03/2021	10:22	0.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	13/03/2021	10:30	0.8	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	13/03/2021	11:53	1.1	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	13/03/2021	12:00	1.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	13/03/2021	12:30	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	13/03/2021	12:18	1.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	13/03/2021	11:00	1.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	13/03/2021	11:06	1.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	13/03/2021	09:58	0.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	13/03/2021	10:04	0.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	13/03/2021	10:43	Complete			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/03/2021	10:22	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	13/03/2021	10:30	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/03/2021	10:22	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	13/03/2021	10:30	<1	MPN/100ml	(0 - 0)	
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	13/03/2021	00:00:00	Complete			

	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	13/03/2021	12:50	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	13/03/2021	11:23	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	13/03/2021	13:00	Complete				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	13/03/2021	10:43	Complete				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	13/03/2021	10:49	Complete				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	13/03/2021	10:22	Complete				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	13/03/2021	10:30	Complete				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	13/03/2021	11:53	Complete				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	13/03/2021	12:00	Complete				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	13/03/2021	12:50	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	13/03/2021	11:23	Complete				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	13/03/2021	12:30	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	13/03/2021	12:18	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	13/03/2021	13:00	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	13/03/2021	11:00	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	13/03/2021	11:06	Complete				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	13/03/2021	09:58	Complete				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	13/03/2021	10:04	Complete				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	13/03/2021	12:38	Complete				
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	1214	Surcharge Fee	13/03/2021	10:30:00	$100				
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	10:30:00	0.564	g/m³			
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	10:40:00	0.4	g/m³			
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	10:50:00	0.015	g/m³			
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	11:00:00	0.022	g/m³			
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	11:10:00	0.016	g/m³			
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	11:20:00	0.026	g/m³			
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	13/03/2021	11:30:00	0.016	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	13:00:00	0.01	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	13:10:00	0.009	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	13:20:00	0.009	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	13:30:00	0.009	g/m³			
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	13:40:00	0.009	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	14:00:00	0.011	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	14:10:00	0.011	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	14:20:00	0.012	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6001	Aluminium - Acid Soluble	13/03/2021	14:30:00	0.012	g/m³			
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	10:30:00	0.0003	g/m³			
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	10:40:00	0.0005	g/m³			
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	10:50:00	<0.0002	g/m³			
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	11:00:00	<0.0002	g/m³			
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	11:10:00	<0.0002	g/m³			
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	11:20:00	<0.0002	g/m³			
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	13/03/2021	11:30:00	<0.0002	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	13:00:00	0.0003	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	13:10:00	<0.0002	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	13:20:00	<0.0002	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	13:30:00	<0.0002	g/m³			
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	13:40:00	<0.0002	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	14:00:00	<0.0002	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	14:10:00	<0.0002	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	14:20:00	<0.0002	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6008	Cadmium - Acid Soluble	13/03/2021	14:30:00	<0.0002	g/m³			
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	10:30:00	1.09	g/m³			
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	10:40:00	0.988	g/m³			
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	10:50:00	0.332	g/m³			
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	11:00:00	0.34	g/m³			
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	11:10:00	0.296	g/m³			
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	11:20:00	0.348	g/m³			
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	13/03/2021	11:30:00	0.314	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6013	Copper - Acid Soluble	13/03/2021	13:00:00	0.0327	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6013	Copper - Acid Soluble	13/03/2021	13:10:00	0.02	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6013	Copper - Acid Soluble	13/03/2021	13:20:00	0.0086	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6013	Copper - Acid Soluble	13/03/2021	13:30:00	0.0057	g/m³			
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6013	Copper - Acid Soluble	13/03/2021	13:40:00	0.0056	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6013	Copper - Acid Soluble	13/03/2021	14:00:00	<0.0005	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6013	Copper - Acid Soluble	13/03/2021	14:10:00	<0.0005	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6013	Copper - Acid Soluble	13/03/2021	14:20:00	0.0007	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6013	Copper - Acid Soluble	13/03/2021	14:30:00	0.0008	g/m³			
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	10:30:00	0.71	g/m³			
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	10:40:00	0.4	g/m³			
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	10:50:00	0.09	g/m³			
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	11:00:00	0.13	g/m³			
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	11:10:00	0.06	g/m³			
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	11:20:00	0.24	g/m³			
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	13/03/2021	11:30:00	0.06	g/m³			
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6017	Iron - Acid Soluble	13/03/2021	13:00:00	<0.01	g/m³			
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6017	Iron - Acid Soluble	13/03/2021	13:10:00	<0.01	g/m³			
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6017	Iron - Acid Soluble	13/03/2021	13:20:00	<0.01	g/m³			
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6017	Iron - Acid Soluble	13/03/2021	13:30:00	<0.01	g/m³			
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6017	Iron - Acid Soluble	13/03/2021	13:40:00	<0.01	g/m³			

First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6017 Iron - Acid Soluble	13/03/2021	14:00:00	<0.01	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6017 Iron - Acid Soluble	13/03/2021	14:10:00	0.01	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6017 Iron - Acid Soluble	13/03/2021	14:20:00	<0.01	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6017 Iron - Acid Soluble	13/03/2021	14:30:00	0.01	g/m³	
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	10:30:00	0.148	g/m³	
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	10:40:00	0.0755	g/m³	
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	10:50:00	0.0266	g/m³	
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	11:00:00	0.0381	g/m³	
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	11:10:00	0.0316	g/m³	
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	11:20:00	0.0478	g/m³	
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018 Lead - Acid Soluble	13/03/2021	11:30:00	0.0342	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6018 Lead - Acid Soluble	13/03/2021	13:00:00	0.0388	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6018 Lead - Acid Soluble	13/03/2021	13:10:00	0.0291	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6018 Lead - Acid Soluble	13/03/2021	13:20:00	0.0091	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6018 Lead - Acid Soluble	13/03/2021	13:30:00	0.0029	g/m³	
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6018 Lead - Acid Soluble	13/03/2021	13:40:00	0.0011	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6018 Lead - Acid Soluble	13/03/2021	14:00:00	<0.0005	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6018 Lead - Acid Soluble	13/03/2021	14:10:00	<0.0005	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6018 Lead - Acid Soluble	13/03/2021	14:20:00	<0.0005	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6018 Lead - Acid Soluble	13/03/2021	14:30:00	<0.0005	g/m³	
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	10:30:00	0.16	g/m³	
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	10:40:00	0.106	g/m³	
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	10:50:00	0.0069	g/m³	
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	11:00:00	0.0074	g/m³	
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	11:10:00	0.0064	g/m³	
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	11:20:00	0.0089	g/m³	
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6021 Manganese - Acid Soluble	13/03/2021	11:30:00	0.0066	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	13:00:00	0.0278	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	13:10:00	0.0132	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	13:20:00	0.0052	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	13:30:00	0.0023	g/m³	
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	13:40:00	0.0009	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	14:00:00	0.0023	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	14:10:00	0.0025	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	14:20:00	0.0036	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6021 Manganese - Acid Soluble	13/03/2021	14:30:00	0.0037	g/m³	
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	10:30:00	0.0164	g/m³	
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	10:40:00	0.0273	g/m³	
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	10:50:00	0.0377	g/m³	
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	11:00:00	0.0442	g/m³	
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	11:10:00	0.0432	g/m³	
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	11:20:00	0.076	g/m³	
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024 Nickel - Acid Soluble	13/03/2021	11:30:00	0.0461	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	13:00:00	0.0072	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	13:10:00	0.0026	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	13:20:00	0.001	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	13:30:00	<0.0005	g/m³	
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	13:40:00	<0.0005	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	14:00:00	<0.0005	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	14:10:00	<0.0005	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	14:20:00	<0.0005	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6024 Nickel - Acid Soluble	13/03/2021	14:30:00	<0.0005	g/m³	
Sample 1 from meter	Karitane Bowls - Toby and meter - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	10:30:00	1.55	g/m³	
Sample 2 for handheld check	Karitane Bowls - Toby and meter - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	10:40:00	2.05	g/m³	
Sample 1 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	10:50:00	0.137	g/m³	
Sample 2 from bottle 1	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	11:00:00	0.145	g/m³	
Sample 3 from bottle 2	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	11:10:00	0.179	g/m³	
Sample 4 from bottle 4	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	11:20:00	0.421	g/m³	
Sample 5 from bottle 3	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038 Zinc - Acid Soluble	13/03/2021	11:30:00	0.189	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	13:00:00	0.999	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	13:10:00	0.991	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	13:20:00	0.324	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	13:30:00	0.095	g/m³	
Fifth 500 mL	Waikouaiti SS - 319 Bendigo Road - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	13:40:00	0.033	g/m³	
First 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	14:00:00	0.035	g/m³	
Second 250 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	14:10:00	0.018	g/m³	
Third 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	14:20:00	0.015	g/m³	
Fourth 500 mL	Waikouaiti SS - 319 Bendigo Road - Plastic Tap - Profile sample	6038 Zinc - Acid Soluble	13/03/2021	14:30:00	0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	1 pH	14/03/2021	09:20	7.8		(1 - 14)
	Waikouaiti SS - 192 Main Rd	1 pH	14/03/2021	09:25	7.9		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St - Preflush	1 pH	14/03/2021	09:30	8		(1 - 14)
	Waikouaiti SS - 210 Edinburgh St	1 pH	14/03/2021	09:35	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St - Preflush	1 pH	14/03/2021	08:40	7.9		(1 - 14)
	Karitane SS - 99 Stornoway St	1 pH	14/03/2021	08:45	7.9		(1 - 14)
	Catchment - Waikouaiti River - Pump Station Intake	1 pH	14/03/2021	08:25	7.8		(1 - 14)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1 pH	14/03/2021	08:10	7.9		(1 - 14)
	Waikouaiti WTP - Containerised Plant Filtrate	1 pH	14/03/2021	08:00	7.9		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1 pH	14/03/2021	08:05	8		(1 - 14)
	Waikouaiti WTP - Waikouaiti River ? Upstream	1 pH	14/03/2021	08:20	8		(1 - 14)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1 pH	14/03/2021	09:05	7.8		(1 - 14)

	Waikouaiti SS - Intersection Beach St/Stewart St		1	pH	14/03/2021	09:10	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		1	pH	14/03/2021	09:50	8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd		1	pH	14/03/2021	09:55	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush		2	Suspended Solids - Total	14/03/2021	09:20	<6	g/m³		
	Waikouaiti SS - 192 Main Rd		2	Suspended Solids - Total	14/03/2021	09:25	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		2	Suspended Solids - Total	14/03/2021	09:30	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St		2	Suspended Solids - Total	14/03/2021	09:35	<6	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		2	Suspended Solids - Total	14/03/2021	08:40	<6	g/m³		
	Karitane SS - 99 Stornoway St		2	Suspended Solids - Total	14/03/2021	08:45	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		2	Suspended Solids - Total	14/03/2021	08:25	<6	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		2	Suspended Solids - Total	14/03/2021	08:10	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		2	Suspended Solids - Total	14/03/2021	08:00	<6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		2	Suspended Solids - Total	14/03/2021	08:05	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		2	Suspended Solids - Total	14/03/2021	08:20	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2	Suspended Solids - Total	14/03/2021	09:05	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		2	Suspended Solids - Total	14/03/2021	09:10	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2	Suspended Solids - Total	14/03/2021	09:50	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		2	Suspended Solids - Total	14/03/2021	09:55	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		52	Alkalinity - Total	14/03/2021	09:20	72	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd		52	Alkalinity - Total	14/03/2021	09:25	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		52	Alkalinity - Total	14/03/2021	09:30	73	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St		52	Alkalinity - Total	14/03/2021	09:35	72	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush		52	Alkalinity - Total	14/03/2021	08:40	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St		52	Alkalinity - Total	14/03/2021	08:45	71	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake		52	Alkalinity - Total	14/03/2021	08:25	68	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	14/03/2021	08:10	69	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		52	Alkalinity - Total	14/03/2021	08:00	69	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	14/03/2021	08:05	70	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		52	Alkalinity - Total	14/03/2021	08:20	70	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52	Alkalinity - Total	14/03/2021	09:05	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		52	Alkalinity - Total	14/03/2021	09:10	72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52	Alkalinity - Total	14/03/2021	09:50	75	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	14/03/2021	09:55	72	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D		Dissolved Inorganic Carbon	14/03/2021	09:20	20.7	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D		Dissolved Inorganic Carbon	14/03/2021	09:25	20.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D		Dissolved Inorganic Carbon	14/03/2021	09:30	20.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D		Dissolved Inorganic Carbon	14/03/2021	09:35	20.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D		Dissolved Inorganic Carbon	14/03/2021	08:40	20.7	g/m³		
	Karitane SS - 99 Stornoway St	0440D		Dissolved Inorganic Carbon	14/03/2021	08:45	20.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D		Dissolved Inorganic Carbon	14/03/2021	08:25	20	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D		Dissolved Inorganic Carbon	14/03/2021	08:10	19.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D		Dissolved Inorganic Carbon	14/03/2021	08:00	19.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D		Dissolved Inorganic Carbon	14/03/2021	08:05	20	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D		Dissolved Inorganic Carbon	14/03/2021	08:20	20	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D		Dissolved Inorganic Carbon	14/03/2021	09:05	20.5	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D		Dissolved Inorganic Carbon	14/03/2021	09:10	20.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D		Dissolved Inorganic Carbon	14/03/2021	09:50	20.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D		Dissolved Inorganic Carbon	14/03/2021	09:55	20.1	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		602	Chloride - Add P1859 Filtration	14/03/2021	09:20	16.3	g/m³		
	Waikouaiti SS - 192 Main Rd		602	Chloride - Add P1859 Filtration	14/03/2021	09:25	16.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		602	Chloride - Add P1859 Filtration	14/03/2021	09:30	16.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St		602	Chloride - Add P1859 Filtration	14/03/2021	09:35	16.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		602	Chloride - Add P1859 Filtration	14/03/2021	08:40	16.5	g/m³		
	Karitane SS - 99 Stornoway St		602	Chloride - Add P1859 Filtration	14/03/2021	08:45	16.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		602	Chloride - Add P1859 Filtration	14/03/2021	08:25	13.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		602	Chloride - Add P1859 Filtration	14/03/2021	08:10	13.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		602	Chloride - Add P1859 Filtration	14/03/2021	08:00	14.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		602	Chloride - Add P1859 Filtration	14/03/2021	08:05	14.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		602	Chloride - Add P1859 Filtration	14/03/2021	08:20	13.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		602	Chloride - Add P1859 Filtration	14/03/2021	09:05	16.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		602	Chloride - Add P1859 Filtration	14/03/2021	09:10	16.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		602	Chloride - Add P1859 Filtration	14/03/2021	09:50	16.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		602	Chloride - Add P1859 Filtration	14/03/2021	09:55	16.4	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		607	Sulphate - Add P1859 Filtration	14/03/2021	09:20	23.1	g/m³		
	Waikouaiti SS - 192 Main Rd		607	Sulphate - Add P1859 Filtration	14/03/2021	09:25	23.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		607	Sulphate - Add P1859 Filtration	14/03/2021	09:30	23.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St		607	Sulphate - Add P1859 Filtration	14/03/2021	09:35	23.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		607	Sulphate - Add P1859 Filtration	14/03/2021	08:40	23.2	g/m³		
	Karitane SS - 99 Stornoway St		607	Sulphate - Add P1859 Filtration	14/03/2021	08:45	23.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		607	Sulphate - Add P1859 Filtration	14/03/2021	08:25	25.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		607	Sulphate - Add P1859 Filtration	14/03/2021	08:10	25.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		607	Sulphate - Add P1859 Filtration	14/03/2021	08:00	24.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		607	Sulphate - Add P1859 Filtration	14/03/2021	08:05	24.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		607	Sulphate - Add P1859 Filtration	14/03/2021	08:20	25.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		607	Sulphate - Add P1859 Filtration	14/03/2021	09:05	23.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		607	Sulphate - Add P1859 Filtration	14/03/2021	09:10	23.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		607	Sulphate - Add P1859 Filtration	14/03/2021	09:50	23.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		607	Sulphate - Add P1859 Filtration	14/03/2021	09:55	23.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		1024	Total Dissolved Solids by Evaporation	14/03/2021	09:20	143	g/m³		
	Waikouaiti SS - 192 Main Rd		1024	Total Dissolved Solids by Evaporation	14/03/2021	09:25	145	g/m³		

	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:30	126	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:35	141	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:40	125	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:45	132	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:25	124	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:10	105	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:00	114	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:05	123	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	14/03/2021	08:20	118	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:05	135	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:10	127	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:50	135	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	14/03/2021	09:55	139	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	14/03/2021	09:20	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	14/03/2021	09:20	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	14/03/2021	09:25	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	14/03/2021	09:30	0.015	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	14/03/2021	09:35	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	14/03/2021	08:40	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	14/03/2021	08:45	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	14/03/2021	08:00	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	14/03/2021	08:05	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	14/03/2021	09:05	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	14/03/2021	09:10	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	14/03/2021	09:50	0.008	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	14/03/2021	09:55	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	14/03/2021	09:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	14/03/2021	09:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	14/03/2021	09:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	14/03/2021	09:35	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	14/03/2021	08:40	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	14/03/2021	08:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	14/03/2021	08:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	14/03/2021	08:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	14/03/2021	09:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	14/03/2021	09:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	14/03/2021	09:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	14/03/2021	09:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	14/03/2021	09:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	14/03/2021	09:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	14/03/2021	09:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	14/03/2021	09:35	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	14/03/2021	08:40	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	14/03/2021	08:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	14/03/2021	08:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	14/03/2021	08:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	14/03/2021	09:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	14/03/2021	09:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	14/03/2021	09:50	0.0003	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	14/03/2021	09:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	14/03/2021	09:20	17.9	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	14/03/2021	09:25	18.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	14/03/2021	09:30	18.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	14/03/2021	09:35	18.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	14/03/2021	08:40	18.5	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	14/03/2021	08:45	18.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	14/03/2021	08:00	18	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	14/03/2021	08:05	17.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	14/03/2021	09:05	18	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	14/03/2021	09:10	18.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	14/03/2021	09:50	18.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	14/03/2021	09:55	18.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	14/03/2021	09:20	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	14/03/2021	09:25	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	14/03/2021	09:30	0.0014	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	14/03/2021	09:35	0.0007	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	14/03/2021	08:40	0.0006	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	14/03/2021	08:45	0.0008	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	14/03/2021	08:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	14/03/2021	08:05	0.0014	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	14/03/2021	09:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	14/03/2021	09:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	14/03/2021	09:50	0.0236	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	14/03/2021	09:55	0.0038	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	14/03/2021	09:20	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	14/03/2021	09:25	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	14/03/2021	09:30	0.02	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	14/03/2021	09:35	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	14/03/2021	08:40	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	14/03/2021	08:45	<0.01	g/m³		

	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	14/03/2021	08:00	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	14/03/2021	08:05	0.02	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	14/03/2021	09:05	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	14/03/2021	09:10	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	14/03/2021	09:50	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	14/03/2021	09:55	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	14/03/2021	09:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	14/03/2021	09:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	14/03/2021	09:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	14/03/2021	09:35	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	14/03/2021	08:40	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	14/03/2021	08:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	14/03/2021	08:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	14/03/2021	08:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	14/03/2021	09:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	14/03/2021	09:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	14/03/2021	09:50	0.0482	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	14/03/2021	09:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	14/03/2021	09:20	10.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	14/03/2021	09:25	10.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	14/03/2021	09:30	9.89	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	14/03/2021	09:35	9.77	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	14/03/2021	08:40	9.79	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	14/03/2021	08:45	9.78	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	14/03/2021	08:00	10.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	14/03/2021	08:05	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	14/03/2021	09:05	9.97	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	14/03/2021	09:10	9.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	14/03/2021	09:50	9.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	14/03/2021	09:55	10.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	14/03/2021	09:20	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	14/03/2021	09:25	0.0008	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	14/03/2021	09:30	0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	14/03/2021	09:35	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	14/03/2021	08:40	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	14/03/2021	08:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	14/03/2021	08:00	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	14/03/2021	08:05	0.0008	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	14/03/2021	09:05	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	14/03/2021	09:10	0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	14/03/2021	09:50	0.0007	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	14/03/2021	09:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	14/03/2021	09:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	14/03/2021	09:25	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	14/03/2021	09:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	14/03/2021	09:35	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	14/03/2021	08:40	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	14/03/2021	08:45	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	14/03/2021	08:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	14/03/2021	08:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	14/03/2021	09:05	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	14/03/2021	09:10	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	14/03/2021	09:50	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	14/03/2021	09:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	14/03/2021	09:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	14/03/2021	09:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	14/03/2021	09:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	14/03/2021	09:35	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	14/03/2021	08:40	0.0006	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	14/03/2021	08:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	14/03/2021	08:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024 Nickel - Acid Soluble	14/03/2021	08:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024 Nickel - Acid Soluble	14/03/2021	09:05	0.0022	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024 Nickel - Acid Soluble	14/03/2021	09:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024 Nickel - Acid Soluble	14/03/2021	09:50	0.0036	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024 Nickel - Acid Soluble	14/03/2021	09:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038 Zinc - Acid Soluble	14/03/2021	09:20	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd	6038 Zinc - Acid Soluble	14/03/2021	09:25	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038 Zinc - Acid Soluble	14/03/2021	09:30	0.004	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038 Zinc - Acid Soluble	14/03/2021	09:35	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038 Zinc - Acid Soluble	14/03/2021	08:40	0.006	g/m³		
	Karitane SS - 99 Stornoway St	6038 Zinc - Acid Soluble	14/03/2021	08:45	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038 Zinc - Acid Soluble	14/03/2021	08:00	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038 Zinc - Acid Soluble	14/03/2021	08:05	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038 Zinc - Acid Soluble	14/03/2021	09:05	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6038 Zinc - Acid Soluble	14/03/2021	09:10	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038 Zinc - Acid Soluble	14/03/2021	09:50	1.42	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038 Zinc - Acid Soluble	14/03/2021	09:55	0.007	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201 Aluminium - Total	14/03/2021	08:15	174,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203 Arsenic - Total	14/03/2021	08:15	28.4	mg/Kg		

	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	14/03/2021	08:15	0.22	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	14/03/2021	08:15	6,400	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	14/03/2021	08:15	20.4	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	14/03/2021	08:15	20,800	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	14/03/2021	08:15	6.7	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	14/03/2021	08:15	1,770	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	14/03/2021	08:15	1,550	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	14/03/2021	08:15	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	14/03/2021	08:15	16.2	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	14/03/2021	08:15	45	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	14/03/2021	08:25	0.017	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	14/03/2021	08:10	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	14/03/2021	08:20	0.012	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	14/03/2021	08:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	14/03/2021	08:10	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	14/03/2021	08:20	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	14/03/2021	08:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	14/03/2021	08:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	14/03/2021	08:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	14/03/2021	08:25	18.7	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	14/03/2021	08:10	19.4	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	14/03/2021	08:20	19	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	14/03/2021	08:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	14/03/2021	08:10	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	14/03/2021	08:20	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	14/03/2021	08:25	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	14/03/2021	08:10	0.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	14/03/2021	08:20	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	14/03/2021	08:25	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	14/03/2021	08:10	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	14/03/2021	08:20	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	14/03/2021	08:25	10.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	14/03/2021	08:10	10	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	14/03/2021	08:20	10	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	14/03/2021	08:25	0.029	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	14/03/2021	08:10	0.013	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	14/03/2021	08:20	0.029	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	14/03/2021	08:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	14/03/2021	08:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	14/03/2021	08:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	14/03/2021	08:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	14/03/2021	08:10	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	14/03/2021	08:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	14/03/2021	08:25	<0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	14/03/2021	08:10	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	14/03/2021	08:20	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	14/03/2021	09:20	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	14/03/2021	09:25	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	14/03/2021	09:30	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	14/03/2021	09:35	0.011	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	14/03/2021	08:40	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	14/03/2021	08:45	0.011	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	14/03/2021	08:25	0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	14/03/2021	08:10	0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	14/03/2021	08:00	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	14/03/2021	08:05	0.008	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	14/03/2021	08:20	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	14/03/2021	09:05	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	14/03/2021	09:10	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	14/03/2021	09:50	0.008	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	14/03/2021	09:55	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	14/03/2021	09:20	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	14/03/2021	09:25	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	14/03/2021	09:30	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	14/03/2021	09:35	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	14/03/2021	08:40	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	14/03/2021	08:45	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	14/03/2021	08:25	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	14/03/2021	08:10	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	14/03/2021	08:00	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	14/03/2021	08:05	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	14/03/2021	08:20	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	14/03/2021	09:05	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	14/03/2021	09:10	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	14/03/2021	09:50	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	14/03/2021	09:55	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	14/03/2021	09:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	14/03/2021	09:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	14/03/2021	09:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	14/03/2021	09:35	<0.0002	g/m³	(.004 - .004)	

	Karitane SS - 99 Stornoway St - Preflush	6708 Cadmium - Dissolved	14/03/2021	08:40	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708 Cadmium - Dissolved	14/03/2021	08:45	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708 Cadmium - Dissolved	14/03/2021	08:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708 Cadmium - Dissolved	14/03/2021	08:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708 Cadmium - Dissolved	14/03/2021	08:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708 Cadmium - Dissolved	14/03/2021	08:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708 Cadmium - Dissolved	14/03/2021	08:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708 Cadmium - Dissolved	14/03/2021	09:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708 Cadmium - Dissolved	14/03/2021	09:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708 Cadmium - Dissolved	14/03/2021	09:50	0.0005	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708 Cadmium - Dissolved	14/03/2021	09:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710 Calcium - Dissolved	14/03/2021	09:20	20.3	g/m³		
	Waikouaiti SS - 192 Main Rd	6710 Calcium - Dissolved	14/03/2021	09:25	20	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710 Calcium - Dissolved	14/03/2021	09:30	20.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710 Calcium - Dissolved	14/03/2021	09:35	20.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710 Calcium - Dissolved	14/03/2021	08:40	20.1	g/m³		
	Karitane SS - 99 Stornoway St	6710 Calcium - Dissolved	14/03/2021	08:45	20	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710 Calcium - Dissolved	14/03/2021	08:25	18.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710 Calcium - Dissolved	14/03/2021	08:10	18.7	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710 Calcium - Dissolved	14/03/2021	08:00	18.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710 Calcium - Dissolved	14/03/2021	08:05	18.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710 Calcium - Dissolved	14/03/2021	08:20	18.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710 Calcium - Dissolved	14/03/2021	09:05	18.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710 Calcium - Dissolved	14/03/2021	09:10	18.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710 Calcium - Dissolved	14/03/2021	09:50	19.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710 Calcium - Dissolved	14/03/2021	09:55	19.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713 Copper - Dissolved	14/03/2021	09:20	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713 Copper - Dissolved	14/03/2021	09:25	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713 Copper - Dissolved	14/03/2021	09:30	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713 Copper - Dissolved	14/03/2021	09:35	0.0007	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713 Copper - Dissolved	14/03/2021	08:40	0.0005	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713 Copper - Dissolved	14/03/2021	08:45	<0.0005	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713 Copper - Dissolved	14/03/2021	08:25	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713 Copper - Dissolved	14/03/2021	08:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713 Copper - Dissolved	14/03/2021	08:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713 Copper - Dissolved	14/03/2021	08:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713 Copper - Dissolved	14/03/2021	08:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713 Copper - Dissolved	14/03/2021	09:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713 Copper - Dissolved	14/03/2021	09:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713 Copper - Dissolved	14/03/2021	09:50	0.0358	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713 Copper - Dissolved	14/03/2021	09:55	0.0039	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717 Iron - Dissolved	14/03/2021	09:20	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717 Iron - Dissolved	14/03/2021	09:25	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717 Iron - Dissolved	14/03/2021	09:30	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717 Iron - Dissolved	14/03/2021	09:35	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717 Iron - Dissolved	14/03/2021	08:40	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717 Iron - Dissolved	14/03/2021	08:45	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717 Iron - Dissolved	14/03/2021	08:25	0.08	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717 Iron - Dissolved	14/03/2021	08:10	0.05	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717 Iron - Dissolved	14/03/2021	08:00	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717 Iron - Dissolved	14/03/2021	08:05	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717 Iron - Dissolved	14/03/2021	08:20	0.08	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717 Iron - Dissolved	14/03/2021	09:05	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717 Iron - Dissolved	14/03/2021	09:10	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717 Iron - Dissolved	14/03/2021	09:50	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717 Iron - Dissolved	14/03/2021	09:55	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718 Lead - Dissolved	14/03/2021	09:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6718 Lead - Dissolved	14/03/2021	09:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718 Lead - Dissolved	14/03/2021	09:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718 Lead - Dissolved	14/03/2021	09:35	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718 Lead - Dissolved	14/03/2021	08:40	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718 Lead - Dissolved	14/03/2021	08:45	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718 Lead - Dissolved	14/03/2021	08:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718 Lead - Dissolved	14/03/2021	08:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718 Lead - Dissolved	14/03/2021	08:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718 Lead - Dissolved	14/03/2021	08:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718 Lead - Dissolved	14/03/2021	08:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718 Lead - Dissolved	14/03/2021	09:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718 Lead - Dissolved	14/03/2021	09:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718 Lead - Dissolved	14/03/2021	09:50	0.0751	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718 Lead - Dissolved	14/03/2021	09:55	0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720 Magnesium - Dissolved	14/03/2021	09:20	9.83	g/m³		
	Waikouaiti SS - 192 Main Rd	6720 Magnesium - Dissolved	14/03/2021	09:25	9.92	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720 Magnesium - Dissolved	14/03/2021	09:30	9.66	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720 Magnesium - Dissolved	14/03/2021	09:35	9.59	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720 Magnesium - Dissolved	14/03/2021	08:40	9.59	g/m³		
	Karitane SS - 99 Stornoway St	6720 Magnesium - Dissolved	14/03/2021	08:45	9.63	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720 Magnesium - Dissolved	14/03/2021	08:25	9.91	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720 Magnesium - Dissolved	14/03/2021	08:10	9.94	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720 Magnesium - Dissolved	14/03/2021	08:00	10.1	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	14/03/2021	08:05	9.9	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	14/03/2021	08:20	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	14/03/2021	09:05	9.77	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	14/03/2021	09:10	9.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	14/03/2021	09:50	9.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	14/03/2021	09:55	9.63	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	14/03/2021	09:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	14/03/2021	09:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	14/03/2021	09:30	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	14/03/2021	09:35	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	14/03/2021	08:40	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	14/03/2021	08:45	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	14/03/2021	08:25	0.0142	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	14/03/2021	08:10	0.0009	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	14/03/2021	08:00	0.0008	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	14/03/2021	08:05	0.0006	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	14/03/2021	08:20	0.0152	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	14/03/2021	09:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	14/03/2021	09:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	14/03/2021	09:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	14/03/2021	09:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	14/03/2021	09:20	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	14/03/2021	09:25	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	14/03/2021	09:30	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	14/03/2021	09:35	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	14/03/2021	08:40	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	14/03/2021	08:45	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	14/03/2021	08:25	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	14/03/2021	08:10	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	14/03/2021	08:00	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	14/03/2021	08:05	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	14/03/2021	08:20	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	14/03/2021	09:05	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	14/03/2021	09:10	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	14/03/2021	09:50	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	14/03/2021	09:55	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	14/03/2021	09:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	14/03/2021	09:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	14/03/2021	09:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	14/03/2021	09:35	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	14/03/2021	08:40	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	14/03/2021	08:45	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	14/03/2021	08:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	14/03/2021	08:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	14/03/2021	08:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	14/03/2021	08:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	14/03/2021	08:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	14/03/2021	09:05	0.0019	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	14/03/2021	09:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	14/03/2021	09:50	0.0095	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	14/03/2021	09:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	14/03/2021	09:20	0.007	g/m³		
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	14/03/2021	09:25	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	14/03/2021	09:30	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	14/03/2021	09:35	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	14/03/2021	08:40	0.005	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	14/03/2021	08:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	14/03/2021	08:25	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	14/03/2021	08:10	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	14/03/2021	08:00	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	14/03/2021	08:05	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	14/03/2021	08:20	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	14/03/2021	09:05	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	14/03/2021	09:10	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	14/03/2021	09:50	1.86	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	14/03/2021	09:55	0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	14/03/2021	09:20	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	14/03/2021	09:25	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	14/03/2021	09:30	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	14/03/2021	09:35	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	14/03/2021	08:40	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	14/03/2021	08:45	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	14/03/2021	08:25	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	14/03/2021	08:10	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	14/03/2021	08:00	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	14/03/2021	08:05	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	14/03/2021	08:20	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	14/03/2021	09:05	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	14/03/2021	09:10	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	14/03/2021	09:50	Completed			

	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	14/03/2021	09:55	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420	Sampler Observation	14/03/2021	08:00	Complete			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:20	7.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:25	7.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:30	6.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:35	6.9	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:40	9.7	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:45	7.2	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:25	7	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:10	6.4	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:00	7.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:05	7	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	14/03/2021	08:20	6.7	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:05	7.4	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:10	7.3	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:50	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	14/03/2021	09:55	7.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	14/03/2021	09:20	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	14/03/2021	09:25	0.87	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	14/03/2021	09:30	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	14/03/2021	09:35	0.36	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	14/03/2021	08:40	0.09	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	14/03/2021	08:45	0.89	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	14/03/2021	08:00	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	14/03/2021	08:05	0.06	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	14/03/2021	09:05	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	14/03/2021	09:10	0.83	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	14/03/2021	09:50	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	14/03/2021	09:55	0.77	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	14/03/2021	09:20	0.1	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	14/03/2021	09:25	0.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	14/03/2021	09:30	0.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	14/03/2021	09:35	0.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	14/03/2021	08:40	0.1	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	14/03/2021	08:45	1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	14/03/2021	08:00	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	14/03/2021	08:05	0.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	14/03/2021	09:05	<0.05	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	14/03/2021	09:10	0.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	14/03/2021	09:50	<0.05	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	14/03/2021	09:55	0.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	14/03/2021	09:20	Complete			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	14/03/2021	09:30	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	14/03/2021	09:35	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	14/03/2021	09:30	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	14/03/2021	09:35	<1	MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/03/2021	08:25	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/03/2021	08:10	Complete			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/03/2021	08:20	Complete			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	14/03/2021	09:20	Complete			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	14/03/2021	09:25	Complete			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	14/03/2021	09:30	Complete			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	14/03/2021	09:35	Complete			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	14/03/2021	08:40	Complete			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	14/03/2021	08:45	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	14/03/2021	08:25	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	14/03/2021	08:10	Complete			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	14/03/2021	08:00	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	14/03/2021	08:05	Complete			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	14/03/2021	08:20	Complete			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	14/03/2021	09:05	Complete			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	14/03/2021	09:10	Complete			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	14/03/2021	09:50	Complete			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	14/03/2021	09:55	Complete			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	14/03/2021	08:15	Complete			
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	15/03/2021	14:10	7.8		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	15/03/2021	14:15	7.7		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	15/03/2021	14:25	7.8		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	15/03/2021	14:30	7.8		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	15/03/2021	13:40	7.9		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	15/03/2021	13:45	7.9		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	15/03/2021	13:20	7.7		(1 - 14)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	15/03/2021	12:55	7.8		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	15/03/2021	12:45	7.8		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	15/03/2021	12:50	7.7		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	15/03/2021	13:15	7.7		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	15/03/2021	14:00	7.8		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	15/03/2021	14:05	7.8		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1	pH	15/03/2021	14:45	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd	1	pH	15/03/2021	14:50	7.9		(1 - 14)	

	Waikouaiti SS - 192 Main Rd - Preflush		2	Suspended Solids - Total	15/03/2021	14:10	<6		g/m³		
	Waikouaiti SS - 192 Main Rd		2	Suspended Solids - Total	15/03/2021	14:15	<6		g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		2	Suspended Solids - Total	15/03/2021	14:25	<6		g/m³		
	Waikouaiti SS - 210 Edinburgh St		2	Suspended Solids - Total	15/03/2021	14:30	<6		g/m³		
	Karitane SS - 99 Stornoway St - Preflush		2	Suspended Solids - Total	15/03/2021	13:40	<6		g/m³		
	Karitane SS - 99 Stornoway St		2	Suspended Solids - Total	15/03/2021	13:45	<6		g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		2	Suspended Solids - Total	15/03/2021	13:20	<6		g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		2	Suspended Solids - Total	15/03/2021	12:55	<6		g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		2	Suspended Solids - Total	15/03/2021	12:45	<6		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		2	Suspended Solids - Total	15/03/2021	12:50	<6		g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		2	Suspended Solids - Total	15/03/2021	13:15	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2	Suspended Solids - Total	15/03/2021	14:00	<6		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		2	Suspended Solids - Total	15/03/2021	14:05	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2	Suspended Solids - Total	15/03/2021	14:45	<6		g/m³		
	Waikouaiti SS - 319 Bendigo Rd		2	Suspended Solids - Total	15/03/2021	14:50	<6		g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		52	Alkalinity - Total	15/03/2021	14:10		70	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd		52	Alkalinity - Total	15/03/2021	14:15		69	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		52	Alkalinity - Total	15/03/2021	14:25		70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St		52	Alkalinity - Total	15/03/2021	14:30		71	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush		52	Alkalinity - Total	15/03/2021	13:40		72	g CaCO3/m³		
	Karitane SS - 99 Stornoway St		52	Alkalinity - Total	15/03/2021	13:45		69	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake		52	Alkalinity - Total	15/03/2021	13:20		67	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	15/03/2021	12:55		68	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		52	Alkalinity - Total	15/03/2021	12:45		68	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	15/03/2021	12:50		68	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		52	Alkalinity - Total	15/03/2021	13:15		69	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52	Alkalinity - Total	15/03/2021	14:00		70	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		52	Alkalinity - Total	15/03/2021	14:05		70	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52	Alkalinity - Total	15/03/2021	14:45		72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	15/03/2021	14:50		72	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D		Dissolved Inorganic Carbon	15/03/2021	14:10		19.6	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D		Dissolved Inorganic Carbon	15/03/2021	14:15		19.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D		Dissolved Inorganic Carbon	15/03/2021	14:25		19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D		Dissolved Inorganic Carbon	15/03/2021	14:30		20	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D		Dissolved Inorganic Carbon	15/03/2021	13:40		19.9	g/m³		
	Karitane SS - 99 Stornoway St	0440D		Dissolved Inorganic Carbon	15/03/2021	13:45		19.9	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D		Dissolved Inorganic Carbon	15/03/2021	13:20		19.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D		Dissolved Inorganic Carbon	15/03/2021	12:55		19.4	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D		Dissolved Inorganic Carbon	15/03/2021	12:45		19.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D		Dissolved Inorganic Carbon	15/03/2021	12:50		19.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D		Dissolved Inorganic Carbon	15/03/2021	13:15		19.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D		Dissolved Inorganic Carbon	15/03/2021	14:00		19.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D		Dissolved Inorganic Carbon	15/03/2021	14:05		19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D		Dissolved Inorganic Carbon	15/03/2021	14:45		20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D		Dissolved Inorganic Carbon	15/03/2021	14:50		19.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		602	Chloride - Add P1859 Filtration	15/03/2021	14:10		16	g/m³		
	Waikouaiti SS - 192 Main Rd		602	Chloride - Add P1859 Filtration	15/03/2021	14:15		16.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		602	Chloride - Add P1859 Filtration	15/03/2021	14:25		16.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St		602	Chloride - Add P1859 Filtration	15/03/2021	14:30		16.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		602	Chloride - Add P1859 Filtration	15/03/2021	13:40		16.3	g/m³		
	Karitane SS - 99 Stornoway St		602	Chloride - Add P1859 Filtration	15/03/2021	13:45		16.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		602	Chloride - Add P1859 Filtration	15/03/2021	13:20		13.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		602	Chloride - Add P1859 Filtration	15/03/2021	12:55		13.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		602	Chloride - Add P1859 Filtration	15/03/2021	12:45		14.4	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		602	Chloride - Add P1859 Filtration	15/03/2021	12:50		14.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		602	Chloride - Add P1859 Filtration	15/03/2021	13:15		13.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		602	Chloride - Add P1859 Filtration	15/03/2021	14:00		16.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		602	Chloride - Add P1859 Filtration	15/03/2021	14:05		16.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		602	Chloride - Add P1859 Filtration	15/03/2021	14:45		16.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		602	Chloride - Add P1859 Filtration	15/03/2021	14:50		16.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		607	Sulphate - Add P1859 Filtration	15/03/2021	14:10		23.5	g/m³		
	Waikouaiti SS - 192 Main Rd		607	Sulphate - Add P1859 Filtration	15/03/2021	14:15		23.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		607	Sulphate - Add P1859 Filtration	15/03/2021	14:25		23.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St		607	Sulphate - Add P1859 Filtration	15/03/2021	14:30		23.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		607	Sulphate - Add P1859 Filtration	15/03/2021	13:40		23.6	g/m³		
	Karitane SS - 99 Stornoway St		607	Sulphate - Add P1859 Filtration	15/03/2021	13:45		23.5	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		607	Sulphate - Add P1859 Filtration	15/03/2021	13:20		23.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		607	Sulphate - Add P1859 Filtration	15/03/2021	12:55		24.2	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		607	Sulphate - Add P1859 Filtration	15/03/2021	12:45		23.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		607	Sulphate - Add P1859 Filtration	15/03/2021	12:50		24	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		607	Sulphate - Add P1859 Filtration	15/03/2021	13:15		23.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		607	Sulphate - Add P1859 Filtration	15/03/2021	14:00		23.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		607	Sulphate - Add P1859 Filtration	15/03/2021	14:05		23.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		607	Sulphate - Add P1859 Filtration	15/03/2021	14:45		23.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		607	Sulphate - Add P1859 Filtration	15/03/2021	14:50		23.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		1024	Total Dissolved Solids by Evaporation	15/03/2021	14:10		132	g/m³		
	Waikouaiti SS - 192 Main Rd		1024	Total Dissolved Solids by Evaporation	15/03/2021	14:15		128	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		1024	Total Dissolved Solids by Evaporation	15/03/2021	14:25		111	g/m³		
	Waikouaiti SS - 210 Edinburgh St		1024	Total Dissolved Solids by Evaporation	15/03/2021	14:30		137	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		1024	Total Dissolved Solids by Evaporation	15/03/2021	13:40		120	g/m³		

	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	15/03/2021	13:45	110	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	15/03/2021	13:20	111	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	15/03/2021	12:55	105	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	15/03/2021	12:45	115	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	15/03/2021	12:50	106	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	15/03/2021	13:15	122	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	15/03/2021	14:00	133	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	15/03/2021	14:05	135	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	15/03/2021	14:45	133	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	15/03/2021	14:50	127	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	15/03/2021	14:10	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	14:10	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	15/03/2021	14:15	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	14:25	0.012	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	15/03/2021	14:30	0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	13:40	0.011	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	15/03/2021	13:45	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	15/03/2021	12:45	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	15/03/2021	12:50	0.009	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	14:00	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	15/03/2021	14:05	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	14:45	0.015	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	15/03/2021	14:50	0.02	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	14:10	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	15/03/2021	14:15	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	14:25	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	15/03/2021	14:30	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	13:40	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	15/03/2021	13:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	15/03/2021	12:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	15/03/2021	12:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	14:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	15/03/2021	14:05	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	14:45	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	15/03/2021	14:50	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	15/03/2021	14:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	14:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	15/03/2021	14:30	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	15/03/2021	13:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	15/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	15/03/2021	12:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	14:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	15/03/2021	14:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	14:45	0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	15/03/2021	14:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	15/03/2021	14:10	20.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	15/03/2021	14:15	20.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	15/03/2021	14:25	21.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	15/03/2021	14:30	21.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	15/03/2021	13:40	21	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	15/03/2021	13:45	21.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	15/03/2021	12:45	20.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	15/03/2021	12:50	20.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	15/03/2021	14:00	20.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	15/03/2021	14:05	20.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	15/03/2021	14:45	21.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	15/03/2021	14:50	21.1	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	15/03/2021	14:10	0.001	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	15/03/2021	14:15	0.0015	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	15/03/2021	14:25	0.0077	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	15/03/2021	14:30	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	15/03/2021	13:40	0.0008	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	15/03/2021	13:45	0.0009	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	15/03/2021	12:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	15/03/2021	12:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	15/03/2021	14:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	15/03/2021	14:05	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	15/03/2021	14:45	0.0238	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	15/03/2021	14:50	0.0037	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	15/03/2021	14:10	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	15/03/2021	14:15	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	15/03/2021	14:25	0.08	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	15/03/2021	14:30	0.05	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	15/03/2021	13:40	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	15/03/2021	13:45	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	15/03/2021	12:45	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	15/03/2021	12:50	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	15/03/2021	14:00	0.01	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	15/03/2021	14:05	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	15/03/2021	14:45	0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	15/03/2021	14:50	0.02	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	15/03/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	15/03/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	15/03/2021	14:25	0.0032	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	15/03/2021	14:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	15/03/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	15/03/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	15/03/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	15/03/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	15/03/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	15/03/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	15/03/2021	14:45	0.0297	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	15/03/2021	14:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	14:10	9.79	g/m³	
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	15/03/2021	14:15	10	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	14:25	9.71	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	15/03/2021	14:30	9.69	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	13:40	9.7	g/m³	
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	15/03/2021	13:45	9.73	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	15/03/2021	12:45	9.91	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	15/03/2021	12:50	10.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	14:00	9.85	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	15/03/2021	14:05	9.88	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	14:45	9.79	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	15/03/2021	14:50	9.7	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	15/03/2021	14:10	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	15/03/2021	14:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	15/03/2021	14:25	0.0042	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	15/03/2021	14:30	0.0024	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	15/03/2021	13:40	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	15/03/2021	13:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	15/03/2021	12:45	0.0018	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	15/03/2021	12:50	0.0015	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	15/03/2021	14:00	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	15/03/2021	14:05	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	15/03/2021	14:45	0.027	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	15/03/2021	14:50	0.0449	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	15/03/2021	14:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	15/03/2021	14:15	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	15/03/2021	14:25	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	15/03/2021	14:30	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	15/03/2021	13:40	<0.0005	g/m³	(.007 - .007)
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	15/03/2021	13:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	15/03/2021	12:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	15/03/2021	12:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	15/03/2021	14:00	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	15/03/2021	14:05	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	15/03/2021	14:45	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	15/03/2021	14:50	<0.0005	g/m³	(.007 - .007)
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	15/03/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	15/03/2021	14:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	15/03/2021	14:25	0.001	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	15/03/2021	14:30	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	15/03/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	15/03/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	15/03/2021	12:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	15/03/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	15/03/2021	14:00	0.0022	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	15/03/2021	14:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	15/03/2021	14:45	0.0028	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	15/03/2021	14:50	0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	15/03/2021	14:10	0.007	g/m³	
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	15/03/2021	14:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	15/03/2021	14:25	0.024	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	15/03/2021	14:30	<0.002	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	15/03/2021	13:40	0.006	g/m³	
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	15/03/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	15/03/2021	12:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	15/03/2021	12:50	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	15/03/2021	14:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	15/03/2021	14:05	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	15/03/2021	14:45	1.17	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	15/03/2021	14:50	0.007	g/m³	
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	15/03/2021	13:05	18,900	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	15/03/2021	13:05	5.33	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	15/03/2021	13:05	0.01	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	15/03/2021	13:05	2,710	mg/Kg	
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	15/03/2021	13:05	5.3	mg/Kg	

	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	15/03/2021	13:05	20,300	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	15/03/2021	13:05	10.2	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	15/03/2021	13:05	2,420	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	15/03/2021	13:05	167	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	15/03/2021	13:05	<0.1	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	15/03/2021	13:05	4.9	mg/Kg			
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	15/03/2021	13:05	24	mg/Kg			
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	15/03/2021	13:20	0.013	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	15/03/2021	12:55	0.008	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	15/03/2021	13:15	0.012	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	15/03/2021	13:20	<0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	15/03/2021	12:55	<0.002	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	15/03/2021	13:15	<0.002	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	15/03/2021	13:20	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	15/03/2021	12:55	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	15/03/2021	13:15	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	15/03/2021	13:20	19.1	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	15/03/2021	12:55	18.8	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	15/03/2021	13:15	22.4	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	15/03/2021	13:20	<0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	15/03/2021	12:55	<0.002	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	15/03/2021	13:15	<0.002	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	15/03/2021	13:20	0.2	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	15/03/2021	12:55	0.2	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	15/03/2021	13:15	0.2	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	15/03/2021	13:20	<0.001	g/m³		(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	15/03/2021	12:55	<0.001	g/m³		(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	15/03/2021	13:15	<0.001	g/m³		(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	15/03/2021	13:20	9.8	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	15/03/2021	12:55	9.8	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	15/03/2021	13:15	9.9	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	15/03/2021	13:20	0.03	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	15/03/2021	12:55	0.012	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	15/03/2021	13:15	0.033	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	15/03/2021	13:20	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	15/03/2021	12:55	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	15/03/2021	13:15	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	15/03/2021	13:20	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	15/03/2021	12:55	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	15/03/2021	13:15	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	15/03/2021	13:20	<0.005	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	15/03/2021	12:55	<0.005	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	15/03/2021	13:15	0.026	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	15/03/2021	14:10	0.009	g/m³			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	15/03/2021	14:15	0.009	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	15/03/2021	14:25	0.009	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	15/03/2021	14:30	0.009	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	15/03/2021	13:40	0.01	g/m³			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	15/03/2021	13:45	0.01	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	15/03/2021	13:20	<0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	15/03/2021	12:55	<0.002	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	15/03/2021	12:45	0.008	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	15/03/2021	12:50	0.009	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	15/03/2021	13:15	<0.002	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	15/03/2021	14:00	0.01	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	15/03/2021	14:05	0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	15/03/2021	14:45	0.007	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	15/03/2021	14:50	0.01	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	15/03/2021	14:10	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	15/03/2021	14:15	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	15/03/2021	14:25	<0.001	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	15/03/2021	14:30	<0.001	g/m³			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	15/03/2021	13:40	<0.001	g/m³			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	15/03/2021	13:45	<0.001	g/m³			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	15/03/2021	13:20	<0.001	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	15/03/2021	12:55	<0.001	g/m³			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	15/03/2021	12:45	<0.001	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	15/03/2021	12:50	<0.001	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	15/03/2021	13:15	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	15/03/2021	14:00	<0.001	g/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	15/03/2021	14:05	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	15/03/2021	14:45	<0.001	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	15/03/2021	14:50	<0.001	g/m³			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	15/03/2021	14:10	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	15/03/2021	14:15	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	15/03/2021	14:25	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	15/03/2021	14:30	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	15/03/2021	13:40	<0.0002	g/m³		(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	15/03/2021	13:45	<0.0002	g/m³		(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	15/03/2021	13:20	<0.0002	g/m³		(.004 - .004)	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	15/03/2021	12:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	15/03/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	15/03/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	15/03/2021	13:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	15/03/2021	14:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	15/03/2021	14:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	15/03/2021	14:45	0.0003	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	15/03/2021	14:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	15/03/2021	14:10	20.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	15/03/2021	14:15	20.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	15/03/2021	14:25	21.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	15/03/2021	14:30	21.1	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	15/03/2021	13:40	20.9	g/m³	
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	15/03/2021	13:45	21.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	15/03/2021	13:20	19.8	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	15/03/2021	12:55	20	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	15/03/2021	12:45	20	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	15/03/2021	12:50	19.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	15/03/2021	13:15	20	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	15/03/2021	14:00	20.6	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	15/03/2021	14:05	20.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	15/03/2021	14:45	21.2	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	15/03/2021	14:50	21.3	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	15/03/2021	14:10	0.0011	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	15/03/2021	14:15	0.0014	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	15/03/2021	14:25	0.0107	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	15/03/2021	14:30	0.0009	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	15/03/2021	13:40	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	15/03/2021	13:45	0.0006	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	15/03/2021	13:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	15/03/2021	12:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	15/03/2021	12:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	15/03/2021	12:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	15/03/2021	13:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	15/03/2021	14:00	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	15/03/2021	14:05	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	15/03/2021	14:45	0.0245	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	15/03/2021	14:50	0.0021	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	15/03/2021	14:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	15/03/2021	14:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	15/03/2021	14:25	<0.01	g/m³	(.2 - .2)
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	15/03/2021	14:30	<0.01	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	15/03/2021	13:40	<0.01	g/m³	(.2 - .2)
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	15/03/2021	13:45	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	15/03/2021	13:20	0.12	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	15/03/2021	12:55	0.06	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	15/03/2021	12:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	15/03/2021	12:50	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	15/03/2021	13:15	0.1	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	15/03/2021	14:00	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	15/03/2021	14:05	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	15/03/2021	14:45	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	15/03/2021	14:50	<0.01	g/m³	
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	15/03/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	15/03/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	15/03/2021	14:25	0.0009	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	15/03/2021	14:30	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	15/03/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	15/03/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	15/03/2021	13:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	15/03/2021	12:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	15/03/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	15/03/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	15/03/2021	13:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	15/03/2021	14:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	15/03/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	15/03/2021	14:45	0.0317	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	15/03/2021	14:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	15/03/2021	14:10	9.77	g/m³	
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	15/03/2021	14:15	9.74	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	15/03/2021	14:25	9.57	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	15/03/2021	14:30	9.55	g/m³	
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	15/03/2021	13:40	9.64	g/m³	
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	15/03/2021	13:45	9.71	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	15/03/2021	13:20	9.69	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	15/03/2021	12:55	9.86	g/m³	
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	15/03/2021	12:45	9.78	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	15/03/2021	12:50	9.83	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	15/03/2021	13:15	9.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	15/03/2021	14:00	9.8	g/m³	

	Waikouaiti SS - Intersection Beach St/Stewart St		6720	Magnesium - Dissolved	15/03/2021	14:05	9.91	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6720	Magnesium - Dissolved	15/03/2021	14:45	9.72	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		6720	Magnesium - Dissolved	15/03/2021	14:50	9.75	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		6721	Manganese - Dissolved	15/03/2021	14:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd		6721	Manganese - Dissolved	15/03/2021	14:15	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush		6721	Manganese - Dissolved	15/03/2021	14:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St		6721	Manganese - Dissolved	15/03/2021	14:30	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush		6721	Manganese - Dissolved	15/03/2021	13:40	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St		6721	Manganese - Dissolved	15/03/2021	13:45	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake		6721	Manganese - Dissolved	15/03/2021	13:20	0.0227	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6721	Manganese - Dissolved	15/03/2021	12:55	0.0027	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate		6721	Manganese - Dissolved	15/03/2021	12:45	0.0018	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir		6721	Manganese - Dissolved	15/03/2021	12:50	0.0013	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream		6721	Manganese - Dissolved	15/03/2021	13:15	0.0231	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6721	Manganese - Dissolved	15/03/2021	14:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St		6721	Manganese - Dissolved	15/03/2021	14:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6721	Manganese - Dissolved	15/03/2021	14:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd		6721	Manganese - Dissolved	15/03/2021	14:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush		6722	Mercury - Dissolved	15/03/2021	14:10	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd		6722	Mercury - Dissolved	15/03/2021	14:15	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		6722	Mercury - Dissolved	15/03/2021	14:25	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St		6722	Mercury - Dissolved	15/03/2021	14:30	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		6722	Mercury - Dissolved	15/03/2021	13:40	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St		6722	Mercury - Dissolved	15/03/2021	13:45	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		6722	Mercury - Dissolved	15/03/2021	13:20	<0.0005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6722	Mercury - Dissolved	15/03/2021	12:55	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		6722	Mercury - Dissolved	15/03/2021	12:45	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		6722	Mercury - Dissolved	15/03/2021	12:50	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		6722	Mercury - Dissolved	15/03/2021	13:15	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6722	Mercury - Dissolved	15/03/2021	14:00	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		6722	Mercury - Dissolved	15/03/2021	14:05	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6722	Mercury - Dissolved	15/03/2021	14:45	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		6722	Mercury - Dissolved	15/03/2021	14:50	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		6724	Nickel - Dissolved	15/03/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd		6724	Nickel - Dissolved	15/03/2021	14:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush		6724	Nickel - Dissolved	15/03/2021	14:25	0.0025	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St		6724	Nickel - Dissolved	15/03/2021	14:30	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush		6724	Nickel - Dissolved	15/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St		6724	Nickel - Dissolved	15/03/2021	13:45	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake		6724	Nickel - Dissolved	15/03/2021	13:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6724	Nickel - Dissolved	15/03/2021	12:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate		6724	Nickel - Dissolved	15/03/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir		6724	Nickel - Dissolved	15/03/2021	12:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream		6724	Nickel - Dissolved	15/03/2021	13:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6724	Nickel - Dissolved	15/03/2021	14:00	0.0022	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St		6724	Nickel - Dissolved	15/03/2021	14:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6724	Nickel - Dissolved	15/03/2021	14:45	0.0035	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd		6724	Nickel - Dissolved	15/03/2021	14:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush		6738	Zinc - Dissolved	15/03/2021	14:10	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd		6738	Zinc - Dissolved	15/03/2021	14:15	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		6738	Zinc - Dissolved	15/03/2021	14:25	0.087	g/m³		
	Waikouaiti SS - 210 Edinburgh St		6738	Zinc - Dissolved	15/03/2021	14:30	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		6738	Zinc - Dissolved	15/03/2021	13:40	0.006	g/m³		
	Karitane SS - 99 Stornoway St		6738	Zinc - Dissolved	15/03/2021	13:45	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		6738	Zinc - Dissolved	15/03/2021	13:20	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6738	Zinc - Dissolved	15/03/2021	12:55	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		6738	Zinc - Dissolved	15/03/2021	12:45	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		6738	Zinc - Dissolved	15/03/2021	12:50	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		6738	Zinc - Dissolved	15/03/2021	13:15	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		6738	Zinc - Dissolved	15/03/2021	14:00	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		6738	Zinc - Dissolved	15/03/2021	14:05	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		6738	Zinc - Dissolved	15/03/2021	14:45	1.39	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		6738	Zinc - Dissolved	15/03/2021	14:50	0.003	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		9402	ICP-MS - 2 Elements	15/03/2021	14:10	Completed			
	Waikouaiti SS - 192 Main Rd		9402	ICP-MS - 2 Elements	15/03/2021	14:15	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush		9402	ICP-MS - 2 Elements	15/03/2021	14:25	Completed			
	Waikouaiti SS - 210 Edinburgh St		9402	ICP-MS - 2 Elements	15/03/2021	14:30	Completed			
	Karitane SS - 99 Stornoway St - Preflush		9402	ICP-MS - 2 Elements	15/03/2021	13:40	Completed			
	Karitane SS - 99 Stornoway St		9402	ICP-MS - 2 Elements	15/03/2021	13:45	Completed			
	Catchment - Waikouaiti River - Pump Station Intake		9402	ICP-MS - 2 Elements	15/03/2021	13:20	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		9402	ICP-MS - 2 Elements	15/03/2021	12:55	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate		9402	ICP-MS - 2 Elements	15/03/2021	12:45	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir		9402	ICP-MS - 2 Elements	15/03/2021	12:50	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream		9402	ICP-MS - 2 Elements	15/03/2021	13:15	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		9402	ICP-MS - 2 Elements	15/03/2021	14:00	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St		9402	ICP-MS - 2 Elements	15/03/2021	14:05	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush		9402	ICP-MS - 2 Elements	15/03/2021	14:45	Completed			
	Waikouaiti SS - 319 Bendigo Rd		9402	ICP-MS - 2 Elements	15/03/2021	14:50	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	C-O1420		Sampler Observation	15/03/2021	12:45	Complete			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F		Dissolved Oxygen - Field	15/03/2021	14:10	6.6	g O2/m³		

	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:15		7.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:25		5.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:30		5.7	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	15/03/2021	13:40		6.4	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	15/03/2021	13:45		7.3	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	15/03/2021	13:20		7.1	g O2/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	15/03/2021	12:55		6.4	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	15/03/2021	12:45		6.1	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	15/03/2021	12:50		6.5	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	15/03/2021	13:15		7.2	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:00		6.1	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:05		6.8	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:45		6.1	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	15/03/2021	14:50		7.1	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	15/03/2021	14:10	<0.05		g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	15/03/2021	14:15		1	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	15/03/2021	14:25	<0.05		g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	15/03/2021	14:30		0.3	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	15/03/2021	13:40		0.26	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	15/03/2021	13:45		1	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	15/03/2021	12:45	<0.05		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/03/2021	12:50	<0.05		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	15/03/2021	14:00	<0.05		g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	15/03/2021	14:05		0.73	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	15/03/2021	14:45	<0.05		g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	15/03/2021	14:50		1.1	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	15/03/2021	14:10	<0.05		g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	15/03/2021	14:15		1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	15/03/2021	14:25	<0.05		g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	15/03/2021	14:30		0.3	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	15/03/2021	13:40		0.3	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	15/03/2021	13:45		1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	15/03/2021	12:45	<0.05		g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	15/03/2021	12:50	<0.05		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	15/03/2021	14:00	<0.05		g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	15/03/2021	14:05		0.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	15/03/2021	14:45	<0.05		g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	15/03/2021	14:50		1.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	15/03/2021	14:10	Complete				
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/03/2021	14:25	<1		MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/03/2021	14:30	<1		MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/03/2021	14:25	<1		MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/03/2021	14:30	<1		MPN/100ml	(0 - 0)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/03/2021	13:20	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/03/2021	12:55	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	15/03/2021	13:15	Complete				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	15/03/2021	14:10	Complete				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	15/03/2021	14:15	Complete				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	15/03/2021	14:25	Complete				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	15/03/2021	14:30	Complete				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	15/03/2021	13:40	Complete				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	15/03/2021	13:45	Complete				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	15/03/2021	13:20	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	15/03/2021	12:55	Complete				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	15/03/2021	12:45	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	15/03/2021	12:50	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	15/03/2021	13:15	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	15/03/2021	14:00	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	15/03/2021	14:05	Complete				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	15/03/2021	14:45	Complete				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	15/03/2021	14:50	Complete				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	15/03/2021	13:05	Complete				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1	pH	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1	pH	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	2	Suspended Solids - Total	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	2	Suspended Solids - Total	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	52	Alkalinity - Total	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	0440D	Dissolved Inorganic Carbon	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	602	Chloride - Add P1859 Filtration	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	602	Chloride - Add P1859 Filtration	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	607	Sulphate - Add P1859 Filtration	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	607	Sulphate - Add P1859 Filtration	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	1024	Total Dissolved Solids by Evaporation	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	1024	Total Dissolved Solids by Evaporation	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6001	Aluminium - Acid Soluble	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6001	Aluminium - Acid Soluble	15/03/2021	08:36:13					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6003	Arsenic - Acid Soluble	15/03/2021	08:36:11					
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6003	Arsenic - Acid Soluble	15/03/2021	08:36:13					

	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6008	Cadmium - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6008	Cadmium - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6010	Calcium - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6010	Calcium - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6013	Copper - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6013	Copper - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6017	Iron - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6017	Iron - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6018	Lead - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6018	Lead - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6020	Magnesium - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6020	Magnesium - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6021	Manganese - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6021	Manganese - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6022	Mercury - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6022	Mercury - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6024	Nickel - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6024	Nickel - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6038	Zinc - Acid Soluble	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6038	Zinc - Acid Soluble	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6701	Aluminium - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6703	Arsenic - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6703	Arsenic - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6708	Cadmium - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6710	Calcium - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6710	Calcium - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6713	Copper - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6717	Iron - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6718	Lead - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6720	Magnesium - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6720	Magnesium - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6721	Manganese - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6722	Mercury - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6722	Mercury - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6724	Nickel - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	6738	Zinc - Dissolved	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	9402	ICP-MS - 2 Elements	15/03/2021	08:36:11	Complete			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	9402	ICP-MS - 2 Elements	15/03/2021	08:36:13	Complete			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0056F	Dissolved Oxygen - Field	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	15/03/2021	08:36:13				
	Karitane School	D-0058H	Free Available Chlorine	15/03/2021	08:36:05				
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	15/03/2021	08:36:06				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0058H	Free Available Chlorine	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	15/03/2021	08:36:13				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	D-0066H	Total Chlorine	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0066H	Total Chlorine	15/03/2021	08:36:13				
	Karitane School	D-0084	Turbidity	15/03/2021	08:36:05				
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	15/03/2021	08:36:06				
	Karitane School	D-1201	Sampling / Inspection 15 Mins	15/03/2021	08:36:05	Complete			
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	15/03/2021	08:36:06	Complete			
	Karitane School	D-1310	Temperature on arrival	15/03/2021	08:36:05				
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	15/03/2021	08:36:06				
	Karitane School	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/03/2021	08:36:05				
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/03/2021	08:36:06				
	Karitane School	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/03/2021	08:36:05				
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/03/2021	08:36:06				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd - Preflush	P1859	Sample Filtration	15/03/2021	08:36:11				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	15/03/2021	08:36:13				
	Waikouaiti SS - 192 Main Rd - Preflush	1	pH	16/03/2021	13:35	7.7		(1 - 14)	
	Waikouaiti SS - 192 Main Rd	1	pH	16/03/2021	13:55	7.7		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	1	pH	16/03/2021	11:30	7.8		(1 - 14)	
	Waikouaiti SS - 210 Edinburgh St	1	pH	16/03/2021	11:55	7.8		(1 - 14)	
	Karitane SS - 99 Stornoway St - Preflush	1	pH	16/03/2021	10:00	7.8		(1 - 14)	
	Karitane SS - 99 Stornoway St	1	pH	16/03/2021	10:20	7.8		(1 - 14)	
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	16/03/2021	15:30	7.9		(1 - 14)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1	pH	16/03/2021	14:30	7.8		(1 - 14)	
	Waikouaiti WTP - Containerised Plant Filtrate	1	pH	16/03/2021	13:40	7.8		(1 - 14)	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	16/03/2021	14:55	7.7		(1 - 14)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	1	pH	16/03/2021	15:40	7.9		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1	pH	16/03/2021	10:40	7.8		(1 - 14)	
	Waikouaiti SS - Intersection Beach St/Stewart St	1	pH	16/03/2021	11:00	7.8		(1 - 14)	

	Waikouaiti SS - 319 Bendigo Rd - Preflush		1 pH	16/03/2021	12:16	7.9		(1 - 14)	
	Waikouaiti SS - 319 Bendigo Rd		1 pH	16/03/2021	12:40	7.9		(1 - 14)	
	Waikouaiti SS - 192 Main Rd - Preflush		2 Suspended Solids - Total	16/03/2021	13:35	<6	g/m³		
	Waikouaiti SS - 192 Main Rd		2 Suspended Solids - Total	16/03/2021	13:55	<6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		2 Suspended Solids - Total	16/03/2021	11:30	24	g/m³		
	Waikouaiti SS - 210 Edinburgh St		2 Suspended Solids - Total	16/03/2021	11:55	18	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		2 Suspended Solids - Total	16/03/2021	10:00	<6	g/m³		
	Karitane SS - 99 Stornoway St		2 Suspended Solids - Total	16/03/2021	10:20	<6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		2 Suspended Solids - Total	16/03/2021	15:30	<6	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		2 Suspended Solids - Total	16/03/2021	14:30	<6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		2 Suspended Solids - Total	16/03/2021	13:40	<6	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		2 Suspended Solids - Total	16/03/2021	14:55	<6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		2 Suspended Solids - Total	16/03/2021	15:40	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		2 Suspended Solids - Total	16/03/2021	10:40	<6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		2 Suspended Solids - Total	16/03/2021	11:00	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		2 Suspended Solids - Total	16/03/2021	12:16	<6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		2 Suspended Solids - Total	16/03/2021	12:40	<6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		52 Alkalinity - Total	16/03/2021	13:35	69	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd		52 Alkalinity - Total	16/03/2021	13:55	69	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		52 Alkalinity - Total	16/03/2021	11:30	71	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St		52 Alkalinity - Total	16/03/2021	11:55	70	g CaCO3/m³		
	Karitane SS - 99 Stornoway St - Preflush		52 Alkalinity - Total	16/03/2021	10:00	70	g CaCO3/m³		
	Karitane SS - 99 Stornoway St		52 Alkalinity - Total	16/03/2021	10:20	70	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake		52 Alkalinity - Total	16/03/2021	15:30	71	g CaCO3/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52 Alkalinity - Total	16/03/2021	14:30	69	g CaCO3/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		52 Alkalinity - Total	16/03/2021	13:40	68	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		52 Alkalinity - Total	16/03/2021	14:55	68	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		52 Alkalinity - Total	16/03/2021	15:40	70	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		52 Alkalinity - Total	16/03/2021	10:40	70	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		52 Alkalinity - Total	16/03/2021	11:00	70	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		52 Alkalinity - Total	16/03/2021	12:16	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd		52 Alkalinity - Total	16/03/2021	12:40	71	g CaCO3/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	16/03/2021	13:35	19.7	g/m³		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	16/03/2021	13:55	19.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	16/03/2021	11:30	19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	16/03/2021	11:55	19.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	16/03/2021	10:00	19.7	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	16/03/2021	10:20	20	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	16/03/2021	15:30	19.3	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	16/03/2021	14:30	19.3	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	16/03/2021	13:40	19.2	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	16/03/2021	14:55	19.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	16/03/2021	15:40	19.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	16/03/2021	10:40	19.7	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	16/03/2021	11:00	19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	16/03/2021	12:16	20.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	16/03/2021	12:40	19.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		602 Chloride - Add P1859 Filtration	16/03/2021	13:35	16.6	g/m³		
	Waikouaiti SS - 192 Main Rd		602 Chloride - Add P1859 Filtration	16/03/2021	13:55	16.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		602 Chloride - Add P1859 Filtration	16/03/2021	11:30	16.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St		602 Chloride - Add P1859 Filtration	16/03/2021	11:55	16.7	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		602 Chloride - Add P1859 Filtration	16/03/2021	10:00	16.6	g/m³		
	Karitane SS - 99 Stornoway St		602 Chloride - Add P1859 Filtration	16/03/2021	10:20	16.6	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		602 Chloride - Add P1859 Filtration	16/03/2021	15:30	13.5	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		602 Chloride - Add P1859 Filtration	16/03/2021	14:30	13.5	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		602 Chloride - Add P1859 Filtration	16/03/2021	13:40	14.7	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		602 Chloride - Add P1859 Filtration	16/03/2021	14:55	16.6	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		602 Chloride - Add P1859 Filtration	16/03/2021	15:40	13.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		602 Chloride - Add P1859 Filtration	16/03/2021	10:40	16.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		602 Chloride - Add P1859 Filtration	16/03/2021	11:00	16.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush		602 Chloride - Add P1859 Filtration	16/03/2021	12:16	16.7	g/m³		
	Waikouaiti SS - 319 Bendigo Rd		602 Chloride - Add P1859 Filtration	16/03/2021	12:40	16.6	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush		607 Sulphate - Add P1859 Filtration	16/03/2021	13:35	24.1	g/m³		
	Waikouaiti SS - 192 Main Rd		607 Sulphate - Add P1859 Filtration	16/03/2021	13:55	24.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush		607 Sulphate - Add P1859 Filtration	16/03/2021	11:30	23.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St		607 Sulphate - Add P1859 Filtration	16/03/2021	11:55	24.2	g/m³		
	Karitane SS - 99 Stornoway St - Preflush		607 Sulphate - Add P1859 Filtration	16/03/2021	10:00	24.1	g/m³		
	Karitane SS - 99 Stornoway St		607 Sulphate - Add P1859 Filtration	16/03/2021	10:20	24.1	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake		607 Sulphate - Add P1859 Filtration	16/03/2021	15:30	22.5	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		607 Sulphate - Add P1859 Filtration	16/03/2021	14:30	22.6	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate		607 Sulphate - Add P1859 Filtration	16/03/2021	13:40	22.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir		607 Sulphate - Add P1859 Filtration	16/03/2021	14:55	24.2	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream		607 Sulphate - Add P1859 Filtration	16/03/2021	15:40	22.2	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush		607 Sulphate - Add P1859 Filtration	16/03/2021	10:40	23.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St		607 Sulphate - Add P1859 Filtration	16/03/2021	11:00	24.1	g/m³		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	16/03/2021	12:16	23.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	16/03/2021	12:40	23.5	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	16/03/2021	13:35	119	g/m³		
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	16/03/2021	13:55	120	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	16/03/2021	11:30	119	g/m³		
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	16/03/2021	11:55	116	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	16/03/2021	10:00	117	g/m³		
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	16/03/2021	10:20	122	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	16/03/2021	15:30	117	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	16/03/2021	14:30	122	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	16/03/2021	13:40	116	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	16/03/2021	14:55	138	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	16/03/2021	15:40	110	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	16/03/2021	10:40	130	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	16/03/2021	11:00	138	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	16/03/2021	12:16	141	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	16/03/2021	12:40	124	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	16/03/2021	13:35	$100			
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	16/03/2021	13:35	0.008	g/m³		
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	16/03/2021	13:55	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	16/03/2021	11:30	0.379	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	16/03/2021	11:55	0.328	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	16/03/2021	10:00	0.01	g/m³		
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	16/03/2021	10:20	0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	16/03/2021	13:40	0.012	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	16/03/2021	14:55	0.009	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	16/03/2021	10:40	0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	16/03/2021	11:00	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	16/03/2021	12:16	0.015	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	16/03/2021	12:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	16/03/2021	13:35	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	16/03/2021	13:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	16/03/2021	11:30	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	16/03/2021	11:55	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	16/03/2021	10:00	<0.001	g/m³	(.01 - .01)	
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	16/03/2021	10:20	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	16/03/2021	13:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	16/03/2021	14:55	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	16/03/2021	10:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	16/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	16/03/2021	12:16	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	16/03/2021	12:40	<0.001	g/m³	(.01 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	16/03/2021	13:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	16/03/2021	13:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	16/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	16/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	16/03/2021	10:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	16/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	16/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	16/03/2021	14:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	16/03/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	16/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	16/03/2021	12:16	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	16/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	16/03/2021	13:35	19.4	g/m³		
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	16/03/2021	13:55	19.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	16/03/2021	11:30	20.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	16/03/2021	11:55	20.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	16/03/2021	10:00	20.3	g/m³		
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	16/03/2021	10:20	19.8	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	16/03/2021	13:40	19.7	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	16/03/2021	14:55	19.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	16/03/2021	10:40	20.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	16/03/2021	11:00	18.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	16/03/2021	12:16	20.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	16/03/2021	12:40	19.9	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	16/03/2021	13:35	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	16/03/2021	13:55	0.0013	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	16/03/2021	11:30	0.0196	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	16/03/2021	11:55	0.0015	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	16/03/2021	10:00	0.0046	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	16/03/2021	10:20	0.0009	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	16/03/2021	13:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	16/03/2021	14:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	16/03/2021	10:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	16/03/2021	11:00	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	16/03/2021	12:16	0.0202	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	16/03/2021	12:40	0.0027	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	16/03/2021	13:35	<0.01	g/m³		

	Waikouaiti SS - 192 Main Rd	6017 Iron - Acid Soluble	16/03/2021	13:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017 Iron - Acid Soluble	16/03/2021	11:30	0.58	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6017 Iron - Acid Soluble	16/03/2021	11:55	0.53	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6017 Iron - Acid Soluble	16/03/2021	10:00	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6017 Iron - Acid Soluble	16/03/2021	10:20	<0.01	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6017 Iron - Acid Soluble	16/03/2021	13:40	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6017 Iron - Acid Soluble	16/03/2021	14:55	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017 Iron - Acid Soluble	16/03/2021	10:40	0.02	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6017 Iron - Acid Soluble	16/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017 Iron - Acid Soluble	16/03/2021	12:16	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6017 Iron - Acid Soluble	16/03/2021	12:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6018 Lead - Acid Soluble	16/03/2021	13:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd	6018 Lead - Acid Soluble	16/03/2021	13:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018 Lead - Acid Soluble	16/03/2021	11:30	0.008	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6018 Lead - Acid Soluble	16/03/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6018 Lead - Acid Soluble	16/03/2021	10:00	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6018 Lead - Acid Soluble	16/03/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6018 Lead - Acid Soluble	16/03/2021	13:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6018 Lead - Acid Soluble	16/03/2021	14:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018 Lead - Acid Soluble	16/03/2021	10:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6018 Lead - Acid Soluble	16/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018 Lead - Acid Soluble	16/03/2021	12:16	0.026	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6018 Lead - Acid Soluble	16/03/2021	12:40	0.001	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6020 Magnesium - Acid Soluble	16/03/2021	13:35	9.91	g/m³		
	Waikouaiti SS - 192 Main Rd	6020 Magnesium - Acid Soluble	16/03/2021	13:55	10.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020 Magnesium - Acid Soluble	16/03/2021	11:30	10.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6020 Magnesium - Acid Soluble	16/03/2021	11:55	9.79	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6020 Magnesium - Acid Soluble	16/03/2021	10:00	9.74	g/m³		
	Karitane SS - 99 Stornoway St	6020 Magnesium - Acid Soluble	16/03/2021	10:20	9.77	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6020 Magnesium - Acid Soluble	16/03/2021	13:40	9.65	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6020 Magnesium - Acid Soluble	16/03/2021	14:55	9.6	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020 Magnesium - Acid Soluble	16/03/2021	10:40	9.79	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6020 Magnesium - Acid Soluble	16/03/2021	11:00	9.85	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020 Magnesium - Acid Soluble	16/03/2021	12:16	9.78	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6020 Magnesium - Acid Soluble	16/03/2021	12:40	10.2	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6021 Manganese - Acid Soluble	16/03/2021	13:35	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6021 Manganese - Acid Soluble	16/03/2021	13:55	0.0017	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021 Manganese - Acid Soluble	16/03/2021	11:30	0.0249	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6021 Manganese - Acid Soluble	16/03/2021	11:55	0.0125	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6021 Manganese - Acid Soluble	16/03/2021	10:00	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6021 Manganese - Acid Soluble	16/03/2021	10:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6021 Manganese - Acid Soluble	16/03/2021	13:40	0.0131	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6021 Manganese - Acid Soluble	16/03/2021	14:55	0.0009	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021 Manganese - Acid Soluble	16/03/2021	10:40	0.0008	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6021 Manganese - Acid Soluble	16/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021 Manganese - Acid Soluble	16/03/2021	12:16	0.0102	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6021 Manganese - Acid Soluble	16/03/2021	12:40	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6022 Mercury - Acid Soluble	16/03/2021	13:35	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd	6022 Mercury - Acid Soluble	16/03/2021	13:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022 Mercury - Acid Soluble	16/03/2021	11:30	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 210 Edinburgh St	6022 Mercury - Acid Soluble	16/03/2021	11:55	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St - Preflush	6022 Mercury - Acid Soluble	16/03/2021	10:00	<0.0005	g/m³	(.007 - .007)	
	Karitane SS - 99 Stornoway St	6022 Mercury - Acid Soluble	16/03/2021	10:20	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Containerised Plant Filtrate	6022 Mercury - Acid Soluble	16/03/2021	13:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti WTP - Post Treated Water Reservoir	6022 Mercury - Acid Soluble	16/03/2021	14:55	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022 Mercury - Acid Soluble	16/03/2021	10:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6022 Mercury - Acid Soluble	16/03/2021	11:00	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022 Mercury - Acid Soluble	16/03/2021	12:16	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 319 Bendigo Rd	6022 Mercury - Acid Soluble	16/03/2021	12:40	<0.0005	g/m³	(.007 - .007)	
	Waikouaiti SS - 192 Main Rd - Preflush	6024 Nickel - Acid Soluble	16/03/2021	13:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6024 Nickel - Acid Soluble	16/03/2021	13:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024 Nickel - Acid Soluble	16/03/2021	11:30	0.0076	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6024 Nickel - Acid Soluble	16/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6024 Nickel - Acid Soluble	16/03/2021	10:00	0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6024 Nickel - Acid Soluble	16/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6024 Nickel - Acid Soluble	16/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024 Nickel - Acid Soluble	16/03/2021	14:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024 Nickel - Acid Soluble	16/03/2021	10:40	0.0039	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6024 Nickel - Acid Soluble	16/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024 Nickel - Acid Soluble	16/03/2021	12:16	0.002	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6024 Nickel - Acid Soluble	16/03/2021	12:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6038 Zinc - Acid Soluble	16/03/2021	13:35	<0.002	g/m³		
	Waikouaiti SS - 192 Main Rd	6038 Zinc - Acid Soluble	16/03/2021	13:55	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038 Zinc - Acid Soluble	16/03/2021	11:30	0.143	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6038 Zinc - Acid Soluble	16/03/2021	11:55	0.003	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6038 Zinc - Acid Soluble	16/03/2021	10:00	0.028	g/m³		
	Karitane SS - 99 Stornoway St	6038 Zinc - Acid Soluble	16/03/2021	10:20	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6038 Zinc - Acid Soluble	16/03/2021	13:40	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6038 Zinc - Acid Soluble	16/03/2021	14:55	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038 Zinc - Acid Soluble	16/03/2021	10:40	<0.002	g/m³		

	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	16/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	16/03/2021	12:16	0.799	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	16/03/2021	12:40	0.015	g/m³		
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	16/03/2021	14:22	452,000	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	16/03/2021	14:22	70.5	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	16/03/2021	14:22	0.17	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	16/03/2021	14:22	11,800	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	16/03/2021	14:22	45.3	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	16/03/2021	14:22	34,600	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	16/03/2021	14:22	5.8	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	16/03/2021	14:22	1,340	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	16/03/2021	14:22	1,970	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	16/03/2021	14:22	<0.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	16/03/2021	14:22	28.1	mg/Kg		
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	16/03/2021	14:22	81	mg/Kg		
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	16/03/2021	15:30	0.012	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	16/03/2021	14:30	0.019	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	16/03/2021	15:40	0.017	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	16/03/2021	15:30	<0.002	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	16/03/2021	14:30	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	16/03/2021	15:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	16/03/2021	15:30	<0.001	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	16/03/2021	14:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	16/03/2021	15:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	16/03/2021	15:30	19.3	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	16/03/2021	14:30	19.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	16/03/2021	15:40	19.8	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	16/03/2021	15:30	<0.002	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	16/03/2021	14:30	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	16/03/2021	15:40	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	16/03/2021	15:30	0.2	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	16/03/2021	14:30	0.3	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	16/03/2021	15:40	0.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	16/03/2021	15:30	<0.001	g/m³	(.005 - .01)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	16/03/2021	14:30	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	16/03/2021	15:40	<0.001	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	16/03/2021	15:30	9.6	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	16/03/2021	14:30	9.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	16/03/2021	15:40	9.7	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	16/03/2021	15:30	0.028	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	16/03/2021	14:30	0.021	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	16/03/2021	15:40	0.029	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	16/03/2021	15:30	<0.001	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	16/03/2021	14:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	16/03/2021	15:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	16/03/2021	15:30	<0.001	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	16/03/2021	14:30	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	16/03/2021	15:40	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	16/03/2021	15:30	<0.005	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	16/03/2021	14:30	<0.005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	16/03/2021	15:40	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	16/03/2021	13:35	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	16/03/2021	13:55	0.011	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	16/03/2021	11:30	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	16/03/2021	11:55	0.009	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	16/03/2021	10:00	0.009	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	16/03/2021	10:20	0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	16/03/2021	15:30	<0.002	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	16/03/2021	14:30	0.003	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	16/03/2021	13:40	0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	16/03/2021	14:55	0.009	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	16/03/2021	15:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	16/03/2021	10:40	0.011	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	16/03/2021	11:00	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	16/03/2021	12:16	0.006	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	16/03/2021	12:40	0.011	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	16/03/2021	13:35	<0.001	g/m³		

	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	16/03/2021	13:55	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	16/03/2021	11:30	<0.001	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	16/03/2021	11:55	<0.001	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	16/03/2021	10:00	<0.001	g/m³		
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	16/03/2021	10:20	<0.001	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	16/03/2021	15:30	<0.001	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	16/03/2021	14:30	<0.001	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	16/03/2021	13:40	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	16/03/2021	14:55	<0.001	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	16/03/2021	15:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	16/03/2021	10:40	<0.001	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	16/03/2021	11:00	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	16/03/2021	12:16	<0.001	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	16/03/2021	12:40	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	16/03/2021	13:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	16/03/2021	13:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	16/03/2021	11:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	16/03/2021	11:55	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	16/03/2021	10:00	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	16/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	16/03/2021	15:30	<0.0002	g/m³	(.004 - .004)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	16/03/2021	14:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	16/03/2021	13:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	16/03/2021	14:55	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	16/03/2021	15:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	16/03/2021	10:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	16/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	16/03/2021	12:16	0.0004	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	16/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	16/03/2021	13:35	20.6	g/m³		
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	16/03/2021	13:55	20.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	16/03/2021	11:30	20.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	16/03/2021	11:55	20.4	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	16/03/2021	10:00	20.3	g/m³		
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	16/03/2021	10:20	21	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	16/03/2021	15:30	19	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	16/03/2021	14:30	19.8	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	16/03/2021	13:40	19.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	16/03/2021	14:55	19.5	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	16/03/2021	15:40	19.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	16/03/2021	10:40	20.8	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	16/03/2021	11:00	20.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	16/03/2021	12:16	20.5	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	16/03/2021	12:40	19.8	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	16/03/2021	13:35	0.0018	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	16/03/2021	13:55	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	16/03/2021	11:30	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	16/03/2021	11:55	<0.0005	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	16/03/2021	10:00	0.0009	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	16/03/2021	10:20	0.0008	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	16/03/2021	15:30	<0.0005	g/m³	(2 - 2)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	16/03/2021	14:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	16/03/2021	13:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	16/03/2021	14:55	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	16/03/2021	15:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	16/03/2021	10:40	0.0038	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	16/03/2021	11:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	16/03/2021	12:16	0.0412	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	16/03/2021	12:40	0.0027	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	16/03/2021	13:35	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	16/03/2021	13:55	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	16/03/2021	11:30	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	16/03/2021	11:55	<0.01	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	16/03/2021	10:00	<0.01	g/m³	(.2 - .2)	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	16/03/2021	10:20	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	16/03/2021	15:30	0.08	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	16/03/2021	14:30	0.1	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	16/03/2021	13:40	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	16/03/2021	14:55	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	16/03/2021	15:40	0.09	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	16/03/2021	10:40	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	16/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	16/03/2021	12:16	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	16/03/2021	12:40	<0.01	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	16/03/2021	13:35	<0.0005	g/m³	(.005 - .01)	

	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	16/03/2021	13:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	16/03/2021	11:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	16/03/2021	11:55	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	16/03/2021	10:00	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	16/03/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	16/03/2021	15:30	<0.0005	g/m³	(.005 - .01)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	16/03/2021	14:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	16/03/2021	13:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	16/03/2021	14:55	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	16/03/2021	15:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	16/03/2021	10:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	16/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	16/03/2021	12:16	0.0566	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	16/03/2021	12:40	0.0007	g/m³	(.005 - .01)	
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	16/03/2021	13:35	10	g/m³		
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	16/03/2021	13:55	9.74	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	16/03/2021	11:30	9.92	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	16/03/2021	11:55	9.52	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	16/03/2021	10:00	9.72	g/m³		
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	16/03/2021	10:20	9.49	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	16/03/2021	15:30	9.31	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	16/03/2021	14:30	9.74	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	16/03/2021	13:40	9.75	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	16/03/2021	14:55	9.74	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	16/03/2021	15:40	9.55	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	16/03/2021	10:40	10.1	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	16/03/2021	11:00	9.74	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	16/03/2021	12:16	9.58	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	16/03/2021	12:40	9.71	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	16/03/2021	13:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	16/03/2021	13:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	16/03/2021	11:30	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	16/03/2021	11:55	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	16/03/2021	10:00	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	16/03/2021	10:20	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	16/03/2021	15:30	0.0201	g/m³	(.4 - .4)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	16/03/2021	14:30	0.0029	g/m³	(.4 - .4)	
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	16/03/2021	13:40	0.0131	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	16/03/2021	14:55	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	16/03/2021	15:40	0.0205	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	16/03/2021	10:40	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	16/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	16/03/2021	12:16	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	16/03/2021	12:40	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	16/03/2021	13:35	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	16/03/2021	13:55	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	16/03/2021	11:30	<0.0005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	16/03/2021	11:55	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	16/03/2021	10:00	<0.0005	g/m³		
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	16/03/2021	10:20	<0.0005	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	16/03/2021	15:30	<0.0005	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	16/03/2021	14:30	<0.0005	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	16/03/2021	13:40	<0.0005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	16/03/2021	14:55	<0.0005	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	16/03/2021	15:40	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	16/03/2021	10:40	<0.0005	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	16/03/2021	11:00	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	16/03/2021	12:16	<0.0005	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	16/03/2021	12:40	<0.0005	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	16/03/2021	13:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	16/03/2021	13:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	16/03/2021	11:30	0.0015	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	16/03/2021	11:55	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	16/03/2021	10:00	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	16/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	16/03/2021	15:30	<0.0005	g/m³	(.08 - .08)	
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	16/03/2021	14:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	16/03/2021	13:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	16/03/2021	14:55	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	16/03/2021	15:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	16/03/2021	10:40	0.0014	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	16/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	16/03/2021	12:16	0.0109	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	16/03/2021	12:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	16/03/2021	13:35	<0.002	g/m³		

	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	16/03/2021	13:55	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	16/03/2021	11:30	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	16/03/2021	11:55	<0.002	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	16/03/2021	10:00	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	16/03/2021	10:20	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	16/03/2021	15:30	<0.002	g/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	16/03/2021	14:30	<0.002	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	16/03/2021	13:40	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	16/03/2021	14:55	<0.002	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	16/03/2021	15:40	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	16/03/2021	10:40	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	16/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	16/03/2021	12:16	1.98	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	16/03/2021	12:40	0.009	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	16/03/2021	13:35	Completed			
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	16/03/2021	13:55	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	16/03/2021	11:30	Completed			
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	16/03/2021	11:55	Completed			
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	16/03/2021	10:00	Completed			
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	16/03/2021	10:20	Completed			
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	16/03/2021	15:30	Completed			
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	16/03/2021	14:30	Completed			
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	16/03/2021	13:40	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	16/03/2021	14:55	Completed			
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	16/03/2021	15:40	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	16/03/2021	10:40	Completed			
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	16/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	16/03/2021	12:16	Completed			
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	16/03/2021	12:40	Completed			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	16/03/2021	13:35	7.8	g O2/m³		
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	16/03/2021	13:55	7.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	16/03/2021	11:30	8.4	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	16/03/2021	11:55	8.3	g O2/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	16/03/2021	10:00	8.6	g O2/m³		
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	16/03/2021	10:20	8.3	g O2/m³		
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	16/03/2021	15:30	6.2	g O2/m³		
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	16/03/2021	14:30	7.4	g O2/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	16/03/2021	13:40	7.3	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	16/03/2021	14:55	6.2	g O2/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	16/03/2021	15:40	6.9	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	16/03/2021	10:40	7.9	g O2/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	16/03/2021	11:00	7.9	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	16/03/2021	12:16	8.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	16/03/2021	12:40	8.6	g O2/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	16/03/2021	13:35	0.31	g/m³	(0 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	16/03/2021	13:55	0.88	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	16/03/2021	11:30	0.41	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	16/03/2021	11:55	0.45	g/m³	(.2 - 5)	
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	16/03/2021	10:00	0.42	g/m³	(0 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	16/03/2021	10:20	0.89	g/m³	(.2 - 5)	
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	16/03/2021	13:40	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	16/03/2021	14:55	0.57	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	16/03/2021	10:40	0.39	g/m³	(0 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	16/03/2021	11:00	0.85	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	16/03/2021	12:16	0.32	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	16/03/2021	12:40	0.64	g/m³	(.2 - 5)	
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	16/03/2021	13:35	0.4	g/m³		
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	16/03/2021	13:55	1	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	16/03/2021	11:30	0.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	16/03/2021	11:55	0.5	g/m³		
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	16/03/2021	10:00	0.5	g/m³		
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	16/03/2021	10:20	0.9	g/m³		
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	16/03/2021	13:40	<0.05	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	16/03/2021	14:55	0.9	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	16/03/2021	10:40	0.3	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	16/03/2021	11:00	0.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	16/03/2021	12:16	0.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	16/03/2021	12:40	0.7	g/m³		
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	16/03/2021	13:35	Complete			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/03/2021	11:30	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	16/03/2021	11:55	<1	MPN/100mL	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/03/2021	11:30	<1	MPN/100ml	(0 - 0)	
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	16/03/2021	11:55	<1	MPN/100ml	(0 - 0)	
	Waikouaiti WTP - Supernatant Tube Settler	O1420	Sampler Observation	16/03/2021	13:50	Complete			
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/03/2021	15:30	Complete			
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/03/2021	14:30	Complete			

	Waikouaiti WTP - Waikouaiti River ? Upstream	P1855	Aqueous Total Metal Digestion for ICPMS codes	16/03/2021	15:40	Complete				
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	16/03/2021	13:35	Complete				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	16/03/2021	13:55	Complete				
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	16/03/2021	11:30	Complete				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	16/03/2021	11:55	Complete				
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	16/03/2021	10:00	Complete				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	16/03/2021	10:20	Complete				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	16/03/2021	15:30	Complete				
Sample taken from raw turbidity meter inside plant as raw	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	16/03/2021	14:30	Complete				
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	16/03/2021	13:40	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	16/03/2021	14:55	Complete				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	16/03/2021	15:40	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	16/03/2021	10:40	Complete				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	16/03/2021	11:00	Complete				
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	16/03/2021	12:16	Complete				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	16/03/2021	12:40	Complete				
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	16/03/2021	14:22	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	17/03/2021	15:04	69	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	17/03/2021	14:37	71	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	17/03/2021	14:22	70	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	17/03/2021	15:04	19	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	17/03/2021	14:37	19.2	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	17/03/2021	14:22	19.1	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	17/03/2021	00:00	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	17/03/2021	15:04	0.009	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	17/03/2021	14:37	0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	17/03/2021	14:22	0.011	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	17/03/2021	15:04	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	17/03/2021	14:37	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	17/03/2021	14:22	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	17/03/2021	15:04	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	17/03/2021	14:37	0.0007	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	17/03/2021	14:22	0.0021	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	17/03/2021	15:04	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	17/03/2021	14:37	<0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	17/03/2021	14:22	<0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	17/03/2021	15:04	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	17/03/2021	14:37	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	17/03/2021	14:22	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	17/03/2021	15:04	0.0007	g/m³		(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	17/03/2021	14:37	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	17/03/2021	14:22	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	17/03/2021	15:04	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	17/03/2021	14:37	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	17/03/2021	14:22	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	17/03/2021	15:04	<0.002	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	17/03/2021	14:37	<0.002	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	17/03/2021	14:22	0.006	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	9401	ICP-MS - 1 Element	17/03/2021	15:04	Completed				
	Waikouaiti SS - 210 Edinburgh St	9401	ICP-MS - 1 Element	17/03/2021	14:37	Completed				
	Waikouaiti SS - 319 Bendigo Rd	9401	ICP-MS - 1 Element	17/03/2021	14:22	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	17/03/2021	15:04	7.8				
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	17/03/2021	14:37	8				
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	17/03/2021	14:22	7.9				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	17/03/2021	15:04	16	Deg C			
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	17/03/2021	14:37	18	Deg C			
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	17/03/2021	14:22	17	Deg C			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	17/03/2021	15:04	7.7	g O2/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	17/03/2021	14:37	8	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	17/03/2021	14:22	7.2	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	17/03/2021	15:04	1.2	g/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	17/03/2021	14:37	0.34	g/m³		(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	17/03/2021	14:22	0.72	g/m³		(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	17/03/2021	00:00	Complete				
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	17/03/2021	14:22	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	17/03/2021	00:00	Complete				
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	17/03/2021	14:22	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	17/03/2021	00:00	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	17/03/2021	15:04	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	17/03/2021	14:37	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	17/03/2021	14:22	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	18/03/2021	14:46	69	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	18/03/2021	14:24	71	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	18/03/2021	14:10	71	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	18/03/2021	14:46	19	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	18/03/2021	14:24	19.4	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	18/03/2021	14:10	19.3	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	18/03/2021	14:50	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	18/03/2021	14:46	0.009	g/m³			

	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	18/03/2021	14:24	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	18/03/2021	14:10	0.011	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	18/03/2021	14:46	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	18/03/2021	14:24	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	18/03/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	18/03/2021	14:46	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	18/03/2021	14:24	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	18/03/2021	14:10	0.0044	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	18/03/2021	14:46	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	18/03/2021	14:24	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	18/03/2021	14:10	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	18/03/2021	14:46	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	18/03/2021	14:24	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	18/03/2021	14:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	18/03/2021	14:46	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	18/03/2021	14:24	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	18/03/2021	14:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	18/03/2021	14:46	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	18/03/2021	14:24	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	18/03/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	18/03/2021	14:46	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	18/03/2021	14:24	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	18/03/2021	14:10	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	18/03/2021	14:46	7.4			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	18/03/2021	14:24	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	18/03/2021	14:10	7.9			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	18/03/2021	14:46	15.5	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	18/03/2021	14:24	17.8	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	18/03/2021	14:10	16.6	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	18/03/2021	14:46	7.4	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	18/03/2021	14:24	6.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	18/03/2021	14:10	7.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	18/03/2021	14:46	1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	18/03/2021	14:24	0.38	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	18/03/2021	14:10	0.93	g/m³	(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	18/03/2021	14:50	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	18/03/2021	14:10	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	18/03/2021	14:50	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	18/03/2021	14:10	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	18/03/2021	14:50	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	18/03/2021	14:46	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	18/03/2021	14:24	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	18/03/2021	14:10	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	19/03/2021	12:05	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	19/03/2021	11:05	72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	19/03/2021	11:40	71	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	19/03/2021	12:05	19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	19/03/2021	11:05	20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	19/03/2021	11:40	20.2	g/m³		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	19/03/2021	12:15	$100			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	19/03/2021	12:05	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	19/03/2021	11:05	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	19/03/2021	11:40	0.012	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	19/03/2021	12:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	19/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	19/03/2021	11:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	19/03/2021	12:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	19/03/2021	11:05	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	19/03/2021	11:40	0.0032	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	19/03/2021	12:05	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	19/03/2021	11:05	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	19/03/2021	11:40	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	19/03/2021	12:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	19/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	19/03/2021	11:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	19/03/2021	12:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	19/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	19/03/2021	11:40	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	19/03/2021	12:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	19/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	19/03/2021	11:40	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	19/03/2021	12:05	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	19/03/2021	11:05	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	19/03/2021	11:40	0.006	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	19/03/2021	12:05	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	19/03/2021	11:05	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	19/03/2021	11:40	8			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	19/03/2021	12:05	15.2	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	19/03/2021	11:05	17.7	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	19/03/2021	11:40	16.4	Deg C		

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	19/03/2021	12:05	6.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	19/03/2021	11:05	6.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	19/03/2021	11:40	7	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	19/03/2021	12:05	1.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	19/03/2021	11:05	0.28	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	19/03/2021	11:40	0.73	g/m³	(.2 - 5)	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	19/03/2021	12:15	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	19/03/2021	11:40	Completed			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	19/03/2021	12:15	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	19/03/2021	11:40	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	19/03/2021	12:05	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	19/03/2021	11:05	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	19/03/2021	11:40	Complete			
	TAB Waikouaiti	D-0058H	Free Available Chlorine	19/03/2021	11:20	0.81	g/m³	(.2 - 5)	
	TAB Waikouaiti	D-0066H	Total Chlorine	19/03/2021	11:20	0.9	g/m³		
	TAB Waikouaiti	D-0084	Turbidity	19/03/2021	11:20	0.12	NTU		
	TAB Waikouaiti	D-1310	Temperature on arrival	19/03/2021	11:20	7.2	Deg C		
	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	19/03/2021	11:20	<1	MPN/100mL	(0 - 0)	
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	19/03/2021	11:20	<1	MPN/100ml	(0 - 0)	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	1	pH	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	52	Alkalinity - Total	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	55	Conductivity at 25°C - mS/m unit	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	0440D	Dissolved Inorganic Carbon	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	702	Chloride - Ultra Trace	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	707	Sulphate - Ultra Trace	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	19/03/2021	08:41:35				

#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:28				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:29				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:30				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:31				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:31				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:31				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:32				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:34				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:34				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	D-0056F	Dissolved Oxygen - Field	19/03/2021	08:41:35				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	D-1202	Sampling / Inspection 30 Mins	19/03/2021	08:41:28	Completed			
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	O0994b	Flow Rate performed by ELS	19/03/2021	08:41:35				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	1	pH	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	52	Alkalinity - Total	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	55	Conductivity at 25°C - mS/m unit	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	0440D	Dissolved Inorganic Carbon	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	702	Chloride - Ultra Trace	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	707	Sulphate - Ultra Trace	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:19				

#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:15				
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:16				
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:17				
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:18				
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:19				
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:19				
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:20				
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:21				
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:22				
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:23				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	19/03/2021	08:45:24				
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	D-0056F	Dissolved Oxygen - Field	19/03/2021	08:45:24				
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	D-1202	Sampling / Inspection 30 Mins	19/03/2021	08:45:15	Completed			
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	O0994b	Flow Rate performed by ELS	19/03/2021	08:45:24				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	20/03/2021	14:20	69	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	20/03/2021	13:57	71	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	20/03/2021	13:44	70	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	20/03/2021	14:20	19.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	20/03/2021	13:57	20.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	20/03/2021	13:44	20.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	20/03/2021	00:00:00	$100			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	20/03/2021	14:20	0.007	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	20/03/2021	13:57	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	20/03/2021	13:44	0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	20/03/2021	14:20	<0.0002	g/m³		(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	20/03/2021	13:57	<0.0002	g/m³		(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	20/03/2021	13:44	<0.0002	g/m³		(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	20/03/2021	14:20	<0.0005	g/m³		(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	20/03/2021	13:57	0.0008	g/m³		(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	20/03/2021	13:44	0.0029	g/m³		(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	20/03/2021	14:20	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	20/03/2021	13:57	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	20/03/2021	13:44	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	20/03/2021	14:20	<0.0005	g/m³		(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	20/03/2021	13:57	<0.0005	g/m³		(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	20/03/2021	13:44	<0.0005	g/m³		(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	20/03/2021	14:20	<0.0005	g/m³		(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	20/03/2021	13:57	<0.0005	g/m³		(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	20/03/2021	13:44	<0.0005	g/m³		(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	20/03/2021	14:20	<0.0005	g/m³		(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	20/03/2021	13:57	<0.0005	g/m³		(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	20/03/2021	13:44	<0.0005	g/m³		(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	20/03/2021	14:20	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	20/03/2021	13:57	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	20/03/2021	13:44	0.006	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	20/03/2021	14:20	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	20/03/2021	13:57	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	20/03/2021	13:44	7.9			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	20/03/2021	14:20	15.1	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	20/03/2021	13:57	17.5	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	20/03/2021	13:44	16.3	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	20/03/2021	14:20	7.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	20/03/2021	13:57	7.1	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	20/03/2021	13:44	7.6	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	20/03/2021	14:20	0.86	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	20/03/2021	13:57	0.47	g/m³		(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	20/03/2021	13:44	0.74	g/m³		(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	20/03/2021	00:00:00	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	20/03/2021	13:44	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	20/03/2021	00:00:00	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	20/03/2021	13:44	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	20/03/2021	00:00:00	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	20/03/2021	14:20	Completed			

	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	20/03/2021	13:57	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	20/03/2021	13:44	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	21/03/2021	08:37	70	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	21/03/2021	08:13	73	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	21/03/2021	07:57	71	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	21/03/2021	08:37	20.3	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	21/03/2021	08:13	20.3	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	21/03/2021	07:57	20.2	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	21/03/2021	00:00	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	21/03/2021	08:37	0.007	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	21/03/2021	08:13	0.011	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	21/03/2021	07:57	0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	21/03/2021	08:37	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	21/03/2021	08:13	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	21/03/2021	07:57	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	21/03/2021	08:37	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	21/03/2021	08:13	0.0007	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	21/03/2021	07:57	0.0032	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	21/03/2021	08:37	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	21/03/2021	08:13	<0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	21/03/2021	07:57	<0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	21/03/2021	08:37	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	21/03/2021	08:13	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	21/03/2021	07:57	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	21/03/2021	08:37	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	21/03/2021	08:13	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	21/03/2021	07:57	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	21/03/2021	08:37	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	21/03/2021	08:13	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	21/03/2021	07:57	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	21/03/2021	08:37	<0.002	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	21/03/2021	08:13	<0.002	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	21/03/2021	07:57	0.009	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	21/03/2021	08:37	7.9				
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	21/03/2021	08:13	8.1				
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	21/03/2021	07:57	8				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	21/03/2021	08:37	15.2	Deg C			
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	21/03/2021	08:13	16.4	Deg C			
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	21/03/2021	07:57	15.4	Deg C			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	21/03/2021	08:37	7.4	g O2/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	21/03/2021	08:13	6.3	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	21/03/2021	07:57	6.9	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	21/03/2021	08:37	0.84	g/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	21/03/2021	08:13	0.32	g/m³		(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	21/03/2021	07:57	0.74	g/m³		(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	21/03/2021	00:00	Complete				
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	21/03/2021	07:57	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	21/03/2021	00:00	Complete				
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	21/03/2021	07:57	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	21/03/2021	00:00	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	21/03/2021	08:37	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	21/03/2021	08:13	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	21/03/2021	07:57	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	22/03/2021	08:50	69	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	22/03/2021	08:25	71	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	22/03/2021	08:10	73	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	22/03/2021	08:50	19.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	22/03/2021	08:25	20	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	22/03/2021	08:10	20.5	g/m³			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	22/03/2021	09:00	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	22/03/2021	08:50	0.007	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	22/03/2021	08:25	0.011	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	22/03/2021	08:10	0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	22/03/2021	08:50	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	22/03/2021	08:25	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	22/03/2021	08:10	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	22/03/2021	08:50	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	22/03/2021	08:25	0.0009	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	22/03/2021	08:10	0.0029	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	22/03/2021	08:50	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	22/03/2021	08:25	<0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	22/03/2021	08:10	<0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	22/03/2021	08:50	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	22/03/2021	08:25	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	22/03/2021	08:10	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	22/03/2021	08:50	0.0008	g/m³		(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	22/03/2021	08:25	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	22/03/2021	08:10	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	22/03/2021	08:50	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	22/03/2021	08:25	<0.0005	g/m³		(.08 - .08)	

	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	22/03/2021	08:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	22/03/2021	08:50	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	22/03/2021	08:25	0.003	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	22/03/2021	08:10	0.007	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	22/03/2021	08:50	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	22/03/2021	08:25	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	22/03/2021	08:10	7.8			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	22/03/2021	08:50	15.1	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	22/03/2021	08:25	17.1	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	22/03/2021	08:10	16.1	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	22/03/2021	08:50	7.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	22/03/2021	08:25	7.3	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	22/03/2021	08:10	7.3	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/03/2021	08:50	0.59	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	22/03/2021	08:25	0.11	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	22/03/2021	08:10	0.54	g/m³	(.2 - 5)	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	22/03/2021	09:00	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	22/03/2021	08:10	Completed			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	22/03/2021	09:00	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	22/03/2021	08:10	Complete			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	22/03/2021	09:00	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	22/03/2021	08:50	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	22/03/2021	08:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	22/03/2021	08:10	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	23/03/2021	11:05	<5	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	23/03/2021	11:00	<5	g/m³		
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	23/03/2021	13:33	73	g CaCO3/m³		
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	23/03/2021	12:00	73	g CaCO3/m³		
	Karitane Bowls	52	Alkalinity - Total	23/03/2021	12:06	72	g CaCO3/m³		
	Waikouaiti Golf Club	52	Alkalinity - Total	23/03/2021	13:50	74	g CaCO3/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	23/03/2021	11:35	73	g CaCO3/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	23/03/2021	13:05	73	g CaCO3/m³		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	23/03/2021	12:40	72	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	23/03/2021	11:05	70	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	23/03/2021	11:00	69	g CaCO3/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	23/03/2021	12:45	73	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	55	Conductivity at 25°C - mS/m unit	23/03/2021	11:05	23.9	mS/m (239.2 x .1)		
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	23/03/2021	11:00	24.1	mS/m (241.2 x .1)		
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	23/03/2021	13:33	20.6	g/m³		
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	23/03/2021	12:00	20.4	g/m³		
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	23/03/2021	12:06	20.4	g/m³		
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	23/03/2021	13:50	20	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	23/03/2021	11:35	20.4	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	23/03/2021	13:05	20.2	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	23/03/2021	12:40	20	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	23/03/2021	11:05	19.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	23/03/2021	11:00	19.8	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	23/03/2021	12:45	19.9	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	23/03/2021	11:05	13.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	23/03/2021	11:00	14.4	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	23/03/2021	11:05	22.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	23/03/2021	11:00	20.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	23/03/2021	11:05	139	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	23/03/2021	11:00	139	g/m³		
	Waikouaiti SS - 192 Main Rd	1214	Surcharge Fee	23/03/2021	13:33	$100			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	23/03/2021	11:00	0.016	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	23/03/2021	11:00	<0.001	g/m³	(.01 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	23/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	23/03/2021	11:00	24.8	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	23/03/2021	11:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	23/03/2021	11:00	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	23/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	23/03/2021	11:00	9.59	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	23/03/2021	11:00	0.017	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	23/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	23/03/2021	11:00	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	23/03/2021	11:05	0.012	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	23/03/2021	11:05	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	23/03/2021	11:05	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	23/03/2021	11:05	19.1	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	23/03/2021	11:05	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	23/03/2021	11:05	0.2	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	23/03/2021	11:05	<0.001	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	23/03/2021	11:05	9.5	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	23/03/2021	11:05	0.016	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	23/03/2021	11:05	<0.001	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	23/03/2021	11:05	<0.005	g/m³		
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	23/03/2021	13:33	0.009	g/m³		
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	23/03/2021	12:00	0.01	g/m³		
	Karitane Bowls	6701	Aluminium - Dissolved	23/03/2021	12:06	0.01	g/m³		

	Waikouaiti Golf Club	6701	Aluminium - Dissolved	23/03/2021	13:50	0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	23/03/2021	11:35	0.008	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	23/03/2021	13:05	0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	23/03/2021	12:40	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	23/03/2021	11:05	0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	23/03/2021	11:00	0.014	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	23/03/2021	12:45	<0.002	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	23/03/2021	11:05	<0.001	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	23/03/2021	11:00	<0.001	g/m³		
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	23/03/2021	13:33	<0.0002	g/m³	(.004 - .004)	
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	23/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Karitane Bowls	6708	Cadmium - Dissolved	23/03/2021	12:06	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	23/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	23/03/2021	11:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	23/03/2021	13:05	<0.0002	g/m³	(.004 - .004)	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	23/03/2021	12:40	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	23/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	23/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	23/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	23/03/2021	11:05	19.9	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	23/03/2021	11:00	20.2	g/m³		
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	23/03/2021	13:33	0.0011	g/m³	(2 - 2)	
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	23/03/2021	12:00	0.0007	g/m³	(2 - 2)	
	Karitane Bowls	6713	Copper - Dissolved	23/03/2021	12:06	0.0032	g/m³	(2 - 2)	
	Waikouaiti Golf Club	6713	Copper - Dissolved	23/03/2021	13:50	0.0114	g/m³	(2 - 2)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	23/03/2021	11:35	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	23/03/2021	13:05	0.0005	g/m³	(2 - 2)	
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	23/03/2021	12:40	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	23/03/2021	12:45	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	23/03/2021	13:33	<0.01	g/m³		
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	23/03/2021	12:00	<0.01	g/m³		
	Karitane Bowls	6717	Iron - Dissolved	23/03/2021	12:06	<0.01	g/m³	(.2 - .2)	
	Waikouaiti Golf Club	6717	Iron - Dissolved	23/03/2021	13:50	<0.01	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	23/03/2021	11:35	<0.01	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	23/03/2021	13:05	<0.01	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	23/03/2021	12:40	0.09	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	23/03/2021	11:05	0.09	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	23/03/2021	11:00	<0.01	g/m³		
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	23/03/2021	12:45	0.09	g/m³		
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	23/03/2021	13:33	<0.0005	g/m³	(.005 - .01)	
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	23/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Karitane Bowls	6718	Lead - Dissolved	23/03/2021	12:06	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti Golf Club	6718	Lead - Dissolved	23/03/2021	13:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	23/03/2021	11:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	23/03/2021	13:05	<0.0005	g/m³	(.005 - .01)	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	23/03/2021	12:40	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	23/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	23/03/2021	11:05	10.3	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	23/03/2021	11:00	9.86	g/m³		
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	23/03/2021	13:33	<0.0005	g/m³	(.4 - .4)	
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	23/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Karitane Bowls	6721	Manganese - Dissolved	23/03/2021	12:06	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti Golf Club	6721	Manganese - Dissolved	23/03/2021	13:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	23/03/2021	11:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	23/03/2021	13:05	<0.0005	g/m³	(.4 - .4)	
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	23/03/2021	12:40	0.0143	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	23/03/2021	11:05	0.0082	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	23/03/2021	11:00	0.0174	g/m³	(.4 - .4)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	23/03/2021	12:45	0.0233	g/m³	(.4 - .4)	
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	23/03/2021	13:33	<0.0005	g/m³	(.08 - .08)	
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	23/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Karitane Bowls	6724	Nickel - Dissolved	23/03/2021	12:06	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti Golf Club	6724	Nickel - Dissolved	23/03/2021	13:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	23/03/2021	11:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	23/03/2021	13:05	<0.0005	g/m³	(.08 - .08)	
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	23/03/2021	12:40	0.0006	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	23/03/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	23/03/2021	13:33	<0.002	g/m³		
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	23/03/2021	12:00	<0.002	g/m³		
	Karitane Bowls	6738	Zinc - Dissolved	23/03/2021	12:06	0.003	g/m³		
	Waikouaiti Golf Club	6738	Zinc - Dissolved	23/03/2021	13:50	0.035	g/m³		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	23/03/2021	11:35	<0.002	g/m³		
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	23/03/2021	13:05	<0.002	g/m³		
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	23/03/2021	12:40	<0.002	g/m³		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	23/03/2021	11:05	<0.002	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	23/03/2021	11:00	<0.002	g/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	23/03/2021	12:45	<0.002	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	23/03/2021	11:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	23/03/2021	11:00	Completed				
	Karitane School	C-O1420	Sampler Observation	23/03/2021	00:00	Complete				
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	23/03/2021	13:33	7.8				
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	23/03/2021	12:00	7.9				
	Karitane Bowls	D-0001F	pH - Field	23/03/2021	12:06	7.9				
	Waikouaiti Golf Club	D-0001F	pH - Field	23/03/2021	13:50	8				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	23/03/2021	11:35	7.8				
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	23/03/2021	13:05	7.9				
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	23/03/2021	12:40	7.7				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	23/03/2021	11:05	764				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	23/03/2021	11:00	7.6				
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	23/03/2021	12:45	7.7				
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	23/03/2021	13:33	16.3	Deg C			
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	23/03/2021	12:00	15.4	Deg C			
	Karitane Bowls	D-0053F	Temperature - Field	23/03/2021	12:06	15.3	Deg C			
	Waikouaiti Golf Club	D-0053F	Temperature - Field	23/03/2021	13:50	15.7	Deg C			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	23/03/2021	11:35	15.8	Deg C			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	23/03/2021	13:05	17.1	Deg C			
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	23/03/2021	12:40	15	Deg C			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	23/03/2021	11:05	14.9	Deg C			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	23/03/2021	11:00	15	Deg C			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	23/03/2021	12:45	15	Deg C			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	23/03/2021	13:33	7.3	g O2/m³			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	23/03/2021	12:00	7	g O2/m³			
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	23/03/2021	12:06	7.2	g O2/m³			
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	23/03/2021	13:50	6.5	g O2/m³			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	23/03/2021	11:35	7	g O2/m³			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	23/03/2021	13:05	6.9	g O2/m³			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	23/03/2021	12:40	6.8	g O2/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	23/03/2021	11:05	6.1	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	23/03/2021	11:00	6.2	g O2/m³			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	23/03/2021	12:45	6.7	g O2/m³			
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	23/03/2021	12:24	0.65	g/m³		(.2 - 5)	
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	23/03/2021	13:33	0.62	g/m³		(.2 - 5)	
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	23/03/2021	12:00	0.54	g/m³		(.2 - 5)	
	Karitane Bowls	D-0058H	Free Available Chlorine	23/03/2021	12:06	0.67	g/m³		(.2 - 5)	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	23/03/2021	13:50	0.4	g/m³			
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	23/03/2021	11:35	0.65	g/m³		(.2 - 5)	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	23/03/2021	13:05	0.67	g/m³		(.2 - 5)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	23/03/2021	11:00	<0.05	g/m³			
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	23/03/2021	12:24	0.32	NTU			
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	23/03/2021	12:24	Completed				
	Waikouaiti SS - 192 Main Rd	D-1201	Sampling / Inspection 15 Mins	23/03/2021	13:33	Completed				
	Karitane SS - 99 Stornoway St	D-1201	Sampling / Inspection 15 Mins	23/03/2021	12:00	Completed				
	Karitane Bowls	D-1201	Sampling / Inspection 15 Mins	23/03/2021	12:06	Completed				
	Waikouaiti Golf Club	D-1201	Sampling / Inspection 15 Mins	23/03/2021	13:50	Completed				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-1201	Sampling / Inspection 15 Mins	23/03/2021	11:35	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	D-1201	Sampling / Inspection 15 Mins	23/03/2021	13:05	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	D-1201	Sampling / Inspection 15 Mins	23/03/2021	12:40	Complete				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1201	Sampling / Inspection 15 Mins	23/03/2021	11:05	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	D-1201	Sampling / Inspection 15 Mins	23/03/2021	11:00	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-1201	Sampling / Inspection 15 Mins	23/03/2021	12:45	Complete				
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	23/03/2021	12:24	4.6	Deg C			
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	23/03/2021	12:24	<1	MPN/100mL		(0 - 0)	
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	23/03/2021	12:24	<1	MPN/100ml		(0 - 0)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	23/03/2021	11:05	Completed				
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	23/03/2021	13:33	Completed				
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	23/03/2021	12:00	Completed				
	Karitane Bowls	P1859	Sample Filtration	23/03/2021	12:06	Completed				
	Waikouaiti Golf Club	P1859	Sample Filtration	23/03/2021	13:50	Completed				
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	23/03/2021	11:35	Completed				
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	23/03/2021	13:05	Completed				
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	23/03/2021	12:40	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	23/03/2021	11:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	23/03/2021	11:00	Completed				
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	23/03/2021	12:45	Completed				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	23/03/2021	11:05	69	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	23/03/2021	11:00	68	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	23/03/2021	14:10	72	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	23/03/2021	14:03	71	g CaCO3/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	23/03/2021	11:05	20.1	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	23/03/2021	11:00	19.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	23/03/2021	14:10	20.4	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	23/03/2021	14:03	20.1	g/m³			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	23/03/2021	11:05	$100				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	23/03/2021	11:05	0.002	g/m³			

	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	23/03/2021	11:00	0.013	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	23/03/2021	14:10	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	23/03/2021	14:03	0.011	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	23/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	23/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	23/03/2021	14:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	23/03/2021	14:03	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	23/03/2021	14:10	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	23/03/2021	14:03	0.0025	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	23/03/2021	11:05	0.07	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	23/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	23/03/2021	14:10	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	23/03/2021	14:03	<0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	23/03/2021	14:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	23/03/2021	14:03	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	23/03/2021	11:05	0.0086	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	23/03/2021	11:00	0.0173	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	23/03/2021	14:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	23/03/2021	14:03	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	23/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	23/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	23/03/2021	14:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	23/03/2021	14:03	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	23/03/2021	11:05	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	23/03/2021	11:00	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	23/03/2021	14:10	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	23/03/2021	14:03	0.007	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	23/03/2021	11:05	7.6			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	23/03/2021	11:00	7.6			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	23/03/2021	14:10	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	23/03/2021	14:03	7.9			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	23/03/2021	11:05	14.9	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	23/03/2021	11:00	15	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	23/03/2021	14:10	17.8	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	23/03/2021	14:03	16.3	Deg C		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	23/03/2021	11:05	6.1	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	23/03/2021	11:00	6.2	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	23/03/2021	14:10	6.6	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	23/03/2021	14:03	7.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	23/03/2021	11:00	<0.05	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	23/03/2021	14:10	0.16	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	23/03/2021	14:03	0.34	g/m³	(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	23/03/2021	11:05	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	23/03/2021	14:03	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	23/03/2021	11:05	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	23/03/2021	14:03	Complete			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	23/03/2021	11:05	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	23/03/2021	11:00	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	23/03/2021	14:10	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	23/03/2021	14:03	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	24/03/2021	13:50	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	24/03/2021	13:10	69	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	24/03/2021	13:25	71	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	24/03/2021	13:50	20.6	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	24/03/2021	13:10	20.1	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	24/03/2021	13:25	21	g/m³		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	24/03/2021	13:55	$100			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	24/03/2021	13:50	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	24/03/2021	13:10	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	24/03/2021	13:25	0.011	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	24/03/2021	13:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	24/03/2021	13:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	24/03/2021	13:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	24/03/2021	13:50	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	24/03/2021	13:10	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	24/03/2021	13:25	0.0037	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	24/03/2021	13:50	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	24/03/2021	13:10	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	24/03/2021	13:25	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	24/03/2021	13:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	24/03/2021	13:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	24/03/2021	13:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	24/03/2021	13:50	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	24/03/2021	13:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	24/03/2021	13:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	24/03/2021	13:50	<0.0005	g/m³	(.08 - .08)	

	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	24/03/2021	13:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	24/03/2021	13:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	24/03/2021	13:50	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	24/03/2021	13:10	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	24/03/2021	13:25	0.008	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	24/03/2021	13:50	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	24/03/2021	13:10	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	24/03/2021	13:25	7.9			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	24/03/2021	13:50	15.5	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	24/03/2021	13:10	17.6	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	24/03/2021	13:25	16.3	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	24/03/2021	13:50	6.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	24/03/2021	13:10	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	24/03/2021	13:25	6.7	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/03/2021	13:50	0.71	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	24/03/2021	13:10	0.13	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	24/03/2021	13:25	0.34	g/m³	(.2 - 5)	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	24/03/2021	13:55	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	24/03/2021	13:25	Complete			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	24/03/2021	13:55	Complete			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	24/03/2021	13:25	Complete			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	24/03/2021	13:50	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	24/03/2021	13:10	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	24/03/2021	13:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	24/03/2021	13:25	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	25/03/2021	12:15	64	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	25/03/2021	12:00	72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	25/03/2021	11:50	72	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	25/03/2021	12:15	80.9	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	25/03/2021	12:00	20.4	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	25/03/2021	11:50	20.7	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	25/03/2021	12:15	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	25/03/2021	12:00	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	25/03/2021	11:50	0.014	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	25/03/2021	12:15	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	25/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	25/03/2021	11:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	25/03/2021	12:15	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	25/03/2021	12:00	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	25/03/2021	11:50	0.0018	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	25/03/2021	12:15	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	25/03/2021	12:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	25/03/2021	11:50	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	25/03/2021	12:15	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	25/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	25/03/2021	11:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	25/03/2021	12:15	0.0008	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	25/03/2021	12:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	25/03/2021	11:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	25/03/2021	12:15	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	25/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	25/03/2021	11:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	25/03/2021	12:15	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	25/03/2021	12:00	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	25/03/2021	11:50	0.005	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	25/03/2021	00:00	No	Water		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	25/03/2021	12:15	7.4			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	25/03/2021	12:00	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	25/03/2021	11:50	8			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	25/03/2021	12:15	15.2	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	25/03/2021	12:00	17.4	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	25/03/2021	11:50	16.2	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	25/03/2021	12:15	6.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	25/03/2021	12:00	6.4	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	25/03/2021	11:50	6.7	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	25/03/2021	12:15	4.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	25/03/2021	12:00	0.13	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	25/03/2021	11:50	0.39	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	25/03/2021	11:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	25/03/2021	11:50	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	25/03/2021	12:15	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	25/03/2021	12:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	25/03/2021	11:50	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	26/03/2021	11:10	72	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	26/03/2021	10:35	75	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	26/03/2021	10:45	72	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	26/03/2021	11:10	21.1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	26/03/2021	10:35	20.8	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	26/03/2021	10:45	21	g/m³		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	26/03/2021	11:15	$100			

	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	26/03/2021	11:10	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	26/03/2021	10:35	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	26/03/2021	10:45	0.011	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	26/03/2021	11:10	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	26/03/2021	10:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	26/03/2021	10:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	26/03/2021	11:10	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	26/03/2021	10:35	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	26/03/2021	10:45	0.002	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	26/03/2021	11:10	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	26/03/2021	10:35	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	26/03/2021	10:45	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	26/03/2021	11:10	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	26/03/2021	10:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	26/03/2021	10:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	26/03/2021	11:10	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	26/03/2021	10:35	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	26/03/2021	10:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	26/03/2021	11:10	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	26/03/2021	10:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	26/03/2021	10:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	26/03/2021	11:10	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	26/03/2021	10:35	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	26/03/2021	10:45	0.005	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	26/03/2021	11:10	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	26/03/2021	10:35	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	26/03/2021	10:45	7.9			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	26/03/2021	11:10	15.4	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	26/03/2021	10:35	17.6	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	26/03/2021	10:45	16.1	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	26/03/2021	11:10	6.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	26/03/2021	10:35	6.1	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	26/03/2021	10:45	6.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	26/03/2021	11:10	1	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	26/03/2021	10:35	0.21	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	26/03/2021	10:45	0.66	g/m³	(.2 - 5)	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	26/03/2021	11:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	26/03/2021	10:45	Completed			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	26/03/2021	11:15	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	26/03/2021	10:45	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	26/03/2021	11:10	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	26/03/2021	10:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	26/03/2021	10:45	Completed			
	Karitane Bowls	D-0058H	Free Available Chlorine	26/03/2021	10:10	0.73	g/m³	(.2 - 5)	
	Karitane Bowls	D-0066H	Total Chlorine	26/03/2021	10:10	0.8	g/m³		
	Karitane Bowls	D-0084	Turbidity	26/03/2021	10:10	0.19	NTU		
	Karitane Bowls	D-1310	Temperature on arrival	26/03/2021	10:10	7.6	Deg C		
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	26/03/2021	10:10	<1	MPN/100mL	(0 - 0)	
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	26/03/2021	10:10	<1	MPN/100ml	(0 - 0)	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	27/03/2021	09:08	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	27/03/2021	08:25	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	27/03/2021	08:13	71	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	27/03/2021	09:08	21.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	27/03/2021	08:25	21.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	27/03/2021	08:13	21.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	27/03/2021	00:00:00	$100			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	27/03/2021	09:08	0.008	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	27/03/2021	08:25	0.011	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	27/03/2021	08:13	0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	27/03/2021	09:08	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	27/03/2021	08:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	27/03/2021	08:13	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	27/03/2021	09:08	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	27/03/2021	08:25	0.0007	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	27/03/2021	08:13	0.0028	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	27/03/2021	09:08	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	27/03/2021	08:25	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	27/03/2021	08:13	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	27/03/2021	09:08	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	27/03/2021	08:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	27/03/2021	08:13	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	27/03/2021	09:08	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	27/03/2021	08:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	27/03/2021	08:13	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	27/03/2021	09:08	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	27/03/2021	08:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	27/03/2021	08:13	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	27/03/2021	09:08	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	27/03/2021	08:25	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	27/03/2021	08:13	0.005	g/m³		

	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	27/03/2021	09:08	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	27/03/2021	08:25	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	27/03/2021	08:13	7.8			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	27/03/2021	09:08	15.3	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	27/03/2021	08:25	17.2	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	27/03/2021	08:13	16.2	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	27/03/2021	09:08	7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	27/03/2021	08:25	6.4	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	27/03/2021	08:13	6.7	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	27/03/2021	09:08	0.94	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	27/03/2021	08:25	0.31	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	27/03/2021	08:13	0.73	g/m³	(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	27/03/2021	00:00:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	27/03/2021	08:13	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	27/03/2021	00:00:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	27/03/2021	08:13	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	27/03/2021	00:00:00	No	water		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	27/03/2021	09:08	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	27/03/2021	08:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	27/03/2021	08:13	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	27/03/2021	00:00:00	$100			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	27/03/2021	00:00:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	27/03/2021	00:00:00	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	27/03/2021	00:00:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	27/03/2021	00:00:00	Completed			

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	27/03/2021	00:00:00				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	27/03/2021	00:00:00				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	27/03/2021	00:00:00				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	27/03/2021	00:00:00				
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	28/03/2021	09:35	68	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	28/03/2021	09:30	67	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	28/03/2021	09:50	75	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	28/03/2021	10:05	72	g CaCO3/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	28/03/2021	09:35	21.2	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	28/03/2021	09:30	20.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	28/03/2021	09:50	21.3	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	28/03/2021	10:05	21.3	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	28/03/2021	09:35	$100			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	28/03/2021	09:35	0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	28/03/2021	09:30	0.005	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	28/03/2021	09:50	0.012	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	28/03/2021	10:05	0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	28/03/2021	09:35	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	28/03/2021	09:30	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	28/03/2021	09:50	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	28/03/2021	10:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	28/03/2021	09:35	<0.0005	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	28/03/2021	09:30	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	28/03/2021	09:50	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	28/03/2021	10:05	0.0027	g/m³	(2 - 2)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	28/03/2021	09:35	0.08	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	28/03/2021	09:30	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	28/03/2021	09:50	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	28/03/2021	10:05	<0.01	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	28/03/2021	09:35	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	28/03/2021	09:30	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	28/03/2021	09:50	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	28/03/2021	10:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	28/03/2021	09:35	0.004	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	28/03/2021	09:30	0.0137	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	28/03/2021	09:50	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	28/03/2021	10:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	28/03/2021	09:35	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	28/03/2021	09:30	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	28/03/2021	09:50	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	28/03/2021	10:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	28/03/2021	09:35	<0.002	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	28/03/2021	09:30	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	28/03/2021	09:50	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	28/03/2021	10:05	0.006	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	28/03/2021	09:35	7.6			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	28/03/2021	09:30	7.6			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	28/03/2021	09:50	8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	28/03/2021	10:05	7.9			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	28/03/2021	09:35	15.1	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	28/03/2021	09:30	15.2	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	28/03/2021	09:50	17.9	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	28/03/2021	10:05	16.5	Deg C		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	28/03/2021	09:35	5.8	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	28/03/2021	09:30	6.3	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	28/03/2021	09:50	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	28/03/2021	10:05	6.9	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	28/03/2021	09:30	<0.05	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	28/03/2021	09:50	0.15	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	28/03/2021	10:05	0.85	g/m³	(.2 - 5)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	28/03/2021	09:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	28/03/2021	10:05	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	28/03/2021	09:35	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	28/03/2021	10:05	Completed			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	28/03/2021	09:35	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	28/03/2021	09:30	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	28/03/2021	09:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	28/03/2021	10:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	29/03/2021	10:20	77	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	29/03/2021	10:20	72	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	29/03/2021	10:25	74	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	29/03/2021	10:25	74	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	29/03/2021	11:00	77	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	29/03/2021	11:00	70	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	29/03/2021	11:05	72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	29/03/2021	11:05	72	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	29/03/2021	10:20	21.2	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	29/03/2021	10:20	21.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	29/03/2021	10:25	21.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	29/03/2021	10:25	21.5	g/m³		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	29/03/2021	11:00	21.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	29/03/2021	11:00	20.9	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	29/03/2021	11:05	21.2	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	29/03/2021	11:05	21.3	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	29/03/2021	10:20	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	29/03/2021	10:20	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	29/03/2021	10:25	0.009	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	29/03/2021	10:25	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	29/03/2021	11:00	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	29/03/2021	11:00	0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	29/03/2021	11:05	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	29/03/2021	11:05	0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	29/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	29/03/2021	10:20	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	29/03/2021	10:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	29/03/2021	10:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	29/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	29/03/2021	11:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	29/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	29/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	29/03/2021	10:20	0.0449	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	29/03/2021	10:20	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	29/03/2021	10:25	0.0011	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	29/03/2021	10:25	0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	29/03/2021	11:00	0.0029	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	29/03/2021	11:00	0.0009	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	29/03/2021	11:05	0.0025	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	29/03/2021	10:20	<0.01	g/m³	(.2 - .2)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	29/03/2021	10:20	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	29/03/2021	10:25	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	29/03/2021	10:25	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	29/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	29/03/2021	11:00	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	29/03/2021	11:05	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	29/03/2021	11:05	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	29/03/2021	10:20	0.0146	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	29/03/2021	10:20	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	29/03/2021	11:00	0.0016	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	29/03/2021	11:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	29/03/2021	10:20	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	29/03/2021	10:20	0.0006	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	29/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	29/03/2021	11:00	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	29/03/2021	10:20	0.0026	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	29/03/2021	10:20	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	29/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	29/03/2021	11:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	29/03/2021	10:20	0.36	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	29/03/2021	10:20	0.015	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	29/03/2021	10:25	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	29/03/2021	10:25	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	29/03/2021	11:00	0.078	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	29/03/2021	11:00	0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	29/03/2021	11:05	0.003	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	29/03/2021	11:05	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	29/03/2021	10:20	8.1			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	29/03/2021	10:20	7.9			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	29/03/2021	10:25	8			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	29/03/2021	10:25	8			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0001F	pH - Field	29/03/2021	11:00	7.9			
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	29/03/2021	11:00	7.8			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	29/03/2021	11:05	7.9			
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	29/03/2021	11:05	7.9			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0053F	Temperature - Field	29/03/2021	10:20	18.3	Deg C		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	29/03/2021	10:20	18.8	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	29/03/2021	10:25	18	Deg C		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	29/03/2021	10:25	17.8	Deg C		

	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0053F	Temperature - Field	29/03/2021	11:00	22.5	Deg C		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	29/03/2021	11:00	22	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	29/03/2021	11:05	16.6	Deg C		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	29/03/2021	11:05	16.5	Deg C		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:20	6.4	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:20	6.6	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:25	6.5	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:25	6.7	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	29/03/2021	11:00	5.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	29/03/2021	11:00	5.2	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	29/03/2021	11:05	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	29/03/2021	11:05	6.7	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	29/03/2021	10:20	0.12	g/m³	(0 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	29/03/2021	10:20	<0.05	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	29/03/2021	10:25	0.23	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	29/03/2021	10:25	0.34	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	29/03/2021	11:00	0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	29/03/2021	11:00	<0.05	g/m³	(0 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	29/03/2021	11:05	0.68	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	29/03/2021	11:05	0.84	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-1201	Sampling / Inspection 15 Mins	29/03/2021	10:20	Completed			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-1201	Sampling / Inspection 15 Mins	29/03/2021	10:20	Completed			
	Waikouaiti SS - 210 Edinburgh St	D-1201	Sampling / Inspection 15 Mins	29/03/2021	10:25	Completed			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-1201	Sampling / Inspection 15 Mins	29/03/2021	10:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-1201	Sampling / Inspection 15 Mins	29/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-1201	Sampling / Inspection 15 Mins	29/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1201	Sampling / Inspection 15 Mins	29/03/2021	11:05	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-1201	Sampling / Inspection 15 Mins	29/03/2021	11:05	Completed			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	29/03/2021	10:20	Completed			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	29/03/2021	10:20	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	29/03/2021	10:25	Completed			
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	29/03/2021	10:25	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	29/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	29/03/2021	11:00	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	29/03/2021	11:05	Completed			
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	29/03/2021	11:05	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	29/03/2021	10:00	71	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	29/03/2021	10:25	75	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	29/03/2021	11:05	71	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	29/03/2021	10:00	20.8	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	29/03/2021	10:25	21	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	29/03/2021	11:05	21	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	29/03/2021	10:00	0.006	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	29/03/2021	10:25	0.009	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	29/03/2021	11:05	0.009	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	29/03/2021	10:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	29/03/2021	10:25	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	29/03/2021	11:05	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	29/03/2021	10:00	<0.0005	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	29/03/2021	10:25	0.0012	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	29/03/2021	11:05	0.0024	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	29/03/2021	10:00	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	29/03/2021	10:25	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	29/03/2021	11:05	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	29/03/2021	10:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	29/03/2021	10:00	0.0013	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	29/03/2021	10:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	29/03/2021	10:25	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	29/03/2021	11:05	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	29/03/2021	10:00	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	29/03/2021	10:25	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	29/03/2021	11:05	0.003	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	29/03/2021	10:00				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	29/03/2021	10:00	7.8			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	29/03/2021	10:25	6			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	29/03/2021	11:05	7.9			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	29/03/2021	10:00	15.4	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	29/03/2021	10:25	18	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	29/03/2021	11:05	16.6	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:00	6.3	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	29/03/2021	10:25	6.5	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	29/03/2021	11:05	6.5	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/03/2021	10:00	1.4	g/m³	(.2 - 5)	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	29/03/2021	10:25	0.23	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	29/03/2021	11:05	0.68	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	29/03/2021	11:05	Completed			

	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	29/03/2021	11:05	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	29/03/2021	10:00	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	29/03/2021	10:25	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	29/03/2021	11:05	Complete				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	30/03/2021	13:05	71	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	30/03/2021	12:15	73	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	30/03/2021	12:30	73	g CaCO3/m³			
	Waikouaiti Golf Club	52	Alkalinity - Total	30/03/2021	12:05	76	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	30/03/2021	13:05	20.9	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	30/03/2021	12:15	20.8	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	30/03/2021	12:30	20.7	g/m³			
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	30/03/2021	12:05	21.1	g/m³			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	30/03/2021	13:10	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	30/03/2021	13:05	0.007	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	30/03/2021	12:15	0.009	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	30/03/2021	12:30	0.011	g/m³			
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	30/03/2021	12:05	0.012	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	30/03/2021	13:05	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	30/03/2021	12:15	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	30/03/2021	12:30	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	30/03/2021	12:05	<0.0002	g/m³		(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	30/03/2021	13:05	<0.0005	g/m³		(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	30/03/2021	12:15	0.0006	g/m³		(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	30/03/2021	12:30	0.0021	g/m³		(2 - 2)	
	Waikouaiti Golf Club	6713	Copper - Dissolved	30/03/2021	12:05	0.0117	g/m³		(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	30/03/2021	13:05	<0.01	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	30/03/2021	12:15	<0.01	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	30/03/2021	12:30	<0.01	g/m³			
	Waikouaiti Golf Club	6717	Iron - Dissolved	30/03/2021	12:05	<0.01	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	30/03/2021	13:05	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	30/03/2021	12:15	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	30/03/2021	12:30	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti Golf Club	6718	Lead - Dissolved	30/03/2021	12:05	<0.0005	g/m³		(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	30/03/2021	13:05	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	30/03/2021	12:15	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	30/03/2021	12:30	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti Golf Club	6721	Manganese - Dissolved	30/03/2021	12:05	<0.0005	g/m³		(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	30/03/2021	13:05	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	30/03/2021	12:15	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	30/03/2021	12:30	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti Golf Club	6724	Nickel - Dissolved	30/03/2021	12:05	<0.0005	g/m³		(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	30/03/2021	13:05	<0.002	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	30/03/2021	12:15	<0.002	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	30/03/2021	12:30	0.004	g/m³			
	Waikouaiti Golf Club	6738	Zinc - Dissolved	30/03/2021	12:05	0.024	g/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	30/03/2021	13:05	7.8				
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	30/03/2021	12:15	8				
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	30/03/2021	12:30	8				
	Waikouaiti Golf Club	D-0001F	pH - Field	30/03/2021	12:05	8.2				
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	30/03/2021	13:05	16.8	Deg C			
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	30/03/2021	12:15	18.3	Deg C			
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	30/03/2021	12:30	16.9	Deg C			
	Waikouaiti Golf Club	D-0053F	Temperature - Field	30/03/2021	12:05	17	Deg C			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	30/03/2021	13:05	7.3	g O2/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	30/03/2021	12:15	7.4	g O2/m³			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	30/03/2021	12:30	7.4	g O2/m³			
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	30/03/2021	12:05	6.9	g O2/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	30/03/2021	13:05	0.64	g/m³			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	30/03/2021	12:15	0.27	g/m³		(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	30/03/2021	12:30	0.53	g/m³		(.2 - 5)	
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	30/03/2021	12:05	0.19	g/m³			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	30/03/2021	13:10	Completed				
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	30/03/2021	12:30	Completed				
	Waikouaiti Golf Club	D-1202	Sampling / Inspection 30 Mins	30/03/2021	12:05	Completed				
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	30/03/2021	13:10	Completed				
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	30/03/2021	12:30	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	30/03/2021	13:05	Completed				
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	30/03/2021	12:15	Completed				
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	30/03/2021	12:30	Completed				
	Waikouaiti Golf Club	P1859	Sample Filtration	30/03/2021	12:05	Completed				
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	31/03/2021	12:45	73	g CaCO3/m³			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	31/03/2021	11:45	74	g CaCO3/m³			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	31/03/2021	12:00	74	g CaCO3/m³			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	31/03/2021	12:45	21	g/m³			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	31/03/2021	11:45	21.1	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	31/03/2021	12:00	21.1	g/m³			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	31/03/2021	12:50	$100				
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	31/03/2021	12:45	0.009	g/m³			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	31/03/2021	11:45	0.009	g/m³			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	31/03/2021	12:00	0.011	g/m³			

	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	31/03/2021	12:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	31/03/2021	11:45	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	31/03/2021	12:00	<0.0002	g/m³	(.004 - .004)	
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	31/03/2021	12:45	0.0006	g/m³	(2 - 2)	
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	31/03/2021	11:45	0.0008	g/m³	(2 - 2)	
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	31/03/2021	12:00	0.0019	g/m³	(2 - 2)	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	31/03/2021	12:45	<0.01	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	31/03/2021	11:45	<0.01	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	31/03/2021	12:00	<0.01	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	31/03/2021	12:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	31/03/2021	11:45	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	31/03/2021	12:00	<0.0005	g/m³	(.005 - .01)	
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	31/03/2021	12:45	0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	31/03/2021	11:45	<0.0005	g/m³	(.4 - .4)	
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	31/03/2021	12:00	0.0007	g/m³	(.4 - .4)	
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	31/03/2021	12:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	31/03/2021	11:45	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	31/03/2021	12:00	<0.0005	g/m³	(.08 - .08)	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	31/03/2021	12:45	<0.002	g/m³		
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	31/03/2021	11:45	<0.002	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	31/03/2021	12:00	0.003	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	31/03/2021	12:45	7.7			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	31/03/2021	11:45	7.9			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	31/03/2021	12:00	7.8			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	31/03/2021	12:45	17.1	Deg C		
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	31/03/2021	11:45	18.7	Deg C		
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	31/03/2021	12:00	17	Deg C		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	31/03/2021	12:45	7.8	g O2/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	31/03/2021	11:45	7.3	g O2/m³		
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	31/03/2021	12:00	7.4	g O2/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	31/03/2021	12:45	0.78	g/m³		
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	31/03/2021	11:45	0.34	g/m³	(.2 - 5)	
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	31/03/2021	12:00	0.42	g/m³	(.2 - 5)	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	31/03/2021	12:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	31/03/2021	12:00	Completed			
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	31/03/2021	12:50	Completed			
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	31/03/2021	12:00	Completed			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	31/03/2021	12:45	Completed			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	31/03/2021	11:45	Completed			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	31/03/2021	12:00	Completed			

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/04/2021	00:00:00	72	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/04/2021	00:00:00	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	01/04/2021	00:00:00	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	01/04/2021	00:00:00	73	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/04/2021	00:00:00	21.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/04/2021	00:00:00	21.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	01/04/2021	00:00:00	20.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	01/04/2021	00:00:00	21.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	01/04/2021	00:00:00	$100		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/04/2021	00:00:00	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/04/2021	00:00:00	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	01/04/2021	00:00:00	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	01/04/2021	00:00:00	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	01/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	01/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	01/04/2021	00:00:00	0.0015	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	01/04/2021	00:00:00	0.0022	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	01/04/2021	00:00:00	0.13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	01/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	01/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	01/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	01/04/2021	00:00:00	0.0042	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	01/04/2021	00:00:00	0.0122	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	01/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	01/04/2021	00:00:00	0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	01/04/2021	00:00:00	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	01/04/2021	00:00:00	7.5		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	01/04/2021	00:00:00	7.5		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	01/04/2021	00:00:00	7.8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	01/04/2021	00:00:00	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	01/04/2021	00:00:00	13.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	01/04/2021	00:00:00	13.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	01/04/2021	00:00:00	18	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	01/04/2021	00:00:00	16.3	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/04/2021	00:00:00	5.9	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/04/2021	00:00:00	6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	01/04/2021	00:00:00	6.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	01/04/2021	00:00:00	6.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/04/2021	00:00:00	<0.05	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	01/04/2021	00:00:00	0.34	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	01/04/2021	00:00:00	0.79	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	01/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	01/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	01/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	01/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/04/2021	00:00:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	01/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	01/04/2021	00:00:00	Completed		
	TAB Waikouaiti	D-0058H	Free Available Chlorine	01/04/2021	10:40	0.88	g/m³	(.2 - 5)
	TAB Waikouaiti	D-0066H	Total Chlorine	01/04/2021	10:40	1	g/m³	
	TAB Waikouaiti	D-0084	Turbidity	01/04/2021	10:40	0.1	NTU	
	TAB Waikouaiti	D-1310	Temperature on arrival	01/04/2021	10:40	9.3	Deg C	

	TAB Waikouaiti	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/04/2021	10:40	<1	MPN/100mL	(0 - 0)
	TAB Waikouaiti	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/04/2021	10:40	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	01/04/2021	08:30	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	01/04/2021	08:20	<5	g/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	01/04/2021	10:40	73	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	01/04/2021	09:48	73	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	01/04/2021	09:55	73	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	01/04/2021	11:15	73	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	01/04/2021	09:00	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	01/04/2021	10:30	73	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	01/04/2021	08:40	71	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/04/2021	08:30	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/04/2021	08:20	71	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	01/04/2021	08:45	73	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	55	Conductivity at 25°C - mS/m unit	01/04/2021	08:30	24.5	mS/m (245.4 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	01/04/2021	08:20	24.6	mS/m (246 x .1)	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	01/04/2021	10:40	21.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	01/04/2021	09:48	21.2	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	01/04/2021	09:55	21.2	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	01/04/2021	11:15	20.8	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	01/04/2021	09:00	21.3	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	01/04/2021	10:30	21.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	01/04/2021	08:40	21.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/04/2021	08:30	21	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/04/2021	08:20	20.9	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	01/04/2021	08:45	21	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	01/04/2021	08:30	13.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	01/04/2021	08:20	14.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	01/04/2021	08:30	19.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	01/04/2021	08:20	19.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	01/04/2021	08:30	122	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	01/04/2021	08:20	126	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	01/04/2021	08:20	0.006	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	01/04/2021	08:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	01/04/2021	08:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	01/04/2021	08:20	20.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	01/04/2021	08:20	<0.0005	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	01/04/2021	08:20	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	01/04/2021	08:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	01/04/2021	08:20	10.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	01/04/2021	08:20	0.0147	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	01/04/2021	08:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	01/04/2021	08:20	<0.002	g/m³	(1.5 - 1.5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	01/04/2021	08:30	0.015	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	01/04/2021	08:30	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	01/04/2021	08:30	<0.001	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	01/04/2021	08:30	21.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	01/04/2021	08:30	<0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	01/04/2021	08:30	0.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	01/04/2021	08:30	<0.001	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	01/04/2021	08:30	11.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	01/04/2021	08:30	0.016	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	01/04/2021	08:30	<0.001	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	01/04/2021	08:30	<0.005	g/m³	
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	01/04/2021	10:40	0.009	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	01/04/2021	09:48	0.01	g/m³	
	Karitane Bowls	6701	Aluminium - Dissolved	01/04/2021	09:55	0.01	g/m³	
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	01/04/2021	11:15	0.009	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	01/04/2021	09:00	0.011	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	01/04/2021	10:30	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	01/04/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/04/2021	08:30	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/04/2021	08:20	0.005	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	01/04/2021	08:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	01/04/2021	08:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	01/04/2021	08:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	01/04/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	01/04/2021	09:48	<0.0002	g/m³	(.004 - .004)
	Karitane Bowls	6708	Cadmium - Dissolved	01/04/2021	09:55	<0.0002	g/m³	(.004 - .004)

	Waikouaiti Golf Club	6708	Cadmium - Dissolved	01/04/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	01/04/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	01/04/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	01/04/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/04/2021	08:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	01/04/2021	08:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	01/04/2021	08:30	18.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	01/04/2021	08:20	17.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	01/04/2021	10:40	0.0011	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	01/04/2021	09:48	<0.0005	g/m³	(2 - 2)
	Karitane Bowls	6713	Copper - Dissolved	01/04/2021	09:55	0.0035	g/m³	(2 - 2)
	Waikouaiti Golf Club	6713	Copper - Dissolved	01/04/2021	11:15	0.0153	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	01/04/2021	09:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	01/04/2021	10:30	<0.0005	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	01/04/2021	08:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	01/04/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	01/04/2021	08:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	01/04/2021	08:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	01/04/2021	10:40	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	01/04/2021	09:48	<0.01	g/m³	
	Karitane Bowls	6717	Iron - Dissolved	01/04/2021	09:55	<0.01	g/m³	(.2 - .2)
	Waikouaiti Golf Club	6717	Iron - Dissolved	01/04/2021	11:15	0.03	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	01/04/2021	09:00	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	01/04/2021	10:30	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	01/04/2021	08:40	0.17	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	01/04/2021	08:30	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	01/04/2021	08:20	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	01/04/2021	08:45	0.14	g/m³	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	01/04/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	01/04/2021	09:48	<0.0005	g/m³	(.005 - .01)
	Karitane Bowls	6718	Lead - Dissolved	01/04/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti Golf Club	6718	Lead - Dissolved	01/04/2021	11:15	0.001	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	01/04/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	01/04/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	01/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	01/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	01/04/2021	08:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	01/04/2021	08:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	01/04/2021	08:30	8.89	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	01/04/2021	08:20	8.75	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	01/04/2021	10:40	0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	01/04/2021	09:48	<0.0005	g/m³	(.4 - .4)
	Karitane Bowls	6721	Manganese - Dissolved	01/04/2021	09:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti Golf Club	6721	Manganese - Dissolved	01/04/2021	11:15	0.0016	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	01/04/2021	09:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	01/04/2021	10:30	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	01/04/2021	08:40	0.01	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	01/04/2021	08:30	0.0043	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	01/04/2021	08:20	0.012	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	01/04/2021	08:45	0.0096	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	01/04/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	01/04/2021	09:48	<0.0005	g/m³	(.08 - .08)
	Karitane Bowls	6724	Nickel - Dissolved	01/04/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti Golf Club	6724	Nickel - Dissolved	01/04/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	01/04/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	01/04/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	01/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	01/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	01/04/2021	08:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	01/04/2021	08:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	01/04/2021	10:40	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	01/04/2021	09:48	<0.002	g/m³	
	Karitane Bowls	6738	Zinc - Dissolved	01/04/2021	09:55	0.002	g/m³	
	Waikouaiti Golf Club	6738	Zinc - Dissolved	01/04/2021	11:15	0.045	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	01/04/2021	09:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	01/04/2021	10:30	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	01/04/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/04/2021	08:30	<0.002	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/04/2021	08:20	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	01/04/2021	08:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	01/04/2021	08:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	01/04/2021	08:20	Completed		
	Karitane School	C-O1420	Sampler Observation	01/04/2021	00:00:00	No	sample	
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	01/04/2021	10:40	7.7		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	01/04/2021	09:48	7.8		
	Karitane Bowls	D-0001F	pH - Field	01/04/2021	09:55	7.8		
	Waikouaiti Golf Club	D-0001F	pH - Field	01/04/2021	11:15	7.9		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	01/04/2021	09:00	7.9		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	01/04/2021	10:30	7.8		
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	01/04/2021	08:40	7.6		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	01/04/2021	08:30	7.5		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	01/04/2021	08:20	7.5		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	01/04/2021	08:45	7.6		
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	01/04/2021	10:40	16.4	Deg C	
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	01/04/2021	09:48	15.2	Deg C	
	Karitane Bowls	D-0053F	Temperature - Field	01/04/2021	09:55	14.9	Deg C	
	Waikouaiti Golf Club	D-0053F	Temperature - Field	01/04/2021	11:15	15.6	Deg C	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	01/04/2021	09:00	14.8	Deg C	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	01/04/2021	10:30	17	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	01/04/2021	08:40	12.5	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	01/04/2021	08:30	13.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	01/04/2021	08:20	13.7	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	01/04/2021	08:45	12.5	Deg C	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	01/04/2021	10:40	6.7	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	01/04/2021	09:48	6.7	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	01/04/2021	09:55	7	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	01/04/2021	11:15	7	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	01/04/2021	09:00	6.7	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	01/04/2021	10:30	6.6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	01/04/2021	08:40	6.9	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/04/2021	08:30	5.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/04/2021	08:20	6	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	01/04/2021	08:45	6.8	g O2/m³	
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	01/04/2021	10:10	0.63	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	01/04/2021	10:40	0.88	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	01/04/2021	09:48	0.68	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	01/04/2021	09:55	0.89	g/m³	(.2 - 5)
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	01/04/2021	11:15	0.17	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	01/04/2021	09:00	0.84	g/m³	(.2 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	01/04/2021	10:30	0.9	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/04/2021	08:20	<0.05	g/m³	
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	01/04/2021	10:10	0.11	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	01/04/2021	10:10	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	01/04/2021	10:10	9.3	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/04/2021	10:10	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/04/2021	10:10	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1855	Aqueous Total Metal Digestion for ICPMS codes	01/04/2021	08:30	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	01/04/2021	10:40	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	01/04/2021	09:48	Completed		
	Karitane Bowls	P1859	Sample Filtration	01/04/2021	09:55	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	01/04/2021	11:15	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	01/04/2021	09:00	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	01/04/2021	10:30	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	01/04/2021	08:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/04/2021	08:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/04/2021	08:20	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	01/04/2021	08:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	02/04/2021	13:12	73	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	02/04/2021	12:51	73	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	02/04/2021	12:35	75	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	02/04/2021	13:12	21.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	02/04/2021	12:51	20.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	02/04/2021	12:35	21.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	02/04/2021	00:00:00	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	02/04/2021	13:12	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	02/04/2021	12:51	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	02/04/2021	12:35	0.011	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	02/04/2021	13:12	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	02/04/2021	12:51	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	02/04/2021	12:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	02/04/2021	13:12	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	02/04/2021	12:51	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	02/04/2021	12:35	0.0021	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	02/04/2021	13:12	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	02/04/2021	12:51	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	02/04/2021	12:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	02/04/2021	13:12	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	02/04/2021	12:51	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	02/04/2021	12:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	02/04/2021	13:12	0.0015	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	02/04/2021	12:51	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	02/04/2021	12:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	02/04/2021	13:12	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	02/04/2021	12:51	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	02/04/2021	12:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	02/04/2021	13:12	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	02/04/2021	12:51	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	02/04/2021	12:35	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	02/04/2021	13:12	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	02/04/2021	12:51	7.8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	02/04/2021	12:35	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	02/04/2021	13:12	16.2	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	02/04/2021	12:51	17.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	02/04/2021	12:35	16.5	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	02/04/2021	13:12	7.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	02/04/2021	12:51	6.5	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	02/04/2021	12:35	6.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	02/04/2021	13:12	0.94	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	02/04/2021	12:51	0.41	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	02/04/2021	12:35	0.78	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	02/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	02/04/2021	12:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	02/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	02/04/2021	12:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	02/04/2021	00:00:00	No	water	
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	02/04/2021	13:12	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	02/04/2021	12:51	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	02/04/2021	12:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	02/04/2021	13:12	3.2	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	02/04/2021	13:22	3.2	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	02/04/2021	13:12	8	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	02/04/2021	13:22	7.5	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	02/04/2021	13:12	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	02/04/2021	13:22	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	03/04/2021	14:13	74	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	03/04/2021	13:31	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	03/04/2021	13:14	73	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	03/04/2021	14:13	21.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	03/04/2021	13:31	21.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	03/04/2021	13:14	21.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	03/04/2021	00:00:00	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	03/04/2021	14:13	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	03/04/2021	13:31	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	03/04/2021	13:14	0.014	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	03/04/2021	14:13	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	03/04/2021	13:31	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	03/04/2021	13:14	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	03/04/2021	14:13	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	03/04/2021	13:31	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	03/04/2021	13:14	0.0025	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	03/04/2021	14:13	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	03/04/2021	13:31	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	03/04/2021	13:14	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	03/04/2021	14:13	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	03/04/2021	13:31	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	03/04/2021	13:14	<0.0005	g/m³	(.005 - .01)

	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	03/04/2021	14:13	0.0013	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	03/04/2021	13:31	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	03/04/2021	13:14	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	03/04/2021	14:13	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	03/04/2021	13:31	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	03/04/2021	13:14	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	03/04/2021	14:13	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	03/04/2021	13:31	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	03/04/2021	13:14	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	03/04/2021	14:13	7.2		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	03/04/2021	13:31	7.8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	03/04/2021	13:14	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	03/04/2021	14:13	15.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	03/04/2021	13:31	17.3	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	03/04/2021	13:14	16.8	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	03/04/2021	14:13	7.3	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	03/04/2021	13:31	6.2	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	03/04/2021	13:14	7.1	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	03/04/2021	14:13	1.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	03/04/2021	13:31	0.43	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	03/04/2021	13:14	0.68	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	03/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	03/04/2021	13:14	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	03/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	03/04/2021	13:14	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	O1420	Sampler Observation	03/04/2021	00:00:00	No	water	
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	03/04/2021	14:13	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	03/04/2021	13:31	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	03/04/2021	13:14	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	04/04/2021	09:00	74	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	04/04/2021	09:25	78	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	04/04/2021	09:15	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	04/04/2021	09:00	21.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	04/04/2021	09:25	21.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	04/04/2021	09:15	21.7	g/m³	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	04/04/2021	09:05	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	04/04/2021	09:00	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	04/04/2021	09:25	0.011	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	04/04/2021	09:15	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	04/04/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	04/04/2021	09:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	04/04/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	04/04/2021	09:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	04/04/2021	09:25	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	04/04/2021	09:15	0.0028	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	04/04/2021	09:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	04/04/2021	09:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	04/04/2021	09:15	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	04/04/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	04/04/2021	09:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	04/04/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	04/04/2021	09:00	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	04/04/2021	09:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	04/04/2021	09:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	04/04/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	04/04/2021	09:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	04/04/2021	09:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	04/04/2021	09:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	04/04/2021	09:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	04/04/2021	09:15	0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	04/04/2021	09:00	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	04/04/2021	09:25	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	04/04/2021	09:15	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	04/04/2021	09:00	15.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	04/04/2021	09:25	17.4	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	04/04/2021	09:15	15	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	04/04/2021	09:00	6.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	04/04/2021	09:25	7.1	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	04/04/2021	09:15	6.6	g O2/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	04/04/2021	09:00	1.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	04/04/2021	09:25	0.58	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	04/04/2021	09:15	1	g/m³	(.2 - 5)
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	04/04/2021	09:05	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	04/04/2021	09:15	Completed		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	04/04/2021	09:05	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	04/04/2021	09:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	04/04/2021	09:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	04/04/2021	09:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	04/04/2021	09:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	05/04/2021	13:35	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	05/04/2021	14:30	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	05/04/2021	14:15	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	05/04/2021	13:35	21.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	05/04/2021	14:30	20.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	05/04/2021	14:15	21	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	05/04/2021	13:40	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	05/04/2021	13:35	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	05/04/2021	14:30	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	05/04/2021	14:15	0.013	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	05/04/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	05/04/2021	14:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	05/04/2021	14:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	05/04/2021	13:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	05/04/2021	14:30	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	05/04/2021	14:15	0.0021	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	05/04/2021	13:35	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	05/04/2021	14:30	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	05/04/2021	14:15	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	05/04/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	05/04/2021	14:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	05/04/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	05/04/2021	13:35	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	05/04/2021	14:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	05/04/2021	14:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	05/04/2021	13:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	05/04/2021	14:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	05/04/2021	14:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	05/04/2021	13:35	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	05/04/2021	14:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	05/04/2021	14:15	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	05/04/2021	13:35	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	05/04/2021	14:30	7.8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	05/04/2021	14:15	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	05/04/2021	13:35	15.4	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	05/04/2021	14:30	17.4	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	05/04/2021	14:15	16.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	05/04/2021	13:35	9.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	05/04/2021	14:30	7.2	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	05/04/2021	14:15	7.9	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	05/04/2021	13:35	1.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	05/04/2021	14:30	0.6	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	05/04/2021	14:15	0.83	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	05/04/2021	13:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	05/04/2021	14:15	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	05/04/2021	13:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	05/04/2021	14:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	05/04/2021	13:35	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	05/04/2021	14:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	05/04/2021	14:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	06/04/2021	10:30	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	06/04/2021	10:55	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	06/04/2021	11:10	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	06/04/2021	10:30	21.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	06/04/2021	10:55	21.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	06/04/2021	11:10	21.5	g/m³	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	06/04/2021	10:35	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	06/04/2021	10:30	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	06/04/2021	10:55	0.01	g/m³	

	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	06/04/2021	11:10	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	06/04/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	06/04/2021	10:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	06/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	06/04/2021	10:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	06/04/2021	10:55	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	06/04/2021	11:10	0.0024	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	06/04/2021	10:30	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	06/04/2021	10:55	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	06/04/2021	11:10	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	06/04/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	06/04/2021	10:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	06/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	06/04/2021	10:30	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	06/04/2021	10:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	06/04/2021	11:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	06/04/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	06/04/2021	10:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	06/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	06/04/2021	10:30	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	06/04/2021	10:55	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	06/04/2021	11:10	0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	06/04/2021	10:30	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	06/04/2021	10:55	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	06/04/2021	11:10	8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	06/04/2021	10:30	15.2	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	06/04/2021	10:55	18	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	06/04/2021	11:10	16.6	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	06/04/2021	10:30	7.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	06/04/2021	10:55	7.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	06/04/2021	11:10	7.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	06/04/2021	10:30	0.59	g/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	06/04/2021	10:55	0.58	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	06/04/2021	11:10	0.54	g/m³	(.2 - 5)
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	06/04/2021	10:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	06/04/2021	11:10	Completed		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	06/04/2021	10:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	06/04/2021	11:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	06/04/2021	10:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	06/04/2021	10:55	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	06/04/2021	11:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	07/04/2021	13:30	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	07/04/2021	13:55	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	07/04/2021	14:05	75	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	07/04/2021	13:30	21.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	07/04/2021	13:55	21.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	07/04/2021	14:05	21.1	g/m³	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	07/04/2021	13:35	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	07/04/2021	13:30	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	07/04/2021	13:55	0.012	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	07/04/2021	14:05	0.012	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	07/04/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	07/04/2021	13:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	07/04/2021	14:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	07/04/2021	13:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	07/04/2021	13:55	0.001	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	07/04/2021	14:05	0.0021	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	07/04/2021	13:30	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	07/04/2021	13:55	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	07/04/2021	14:05	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	07/04/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	07/04/2021	13:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	07/04/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	07/04/2021	13:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	07/04/2021	13:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	07/04/2021	14:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	07/04/2021	13:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	07/04/2021	13:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	07/04/2021	14:05	<0.0005	g/m³	(.08 - .08)

	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	07/04/2021	13:30	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	07/04/2021	13:55	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	07/04/2021	14:05	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	07/04/2021	13:30	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	07/04/2021	13:55	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	07/04/2021	14:05	8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	07/04/2021	13:30	15.9	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	07/04/2021	13:55	18	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	07/04/2021	14:05	16.4	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	07/04/2021	13:30	8.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	07/04/2021	13:55	7.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	07/04/2021	14:05	8.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	07/04/2021	13:30	0.94	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	07/04/2021	13:55	0.56	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	07/04/2021	14:05	0.74	g/m³	(.2 - 5)
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	07/04/2021	13:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	07/04/2021	14:05	Completed		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	07/04/2021	13:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	07/04/2021	14:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	07/04/2021	13:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	07/04/2021	13:55	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	07/04/2021	14:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	08/04/2021	10:15	74	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	08/04/2021	10:30	77	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	08/04/2021	10:45	75	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	08/04/2021	10:15	21.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	08/04/2021	10:30	21.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	08/04/2021	10:45	21.4	g/m³	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	08/04/2021	10:20	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	08/04/2021	10:15	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	08/04/2021	10:30	0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	08/04/2021	10:45	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	08/04/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	08/04/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	08/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	08/04/2021	10:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	08/04/2021	10:30	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	08/04/2021	10:45	0.0025	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	08/04/2021	10:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	08/04/2021	10:30	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	08/04/2021	10:45	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	08/04/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	08/04/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	08/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	08/04/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	08/04/2021	10:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	08/04/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	08/04/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	08/04/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	08/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	08/04/2021	10:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	08/04/2021	10:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	08/04/2021	10:45	0.006	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	08/04/2021	10:15	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	08/04/2021	10:30	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	08/04/2021	10:45	8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	08/04/2021	10:15	15.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	08/04/2021	10:30	17	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	08/04/2021	10:45	15.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	08/04/2021	10:15	7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	08/04/2021	10:30	6.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	08/04/2021	10:45	7.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	08/04/2021	10:15	0.77	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	08/04/2021	10:30	0.52	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	08/04/2021	10:45	0.74	g/m³	(.2 - 5)
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	08/04/2021	10:20	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	08/04/2021	10:45	Completed		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	08/04/2021	10:20	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	08/04/2021	10:45	Completed		

	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	08/04/2021	10:15	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	08/04/2021	10:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	08/04/2021	10:45	Completed		
	Karitane Bowls	D-0058H	Free Available Chlorine	08/04/2021	13:40	0.78	g/m³	(.2 - 5)
	Karitane Bowls	D-0066H	Total Chlorine	08/04/2021	13:40	0.8	g/m³	
	Karitane Bowls	D-0084	Turbidity	08/04/2021	13:40	0.12	NTU	
	Karitane Bowls	D-1310	Temperature on arrival	08/04/2021	13:40	9.7	Deg C	
	Karitane Bowls	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	08/04/2021	13:40	<1	MPN/100mL	(0 - 0)
	Karitane Bowls	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	08/04/2021	13:40	<1	MPN/100ml	(0 - 0)
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	09/04/2021	09:55	77	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	09/04/2021	12:00	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	09/04/2021	12:15	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	09/04/2021	09:55	21	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	09/04/2021	12:00	21.3	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	09/04/2021	12:15	21.2	g/m³	
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	09/04/2021	09:55	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	09/04/2021	09:55	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	09/04/2021	12:00	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	09/04/2021	12:15	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	09/04/2021	09:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	09/04/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	09/04/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	09/04/2021	09:55	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	09/04/2021	12:00	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	09/04/2021	12:15	0.0016	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	09/04/2021	09:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	09/04/2021	12:00	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	09/04/2021	12:15	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	09/04/2021	09:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	09/04/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	09/04/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	09/04/2021	09:55	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	09/04/2021	12:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	09/04/2021	12:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	09/04/2021	09:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	09/04/2021	12:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	09/04/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	09/04/2021	09:55	0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	09/04/2021	12:00	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	09/04/2021	12:15	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	09/04/2021	09:55	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	09/04/2021	12:00	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	09/04/2021	12:15	7.9		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	09/04/2021	09:55	14.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	09/04/2021	12:00	16.6	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	09/04/2021	12:15	16.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	09/04/2021	09:55	7.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	09/04/2021	12:00	6.3	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	09/04/2021	12:15	7.3	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	09/04/2021	09:55	0.94	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	09/04/2021	12:00	0.72	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	09/04/2021	12:15	0.77	g/m³	(.2 - 5)
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	09/04/2021	09:55	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	09/04/2021	12:15	Completed		
No water	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	09/04/2021	09:55	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	09/04/2021	12:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	09/04/2021	09:55	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	09/04/2021	12:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	09/04/2021	12:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	09/04/2021	00:00:00	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	09/04/2021	00:00:00	77	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	09/04/2021	00:00:00	77	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	09/04/2021	00:00:00	75	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	09/04/2021	00:00:00	78	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	09/04/2021	00:00:00	75	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	09/04/2021	00:00:00	77	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	09/04/2021	00:00:00	74	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	09/04/2021	00:00:00	75	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	09/04/2021	00:00:00	73	g CaCO3/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	09/04/2021	00:00:00	25.5	mS/m (254.8 x .1)	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	20.9	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.6	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.5	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.6	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.4	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	20.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.3	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	09/04/2021	00:00:00	21.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	09/04/2021	00:00:00	16.7	g/m³	(250 - 250)
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	09/04/2021	00:00:00	23.5	g/m³	(250 - 250)
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	09/04/2021	00:00:00	104	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	09/04/2021	00:00:00	0.007	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	09/04/2021	00:00:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	09/04/2021	00:00:00	22.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	09/04/2021	00:00:00	<0.0005	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	09/04/2021	00:00:00	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	09/04/2021	00:00:00	9.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	09/04/2021	00:00:00	0.0135	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	09/04/2021	00:00:00	<0.002	g/m³	(1.5 - 1.5)
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.009	g/m³	
	Karitane Bowls	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.009	g/m³	
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.015	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.009	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.008	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	09/04/2021	00:00:00	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	09/04/2021	00:00:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Karitane Bowls	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	09/04/2021	00:00:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	09/04/2021	00:00:00	20.8	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0008	g/m³	(2 - 2)
	Karitane Bowls	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0131	g/m³	(2 - 2)
	Waikouaiti Golf Club	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0165	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	09/04/2021	00:00:00	0.0007	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Karitane Bowls	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	(.2 - .2)
	Waikouaiti Golf Club	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	09/04/2021	00:00:00	0.12	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	09/04/2021	00:00:00	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	09/04/2021	00:00:00	0.09	g/m³	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Karitane Bowls	6718	Lead - Dissolved	09/04/2021	00:00:00	0.0005	g/m³	(.005 - .01)
	Waikouaiti Golf Club	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)

	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	09/04/2021	00:00:00	9.2	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	09/04/2021	00:00:00	0.0006	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Karitane Bowls	6721	Manganese - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti Golf Club	6721	Manganese - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	09/04/2021	00:00:00	0.0178	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	09/04/2021	00:00:00	0.0006	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	09/04/2021	00:00:00	0.0193	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Karitane Bowls	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti Golf Club	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	09/04/2021	00:00:00	0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	09/04/2021	00:00:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Karitane Bowls	6738	Zinc - Dissolved	09/04/2021	00:00:00	0.012	g/m³	
	Waikouaiti Golf Club	6738	Zinc - Dissolved	09/04/2021	00:00:00	0.03	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	09/04/2021	00:00:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	09/04/2021	00:00:00	Completed		
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	09/04/2021	00:00:00	7.8		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	09/04/2021	00:00:00	7.8		
	Karitane Bowls	D-0001F	pH - Field	09/04/2021	00:00:00	7.9		
	Waikouaiti Golf Club	D-0001F	pH - Field	09/04/2021	00:00:00	8.1		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	09/04/2021	00:00:00	8		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	09/04/2021	00:00:00	7.8		
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	09/04/2021	00:00:00	7.7		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	09/04/2021	00:00:00	7.7		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	09/04/2021	00:00:00	7.6		
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	09/04/2021	00:00:00	15.1	Deg C	
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	09/04/2021	00:00:00	15.1	Deg C	
	Karitane Bowls	D-0053F	Temperature - Field	09/04/2021	00:00:00	14.1	Deg C	
	Waikouaiti Golf Club	D-0053F	Temperature - Field	09/04/2021	00:00:00	14.8	Deg C	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	09/04/2021	00:00:00	14.6	Deg C	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	09/04/2021	00:00:00	16.3	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	09/04/2021	00:00:00	13.3	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	09/04/2021	00:00:00	14.5	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	09/04/2021	00:00:00	13.5	Deg C	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.4	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.3	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.3	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.1	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.1	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	6.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	7.2	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	09/04/2021	00:00:00	6.9	g O2/m³	
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-0058H	Free Available Chlorine	09/04/2021	11:20:00	0.45	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.28	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.8	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.93	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.88	g/m³	(.2 - 5)
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.36	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.69	g/m³	(.2 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.84	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	09/04/2021	00:00:00	0.94	g/m³	(.2 - 5)

Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-0084	Turbidity	09/04/2021	11:20:00	0.14	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	09/04/2021	00:00:00	0.12	NTU	
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-1201	Sampling / Inspection 15 Mins	09/04/2021	11:20:00	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	09/04/2021	00:00:00	Completed		
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-1205	Sampling / Inspection 2 hours	09/04/2021	11:20:00	Completed		
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-1310	Temperature on arrival	09/04/2021	11:20:00	10.4	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	09/04/2021	00:00:00	10.4	Deg C	
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/04/2021	11:20:00	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	09/04/2021	00:00:00	<1	MPN/100mL	(0 - 0)
Waikouaiti Camp ground tank, not Karitane school	Karitane School	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/04/2021	11:20:00	<1	MPN/100ml	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	09/04/2021	00:00:00	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Karitane Bowls	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	09/04/2021	00:00:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	09/04/2021	00:00:00	3.6	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	09/04/2021	00:00:00	3.3	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	09/04/2021	00:00:00	11	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	09/04/2021	00:00:00	13	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	09/04/2021	00:00:00	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	09/04/2021	00:00:00	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	10/04/2021	09:10	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	10/04/2021	10:00	75	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	10/04/2021	09:35	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	10/04/2021	09:10	21.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	10/04/2021	10:00	21.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	10/04/2021	09:35	21.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	10/04/2021	09:10	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	10/04/2021	09:10	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	10/04/2021	10:00	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	10/04/2021	09:35	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	10/04/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	10/04/2021	10:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	10/04/2021	09:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	10/04/2021	09:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	10/04/2021	10:00	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	10/04/2021	09:35	0.0036	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	10/04/2021	09:10	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	10/04/2021	10:00	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	10/04/2021	09:35	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	10/04/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	10/04/2021	10:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	10/04/2021	09:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	10/04/2021	09:10	0.0011	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	10/04/2021	10:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	10/04/2021	09:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	10/04/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	10/04/2021	10:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	10/04/2021	09:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	10/04/2021	09:10	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	10/04/2021	10:00	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	10/04/2021	09:35	0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	10/04/2021	09:10	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	10/04/2021	10:00	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	10/04/2021	09:35	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	10/04/2021	09:10	14.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	10/04/2021	10:00	16.5	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	10/04/2021	09:35	15.6	Deg C	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	10/04/2021	09:10	8.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	10/04/2021	10:00	7.1	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	10/04/2021	09:35	8.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	10/04/2021	09:10	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	10/04/2021	10:00	0.39	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	10/04/2021	09:35	0.83	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	10/04/2021	09:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	10/04/2021	09:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	10/04/2021	09:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	10/04/2021	09:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	10/04/2021	09:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	10/04/2021	10:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	10/04/2021	09:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	11/04/2021	09:00	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	11/04/2021	09:30	75	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	11/04/2021	09:50	76	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	11/04/2021	09:00	19.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	11/04/2021	09:30	21.1	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	11/04/2021	09:50	21.8	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	11/04/2021	09:00	0.004	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	11/04/2021	09:30	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	11/04/2021	09:50	0.007	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	11/04/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	11/04/2021	09:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	11/04/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	11/04/2021	09:00	0.0021	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	11/04/2021	09:30	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	11/04/2021	09:50	0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	11/04/2021	09:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	11/04/2021	09:30	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	11/04/2021	09:50	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	11/04/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	11/04/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	11/04/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	11/04/2021	09:00	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	11/04/2021	09:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	11/04/2021	09:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	11/04/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	11/04/2021	09:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	11/04/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	11/04/2021	09:00	0.005	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	11/04/2021	09:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	11/04/2021	09:50	0.004	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	11/04/2021	09:10	No	water	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	11/04/2021	09:00	7.2		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	11/04/2021	09:30	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	11/04/2021	09:50	7.9		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	11/04/2021	09:00	14.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	11/04/2021	09:30	17	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	11/04/2021	09:50	15.4	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	11/04/2021	09:00	6.3	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	11/04/2021	09:30	6.2	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	11/04/2021	09:50	7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	11/04/2021	09:00	4.2	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	11/04/2021	09:30	1.6	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	11/04/2021	09:50	0.89	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	11/04/2021	09:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	11/04/2021	09:50	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	11/04/2021	09:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	11/04/2021	09:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	11/04/2021	09:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	12/04/2021	09:50	72	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	12/04/2021	09:45	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	12/04/2021	10:10	79	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	12/04/2021	10:20	76	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	12/04/2021	09:50	21.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	12/04/2021	09:45	21.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	12/04/2021	10:10	21.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	12/04/2021	10:20	21.5	g/m³	

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	12/04/2021	09:50	$100		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	12/04/2021	09:50	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	12/04/2021	09:45	0.34	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	12/04/2021	10:10	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	12/04/2021	10:20	0.008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	12/04/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	12/04/2021	09:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	12/04/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	12/04/2021	10:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	12/04/2021	09:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	12/04/2021	09:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	12/04/2021	10:10	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	12/04/2021	10:20	0.002	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	12/04/2021	09:50	0.09	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	12/04/2021	09:45	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	12/04/2021	10:10	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	12/04/2021	10:20	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	12/04/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	12/04/2021	09:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	12/04/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	12/04/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	12/04/2021	09:50	0.0039	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	12/04/2021	09:45	0.0125	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	12/04/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	12/04/2021	10:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	12/04/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	12/04/2021	09:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	12/04/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	12/04/2021	10:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	12/04/2021	09:50	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	12/04/2021	09:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	12/04/2021	10:10	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	12/04/2021	10:20	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	12/04/2021	09:50	7.6		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	12/04/2021	09:45	7.5		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	12/04/2021	10:10	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	12/04/2021	10:20	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	12/04/2021	09:50	13.6	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	12/04/2021	09:45	14	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	12/04/2021	10:10	16.7	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	12/04/2021	10:20	15.3	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	12/04/2021	09:50	5.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	12/04/2021	09:45	5.8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	12/04/2021	10:10	6.1	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	12/04/2021	10:20	6.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	12/04/2021	09:45	0.41	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	12/04/2021	10:10	0.87	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	12/04/2021	10:20	1	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	12/04/2021	09:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	12/04/2021	10:20	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	12/04/2021	09:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	12/04/2021	10:20	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	12/04/2021	09:50	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	12/04/2021	09:45	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	12/04/2021	10:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	12/04/2021	10:20	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	13/04/2021	10:50	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	13/04/2021	11:10	78	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	13/04/2021	11:20	77	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	13/04/2021	10:50	21.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	13/04/2021	11:10	22.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	13/04/2021	11:20	22.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	13/04/2021	10:50	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	13/04/2021	11:10	0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	13/04/2021	11:20	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	13/04/2021	10:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	13/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	13/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	13/04/2021	10:50	0.0015	g/m³	(2 - 2)

	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	13/04/2021	11:10	0.0013	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	13/04/2021	11:20	0.0025	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	13/04/2021	10:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	13/04/2021	11:10	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	13/04/2021	11:20	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	13/04/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	13/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	13/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	13/04/2021	10:50	0.0025	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	13/04/2021	11:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	13/04/2021	11:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	13/04/2021	10:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	13/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	13/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	13/04/2021	10:50	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	13/04/2021	11:10	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	13/04/2021	11:20	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	13/04/2021	00:00	No	Water	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	13/04/2021	10:50	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	13/04/2021	11:10	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	13/04/2021	11:20	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	13/04/2021	10:50	14.3	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	13/04/2021	11:10	16.3	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	13/04/2021	11:20	15.2	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	13/04/2021	10:50	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	13/04/2021	11:10	6.3	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	13/04/2021	11:20	6.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	13/04/2021	10:50	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	13/04/2021	11:10	0.57	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	13/04/2021	11:20	1	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	13/04/2021	11:20	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	13/04/2021	11:20	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	13/04/2021	10:50	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	13/04/2021	11:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	13/04/2021	11:20	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	1	pH	14/04/2021	12:40	7.7		(1 - 14)
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	14/04/2021	12:10	7.2		(7 - 8.5)
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	14/04/2021	12:40	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	14/04/2021	12:10	<6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0040B	Total Organic Carbon by TOC analyser	14/04/2021	12:40	4.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0040B	Total Organic Carbon by TOC analyser	14/04/2021	12:10	2.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	49	Total Solids - g/m3 units	14/04/2021	12:40	172	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	49	Total Solids - g/m3 units	14/04/2021	12:10	195	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	14/04/2021	12:40	71	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	14/04/2021	12:10	62	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	55	Conductivity at 25°C - mS/m unit	14/04/2021	12:40	24.1	mS/m (241.3 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	14/04/2021	12:10	24.9	mS/m (249.4 x .1)	
	Catchment - Waikouaiti River - Pump Station Intake	73	Bicarbonate by Calculation - requires tests 1 & 52	14/04/2021	12:40	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	73	Bicarbonate by Calculation - requires tests 1 & 52	14/04/2021	12:10	61	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	74	Carbonate by Calculation - requires tests 1, 52, 73	14/04/2021	12:40	<1	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	74	Carbonate by Calculation - requires tests 1, 52, 73	14/04/2021	12:10	<1	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	76	Free CO2 by Calculation - requires tests 1, 52 & 73	14/04/2021	12:40	3	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	76	Free CO2 by Calculation - requires tests 1, 52 & 73	14/04/2021	12:10	7	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 7(	14/04/2021	12:40	65	g CO2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	77	Total CO2 by Calculation - requires tests 1, 52, 73, 74, 7(	14/04/2021	12:10	61	g CO2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	84	Turbidity	14/04/2021	12:40	0.94	NTU	(2.5 - 2.5)
	Waikouaiti WTP - Post Treated Water Reservoir	84	Turbidity	14/04/2021	12:10	0.22	NTU	(2.5 - 2.5)
	Catchment - Waikouaiti River - Pump Station Intake	123	Total Dissolved Solids - Calc by conductivity meter	14/04/2021	12:40	118	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	123	Total Dissolved Solids - Calc by conductivity meter	14/04/2021	12:10	122	g/m³	(1000 - 1000)
	Catchment - Waikouaiti River - Pump Station Intake	0440B	Dissolved Organic Carbon	14/04/2021	12:40	2.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440B	Dissolved Organic Carbon	14/04/2021	12:10	1.3	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	601	Fluoride - Add P1859 Filtration	14/04/2021	12:40	0.15	g/m³	(1.5 - 1.5)
	Waikouaiti WTP - Post Treated Water Reservoir	601	Fluoride - Add P1859 Filtration	14/04/2021	12:10	0.14	g/m³	(1.5 - 1.5)
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	14/04/2021	12:40	13.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	14/04/2021	12:10	20.2	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	603	Nitrite - Nitrogen - Add P1859 Filtration	14/04/2021	12:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	603	Nitrite - Nitrogen - Add P1859 Filtration	14/04/2021	12:10	<0.01	g/m³	(.061 - .061)
	Catchment - Waikouaiti River - Pump Station Intake	604	Bromide - Add P1859 Filtration	14/04/2021	12:40	0.04	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	604	Bromide - Add P1859 Filtration	14/04/2021	12:10	<0.02	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake	605	Nitrate - Nitrogen - Add P1859 Filtration	14/04/2021	12:40	0.01	g/m³	(11.3 - 11.3)
	Waikouaiti WTP - Post Treated Water Reservoir	605	Nitrate - Nitrogen - Add P1859 Filtration	14/04/2021	12:10	0.02	g/m³	(11.3 - 11.3)
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	14/04/2021	12:40	16.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	14/04/2021	12:10	16.7	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	725	Cyanide by Discrete Analyser	14/04/2021	12:40	<0.005	g/m³	(.6 - .6)
	Waikouaiti WTP - Post Treated Water Reservoir	725	Cyanide by Discrete Analyser	14/04/2021	12:10	<0.005	g/m³	(.6 - .6)
	Catchment - Waikouaiti River - Pump Station Intake	1250	Transmissivity @ 253.7nm	14/04/2021	12:40	86.5	%	
	Waikouaiti WTP - Post Treated Water Reservoir	1250	Transmissivity @ 253.7nm	14/04/2021	12:10	95.5	%	
	Catchment - Waikouaiti River - Pump Station Intake	1643	Silica by OES	14/04/2021	12:40	3.04	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1643	Silica by OES	14/04/2021	12:10	3.13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	14/04/2021	12:10	0.008	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6002	Antimony - Acid Soluble	14/04/2021	12:10	<0.001	g/m³	(.02 - .02)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	14/04/2021	12:10	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6004	Barium - Acid Soluble	14/04/2021	12:10	0.013	g/m³	(.7 - .7)
	Waikouaiti WTP - Post Treated Water Reservoir	6007	Boron - Acid Soluble	14/04/2021	12:10	<0.03	g/m³	(1.4 - 1.4)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	14/04/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	14/04/2021	12:10	19.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6011	Chromium - Acid Soluble	14/04/2021	12:10	<0.001	g/m³	(.05 - .05)
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	14/04/2021	12:10	0.0023	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	14/04/2021	12:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	14/04/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	14/04/2021	12:10	8.68	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	14/04/2021	12:10	0.0099	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	14/04/2021	12:10	<0.0005	g/m³	(.007 - .007)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	14/04/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6028	Selenium - Acid Soluble	14/04/2021	12:10	<0.002	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6031	Sodium - Acid Soluble	14/04/2021	12:10	10.3	g/m³	(200 - 200)
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	14/04/2021	12:40	0.011	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6602	Antimony - Total	14/04/2021	12:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	14/04/2021	12:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6604	Barium - Total	14/04/2021	12:40	0.012	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6607	Boron - Total	14/04/2021	12:40	<0.05	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	14/04/2021	12:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	14/04/2021	12:40	19	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6611	Chromium - Total	14/04/2021	12:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	14/04/2021	12:40	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	14/04/2021	12:40	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	14/04/2021	12:40	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	14/04/2021	12:40	8.9	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	14/04/2021	12:40	0.022	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	14/04/2021	12:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	14/04/2021	12:40	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6628	Selenium - Total	14/04/2021	12:40	<0.005	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6631	Sodium - Total	14/04/2021	12:40	10.4	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	14/04/2021	00:00	No	Water	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	14/04/2021	12:40	14.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	14/04/2021	12:10	14.8	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	14/04/2021	12:40	7.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	14/04/2021	12:10	8.6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-1201	Sampling / Inspection 15 Mins	14/04/2021	12:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	14/04/2021	12:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-M0102	Faecal Coliforms by MF - Environmental Water	14/04/2021	12:40	210	cfu/100ml (207 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0102	Faecal Coliforms by MF - Environmental Water	14/04/2021	12:10	<1	cfu/100ml (<1 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0107	Enterococci - Environmental water	14/04/2021	12:40	150	cfu/100mL (145 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0107	Enterococci - Environmental water	14/04/2021	12:10	<1	cfu/100mL (<1 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/04/2021	12:40	2,000	MPN/100ml (1986.3 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0114	Total Coliforms by Colilert MPN 97 Wells- Enviro Water	14/04/2021	12:10	<1	MPN/100ml (<1 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/04/2021	12:40	460	MPN/100mL (461.1 x 1)	
	Waikouaiti WTP - Post Treated Water Reservoir	D-M0115	E. coli by Colilert MPN 97 Wells - Environmental Water	14/04/2021	12:10	<1	MPN/100mL (<1 x 1)	
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	14/04/2021	12:40	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	14/04/2021	12:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	14/04/2021	12:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	4000a	Total Algae Count - cells	14/04/2021	12:40	25	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4000b	Total Algae Count - units	14/04/2021	12:40	18	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4100a	Green Algae using cells	14/04/2021	12:40	3	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4100b	Green Algae using units	14/04/2021	12:40	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4153a	Rhizoclonium cells	14/04/2021	12:40	3	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4153b	Rhizoclonium units	14/04/2021	12:40	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4300a	Chrysophyta using cells	14/04/2021	12:40	21	Cells per mL	

	Catchment - Waikouaiti River - Pump Station Intake	4300b	Chrysophyta using units	14/04/2021	12:40	16	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4309a	Cocconeis cells	14/04/2021	12:40	2	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4309b	Cocconeis units	14/04/2021	12:40	2	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4315a	Cymbella cells	14/04/2021	12:40	2	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4315b	Cymbella units	14/04/2021	12:40	2	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4324a	Epithemia cells	14/04/2021	12:40	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4324b	Epithemia units	14/04/2021	12:40	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4332a	Gomphoneis cells	14/04/2021	12:40	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4332b	Gomphoneis units	14/04/2021	12:40	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4342a	Melosira cells	14/04/2021	12:40	5	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4342b	Melosira units	14/04/2021	12:40	<1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4348a	Nitzschia cells	14/04/2021	12:40	10	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4348b	Nitzschia units	14/04/2021	12:40	10	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4700a	Other Algae using cells	14/04/2021	12:40	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4700b	Other Algae using units	14/04/2021	12:40	1	Units per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4703a	Cryptomonas cells	14/04/2021	12:40	1	Cells per mL	
	Catchment - Waikouaiti River - Pump Station Intake	4703b	Cryptomonas units	14/04/2021	12:40	1	Units per mL	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	14/04/2021	00:00:00	No	Water	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV001	Aldrin and Dieldrin	14/04/2021	12:40	<0.00003	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV001	Aldrin and Dieldrin	14/04/2021	12:10	<0.00003	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV007	DDT and Isomers	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV007	DDT and Isomers	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV020	Cyanazine	14/04/2021	12:40	<0.0007	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV020	Cyanazine	14/04/2021	12:10	<0.0007	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV027	Oryzalin	14/04/2021	12:40	<0.010	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV027	Oryzalin	14/04/2021	12:10	<0.010	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV033	Terbacil	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV033	Terbacil	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV036	Azinphos Methyl	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV036	Azinphos Methyl	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV040	Aldicarb	14/04/2021	12:40	<0.006	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV040	Aldicarb	14/04/2021	12:10	<0.006	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV042	Chlorotoluron	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV042	Chlorotoluron	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV043	Diuron	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV043	Diuron	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV044	Isoproturon	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV044	Isoproturon	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV045	Primisulfuron-methyl	14/04/2021	12:40	<0.01	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV045	Primisulfuron-methyl	14/04/2021	12:10	<0.01	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	LS-SV046	Thiabendazole	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	LS-SV046	Thiabendazole	14/04/2021	12:10	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-003	a-chlordane	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-010	Endrin	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-017	Lindane (g-BHC)	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-018	Methoxychlor	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-022	Procymidone	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-025	Alachlor	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-027	Atrazine	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-028	Bromacil	14/04/2021	12:10	<0.005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-029	Carbofuran	14/04/2021	12:10	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-032	Metalaxyl-M	14/04/2021	12:10	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-033	Metolachlor	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-034	Metribuzin	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-035	Molinate	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-037	Oxadiazon	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-038	Pendimethalin	14/04/2021	12:10	<0.002	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-039	Propazine	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-040	Pyriproxyfen	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-041	Simazine	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-042	Terbuthylazine	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-043	Trifluralin	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-044	Hexazinone	14/04/2021	12:10	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-045	Chlorpyrifos	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-047	Dimethoate	14/04/2021	12:10	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-048	Pirimiphos methyl	14/04/2021	12:10	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-053	Benzo(a)pyrene	14/04/2021	12:10	<0.0001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	SVOC-073	Bis(2-ethylhexyl)phthalate	14/04/2021	12:40	<0.0050	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	SVOC-073	Bis(2-ethylhexyl)phthalate	14/04/2021	12:10	<0.0050	mg/L	

	Catchment - Waikouaiti River - Pump Station Intake	VOC-001	1,2,4-Trimethylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-001	1,2,4-Trimethylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-002	1,3,5-Trimethylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-002	1,3,5-Trimethylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-003	Benzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-003	Benzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-005	Isopropylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-005	Isopropylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-007	Naphthalene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-007	Naphthalene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-008	n-Butylbenezene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-008	n-Butylbenezene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-009	n-Propylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-009	n-Propylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-010	o-Xylene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-010	o-Xylene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-011	p-Isopropyltoluene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-011	p-Isopropyltoluene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-013	sec-Butylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-013	sec-Butylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-014	Styrene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-014	Styrene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-015	tert-Butylbenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-015	tert-Butylbenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-016	Toluene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-016	Toluene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-017	Total p,m Xylene, Ethylbenzene	14/04/2021	12:40	<0.0015	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-017	Total p,m Xylene, Ethylbenzene	14/04/2021	12:10	<0.0015	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-018	1,1,1,2-Tetrachloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-018	1,1,1,2-Tetrachloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-019	1,1,1-Trichloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-019	1,1,1-Trichloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-020	1,1,2,2-Tetrachloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-020	1,1,2,2-Tetrachloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-021	1,1,2-Trichloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-021	1,1,2-Trichloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-022	1,1-Dichloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-022	1,1-Dichloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-023	1,1-Dichloroethene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-023	1,1-Dichloroethene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-024	1,1-Dichloropropene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-024	1,1-Dichloropropene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-025	1,2,3-Trichloropropane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-025	1,2,3-Trichloropropane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-026	1,2-Dibromo-3-chloropropane	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-026	1,2-Dibromo-3-chloropropane	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-027	1,2-Dibromoethane	14/04/2021	12:40	<0.0002	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-027	1,2-Dibromoethane	14/04/2021	12:10	<0.0002	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-028	1,2-Dichloroethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-028	1,2-Dichloroethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-029	1,2-Dichloropropane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-029	1,2-Dichloropropane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-030	1,3-Dichloropropane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-030	1,3-Dichloropropane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-031	2,2-Dichloropropane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-031	2,2-Dichloropropane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-032	Allyl chloride	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-032	Allyl chloride	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-033	Bromochloromethane	14/04/2021	12:40	<0.0012	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-033	Bromochloromethane	14/04/2021	12:10	<0.0012	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-034	Bromomethane	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-034	Bromomethane	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-035	Carbon tetrachloride	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-035	Carbon tetrachloride	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-036	Chloroethane	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-036	Chloroethane	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-037	Chloromethane	14/04/2021	12:40	<0.006	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-037	Chloromethane	14/04/2021	12:10	<0.006	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-038	cis-1,2-Dichloroethene	14/04/2021	12:40	<0.0005	mg/L	

	Waikouaiti WTP - Post Treated Water Reservoir	VOC-038	cis-1,2-Dichloroethene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-039	cis-1,3-Dichloropropene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-039	cis-1,3-Dichloropropene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-040	Dibromomethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-040	Dibromomethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-041	Dichlorodifluoromethane	14/04/2021	12:40	<0.001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-041	Dichlorodifluoromethane	14/04/2021	12:10	<0.001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-042	Dichloromethane	14/04/2021	12:40	<0.005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-042	Dichloromethane	14/04/2021	12:10	<0.005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-043	Hexachlorobutadiene	14/04/2021	12:40	<0.0002	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-043	Hexachlorobutadiene	14/04/2021	12:10	<0.0002	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-044	Tetrachloroethene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-044	Tetrachloroethene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-045	trans-1,2-Dichloroethene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-045	trans-1,2-Dichloroethene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-046	trans-1,3-Dichloropropene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-046	trans-1,3-Dichloropropene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-047	Trichloroethene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-047	Trichloroethene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-048	Trichlorofluoromethane	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-048	Trichlorofluoromethane	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-049	Vinyl Chloride	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-049	Vinyl Chloride	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-050	1,2,3-Trichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-050	1,2,3-Trichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-051	1,2,4-Trichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-051	1,2,4-Trichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-052	1,2-Dichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-052	1,2-Dichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-053	1,3-Dichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-053	1,3-Dichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-054	1,4-Dichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-054	1,4-Dichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-055	2-Chlorotoluene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-055	2-Chlorotoluene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-056	4-Chlorotoluene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-056	4-Chlorotoluene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-057	Bromobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-057	Bromobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-058	Chlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-058	Chlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-059	1,3,5-Trichlorobenzene	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-059	1,3,5-Trichlorobenzene	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-060	4-Methyl-2-Pentanone	14/04/2021	12:40	<0.0010	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-060	4-Methyl-2-Pentanone	14/04/2021	12:10	<0.0010	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-061	Carbon disulphide	14/04/2021	12:40	<0.0005	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-061	Carbon disulphide	14/04/2021	12:10	<0.0005	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-062	Bromodichloromethane	14/04/2021	12:40	<0.0005	mg/L	(.06 - .06)
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-062	Bromodichloromethane	14/04/2021	12:10	0.0014	mg/L	(.06 - .06)
	Catchment - Waikouaiti River - Pump Station Intake	VOC-063	Bromoform	14/04/2021	12:40	<0.0005	mg/L	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-063	Bromoform	14/04/2021	12:10	<0.0005	mg/L	(.1 - .1)
	Catchment - Waikouaiti River - Pump Station Intake	VOC-064	Chloroform	14/04/2021	12:40	<0.0005	mg/L	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-064	Chloroform	14/04/2021	12:10	0.0036	mg/L	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	VOC-065	Dibromochloromethane	14/04/2021	12:40	<0.0005	mg/L	(.15 - .15)
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-065	Dibromochloromethane	14/04/2021	12:10	0.0008	mg/L	(.15 - .15)
	Catchment - Waikouaiti River - Pump Station Intake	VOC-067	Epichlorohydrin	14/04/2021	12:40	<0.0001	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-067	Epichlorohydrin	14/04/2021	12:10	<0.0001	mg/L	
	Catchment - Waikouaiti River - Pump Station Intake	VOC-068	1,4-Dioxane	14/04/2021	12:40	<0.04	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	VOC-068	1,4-Dioxane	14/04/2021	12:10	<0.04	mg/L	
	Waikouaiti WTP - Post Treated Water Reservoir	1	pH	14/04/2021	12:10	7.1		(7 - 8.5)
	Waikouaiti SS - 210 Edinburgh St	1	pH	14/04/2021	13:15	7.8		(7 - 8.5)
	Waikouaiti SS - 319 Bendigo Rd	1	pH	14/04/2021	13:40	7.7		(7 - 8.5)
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	14/04/2021	12:10	61	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	14/04/2021	13:15	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	14/04/2021	13:40	75	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	14/04/2021	12:10	19.5	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	14/04/2021	13:15	22.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	14/04/2021	13:40	22.2	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	14/04/2021	00:00	$100		

	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	14/04/2021	12:10	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	14/04/2021	13:15	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	14/04/2021	13:40	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	14/04/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	14/04/2021	13:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	14/04/2021	13:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	14/04/2021	12:10	0.0025	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	14/04/2021	13:15	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	14/04/2021	13:40	0.0019	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	14/04/2021	12:10	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	14/04/2021	13:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	14/04/2021	13:40	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	14/04/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	14/04/2021	13:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	14/04/2021	13:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	14/04/2021	12:10	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	14/04/2021	13:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	14/04/2021	13:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	14/04/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	14/04/2021	13:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	14/04/2021	13:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	14/04/2021	12:10	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	14/04/2021	13:15	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	14/04/2021	13:40	0.006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	14/04/2021	00:00	No	Water	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	14/04/2021	12:10	14.8	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	14/04/2021	13:15	16.5	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	14/04/2021	13:40	15.5	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	14/04/2021	12:10	8.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	14/04/2021	13:15	7.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	14/04/2021	13:40	8.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	14/04/2021	12:10	4.4	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	14/04/2021	13:15	0.76	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	14/04/2021	13:40	0.72	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	14/04/2021	00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	14/04/2021	13:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	14/04/2021	00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	14/04/2021	13:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	14/04/2021	12:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	14/04/2021	13:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	14/04/2021	13:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	15/04/2021	08:40	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	15/04/2021	11:25	76	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	15/04/2021	12:00	77	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	15/04/2021	08:40	23	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	15/04/2021	11:25	22.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	15/04/2021	12:00	22.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	15/04/2021	00:00:00	$100		
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	15/04/2021	08:40	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	15/04/2021	11:25	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	15/04/2021	12:00	0.009	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	15/04/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	15/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	15/04/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	15/04/2021	11:25	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	15/04/2021	12:00	0.0028	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	15/04/2021	08:40	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	15/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	15/04/2021	12:00	<0.01	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	15/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	15/04/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	15/04/2021	08:40	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	15/04/2021	11:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	15/04/2021	12:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	15/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	15/04/2021	12:00	<0.0005	g/m³	(.08 - .08)

	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	15/04/2021	08:40	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	15/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	15/04/2021	12:00	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	15/04/2021	00:00:00	No	Water	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	15/04/2021	08:40	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	15/04/2021	11:25	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	15/04/2021	12:00	7.9		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	15/04/2021	08:40	13.2	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	15/04/2021	11:25	15.6	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	15/04/2021	12:00	13.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	15/04/2021	08:40	6.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	15/04/2021	11:25	7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	15/04/2021	12:00	6.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/04/2021	08:40	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	15/04/2021	11:25	0.41	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	15/04/2021	12:00	1	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	15/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	15/04/2021	12:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	15/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	15/04/2021	12:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	15/04/2021	08:40	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	15/04/2021	11:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	15/04/2021	12:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	15/04/2021	08:40	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	15/04/2021	11:00	74	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	15/04/2021	10:10	76	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	15/04/2021	10:15	76	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	15/04/2021	11:40	77	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	15/04/2021	09:40	76	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	15/04/2021	09:50	76	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	15/04/2021	09:05	73	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	15/04/2021	08:40	77	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	15/04/2021	09:10	73	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	15/04/2021	08:40	25.5	mS/m (254.5 x .1)	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	15/04/2021	11:00	22.7	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	15/04/2021	10:10	22.9	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	15/04/2021	10:15	22.4	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	15/04/2021	11:40	22.3	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	15/04/2021	09:40	22.4	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	15/04/2021	09:50	23	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	15/04/2021	09:05	22.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	15/04/2021	08:40	22.6	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	15/04/2021	09:10	21.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	15/04/2021	08:40	16.5	g/m³	(250 - 250)
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	15/04/2021	08:40	16.4	g/m³	(250 - 250)
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	15/04/2021	08:40	127	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	15/04/2021	08:40	0.007	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	15/04/2021	08:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	15/04/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	15/04/2021	08:40	19.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	15/04/2021	08:40	<0.0005	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	15/04/2021	08:40	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	15/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	15/04/2021	08:40	8.79	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	15/04/2021	08:40	0.0091	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	15/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	15/04/2021	08:40	<0.002	g/m³	(1.5 - 1.5)
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	15/04/2021	11:00	0.007	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	15/04/2021	10:10	0.008	g/m³	
	Karitane Bowls	6701	Aluminium - Dissolved	15/04/2021	10:15	0.008	g/m³	
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	15/04/2021	11:40	0.012	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	15/04/2021	09:40	0.007	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	15/04/2021	09:50	0.008	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	15/04/2021	09:05	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	15/04/2021	08:40	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	15/04/2021	09:10	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	15/04/2021	08:40	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	15/04/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	15/04/2021	10:10	<0.0002	g/m³	(.004 - .004)

	Karitane Bowls	6708	Cadmium - Dissolved	15/04/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	15/04/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	15/04/2021	09:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	15/04/2021	09:50	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	15/04/2021	09:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	15/04/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	15/04/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	15/04/2021	08:40	22.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	15/04/2021	11:00	0.0008	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	15/04/2021	10:10	0.0007	g/m³	(2 - 2)
	Karitane Bowls	6713	Copper - Dissolved	15/04/2021	10:15	0.0063	g/m³	(2 - 2)
	Waikouaiti Golf Club	6713	Copper - Dissolved	15/04/2021	11:40	0.019	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	15/04/2021	09:40	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	15/04/2021	09:50	<0.0005	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	15/04/2021	09:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	15/04/2021	09:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	15/04/2021	11:00	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	15/04/2021	10:10	<0.01	g/m³	
	Karitane Bowls	6717	Iron - Dissolved	15/04/2021	10:15	<0.01	g/m³	(.2 - .2)
	Waikouaiti Golf Club	6717	Iron - Dissolved	15/04/2021	11:40	0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	15/04/2021	09:40	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	15/04/2021	09:50	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	15/04/2021	09:05	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	15/04/2021	08:40	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	15/04/2021	09:10	0.14	g/m³	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	15/04/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	15/04/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Karitane Bowls	6718	Lead - Dissolved	15/04/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti Golf Club	6718	Lead - Dissolved	15/04/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	15/04/2021	09:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	15/04/2021	09:50	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	15/04/2021	09:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	15/04/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	15/04/2021	08:40	9.63	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	15/04/2021	11:00	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	15/04/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Karitane Bowls	6721	Manganese - Dissolved	15/04/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti Golf Club	6721	Manganese - Dissolved	15/04/2021	11:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	15/04/2021	09:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	15/04/2021	09:50	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	15/04/2021	09:05	0.012	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	15/04/2021	08:40	0.0008	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	15/04/2021	09:10	0.0123	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	15/04/2021	11:00	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	15/04/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Karitane Bowls	6724	Nickel - Dissolved	15/04/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti Golf Club	6724	Nickel - Dissolved	15/04/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	15/04/2021	09:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	15/04/2021	09:50	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	15/04/2021	09:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	15/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	15/04/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	15/04/2021	11:00	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	15/04/2021	10:10	<0.002	g/m³	
	Karitane Bowls	6738	Zinc - Dissolved	15/04/2021	10:15	0.006	g/m³	
	Waikouaiti Golf Club	6738	Zinc - Dissolved	15/04/2021	11:40	0.065	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	15/04/2021	09:40	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	15/04/2021	09:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	15/04/2021	09:05	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	15/04/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	15/04/2021	09:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	15/04/2021	08:40	Completed		
	Karitane School	C-O1420	Sampler Observation	15/04/2021	00:00	No	sample	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	C-O1420	Sampler Observation	15/04/2021	00:00:00	No	Water	
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	15/04/2021	11:00	7.8		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	15/04/2021	10:10	7.9		
	Karitane Bowls	D-0001F	pH - Field	15/04/2021	10:15	7.9		

	Waikouaiti Golf Club	D-0001F	pH - Field	15/04/2021	11:40	8.1		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	15/04/2021	09:40	8		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	15/04/2021	09:50	7.9		
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	15/04/2021	09:05	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	15/04/2021	08:40	7.7		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	15/04/2021	09:10	7.8		
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	15/04/2021	11:00	14.8	Deg C	
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	15/04/2021	10:10	14.1	Deg C	
	Karitane Bowls	D-0053F	Temperature - Field	15/04/2021	10:15	12.9	Deg C	
	Waikouaiti Golf Club	D-0053F	Temperature - Field	15/04/2021	11:40	13.6	Deg C	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	15/04/2021	09:40	13.7	Deg C	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	15/04/2021	09:50	15.5	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	15/04/2021	09:05	12.3	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	15/04/2021	08:40	13.2	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	15/04/2021	09:10	12.3	Deg C	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	15/04/2021	11:00	6.4	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	15/04/2021	10:10	6.6	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	15/04/2021	10:15	7	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	15/04/2021	11:40	7.7	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	15/04/2021	09:40	6.9	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	15/04/2021	09:50	6.6	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	15/04/2021	09:05	7.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	15/04/2021	08:40	6.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	15/04/2021	09:10	7.3	g O2/m³	
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	15/04/2021	10:30	0.43	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	15/04/2021	11:00	1	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	15/04/2021	10:10	1	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	15/04/2021	10:15	1	g/m³	(.2 - 5)
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	15/04/2021	11:40	0.32	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	15/04/2021	09:40	0.8	g/m³	(.2 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	15/04/2021	09:50	0.92	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	15/04/2021	08:40	1	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	15/04/2021	10:30	0.35	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	15/04/2021	10:30	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	15/04/2021	10:30	7.8	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	15/04/2021	10:30	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	15/04/2021	10:30	<1	MPN/100ml	(0 - 0)
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	15/04/2021	11:00	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	15/04/2021	10:10	Completed		
	Karitane Bowls	P1859	Sample Filtration	15/04/2021	10:15	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	15/04/2021	11:40	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	15/04/2021	09:40	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	15/04/2021	09:50	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	15/04/2021	09:05	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	15/04/2021	08:40	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	15/04/2021	09:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	15/04/2021	09:05	3.5	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	15/04/2021	08:40	4	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	15/04/2021	09:05	6.8	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	15/04/2021	08:40	7.5	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	15/04/2021	09:05	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	15/04/2021	08:40	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	16/04/2021	11:45	66	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	16/04/2021	11:20	74	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	16/04/2021	10:45	77	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	16/04/2021	10:05	77	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	16/04/2021	11:45	18.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	16/04/2021	11:20	20.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	16/04/2021	10:45	21.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	16/04/2021	10:05	20.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1214	Surcharge Fee	16/04/2021	11:45	$100		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	16/04/2021	11:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	16/04/2021	11:20	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	16/04/2021	10:45	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	16/04/2021	10:05	0.007	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	16/04/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	16/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	16/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	16/04/2021	10:05	<0.0002	g/m³	(.004 - .004)

	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	16/04/2021	11:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	16/04/2021	11:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	16/04/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	16/04/2021	10:05	0.0028	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	16/04/2021	11:45	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	16/04/2021	11:20	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	16/04/2021	10:45	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	16/04/2021	10:05	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	16/04/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	16/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	16/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	16/04/2021	10:05	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	16/04/2021	11:45	0.0103	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	16/04/2021	11:20	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	16/04/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	16/04/2021	10:05	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	16/04/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	16/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	16/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	16/04/2021	10:05	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	16/04/2021	11:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	16/04/2021	11:20	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	16/04/2021	10:45	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	16/04/2021	10:05	0.008	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	16/04/2021	11:45	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	16/04/2021	11:20	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	16/04/2021	10:45	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	16/04/2021	10:05	7.7		
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	16/04/2021	11:45	12.9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	16/04/2021	11:20	13.8	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	16/04/2021	10:45	15.9	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	16/04/2021	10:05	15	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	16/04/2021	11:45	8.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	16/04/2021	11:20	8.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	16/04/2021	10:45	7.2	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	16/04/2021	10:05	7.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	16/04/2021	11:20	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	16/04/2021	10:45	0.39	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	16/04/2021	10:05	1	g/m³	(.2 - 5)
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	16/04/2021	11:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	16/04/2021	10:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	16/04/2021	11:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	16/04/2021	10:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	16/04/2021	11:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	16/04/2021	11:20	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	16/04/2021	10:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	16/04/2021	10:05	Completed		
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1214	Surcharge Fee	16/04/2021	09:45:00	$100		
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	09:45:00	6.08	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	09:50:00	6.11	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	09:55:00	6.17	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	10:00:00	3.81	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	10:05:00	3.95	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1610	Calcium - Acid Soluble by OES	16/04/2021	10:10:00	4.07	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	09:45:00	1.8	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	09:50:00	1.82	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	09:55:00	1.95	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	10:00:00	1.16	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	10:05:00	1.19	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1622	Magnesium - Acid Soluble by OES	16/04/2021	10:10:00	1.19	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	09:45:00	0.069	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	09:50:00	0.07	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	09:55:00	0.086	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	10:00:00	<0.005	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	10:05:00	<0.005	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	1623	Manganese - Acid Soluble by OES	16/04/2021	10:10:00	<0.005	g/m³	

Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	09:45:00	0.106	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	09:50:00	0.098	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	09:55:00	0.691	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	10:00:00	0.013	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	10:05:00	0.015	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6001	Aluminium - Acid Soluble	16/04/2021	10:10:00	0.017	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	09:45:00	<0.001	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	09:50:00	<0.001	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	09:55:00	0.001	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	10:00:00	<0.001	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	10:05:00	<0.001	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6003	Arsenic - Acid Soluble	16/04/2021	10:10:00	<0.001	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	09:45:00	0.0003	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	09:50:00	0.0003	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	09:55:00	0.0003	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	10:00:00	0.0003	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	10:05:00	<0.0002	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6008	Cadmium - Acid Soluble	16/04/2021	10:10:00	<0.0002	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	09:45:00	0.375	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	09:50:00	0.406	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	09:55:00	0.709	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	10:00:00	0.0498	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	10:05:00	0.0593	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6013	Copper - Acid Soluble	16/04/2021	10:10:00	0.0775	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	09:45:00	0.11	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	09:50:00	0.11	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	09:55:00	0.4	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	10:00:00	0.01	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	10:05:00	0.03	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6017	Iron - Acid Soluble	16/04/2021	10:10:00	0.02	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	09:45:00	0.0402	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	09:50:00	0.0436	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	09:55:00	0.0578	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	10:00:00	0.0067	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	10:05:00	0.009	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6018	Lead - Acid Soluble	16/04/2021	10:10:00	0.0089	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	09:45:00	0.0159	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	09:50:00	0.0164	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	09:55:00	0.0176	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	10:00:00	0.0384	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	10:05:00	0.0315	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6024	Nickel - Acid Soluble	16/04/2021	10:10:00	0.0272	g/m³	
Sample 1 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	09:45:00	1.22	g/m³	
Sample 2 Handheld Duplicate	Karitane Bowls - Toby and meter - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	09:50:00	1.26	g/m³	
Sample 3 Contained particulates	Karitane Bowls - Toby and meter - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	09:55:00	1.33	g/m³	
Sample 1 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	10:00:00	0.68	g/m³	
Sample 2 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	10:05:00	0.398	g/m³	
Sample 3 Handheld Duplicate	Waikouaiti Golf Club - Double Check Valve and fittings - Stagnation Test	6038	Zinc - Acid Soluble	16/04/2021	10:10:00	0.25	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	17/04/2021	07:50	66	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	17/04/2021	08:03	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	17/04/2021	08:42	77	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	17/04/2021	08:25	74	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	17/04/2021	07:50	18.6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	17/04/2021	08:03	20.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	17/04/2021	08:42	21.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	17/04/2021	08:25	20.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1214	Surcharge Fee	17/04/2021	07:50	$100		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	17/04/2021	07:50	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	17/04/2021	08:03	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	17/04/2021	08:42	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	17/04/2021	08:25	0.008	g/m³	

	Catchment - Waikouaiti River - Pump Station Intake		6708	Cadmium - Dissolved	17/04/2021	07:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir		6708	Cadmium - Dissolved	17/04/2021	08:03	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St		6708	Cadmium - Dissolved	17/04/2021	08:42	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd		6708	Cadmium - Dissolved	17/04/2021	08:25	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake		6713	Copper - Dissolved	17/04/2021	07:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir		6713	Copper - Dissolved	17/04/2021	08:03	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St		6713	Copper - Dissolved	17/04/2021	08:42	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd		6713	Copper - Dissolved	17/04/2021	08:25	0.0026	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake		6717	Iron - Dissolved	17/04/2021	07:50	0.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		6717	Iron - Dissolved	17/04/2021	08:03	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St		6717	Iron - Dissolved	17/04/2021	08:42	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		6717	Iron - Dissolved	17/04/2021	08:25	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake		6718	Lead - Dissolved	17/04/2021	07:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir		6718	Lead - Dissolved	17/04/2021	08:03	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St		6718	Lead - Dissolved	17/04/2021	08:42	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd		6718	Lead - Dissolved	17/04/2021	08:25	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake		6721	Manganese - Dissolved	17/04/2021	07:50	0.0053	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir		6721	Manganese - Dissolved	17/04/2021	08:03	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St		6721	Manganese - Dissolved	17/04/2021	08:42	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd		6721	Manganese - Dissolved	17/04/2021	08:25	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake		6724	Nickel - Dissolved	17/04/2021	07:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir		6724	Nickel - Dissolved	17/04/2021	08:03	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St		6724	Nickel - Dissolved	17/04/2021	08:42	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd		6724	Nickel - Dissolved	17/04/2021	08:25	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake		6738	Zinc - Dissolved	17/04/2021	07:50	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		6738	Zinc - Dissolved	17/04/2021	08:03	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St		6738	Zinc - Dissolved	17/04/2021	08:42	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		6738	Zinc - Dissolved	17/04/2021	08:25	0.006	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F		pH - Field	17/04/2021	07:50	8.2		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F		pH - Field	17/04/2021	08:03	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F		pH - Field	17/04/2021	08:42	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F		pH - Field	17/04/2021	08:25	7.9		
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F		Temperature - Field	17/04/2021	07:50	10.9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F		Temperature - Field	17/04/2021	08:03	13.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F		Temperature - Field	17/04/2021	08:42	14.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F		Temperature - Field	17/04/2021	08:25	14.2	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F		Dissolved Oxygen - Field	17/04/2021	07:50	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F		Dissolved Oxygen - Field	17/04/2021	08:03	6.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F		Dissolved Oxygen - Field	17/04/2021	08:42	6.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F		Dissolved Oxygen - Field	17/04/2021	08:25	7.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H		Free Available Chlorine	17/04/2021	08:03	0.47	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H		Free Available Chlorine	17/04/2021	08:42	0.34	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H		Free Available Chlorine	17/04/2021	08:25	0.91	g/m³	(.2 - 5)
	Catchment - Waikouaiti River - Pump Station Intake	D-1202		Sampling / Inspection 30 Mins	17/04/2021	07:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202		Sampling / Inspection 30 Mins	17/04/2021	08:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204		Sampling / Inspection 60 Mins	17/04/2021	07:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204		Sampling / Inspection 60 Mins	17/04/2021	08:25	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859		Sample Filtration	17/04/2021	07:50	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859		Sample Filtration	17/04/2021	08:03	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859		Sample Filtration	17/04/2021	08:42	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859		Sample Filtration	17/04/2021	08:25	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		52	Alkalinity - Total	18/04/2021	08:10	67	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		52	Alkalinity - Total	18/04/2021	08:00	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St		52	Alkalinity - Total	18/04/2021	08:30	77	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd		52	Alkalinity - Total	18/04/2021	09:00	74	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D		Dissolved Inorganic Carbon	18/04/2021	08:10	18.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D		Dissolved Inorganic Carbon	18/04/2021	08:00	20.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D		Dissolved Inorganic Carbon	18/04/2021	08:30	21.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D		Dissolved Inorganic Carbon	18/04/2021	09:00	20.5	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		1214	Surcharge Fee	18/04/2021	08:10	$100		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6701	Aluminium - Dissolved	18/04/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir		6701	Aluminium - Dissolved	18/04/2021	08:00	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St		6701	Aluminium - Dissolved	18/04/2021	08:30	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd		6701	Aluminium - Dissolved	18/04/2021	09:00	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6708	Cadmium - Dissolved	18/04/2021	08:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir		6708	Cadmium - Dissolved	18/04/2021	08:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St		6708	Cadmium - Dissolved	18/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd		6708	Cadmium - Dissolved	18/04/2021	09:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		6713	Copper - Dissolved	18/04/2021	08:10	0.0011	g/m³	(2 - 2)

	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	18/04/2021	08:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	18/04/2021	08:30	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	18/04/2021	09:00	0.0019	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	18/04/2021	08:10	0.09	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	18/04/2021	08:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	18/04/2021	08:30	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	18/04/2021	09:00	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	18/04/2021	08:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	18/04/2021	08:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	18/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	18/04/2021	09:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	18/04/2021	08:10	0.0036	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	18/04/2021	08:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	18/04/2021	08:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	18/04/2021	09:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	18/04/2021	08:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	18/04/2021	08:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	18/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	18/04/2021	09:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	18/04/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	18/04/2021	08:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	18/04/2021	08:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	18/04/2021	09:00	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	18/04/2021	08:10	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	18/04/2021	08:00	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	18/04/2021	08:30	8.1		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	18/04/2021	09:00	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	18/04/2021	08:10	12.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	18/04/2021	08:00	13.9	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	18/04/2021	08:30	14.4	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	18/04/2021	09:00	14.4	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	18/04/2021	08:10	7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	18/04/2021	08:00	7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	18/04/2021	08:30	6.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	18/04/2021	09:00	6.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	18/04/2021	08:00	0.93	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	18/04/2021	08:30	0.43	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	18/04/2021	09:00	0.87	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	18/04/2021	08:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	18/04/2021	09:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	18/04/2021	08:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	18/04/2021	09:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	18/04/2021	08:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	18/04/2021	08:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	18/04/2021	08:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	18/04/2021	09:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	19/04/2021	10:10	67	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	19/04/2021	10:00	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	19/04/2021	10:30	78	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	19/04/2021	10:45	74	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	19/04/2021	10:10	18.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	19/04/2021	10:00	20.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	19/04/2021	10:30	21.3	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	19/04/2021	10:45	20.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1214	Surcharge Fee	19/04/2021	10:10	$100		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	19/04/2021	10:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	19/04/2021	10:00	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	19/04/2021	10:30	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	19/04/2021	10:45	0.009	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	19/04/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	19/04/2021	10:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	19/04/2021	10:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	19/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	19/04/2021	10:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	19/04/2021	10:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	19/04/2021	10:30	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	19/04/2021	10:45	0.0016	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	19/04/2021	10:10	0.12	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	19/04/2021	10:00	<0.01	g/m³	

	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	19/04/2021	10:30	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	19/04/2021	10:45	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	19/04/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	19/04/2021	10:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	19/04/2021	10:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	19/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	19/04/2021	10:10	0.0189	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	19/04/2021	10:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	19/04/2021	10:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	19/04/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	19/04/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	19/04/2021	10:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	19/04/2021	10:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	19/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	19/04/2021	10:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	19/04/2021	10:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	19/04/2021	10:30	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	19/04/2021	10:45	0.004	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	19/04/2021	10:10	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	19/04/2021	10:00	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	19/04/2021	10:30	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	19/04/2021	10:45	7.9		
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	19/04/2021	10:10	11.3	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	19/04/2021	10:00	14.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	19/04/2021	10:30	15.2	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	19/04/2021	10:45	14.4	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	19/04/2021	10:10	8.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	19/04/2021	10:00	7.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	19/04/2021	10:30	7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	19/04/2021	10:45	7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	19/04/2021	10:00	0.81	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	19/04/2021	10:30	0.34	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	19/04/2021	10:45	0.79	g/m³	(.2 - 5)
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	19/04/2021	10:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	19/04/2021	10:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	19/04/2021	10:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	19/04/2021	10:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	19/04/2021	10:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	19/04/2021	10:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	19/04/2021	10:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	19/04/2021	10:45	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	1004c	Temperature on arrival	19/04/2021	10:10	9	Deg C	(0 - 20)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1004c	Temperature on arrival	19/04/2021	10:00	12.7	Deg C	(0 - 20)
	Waikouaiti WTP - Post Treated Water Reservoir	C-O1420	Sampler Observation	19/04/2021	00:00:00	No	Sample	
	Catchment - Waikouaiti River - Pump Station Intake	M0201	Giardia - confirmed per 10L	19/04/2021	10:10	<0.5	cysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0201	Giardia - confirmed per 10L	19/04/2021	10:00	<0.5	cysts/10L	
	Catchment - Waikouaiti River - Pump Station Intake	M0202	Giardia - Presumptive per 10L	19/04/2021	10:10	<0.5	cysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0202	Giardia - Presumptive per 10L	19/04/2021	10:00	<0.5	cysts/10L	
	Catchment - Waikouaiti River - Pump Station Intake	M0203	Giardia Recovery - %	19/04/2021	10:10	51	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0203	Giardia Recovery - %	19/04/2021	10:00	52	%	
	Catchment - Waikouaiti River - Pump Station Intake	M0208	Cryptosporidium - confirmed per 10L	19/04/2021	10:10	<0.5	oocysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0208	Cryptosporidium - confirmed per 10L	19/04/2021	10:00	<0.5	oocysts/10L	
	Catchment - Waikouaiti River - Pump Station Intake	M0209	Cryptosporidium - presumptive per 10L	19/04/2021	10:10	<0.5	oocysts/10L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0209	Cryptosporidium - presumptive per 10L	19/04/2021	10:00	<0.5	oocysts/10L	
	Catchment - Waikouaiti River - Pump Station Intake	M0210	Crypto Recovery - %	19/04/2021	10:10	54	%	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	M0210	Crypto Recovery - %	19/04/2021	10:00	55	%	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1610	Calcium - Acid Soluble by OES	19/04/2021	12:35:00	20	g/m³	
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1610	Calcium - Acid Soluble by OES	19/04/2021	12:30:00	20	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1610	Calcium - Acid Soluble by OES	19/04/2021	12:31:00	19	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1610	Calcium - Acid Soluble by OES	19/04/2021	12:32:00	19.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	19/04/2021	11:20:00	19.7	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	19/04/2021	12:20:00	20.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	19/04/2021	13:25:00	19.7	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	19/04/2021	13:30:00	21.5	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	19/04/2021	13:33:00	22.4	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1622	Magnesium - Acid Soluble by OES	19/04/2021	12:35:00	10.1	g/m³	
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1622	Magnesium - Acid Soluble by OES	19/04/2021	12:30:00	10.1	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1622	Magnesium - Acid Soluble by OES	19/04/2021	12:31:00	9.53	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1622	Magnesium - Acid Soluble by OES	19/04/2021	12:32:00	9.88	g/m³	

	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	19/04/2021	11:20:00	9.87	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	19/04/2021	12:20:00	10.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	19/04/2021	13:25:00	10	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	19/04/2021	13:30:00	10.5	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	19/04/2021	13:33:00	11.1	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1623	Manganese - Acid Soluble by OES	19/04/2021	12:35:00	0.015	g/m³	(.4 - .4)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1623	Manganese - Acid Soluble by OES	19/04/2021	12:30:00	0.011	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1623	Manganese - Acid Soluble by OES	19/04/2021	12:31:00	0.014	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	1623	Manganese - Acid Soluble by OES	19/04/2021	12:32:00	0.014	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	19/04/2021	11:20:00	0.011	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	19/04/2021	12:20:00	0.012	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	19/04/2021	13:25:00	0.009	g/m³	(.4 - .4)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	19/04/2021	13:30:00	0.293	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	19/04/2021	13:33:00	0.261	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6001	Aluminium - Acid Soluble	19/04/2021	12:35:00	0.004	g/m³	(.1 - .1)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6001	Aluminium - Acid Soluble	19/04/2021	12:30:00	0.004	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6001	Aluminium - Acid Soluble	19/04/2021	12:31:00	0.003	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6001	Aluminium - Acid Soluble	19/04/2021	12:32:00	0.003	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	19/04/2021	11:20:00	1.92	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	19/04/2021	12:20:00	1.89	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	19/04/2021	13:25:00	1.39	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	19/04/2021	13:30:00	0.008	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	19/04/2021	13:33:00	0.008	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6003	Arsenic - Acid Soluble	19/04/2021	12:35:00	<0.001	g/m³	(.01 - .01)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6003	Arsenic - Acid Soluble	19/04/2021	12:30:00	<0.001	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6003	Arsenic - Acid Soluble	19/04/2021	12:31:00	<0.001	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6003	Arsenic - Acid Soluble	19/04/2021	12:32:00	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	19/04/2021	11:20:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	19/04/2021	12:20:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	19/04/2021	13:25:00	<0.001	g/m³	(.01 - .01)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	19/04/2021	13:30:00	0.007	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	19/04/2021	13:33:00	0.006	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6008	Cadmium - Acid Soluble	19/04/2021	12:35:00	<0.0002	g/m³	(.004 - .004)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6008	Cadmium - Acid Soluble	19/04/2021	12:30:00	0.0003	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6008	Cadmium - Acid Soluble	19/04/2021	12:31:00	<0.0002	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6008	Cadmium - Acid Soluble	19/04/2021	12:32:00	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	19/04/2021	11:20:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	19/04/2021	12:20:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	19/04/2021	13:25:00	<0.0002	g/m³	(.004 - .004)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	19/04/2021	13:30:00	<0.0002	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	19/04/2021	13:33:00	<0.0002	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6013	Copper - Acid Soluble	19/04/2021	12:35:00	0.0009	g/m³	(1 - 2)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6013	Copper - Acid Soluble	19/04/2021	12:30:00	0.0444	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6013	Copper - Acid Soluble	19/04/2021	12:31:00	0.0103	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6013	Copper - Acid Soluble	19/04/2021	12:32:00	0.0024	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	19/04/2021	11:20:00	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	19/04/2021	12:20:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	19/04/2021	13:25:00	<0.0005	g/m³	(2 - 2)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	19/04/2021	13:30:00	0.0056	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	19/04/2021	13:33:00	0.005	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6017	Iron - Acid Soluble	19/04/2021	12:35:00	0.15	g/m³	(.2 - .2)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6017	Iron - Acid Soluble	19/04/2021	12:30:00	0.13	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6017	Iron - Acid Soluble	19/04/2021	12:31:00	0.15	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6017	Iron - Acid Soluble	19/04/2021	12:32:00	0.14	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	19/04/2021	11:20:00	0.14	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	19/04/2021	12:20:00	0.14	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	19/04/2021	13:25:00	0.11	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	19/04/2021	13:30:00	3.11	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	19/04/2021	13:33:00	2.7	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6018	Lead - Acid Soluble	19/04/2021	12:35:00	<0.0005	g/m³	(.005 - .01)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6018	Lead - Acid Soluble	19/04/2021	12:30:00	0.0044	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6018	Lead - Acid Soluble	19/04/2021	12:31:00	0.0014	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6018	Lead - Acid Soluble	19/04/2021	12:32:00	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	19/04/2021	11:20:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	19/04/2021	12:20:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	19/04/2021	13:25:00	<0.0005	g/m³	(.005 - .01)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	19/04/2021	13:30:00	<0.0005	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	19/04/2021	13:33:00	0.0005	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6024	Nickel - Acid Soluble	19/04/2021	12:35:00	<0.0005	g/m³	(.08 - .08)

Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6024	Nickel - Acid Soluble	19/04/2021	12:30:00	0.0015	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6024	Nickel - Acid Soluble	19/04/2021	12:31:00	<0.0005	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6024	Nickel - Acid Soluble	19/04/2021	12:32:00	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	19/04/2021	11:20:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	19/04/2021	12:20:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	19/04/2021	13:25:00	<0.0005	g/m³	(.08 - .08)
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	19/04/2021	13:30:00	0.0061	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	19/04/2021	13:33:00	0.0097	g/m³	
2 min flushed sample	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6038	Zinc - Acid Soluble	19/04/2021	12:35:00	0.002	g/m³	(1.5 - 1.5)
Pre-flush sample (first 150 ml)	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6038	Zinc - Acid Soluble	19/04/2021	12:30:00	0.427	g/m³	
poor sampling technique 1	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6038	Zinc - Acid Soluble	19/04/2021	12:31:00	0.032	g/m³	
poor sampling technique 2	Waikouaiti WTP-Raw water Reservooir Feed to Plant-Lead inverstigation	6038	Zinc - Acid Soluble	19/04/2021	12:32:00	0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	19/04/2021	11:20:00	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	19/04/2021	12:20:00	<0.002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	19/04/2021	13:25:00	<0.002	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	19/04/2021	13:30:00	0.011	g/m³	
10 Sec Flush	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	19/04/2021	13:33:00	0.018	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	20/04/2021	10:45	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	20/04/2021	11:05	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	20/04/2021	12:10	71	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	20/04/2021	13:50	72	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	20/04/2021	14:10	69	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	20/04/2021	12:40	77	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	20/04/2021	11:25	75	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	20/04/2021	11:40	72	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	20/04/2021	11:10	67	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	20/04/2021	10:45	69	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	20/04/2021	11:05	69	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	20/04/2021	10:50	67	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	55	Conductivity at 25°C - mS/m unit	20/04/2021	10:45	23.2	mS/m (232.2 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	20/04/2021	11:05	24.9	mS/m (249 x .1)	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	20/04/2021	12:10	19.2	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	20/04/2021	13:50	19.3	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	20/04/2021	14:10	18.8	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	20/04/2021	12:40	19.7	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	20/04/2021	11:25	19.9	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	20/04/2021	11:40	18.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	20/04/2021	11:10	18.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	20/04/2021	10:45	18.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	20/04/2021	11:05	18.5	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	20/04/2021	10:50	18.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	20/04/2021	10:45	13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	20/04/2021	11:05	16	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	20/04/2021	10:45	20.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	20/04/2021	11:05	22.6	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	20/04/2021	10:45	101	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	20/04/2021	11:05	106	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	20/04/2021	11:05	0.007	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	20/04/2021	11:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	20/04/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	20/04/2021	11:05	22.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	20/04/2021	11:05	<0.0005	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	20/04/2021	11:05	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	20/04/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	20/04/2021	11:05	10.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	20/04/2021	11:05	0.0035	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	20/04/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	20/04/2021	11:05	<0.002	g/m³	(1.5 - 1.5)
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	20/04/2021	10:45	0.007	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	20/04/2021	10:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	20/04/2021	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	20/04/2021	10:45	18.6	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	20/04/2021	10:45	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	20/04/2021	10:45	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	20/04/2021	10:45	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	20/04/2021	10:45	9.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	20/04/2021	10:45	0.023	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	20/04/2021	10:45	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	20/04/2021	10:45	0.034	g/m³	

	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	20/04/2021	12:10	0.008	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	20/04/2021	13:50	0.009	g/m³	
	Karitane Bowls	6701	Aluminium - Dissolved	20/04/2021	14:10	0.009	g/m³	
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	20/04/2021	12:40	0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	20/04/2021	11:25	0.008	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	20/04/2021	11:40	0.009	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	20/04/2021	11:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	20/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	20/04/2021	11:05	0.007	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	20/04/2021	10:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	20/04/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	20/04/2021	11:05	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	20/04/2021	12:10	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	20/04/2021	13:50	<0.0002	g/m³	(.004 - .004)
	Karitane Bowls	6708	Cadmium - Dissolved	20/04/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	20/04/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	20/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	20/04/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	20/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	20/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	20/04/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	20/04/2021	10:50	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	20/04/2021	10:45	20.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	20/04/2021	11:05	21.7	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	20/04/2021	12:10	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	20/04/2021	13:50	<0.0005	g/m³	(2 - 2)
	Karitane Bowls	6713	Copper - Dissolved	20/04/2021	14:10	0.0061	g/m³	(2 - 2)
	Waikouaiti Golf Club	6713	Copper - Dissolved	20/04/2021	12:40	0.0353	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	20/04/2021	11:25	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	20/04/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	20/04/2021	11:10	<0.0005	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	20/04/2021	10:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	20/04/2021	12:10	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	20/04/2021	13:50	<0.01	g/m³	
	Karitane Bowls	6717	Iron - Dissolved	20/04/2021	14:10	<0.01	g/m³	(.2 - .2)
	Waikouaiti Golf Club	6717	Iron - Dissolved	20/04/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	20/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	20/04/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	20/04/2021	11:10	0.09	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	20/04/2021	10:45	0.14	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	20/04/2021	11:05	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	20/04/2021	10:50	0.13	g/m³	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	20/04/2021	12:10	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	20/04/2021	13:50	<0.0005	g/m³	(.005 - .01)
	Karitane Bowls	6718	Lead - Dissolved	20/04/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti Golf Club	6718	Lead - Dissolved	20/04/2021	12:40	0.0007	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	20/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	20/04/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	20/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	20/04/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	20/04/2021	10:45	9.86	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	20/04/2021	11:05	10.1	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	20/04/2021	12:10	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	20/04/2021	13:50	<0.0005	g/m³	(.4 - .4)
	Karitane Bowls	6721	Manganese - Dissolved	20/04/2021	14:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti Golf Club	6721	Manganese - Dissolved	20/04/2021	12:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	20/04/2021	11:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	20/04/2021	11:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	20/04/2021	11:10	0.0032	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	20/04/2021	10:45	0.0196	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	20/04/2021	10:50	0.0203	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	20/04/2021	12:10	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	20/04/2021	13:50	<0.0005	g/m³	(.08 - .08)
	Karitane Bowls	6724	Nickel - Dissolved	20/04/2021	14:10	<0.0005	g/m³	(.08 - .08)

	Waikouaiti Golf Club	6724	Nickel - Dissolved	20/04/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	20/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	20/04/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	20/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	20/04/2021	10:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	20/04/2021	12:10	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	20/04/2021	13:50	<0.002	g/m³	
	Karitane Bowls	6738	Zinc - Dissolved	20/04/2021	14:10	0.006	g/m³	
	Waikouaiti Golf Club	6738	Zinc - Dissolved	20/04/2021	12:40	0.096	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	20/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	20/04/2021	11:40	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	20/04/2021	11:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	20/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	20/04/2021	11:05	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	20/04/2021	10:50	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	20/04/2021	10:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	20/04/2021	11:05	Completed		
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	20/04/2021	12:10	7.8		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	20/04/2021	13:50	7.9		
	Karitane Bowls	D-0001F	pH - Field	20/04/2021	14:10	7.9		
	Waikouaiti Golf Club	D-0001F	pH - Field	20/04/2021	12:40	8		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	20/04/2021	11:25	8		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	20/04/2021	11:40	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	20/04/2021	11:10	7.8		
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	20/04/2021	10:45	7.7		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	20/04/2021	11:05	7.7		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	20/04/2021	10:50	7.6		
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	20/04/2021	12:10	15.5	Deg C	
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	20/04/2021	13:50	14.2	Deg C	
	Karitane Bowls	D-0053F	Temperature - Field	20/04/2021	14:10	12	Deg C	
	Waikouaiti Golf Club	D-0053F	Temperature - Field	20/04/2021	12:40	14.3	Deg C	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	20/04/2021	11:25	14	Deg C	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	20/04/2021	11:40	15.5	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	20/04/2021	11:10	14.4	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	20/04/2021	10:45	11.9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	20/04/2021	11:05	14.5	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	20/04/2021	10:50	12.4	Deg C	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	20/04/2021	12:10	6.1	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	20/04/2021	13:50	7.7	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	20/04/2021	14:10	8.4	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	20/04/2021	12:40	8.6	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	20/04/2021	11:25	7.8	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	20/04/2021	11:40	7.1	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	20/04/2021	11:10	6.9	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	20/04/2021	10:45	9.2	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	20/04/2021	11:05	7.6	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	20/04/2021	10:50	9.1	g O2/m³	
Waikouaiti campground	Karitane School	D-0058H	Free Available Chlorine	20/04/2021	11:50	0.68	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	20/04/2021	14:10	0.49	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	20/04/2021	12:10	0.75	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	20/04/2021	13:50	0.93	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	20/04/2021	14:10	0.77	g/m³	(.2 - 5)
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	20/04/2021	12:40	0.34	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	20/04/2021	11:25	0.79	g/m³	(.2 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	20/04/2021	11:40	0.9	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	20/04/2021	11:05	1	g/m³	(.2 - 5)
Waikouaiti campground	Karitane School	D-0084	Turbidity	20/04/2021	11:50	0.42	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	20/04/2021	14:10	0.45	NTU	
Waikouaiti campground	Karitane School	D-1201	Sampling / Inspection 15 Mins	20/04/2021	11:50	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	20/04/2021	14:10	Completed		
Waikouaiti campground	Karitane School	D-1310	Temperature on arrival	20/04/2021	11:50	9.6	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	20/04/2021	14:10	9.6	Deg C	
Waikouaiti campground	Karitane School	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	20/04/2021	11:50	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	20/04/2021	14:10	<1	MPN/100mL	(0 - 0)
Waikouaiti campground	Karitane School	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	20/04/2021	11:50	<1	MPN/100ml	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	20/04/2021	14:10	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	20/04/2021	10:45	Completed		

	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	20/04/2021	12:10	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	20/04/2021	13:50	Completed		
	Karitane Bowls	P1859	Sample Filtration	20/04/2021	14:10	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	20/04/2021	12:40	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	20/04/2021	11:25	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	20/04/2021	11:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	20/04/2021	11:10	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	20/04/2021	10:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	20/04/2021	11:05	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	20/04/2021	10:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	20/04/2021	11:10	2.9	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	20/04/2021	10:45	3.3	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	20/04/2021	11:05	2.7	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	20/04/2021	11:10	7.2	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	20/04/2021	10:45	7.4	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	20/04/2021	11:05	5.4	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	20/04/2021	11:10	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	20/04/2021	10:45	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	20/04/2021	11:05	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	20/04/2021	10:45	68	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	20/04/2021	11:05	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	20/04/2021	12:15	75	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	20/04/2021	13:05	74	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	20/04/2021	10:45	18.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	20/04/2021	11:05	18.8	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	20/04/2021	12:15	20.1	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	20/04/2021	13:05	19.8	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	1214	Surcharge Fee	20/04/2021	10:45	$100		
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	20/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	20/04/2021	11:05	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	20/04/2021	12:15	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	20/04/2021	13:05	0.009	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	20/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	20/04/2021	11:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	20/04/2021	12:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	20/04/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	20/04/2021	12:15	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	20/04/2021	13:05	0.0021	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	20/04/2021	10:45	0.14	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	20/04/2021	11:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	20/04/2021	12:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	20/04/2021	13:05	<0.01	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	20/04/2021	12:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	20/04/2021	13:05	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	20/04/2021	10:45	0.0174	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	20/04/2021	12:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	20/04/2021	13:05	<0.0005	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	20/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	20/04/2021	11:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	20/04/2021	12:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	20/04/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	20/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	20/04/2021	11:05	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	20/04/2021	12:15	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	20/04/2021	13:05	0.006	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	20/04/2021	10:45	7.7		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	20/04/2021	11:05	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	20/04/2021	12:15	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	20/04/2021	13:05	7.9		
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	20/04/2021	10:45	11.9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	20/04/2021	11:05	14.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	20/04/2021	12:15	15.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	20/04/2021	13:05	14.9	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	20/04/2021	10:45	9.2	g O2/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	20/04/2021	11:05	7.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	20/04/2021	12:15	7.6	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	20/04/2021	13:05	7.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	20/04/2021	11:05	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	20/04/2021	12:15	0.43	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	20/04/2021	13:05	0.71	g/m³	(.2 - 5)
	Catchment - Waikouaiti River - Pump Station Intake	D-1202	Sampling / Inspection 30 Mins	20/04/2021	10:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	20/04/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	D-1204	Sampling / Inspection 60 Mins	20/04/2021	10:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	20/04/2021	13:05	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	20/04/2021	10:45	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	20/04/2021	11:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	20/04/2021	12:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	20/04/2021	13:05	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	21/04/2021	12:30	64	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	21/04/2021	12:25	66	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	21/04/2021	11:25	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	21/04/2021	11:35	69	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	21/04/2021	12:30	18.9	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	21/04/2021	12:25	19.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	21/04/2021	11:25	20.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	21/04/2021	11:35	19.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	21/04/2021	12:30	$100		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	21/04/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	21/04/2021	12:25	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	21/04/2021	11:25	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	21/04/2021	11:35	0.008	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	21/04/2021	12:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	21/04/2021	12:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	21/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	21/04/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	21/04/2021	12:30	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	21/04/2021	12:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	21/04/2021	11:25	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	21/04/2021	11:35	0.0024	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	21/04/2021	12:30	0.09	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	21/04/2021	12:25	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	21/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	21/04/2021	11:35	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	21/04/2021	12:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	21/04/2021	12:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	21/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	21/04/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	21/04/2021	12:30	0.0025	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	21/04/2021	12:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	21/04/2021	11:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	21/04/2021	11:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	21/04/2021	12:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	21/04/2021	12:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	21/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	21/04/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	21/04/2021	12:30	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	21/04/2021	12:25	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	21/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	21/04/2021	11:35	0.005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	21/04/2021	12:30	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	21/04/2021	12:25	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	21/04/2021	11:25	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	21/04/2021	11:35	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	21/04/2021	12:30	14.2	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	21/04/2021	12:25	14.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	21/04/2021	11:25	15.7	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	21/04/2021	11:35	15.1	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	21/04/2021	12:30	7.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	21/04/2021	12:25	8.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	21/04/2021	11:25	6.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	21/04/2021	11:35	7.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	21/04/2021	12:25	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	21/04/2021	11:25	0.33	g/m³	(.2 - 5)

	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	21/04/2021	11:35	1	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	21/04/2021	12:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	21/04/2021	11:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	21/04/2021	12:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	21/04/2021	11:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	21/04/2021	12:30	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	21/04/2021	12:25	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	21/04/2021	11:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	21/04/2021	11:35	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	22/04/2021	00:00:00	$100		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	22/04/2021	00:00:00			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	22/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	22/04/2021	00:00:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	22/04/2021	00:00:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	22/04/2021	00:00:00	Completed		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	22/04/2021	00:00:00			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	22/04/2021	00:00:00			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	22/04/2021	00:00:00			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	22/04/2021	00:00:00			
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	1	pH	22/04/2021	13:36	7.9		(1 - 14)
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	52	Alkalinity - Total	22/04/2021	13:36	70	g CaCO3/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	55	Conductivity at 25°C - mS/m unit	22/04/2021	13:36	25.1	mS/m (251.4 x .1)	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	0440D	Dissolved Inorganic Carbon	22/04/2021	13:36	19.6	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	702	Chloride - Ultra Trace	22/04/2021	13:36	15.7	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	707	Sulphate - Ultra Trace	22/04/2021	13:36	21.5	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:16	0.073	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:18	0.012	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:20	0.01	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:22	0.01	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:24	0.01	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:26	0.01	g/m³	
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:28	0.012	g/m³	
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:30	0.014	g/m³	
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:32	0.011	g/m³	
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:34	0.011	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6001	Aluminium - Acid Soluble	22/04/2021	13:36	0.011	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:16	0.272	g/m³	(2 - 2)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:18	0.038	g/m³	(2 - 2)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:20	0.0336	g/m³	(2 - 2)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:22	0.0335	g/m³	(2 - 2)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:24	0.0339	g/m³	(2 - 2)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:26	0.0385	g/m³	(2 - 2)
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:28	0.0371	g/m³	(2 - 2)
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:30	0.0398	g/m³	(2 - 2)
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:32	0.0258	g/m³	(2 - 2)
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:34	0.0167	g/m³	(2 - 2)
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6013	Copper - Acid Soluble	22/04/2021	13:36	0.0159	g/m³	(2 - 2)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:16	0.49	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:18	0.02	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:20	0.01	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:22	0.01	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:24	0.02	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:26	0.02	g/m³	
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:28	0.04	g/m³	
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:30	0.05	g/m³	
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:32	0.05	g/m³	
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:34	0.04	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6017	Iron - Acid Soluble	22/04/2021	13:36	0.05	g/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:16	0.0194	g/m³	(.005 - .01)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:18	0.0017	g/m³	(.005 - .01)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:20	0.0015	g/m³	(.005 - .01)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:22	0.0016	g/m³	(.005 - .01)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:24	0.0017	g/m³	(.005 - .01)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:26	0.0023	g/m³	(.005 - .01)
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:28	0.0026	g/m³	(.005 - .01)
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:30	0.0031	g/m³	(.005 - .01)
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:32	0.0021	g/m³	(.005 - .01)
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:34	0.001	g/m³	(.005 - .01)
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6018	Lead - Acid Soluble	22/04/2021	13:36	0.0009	g/m³	(.005 - .01)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:16	0.0247	g/m³	(.4 - .4)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:18	0.002	g/m³	(.4 - .4)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:20	0.0009	g/m³	(.4 - .4)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:22	0.0007	g/m³	(.4 - .4)
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:24	0.0011	g/m³	(.4 - .4)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:26	0.0023	g/m³	(.4 - .4)
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:28	0.007	g/m³	(.4 - .4)
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:30	0.0135	g/m³	(.4 - .4)
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:32	0.0153	g/m³	(.4 - .4)
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:34	0.013	g/m³	(.4 - .4)
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6021	Manganese - Acid Soluble	22/04/2021	13:36	0.0115	g/m³	(.4 - .4)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:16	0.001	g/m³	(.08 - .08)
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:18	<0.0005	g/m³	(.08 - .08)
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:20	<0.0005	g/m³	(.08 - .08)
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:22	<0.0005	g/m³	(.08 - .08)

#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:24	<0.0005	g/m³	(.08 - .08)
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:26	<0.0005	g/m³	(.08 - .08)
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:28	0.0009	g/m³	(.08 - .08)
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:30	0.0005	g/m³	(.08 - .08)
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:32	<0.0005	g/m³	(.08 - .08)
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:34	<0.0005	g/m³	(.08 - .08)
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6024	Nickel - Acid Soluble	22/04/2021	13:36	<0.0005	g/m³	(.08 - .08)
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:16	0.223	g/m³	
#2 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:18	0.092	g/m³	
#4 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:20	0.088	g/m³	
#6 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:22	0.084	g/m³	
#8 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:24	0.08	g/m³	
#10 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:26	0.09	g/m³	
#12 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:28	0.082	g/m³	
#14 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:30	0.08	g/m³	
#16 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:32	0.056	g/m³	
#18 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:34	0.034	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	6038	Zinc - Acid Soluble	22/04/2021	13:36	0.03	g/m³	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	D-0056F	Dissolved Oxygen - Field	22/04/2021	13:36	7.4	g O2/m³	
#0	Waikouaiti Golf Club - Customer Tap - Profile sample	D-1203	Sampling / Inspection 45 Mins	22/04/2021	13:16	Completed		
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	O0994b	Flow Rate performed by ELS	22/04/2021	13:36	0.2	litres/sec	
#20 minute	Waikouaiti Golf Club - Customer Tap - Profile sample	P1859	Sample Filtration	22/04/2021	13:36	Completed		
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	1	pH	22/04/2021	14:33	7.8		(7 - 8.5)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	52	Alkalinity - Total	22/04/2021	14:33	72	g CaCO3/m³	
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	55	Conductivity at 25°C - mS/m unit	22/04/2021	14:33	24.8	mS/m (247.7 x .1)	
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	0440D	Dissolved Inorganic Carbon	22/04/2021	14:33	19.3	g/m³	
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	702	Chloride - Ultra Trace	22/04/2021	14:33	15.8	g/m³	(250 - 250)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	707	Sulphate - Ultra Trace	22/04/2021	14:33	21.4	g/m³	(250 - 250)
#0	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:13	0.01	g/m³	(.1 - .1)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:15	0.009	g/m³	(.1 - .1)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:17	0.009	g/m³	(.1 - .1)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:19	0.009	g/m³	(.1 - .1)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:21	0.009	g/m³	(.1 - .1)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:23	0.009	g/m³	(.1 - .1)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:25	0.009	g/m³	(.1 - .1)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:27	0.009	g/m³	(.1 - .1)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:29	0.009	g/m³	(.1 - .1)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:31	0.009	g/m³	(.1 - .1)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6001	Aluminium - Acid Soluble	22/04/2021	14:33	0.009	g/m³	(.1 - .1)
#0	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:13	0.0394	g/m³	(1 - 2)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:15	0.0056	g/m³	(1 - 2)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:17	0.0051	g/m³	(1 - 2)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:19	0.0045	g/m³	(1 - 2)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:21	0.0043	g/m³	(1 - 2)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:23	0.0042	g/m³	(1 - 2)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:25	0.0041	g/m³	(1 - 2)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:27	0.004	g/m³	(1 - 2)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:29	0.0039	g/m³	(1 - 2)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:31	0.0038	g/m³	(1 - 2)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6013	Copper - Acid Soluble	22/04/2021	14:33	0.0037	g/m³	(1 - 2)
#0	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:13	<0.01	g/m³	(.2 - .2)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:15	<0.01	g/m³	(.2 - .2)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:17	<0.01	g/m³	(.2 - .2)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:19	<0.01	g/m³	(.2 - .2)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:21	<0.01	g/m³	(.2 - .2)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:23	<0.01	g/m³	(.2 - .2)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:25	<0.01	g/m³	(.2 - .2)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:27	<0.01	g/m³	(.2 - .2)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:29	<0.01	g/m³	(.2 - .2)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:31	<0.01	g/m³	(.2 - .2)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6017	Iron - Acid Soluble	22/04/2021	14:33	<0.01	g/m³	(.2 - .2)
#0	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:13	0.004	g/m³	(.005 - .01)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:15	<0.0005	g/m³	(.005 - .01)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:17	<0.0005	g/m³	(.005 - .01)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:19	<0.0005	g/m³	(.005 - .01)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:21	<0.0005	g/m³	(.005 - .01)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:23	<0.0005	g/m³	(.005 - .01)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:25	<0.0005	g/m³	(.005 - .01)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:27	<0.0005	g/m³	(.005 - .01)

#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:29	<0.0005	g/m³	(.005 - .01)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:31	<0.0005	g/m³	(.005 - .01)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6018	Lead - Acid Soluble	22/04/2021	14:33	<0.0005	g/m³	(.005 - .01)
#0	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:13	0.0011	g/m³	(.04 - .4)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:15	0.005	g/m³	(.04 - .4)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:17	0.004	g/m³	(.04 - .4)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:19	0.0041	g/m³	(.04 - .4)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:21	0.0049	g/m³	(.04 - .4)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:23	0.0069	g/m³	(.04 - .4)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:25	0.0068	g/m³	(.04 - .4)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:27	0.0056	g/m³	(.04 - .4)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:29	0.008	g/m³	(.04 - .4)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:31	0.0057	g/m³	(.04 - .4)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6021	Manganese - Acid Soluble	22/04/2021	14:33	0.008	g/m³	(.04 - .4)
#0	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:13	<0.0005	g/m³	(.08 - .08)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:15	<0.0005	g/m³	(.08 - .08)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:17	<0.0005	g/m³	(.08 - .08)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:19	<0.0005	g/m³	(.08 - .08)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:21	<0.0005	g/m³	(.08 - .08)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:23	<0.0005	g/m³	(.08 - .08)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:25	<0.0005	g/m³	(.08 - .08)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:27	<0.0005	g/m³	(.08 - .08)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:29	<0.0005	g/m³	(.08 - .08)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:31	<0.0005	g/m³	(.08 - .08)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6024	Nickel - Acid Soluble	22/04/2021	14:33	<0.0005	g/m³	(.08 - .08)
#0	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:13	0.083	g/m³	(1.5 - 1.5)
#2 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:15	0.005	g/m³	(1.5 - 1.5)
#4 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:17	0.004	g/m³	(1.5 - 1.5)
#6 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:19	0.003	g/m³	(1.5 - 1.5)
#8 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:21	0.003	g/m³	(1.5 - 1.5)
#10 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:23	0.003	g/m³	(1.5 - 1.5)
#12 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:25	0.004	g/m³	(1.5 - 1.5)
#14 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:27	0.003	g/m³	(1.5 - 1.5)
#16 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:29	0.003	g/m³	(1.5 - 1.5)
#18 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:31	0.002	g/m³	(1.5 - 1.5)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	6038	Zinc - Acid Soluble	22/04/2021	14:33	0.002	g/m³	(1.5 - 1.5)
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	D-0056F	Dissolved Oxygen - Field	22/04/2021	14:33	8.2	g O2/m³	
#0	Karitane Bowls - Customer Tap - Profile Sample	D-1203	Sampling / Inspection 45 Mins	22/04/2021	14:13	Completed		
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	O0994b	Flow Rate performed by ELS	22/04/2021	14:33	0.3	litres/sec	
#20 minute	Karitane Bowls - Customer Tap - Profile Sample	P1859	Sample Filtration	22/04/2021	14:33	Completed		
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1	pH	22/04/2021	11:10	7.8		(1 - 14)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	22/04/2021	11:15	7.6		(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	22/04/2021	11:20	7.6		(1 - 14)
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	22/04/2021	11:10	<6	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	22/04/2021	11:15	216	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	22/04/2021	11:20	278	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	22/04/2021	11:10	<1	mL/L	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	22/04/2021	11:15	90	mL/L	
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	22/04/2021	11:20	190	mL/L	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	22/04/2021	11:10	786	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	22/04/2021	11:15	452	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	22/04/2021	11:20	845	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	22/04/2021	11:28	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	22/04/2021	10:45	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	22/04/2021	13:49	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	22/04/2021	12:00	73	g CaCO3/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	22/04/2021	11:10	68	g CaCO3/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	22/04/2021	11:15	80	g CaCO3/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	22/04/2021	11:20	87	g CaCO3/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	22/04/2021	11:10	23.6	mS/m (236.3 x .1)	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	22/04/2021	11:15	23.5	mS/m (234.9 x .1)	
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	22/04/2021	11:20	23.5	mS/m (235 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	22/04/2021	11:28	18.8	g/m³	

	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	22/04/2021	10:45	19	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	22/04/2021	13:49	19.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	22/04/2021	12:00	19.7	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	22/04/2021	11:10	18.5	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	22/04/2021	11:15	18.3	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	22/04/2021	11:20	18.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	22/04/2021	11:28	$100		
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	22/04/2021	11:10	20.1	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	22/04/2021	11:15	21	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	22/04/2021	11:20	23.3	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	22/04/2021	11:10	10.1	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	22/04/2021	11:15	10.1	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	22/04/2021	11:20	11.1	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	22/04/2021	11:10	0.007	g/m³	(.4 - .4)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	22/04/2021	11:15	0.392	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	22/04/2021	11:20	0.558	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	22/04/2021	11:10	20	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	22/04/2021	11:15	20	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	22/04/2021	11:20	20.3	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	22/04/2021	11:10	9.91	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	22/04/2021	11:15	9.9	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	22/04/2021	11:20	10.1	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	22/04/2021	11:10	<0.005	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	22/04/2021	11:15	<0.005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	22/04/2021	11:20	<0.005	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	22/04/2021	11:10	1.07	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	22/04/2021	11:15	46.1	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	22/04/2021	11:20	60.1	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	22/04/2021	11:10	<0.001	g/m³	(.01 - .01)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	22/04/2021	11:15	0.008	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	22/04/2021	11:20	0.01	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	22/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	22/04/2021	11:15	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	22/04/2021	11:20	<0.0002	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	22/04/2021	11:10	<0.0005	g/m³	(2 - 2)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	22/04/2021	11:15	0.0066	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	22/04/2021	11:20	0.0085	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	22/04/2021	11:10	0.09	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	22/04/2021	11:15	4.17	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	22/04/2021	11:20	5.35	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	22/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	22/04/2021	11:15	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	22/04/2021	11:20	0.0006	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	22/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	22/04/2021	11:15	0.0043	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	22/04/2021	11:20	0.0075	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	22/04/2021	11:10	<0.002	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	22/04/2021	11:15	0.007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	22/04/2021	11:20	0.012	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	22/04/2021	11:28	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	22/04/2021	10:45	0.014	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	22/04/2021	13:49	0.012	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	22/04/2021	12:00	0.009	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	22/04/2021	11:10	0.166	g/m³	

The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	22/04/2021	11:15	0.571	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	22/04/2021	11:20	0.012	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	22/04/2021	11:10	<0.001	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	22/04/2021	11:15	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	22/04/2021	11:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	22/04/2021	11:28	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	22/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	22/04/2021	13:49	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	22/04/2021	12:00	<0.0002	g/m³	(.004 - .004)
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	22/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	22/04/2021	11:15	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	22/04/2021	11:20	<0.0002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	22/04/2021	11:28	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	22/04/2021	10:45	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	22/04/2021	13:49	0.0009	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	22/04/2021	12:00	0.0024	g/m³	(2 - 2)
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	22/04/2021	11:10	<0.0005	g/m³	(2 - 2)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	22/04/2021	11:15	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	22/04/2021	11:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	22/04/2021	11:28	0.07	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	22/04/2021	10:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	22/04/2021	13:49	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	22/04/2021	12:00	<0.01	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	22/04/2021	11:10	<0.01	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	22/04/2021	11:15	0.02	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	22/04/2021	11:20	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	22/04/2021	11:28	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	22/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	22/04/2021	13:49	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	22/04/2021	12:00	<0.0005	g/m³	(.005 - .01)
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	22/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	22/04/2021	11:15	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	22/04/2021	11:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	22/04/2021	11:28	0.0019	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	22/04/2021	10:45	0.0009	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	22/04/2021	13:49	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	22/04/2021	12:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	22/04/2021	11:28	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	22/04/2021	10:45	0.0006	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	22/04/2021	13:49	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	22/04/2021	12:00	<0.0005	g/m³	(.08 - .08)
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	22/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	22/04/2021	11:15	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	22/04/2021	11:20	<0.0005	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	22/04/2021	11:28	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	22/04/2021	10:45	0.003	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	22/04/2021	13:49	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	22/04/2021	12:00	0.006	g/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	22/04/2021	11:10	<0.002	g/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	22/04/2021	11:15	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	22/04/2021	11:20	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	22/04/2021	11:28	7.7		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	22/04/2021	10:45	7.6		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	22/04/2021	13:49	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	22/04/2021	12:00	7.8		
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	22/04/2021	11:10	7.7		
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	22/04/2021	11:15	7.7		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	22/04/2021	11:20	7.7		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	22/04/2021	11:28	13.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	22/04/2021	10:45	13.8	Deg C	

	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	22/04/2021	13:49	16.4	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	22/04/2021	12:00	14.9	Deg C	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	22/04/2021	11:10	13.9	Deg C	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	22/04/2021	11:15	13.9	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	22/04/2021	11:20	14.6	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	22/04/2021	11:28	8.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	22/04/2021	10:45	7.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	22/04/2021	13:49	7.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	22/04/2021	12:00	7.8	g O2/m³	
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	22/04/2021	11:10	8.7	g O2/m³	
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	22/04/2021	11:15	8.9	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	22/04/2021	11:20	9.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	22/04/2021	10:45	0.88	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	22/04/2021	13:49	0.68	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	22/04/2021	12:00	0.69	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	22/04/2021	11:28	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	22/04/2021	12:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	22/04/2021	11:28	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	22/04/2021	12:00	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	22/04/2021	11:28	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	22/04/2021	10:45	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	22/04/2021	13:49	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	22/04/2021	12:00	Completed		
No visible solids	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	22/04/2021	11:10	Completed		
The high flow rate gives a Highly agitated sample	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	22/04/2021	11:15	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	22/04/2021	11:20	Completed		
1100-1540 (850 L)	Waikouaiti WTP - Post Treated Water Reservoir	1004	Temperature on arrival	22/04/2021	11:00:00	6.2	Deg C	(- 10)
1100-1540 (850 L)	Waikouaiti WTP - Post Treated Water Reservoir	M0203	Giardia Recovery - %	22/04/2021	11:00:00	57	%	
1100-1540 (850 L)	Waikouaiti WTP - Post Treated Water Reservoir	M0205	Giardia - confirmed per 100L	22/04/2021	11:00:00	<0.1	cysts/100L	
1100-1540 (850 L)	Waikouaiti WTP - Post Treated Water Reservoir	M0210	Crypto Recovery - %	22/04/2021	11:00:00	60	%	
1100-1540 (850 L)	Waikouaiti WTP - Post Treated Water Reservoir	M0212	Cryptosporidium - confirmed per 100L	22/04/2021	11:00:00	<0.1	oocysts/100L	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1	pH	23/04/2021	12:16	7.7		(1 - 14)
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	23/04/2021	12:23	7.6		(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	23/04/2021	12:27	7.6		(1 - 14)
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	23/04/2021	12:16	5	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	23/04/2021	12:23	203	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	23/04/2021	12:27	182	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	23/04/2021	12:16	<1	mL/L	
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	23/04/2021	12:23	125	mL/L	
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	23/04/2021	12:27	50	mL/L	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	23/04/2021	12:16	245	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	23/04/2021	12:23	452	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	23/04/2021	12:27	466	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	23/04/2021	12:08	69	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	23/04/2021	12:01	67	g CaCO3/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	23/04/2021	14:16	71	g CaCO3/m³	
Low Flow	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	23/04/2021	13:34	70	g CaCO3/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	23/04/2021	12:16	70	g CaCO3/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	23/04/2021	12:23	84	g CaCO3/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	23/04/2021	12:27	80	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	23/04/2021	14:09	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	23/04/2021	14:05	73	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	23/04/2021	13:28	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	23/04/2021	13:24	71	g CaCO3/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	23/04/2021	12:16	23.6	mS/m (236.1 x .1)	
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	23/04/2021	12:23	23.5	mS/m (235.4 x .1)	
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	23/04/2021	12:27	23.6	mS/m (235.9 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	23/04/2021	12:08	18.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	23/04/2021	12:01	18	g/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	23/04/2021	14:16	18.8	g/m³	

Low Flow	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	23/04/2021	13:34	18.5	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	23/04/2021	12:16	18	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	23/04/2021	12:23	18	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	23/04/2021	12:27	18.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	23/04/2021	14:09	18.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	23/04/2021	14:05	18.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	23/04/2021	13:28	18.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	23/04/2021	13:24	18.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	23/04/2021	12:08	$100		
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	23/04/2021	12:16	21.5	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	23/04/2021	12:23	22.2	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	23/04/2021	12:27	22.2	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	23/04/2021	12:16	10.6	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	23/04/2021	12:23	10.5	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	23/04/2021	12:27	10.6	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	23/04/2021	12:16	0.008	g/m³	(.4 - .4)
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	23/04/2021	12:23	0.38	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	23/04/2021	12:27	0.339	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	23/04/2021	12:16	20.5	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	23/04/2021	12:23	21.3	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	23/04/2021	12:27	19.9	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	23/04/2021	12:16	10.5	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	23/04/2021	12:23	11.1	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	23/04/2021	12:27	10.2	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	23/04/2021	12:16	<0.005	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	23/04/2021	12:23	<0.005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	23/04/2021	12:27	<0.005	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	23/04/2021	12:16	1.23	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	23/04/2021	12:23	44.6	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	23/04/2021	12:27	39.6	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	23/04/2021	12:16	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	23/04/2021	12:23	0.007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	23/04/2021	12:27	0.006	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	23/04/2021	12:16	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	23/04/2021	12:23	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	23/04/2021	12:27	<0.0002	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	23/04/2021	12:16	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	23/04/2021	12:23	0.0054	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	23/04/2021	12:27	0.0049	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	23/04/2021	12:16	0.1	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	23/04/2021	12:23	4.01	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	23/04/2021	12:27	3.55	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	23/04/2021	12:16	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	23/04/2021	12:23	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	23/04/2021	12:27	<0.0005	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	23/04/2021	12:16	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	23/04/2021	12:23	0.0049	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	23/04/2021	12:27	0.0033	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	23/04/2021	12:16	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	23/04/2021	12:23	0.007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	23/04/2021	12:27	0.007	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	23/04/2021	12:08	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	23/04/2021	12:01	0.009	g/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	23/04/2021	14:16	0.008	g/m³	

Low Flow	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	23/04/2021	13:34	0.008	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	23/04/2021	12:16	0.176	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	23/04/2021	12:23	0.491	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	23/04/2021	12:27	0.217	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	23/04/2021	14:09	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	23/04/2021	14:05	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	23/04/2021	13:28	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	23/04/2021	13:24	0.01	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	23/04/2021	12:16	<0.001	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	23/04/2021	12:23	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	23/04/2021	12:27	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	23/04/2021	12:08	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	23/04/2021	12:01	<0.0002	g/m³	(.004 - .004)
Low Flow	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	23/04/2021	14:16	<0.0002	g/m³	(.004 - .004)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	23/04/2021	13:34	<0.0002	g/m³	(.004 - .004)
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	23/04/2021	12:16	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	23/04/2021	12:23	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	23/04/2021	12:27	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	23/04/2021	14:09	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	23/04/2021	14:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	23/04/2021	13:28	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	23/04/2021	13:24	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	23/04/2021	12:08	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	23/04/2021	12:01	<0.0005	g/m³	(2 - 2)
Low Flow	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	23/04/2021	14:16	0.0008	g/m³	(2 - 2)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	23/04/2021	13:34	0.0011	g/m³	(2 - 2)
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	23/04/2021	12:16	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	23/04/2021	12:23	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	23/04/2021	12:27	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	23/04/2021	14:09	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	23/04/2021	14:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	23/04/2021	13:28	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	23/04/2021	13:24	0.0014	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	23/04/2021	12:08	0.07	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	23/04/2021	12:01	<0.01	g/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	23/04/2021	14:16	<0.01	g/m³	
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	23/04/2021	13:34	<0.01	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	23/04/2021	12:16	<0.01	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	23/04/2021	12:23	0.02	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	23/04/2021	12:27	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	23/04/2021	14:09	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	23/04/2021	14:05	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	23/04/2021	13:28	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	23/04/2021	13:24	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	23/04/2021	12:08	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	23/04/2021	12:01	<0.0005	g/m³	(.005 - .01)
Low Flow	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	23/04/2021	14:16	<0.0005	g/m³	(.005 - .01)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	23/04/2021	13:34	<0.0005	g/m³	(.005 - .01)
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	23/04/2021	12:16	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	23/04/2021	12:23	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	23/04/2021	12:27	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	23/04/2021	14:09	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	23/04/2021	14:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	23/04/2021	13:28	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	23/04/2021	13:24	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	23/04/2021	12:08	0.0028	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	23/04/2021	12:01	<0.0005	g/m³	(.4 - .4)
Low Flow	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	23/04/2021	14:16	<0.0005	g/m³	(.4 - .4)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	23/04/2021	13:34	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	23/04/2021	14:09	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	23/04/2021	14:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	23/04/2021	13:28	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	23/04/2021	13:24	0.0041	g/m³	(.4 - .4)

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	23/04/2021	12:08	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	23/04/2021	12:01	<0.0005	g/m³	(.08 - .08)
Low Flow	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	23/04/2021	14:16	<0.0005	g/m³	(.08 - .08)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	23/04/2021	13:34	<0.0005	g/m³	(.08 - .08)
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	23/04/2021	12:16	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	23/04/2021	12:23	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	23/04/2021	12:27	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	23/04/2021	14:09	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	23/04/2021	14:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	23/04/2021	13:28	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	23/04/2021	13:24	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	23/04/2021	12:08	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	23/04/2021	12:01	<0.002	g/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	23/04/2021	14:16	<0.002	g/m³	
Low Flow	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	23/04/2021	13:34	0.003	g/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	23/04/2021	12:16	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	23/04/2021	12:23	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	23/04/2021	12:27	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	23/04/2021	14:09	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	23/04/2021	14:05	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	23/04/2021	13:28	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	23/04/2021	13:24	0.052	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	23/04/2021	12:08	7.7		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	23/04/2021	12:01	7.7		
Low Flow	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	23/04/2021	14:16	8		
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	23/04/2021	13:34	7.9		
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	23/04/2021	12:16	7.7		
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	23/04/2021	12:23	7.8		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	23/04/2021	12:27	7.8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	23/04/2021	14:09	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	23/04/2021	14:05	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	23/04/2021	13:28	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	23/04/2021	13:24	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	23/04/2021	12:08	12.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	23/04/2021	12:01	13.2	Deg C	
Low Flow	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	23/04/2021	14:16	15.1	Deg C	
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	23/04/2021	13:34	13.8	Deg C	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	23/04/2021	12:16	13	Deg C	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	23/04/2021	12:23	13.2	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	23/04/2021	12:27	13.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	23/04/2021	14:09	15.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	23/04/2021	14:05	15.3	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	23/04/2021	13:28	14	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	23/04/2021	13:24	14.1	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	23/04/2021	12:08	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	23/04/2021	12:01	7.2	g O2/m³	
Low Flow	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	23/04/2021	14:16	7	g O2/m³	
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	23/04/2021	13:34	7.3	g O2/m³	
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	23/04/2021	12:16	8.1	g O2/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	23/04/2021	12:23	8.3	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	23/04/2021	12:27	8.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	23/04/2021	14:09	7.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	23/04/2021	14:05	6.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	23/04/2021	13:28	7.3	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	23/04/2021	13:24	7.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	23/04/2021	12:01	1.1	g/m³	(.2 - 5)
Low Flow	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	23/04/2021	14:16	0.66	g/m³	(.2 - 5)
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	23/04/2021	13:34	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	23/04/2021	14:09	0.66	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	23/04/2021	14:05	0.63	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	23/04/2021	13:28	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	23/04/2021	13:24	0.84	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	23/04/2021	12:08	Completed		
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	23/04/2021	13:34	Completed		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	23/04/2021	12:08	Completed		
Low Flow	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	23/04/2021	13:34	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	23/04/2021	12:08	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	23/04/2021	12:01	Completed		
Low Flow	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	23/04/2021	14:16	Completed		
Low Flow	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	23/04/2021	13:34	Completed		
Not flowing out the weirs- No solids visible	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	23/04/2021	12:16	Completed		
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	23/04/2021	12:23	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	23/04/2021	12:27	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	23/04/2021	14:09	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	23/04/2021	14:05	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	23/04/2021	13:28	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	23/04/2021	13:24	Completed		
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	1	pH	23/04/2021	11:02	7.7		(7 - 8.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	52	Alkalinity - Total	23/04/2021	11:02	69	g CaCO3/m³	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	55	Conductivity at 25°C - mS/m unit	23/04/2021	11:02	23.4	mS/m (234.2 x .1)	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	0440D	Dissolved Inorganic Carbon	23/04/2021	11:02	18.3	g/m³	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	702	Chloride - Ultra Trace	23/04/2021	11:02	13.1	g/m³	(250 - 250)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	707	Sulphate - Ultra Trace	23/04/2021	11:02	19.6	g/m³	(250 - 250)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:52	0.008	g/m³	(.1 - .1)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:53	0.005	g/m³	(.1 - .1)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:54	0.002	g/m³	(.1 - .1)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:55	0.003	g/m³	(.1 - .1)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:56	0.004	g/m³	(.1 - .1)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:57	0.003	g/m³	(.1 - .1)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:58	0.003	g/m³	(.1 - .1)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	10:59	0.004	g/m³	(.1 - .1)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	11:00	0.003	g/m³	(.1 - .1)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	11:01	0.003	g/m³	(.1 - .1)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6001	Aluminium - Acid Soluble	23/04/2021	11:02	0.003	g/m³	(.1 - .1)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:52	0.0461	g/m³	(1 - 2)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:53	0.0015	g/m³	(1 - 2)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:54	0.0012	g/m³	(1 - 2)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:55	0.0012	g/m³	(1 - 2)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:56	0.0012	g/m³	(1 - 2)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:57	0.0012	g/m³	(1 - 2)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:58	0.0011	g/m³	(1 - 2)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	10:59	0.0011	g/m³	(1 - 2)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	11:00	0.0011	g/m³	(1 - 2)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	11:01	0.0011	g/m³	(1 - 2)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6013	Copper - Acid Soluble	23/04/2021	11:02	0.0011	g/m³	(1 - 2)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:52	0.27	g/m³	(.2 - .2)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:53	0.2	g/m³	(.2 - .2)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:54	0.2	g/m³	(.2 - .2)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:55	0.2	g/m³	(.2 - .2)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:56	0.2	g/m³	(.2 - .2)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:57	0.2	g/m³	(.2 - .2)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:58	0.2	g/m³	(.2 - .2)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	10:59	0.2	g/m³	(.2 - .2)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	11:00	0.2	g/m³	(.2 - .2)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	11:01	0.2	g/m³	(.2 - .2)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6017	Iron - Acid Soluble	23/04/2021	11:02	0.2	g/m³	(.2 - .2)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:52	0.0111	g/m³	(.005 - .01)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:53	<0.0005	g/m³	(.005 - .01)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:54	<0.0005	g/m³	(.005 - .01)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:55	<0.0005	g/m³	(.005 - .01)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:56	<0.0005	g/m³	(.005 - .01)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:57	<0.0005	g/m³	(.005 - .01)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:58	<0.0005	g/m³	(.005 - .01)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	10:59	<0.0005	g/m³	(.005 - .01)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	11:00	<0.0005	g/m³	(.005 - .01)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	11:01	<0.0005	g/m³	(.005 - .01)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6018	Lead - Acid Soluble	23/04/2021	11:02	<0.0005	g/m³	(.005 - .01)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:52	0.0519	g/m³	(.04 - .4)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:53	0.0192	g/m³	(.04 - .4)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:54	0.0193	g/m³	(.04 - .4)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:55	0.0188	g/m³	(.04 - .4)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:56	0.0185	g/m³	(.04 - .4)

#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:57	0.0185	g/m³	(.04 - .4)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:58	0.0181	g/m³	(.04 - .4)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	10:59	0.0187	g/m³	(.04 - .4)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	11:00	0.0188	g/m³	(.04 - .4)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	11:01	0.0182	g/m³	(.04 - .4)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6021	Manganese - Acid Soluble	23/04/2021	11:02	0.0184	g/m³	(.04 - .4)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:52	<0.0005	g/m³	(.08 - .08)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:53	<0.0005	g/m³	(.08 - .08)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:54	<0.0005	g/m³	(.08 - .08)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:55	<0.0005	g/m³	(.08 - .08)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:56	<0.0005	g/m³	(.08 - .08)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:57	<0.0005	g/m³	(.08 - .08)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:58	<0.0005	g/m³	(.08 - .08)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	10:59	<0.0005	g/m³	(.08 - .08)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	11:00	<0.0005	g/m³	(.08 - .08)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	11:01	<0.0005	g/m³	(.08 - .08)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6024	Nickel - Acid Soluble	23/04/2021	11:02	<0.0005	g/m³	(.08 - .08)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:52	0.029	g/m³	(1.5 - 1.5)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:53	0.003	g/m³	(1.5 - 1.5)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:54	0.003	g/m³	(1.5 - 1.5)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:55	0.002	g/m³	(1.5 - 1.5)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:56	0.003	g/m³	(1.5 - 1.5)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:57	0.002	g/m³	(1.5 - 1.5)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:58	0.002	g/m³	(1.5 - 1.5)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	10:59	0.002	g/m³	(1.5 - 1.5)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	11:00	0.002	g/m³	(1.5 - 1.5)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	11:01	0.002	g/m³	(1.5 - 1.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	6038	Zinc - Acid Soluble	23/04/2021	11:02	0.004	g/m³	(1.5 - 1.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	D-0056F	Dissolved Oxygen - Field	23/04/2021	11:02	8.1	g O2/m³	
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	D-1202	Sampling / Inspection 30 Mins	23/04/2021	10:52	Completed		
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	O0994b	Flow Rate performed by ELS	23/04/2021	11:02	0.2	litres/sec	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample Old Tap	P1859	Sample Filtration	23/04/2021	11:02	Completed		
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	1	pH	23/04/2021	11:34	7.7		(7 - 8.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	52	Alkalinity - Total	23/04/2021	11:34	69	g CaCO3/m³	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	55	Conductivity at 25°C - mS/m unit	23/04/2021	11:34	23.4	mS/m (234.1 x .1)	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	0440D	Dissolved Inorganic Carbon	23/04/2021	11:34	18.5	g/m³	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	702	Chloride - Ultra Trace	23/04/2021	11:34	13	g/m³	(250 - 250)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	707	Sulphate - Ultra Trace	23/04/2021	11:34	19.5	g/m³	(250 - 250)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:24	0.01	g/m³	(.1 - .1)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:25	0.006	g/m³	(.1 - .1)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:26	0.005	g/m³	(.1 - .1)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:27	0.004	g/m³	(.1 - .1)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:28	0.004	g/m³	(.1 - .1)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:29	0.004	g/m³	(.1 - .1)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:30	0.003	g/m³	(.1 - .1)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:31	0.003	g/m³	(.1 - .1)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:32	0.003	g/m³	(.1 - .1)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:33	0.003	g/m³	(.1 - .1)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6001	Aluminium - Acid Soluble	23/04/2021	11:34	0.003	g/m³	(.1 - .1)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:24	0.003	g/m³	(1 - 2)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:25	0.0009	g/m³	(1 - 2)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:26	0.0007	g/m³	(1 - 2)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:27	0.0007	g/m³	(1 - 2)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:28	0.0007	g/m³	(1 - 2)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:29	0.0006	g/m³	(1 - 2)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:30	0.0008	g/m³	(1 - 2)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:31	0.0005	g/m³	(1 - 2)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:32	0.0007	g/m³	(1 - 2)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:33	0.0006	g/m³	(1 - 2)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6013	Copper - Acid Soluble	23/04/2021	11:34	0.0007	g/m³	(1 - 2)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:24	0.21	g/m³	(.2 - .2)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:25	0.2	g/m³	(.2 - .2)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:26	0.2	g/m³	(.2 - .2)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:27	0.21	g/m³	(.2 - .2)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:28	0.2	g/m³	(.2 - .2)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:29	0.2	g/m³	(.2 - .2)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:30	0.2	g/m³	(.2 - .2)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:31	0.2	g/m³	(.2 - .2)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:32	0.21	g/m³	(.2 - .2)

#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:33	0.2	g/m³	(.2 - .2)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6017	Iron - Acid Soluble	23/04/2021	11:34	0.2	g/m³	(.2 - .2)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:24	0.0017	g/m³	(.005 - .01)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:26	<0.0005	g/m³	(.005 - .01)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:27	<0.0005	g/m³	(.005 - .01)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:28	<0.0005	g/m³	(.005 - .01)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:29	<0.0005	g/m³	(.005 - .01)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:30	<0.0005	g/m³	(.005 - .01)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:31	<0.0005	g/m³	(.005 - .01)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:32	<0.0005	g/m³	(.005 - .01)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:33	<0.0005	g/m³	(.005 - .01)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6018	Lead - Acid Soluble	23/04/2021	11:34	<0.0005	g/m³	(.005 - .01)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:24	0.0212	g/m³	(.04 - .4)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:25	0.0191	g/m³	(.04 - .4)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:26	0.0186	g/m³	(.04 - .4)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:27	0.0184	g/m³	(.04 - .4)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:28	0.0185	g/m³	(.04 - .4)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:29	0.0184	g/m³	(.04 - .4)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:30	0.0184	g/m³	(.04 - .4)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:31	0.0185	g/m³	(.04 - .4)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:32	0.0187	g/m³	(.04 - .4)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:33	0.0184	g/m³	(.04 - .4)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6021	Manganese - Acid Soluble	23/04/2021	11:34	0.0184	g/m³	(.04 - .4)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:24	0.0009	g/m³	(.08 - .08)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:26	<0.0005	g/m³	(.08 - .08)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:27	<0.0005	g/m³	(.08 - .08)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:28	<0.0005	g/m³	(.08 - .08)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:29	<0.0005	g/m³	(.08 - .08)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:30	<0.0005	g/m³	(.08 - .08)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:31	<0.0005	g/m³	(.08 - .08)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:32	<0.0005	g/m³	(.08 - .08)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:33	<0.0005	g/m³	(.08 - .08)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6024	Nickel - Acid Soluble	23/04/2021	11:34	<0.0005	g/m³	(.08 - .08)
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:24	0.014	g/m³	(1.5 - 1.5)
#1 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:25	0.002	g/m³	(1.5 - 1.5)
#2 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:26	0.002	g/m³	(1.5 - 1.5)
#3 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:27	<0.002	g/m³	(1.5 - 1.5)
#4 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:28	<0.002	g/m³	(1.5 - 1.5)
#5 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:29	<0.002	g/m³	(1.5 - 1.5)
#6 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:30	<0.002	g/m³	(1.5 - 1.5)
#7 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:31	<0.002	g/m³	(1.5 - 1.5)
#8 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:32	<0.002	g/m³	(1.5 - 1.5)
#9 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:33	<0.002	g/m³	(1.5 - 1.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	6038	Zinc - Acid Soluble	23/04/2021	11:34	<0.002	g/m³	(1.5 - 1.5)
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	D-0056F	Dissolved Oxygen - Field	23/04/2021	11:34	7.1	g O2/m³	
#0	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	D-1202	Sampling / Inspection 30 Mins	23/04/2021	11:24	Completed		
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	O0994b	Flow Rate performed by ELS	23/04/2021	11:34	<0.1	litres/sec	
#10 minute	Waikouaiti WTP - Raw Water Reservoir Feed to Plant - Profile Sample	P1859	Sample Filtration	23/04/2021	11:34	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	24/04/2021	10:20	7.8		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	24/04/2021	10:20	14	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	24/04/2021	10:20	<1	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	24/04/2021	10:20	328	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	24/04/2021	10:00	69	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	24/04/2021	10:05	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	24/04/2021	12:00	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	24/04/2021	11:25	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	24/04/2021	10:20	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	24/04/2021	11:50	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	24/04/2021	11:45	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	24/04/2021	11:15	70	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	24/04/2021	11:00	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	24/04/2021	10:20	23.6	mS/m (236.1 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	24/04/2021	10:00	19.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	24/04/2021	10:05	19.4	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	24/04/2021	12:00	19.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	24/04/2021	11:25	19.5	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	24/04/2021	10:20	19.3	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	24/04/2021	11:50	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	24/04/2021	11:45	19.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	24/04/2021	11:15	19.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	24/04/2021	11:00	19.6	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	24/04/2021	10:00	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	24/04/2021	10:20	20.2	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	24/04/2021	10:20	9.58	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	24/04/2021	10:20	0.034	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	24/04/2021	10:20	16	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	24/04/2021	10:20	8.49	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	24/04/2021	10:20	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	24/04/2021	10:20	2.48	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	24/04/2021	10:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	24/04/2021	10:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	24/04/2021	10:20	0.0008	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	24/04/2021	10:20	0.46	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	24/04/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	24/04/2021	10:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	24/04/2021	10:20	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	24/04/2021	10:00	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	24/04/2021	10:05	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	24/04/2021	12:00	0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	24/04/2021	11:25	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	24/04/2021	10:20	0.173	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	24/04/2021	11:50	0.011	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	24/04/2021	11:45	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	24/04/2021	11:15	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	24/04/2021	11:00	0.008	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	24/04/2021	10:20	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	24/04/2021	10:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	24/04/2021	10:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	24/04/2021	12:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	24/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	24/04/2021	10:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	24/04/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	24/04/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	24/04/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	24/04/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	24/04/2021	10:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	24/04/2021	10:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	24/04/2021	12:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	24/04/2021	11:25	0.0022	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	24/04/2021	10:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	24/04/2021	11:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	24/04/2021	11:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	24/04/2021	11:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	24/04/2021	11:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	24/04/2021	10:00	0.12	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	24/04/2021	10:05	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	24/04/2021	12:00	0.07	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	24/04/2021	11:25	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	24/04/2021	10:20	0.02	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	24/04/2021	11:50	0.13	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	24/04/2021	11:45	0.02	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	24/04/2021	11:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	24/04/2021	11:00	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	24/04/2021	10:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	24/04/2021	10:05	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	24/04/2021	12:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	24/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	24/04/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	24/04/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	24/04/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	24/04/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	24/04/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	24/04/2021	10:00	0.0082	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	24/04/2021	10:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	24/04/2021	12:00	0.0054	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	24/04/2021	11:25	<0.0005	g/m³	(.4 - .4)

	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	24/04/2021	11:50	0.0099	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	24/04/2021	11:45	0.0013	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	24/04/2021	11:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	24/04/2021	11:00	0.0024	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	24/04/2021	10:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	24/04/2021	10:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	24/04/2021	12:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	24/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	24/04/2021	10:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	24/04/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	24/04/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	24/04/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	24/04/2021	11:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	24/04/2021	10:00	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	24/04/2021	10:05	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	24/04/2021	12:00	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	24/04/2021	11:25	0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	24/04/2021	10:20	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	24/04/2021	11:50	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	24/04/2021	11:45	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	24/04/2021	11:15	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	24/04/2021	11:00	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	24/04/2021	10:00	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	24/04/2021	10:05	7.6		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	24/04/2021	12:00	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	24/04/2021	11:25	7.8		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	24/04/2021	10:20	7.9		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	24/04/2021	11:50	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	24/04/2021	11:45	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	24/04/2021	11:15	7.8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	24/04/2021	11:00	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	24/04/2021	10:00	12.1	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	24/04/2021	10:05	12.6	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	24/04/2021	12:00	14.9	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	24/04/2021	11:25	14	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	24/04/2021	10:20	12.4	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	24/04/2021	11:50	14.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	24/04/2021	11:45	12.6	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	24/04/2021	11:15	14	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	24/04/2021	11:00	14.7	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	24/04/2021	10:00	8.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	24/04/2021	10:05	9.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	24/04/2021	12:00	8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	24/04/2021	11:25	8.6	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	24/04/2021	10:20	9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	24/04/2021	11:50	7.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	24/04/2021	11:45	8.5	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	24/04/2021	11:15	8.7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	24/04/2021	11:00	8.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	24/04/2021	10:05	1.2	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	24/04/2021	12:00	1.6	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	24/04/2021	11:25	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	24/04/2021	11:50	1.4	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	24/04/2021	11:45	0.5	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	24/04/2021	11:15	1	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	24/04/2021	11:00	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	24/04/2021	10:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	24/04/2021	11:25	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	24/04/2021	10:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	24/04/2021	11:25	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	24/04/2021	10:00	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	24/04/2021	10:05	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	24/04/2021	12:00	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	24/04/2021	11:25	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	24/04/2021	10:20	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	24/04/2021	11:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	24/04/2021	11:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	24/04/2021	11:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	24/04/2021	11:00	Completed		

	Waikouaiti WTP - Supernatant Tube Settler	1	pH	25/04/2021	08:15	7.8		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	25/04/2021	08:15	<3	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	25/04/2021	08:15	<1	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	25/04/2021	08:15	256	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	25/04/2021	08:10	72	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	25/04/2021	08:00	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	25/04/2021	08:35	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	25/04/2021	08:55	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	25/04/2021	08:15	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	25/04/2021	08:30	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	25/04/2021	08:25	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	25/04/2021	08:50	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	25/04/2021	08:45	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	25/04/2021	08:15	23.7	mS/m (237.1 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	25/04/2021	08:10	20	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	25/04/2021	08:00	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	25/04/2021	08:35	19.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	25/04/2021	08:55	19.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	25/04/2021	08:15	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	25/04/2021	08:30	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	25/04/2021	08:25	19.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	25/04/2021	08:50	19.8	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	25/04/2021	08:45	19.7	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	25/04/2021	08:10	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	25/04/2021	08:15	21.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	25/04/2021	08:15	10.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	25/04/2021	08:15	<0.005	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	25/04/2021	08:15	18.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	25/04/2021	08:15	9.72	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	25/04/2021	08:15	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	25/04/2021	08:15	0.414	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	25/04/2021	08:15	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	25/04/2021	08:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	25/04/2021	08:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	25/04/2021	08:15	0.06	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	25/04/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	25/04/2021	08:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	25/04/2021	08:15	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	25/04/2021	08:10	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	25/04/2021	08:00	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	25/04/2021	08:35	0.012	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	25/04/2021	08:55	0.008	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	25/04/2021	08:15	0.062	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	25/04/2021	08:30	0.009	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	25/04/2021	08:25	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	25/04/2021	08:50	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	25/04/2021	08:45	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	25/04/2021	08:15	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	25/04/2021	08:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	25/04/2021	08:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	25/04/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	25/04/2021	08:55	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	25/04/2021	08:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	25/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	25/04/2021	08:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	25/04/2021	08:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	25/04/2021	08:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	25/04/2021	08:10	0.0008	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	25/04/2021	08:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	25/04/2021	08:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	25/04/2021	08:55	0.0014	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	25/04/2021	08:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	25/04/2021	08:30	0.0027	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	25/04/2021	08:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	25/04/2021	08:50	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	25/04/2021	08:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	25/04/2021	08:10	0.06	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	25/04/2021	08:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	25/04/2021	08:35	0.05	g/m³	

	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	25/04/2021	08:55	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	25/04/2021	08:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	25/04/2021	08:30	0.04	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	25/04/2021	08:25	0.02	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	25/04/2021	08:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	25/04/2021	08:45	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	25/04/2021	08:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	25/04/2021	08:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	25/04/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	25/04/2021	08:55	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	25/04/2021	08:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	25/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	25/04/2021	08:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	25/04/2021	08:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	25/04/2021	08:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	25/04/2021	08:10	0.0031	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	25/04/2021	08:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	25/04/2021	08:35	0.0024	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	25/04/2021	08:55	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	25/04/2021	08:30	0.0023	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	25/04/2021	08:25	0.0008	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	25/04/2021	08:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	25/04/2021	08:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	25/04/2021	08:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	25/04/2021	08:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	25/04/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	25/04/2021	08:55	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	25/04/2021	08:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	25/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	25/04/2021	08:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	25/04/2021	08:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	25/04/2021	08:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	25/04/2021	08:10	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	25/04/2021	08:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	25/04/2021	08:35	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	25/04/2021	08:55	0.003	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	25/04/2021	08:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	25/04/2021	08:30	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	25/04/2021	08:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	25/04/2021	08:50	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	25/04/2021	08:45	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	25/04/2021	08:10	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	25/04/2021	08:00	7.7		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	25/04/2021	08:35	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	25/04/2021	08:55	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	25/04/2021	08:15	7.9		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	25/04/2021	08:30	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	25/04/2021	08:25	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	25/04/2021	08:50	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	25/04/2021	08:45	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	25/04/2021	08:10	11.4	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	25/04/2021	08:00	12.6	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	25/04/2021	08:35	13.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	25/04/2021	08:55	13.5	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	25/04/2021	08:15	10.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	25/04/2021	08:30	13.3	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	25/04/2021	08:25	6.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	25/04/2021	08:50	13	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	25/04/2021	08:45	8.5	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:10	6.9	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:00	7.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:35	7.7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:55	7.4	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:15	8.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:30	7.6	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:25	7.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:50	7.6	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	25/04/2021	08:45	8.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	25/04/2021	08:00	1	g/m³	(.2 - 5)

	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	25/04/2021	08:35	0.36	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	25/04/2021	08:55	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	25/04/2021	08:30	0.54	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	25/04/2021	08:25	0.46	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	25/04/2021	08:50	1	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	25/04/2021	08:45	0.75	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	25/04/2021	08:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	25/04/2021	08:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	25/04/2021	08:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	25/04/2021	08:55	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	25/04/2021	08:10	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	25/04/2021	08:00	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	25/04/2021	08:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	25/04/2021	08:55	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	25/04/2021	08:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	25/04/2021	08:30	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	25/04/2021	08:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	25/04/2021	08:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	25/04/2021	08:45	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	26/04/2021	11:00	7.8		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	26/04/2021	11:00	7	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	26/04/2021	11:00	<1	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	26/04/2021	11:00	175	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	26/04/2021	10:50	67	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	26/04/2021	10:45	67	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	26/04/2021	11:25	69	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	26/04/2021	11:50	69	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	26/04/2021	11:00	73	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	26/04/2021	11:20	68	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	26/04/2021	11:15	70	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	26/04/2021	11:45	70	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	26/04/2021	11:40	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	26/04/2021	11:00	24.1	mS/m (241.4 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	26/04/2021	10:50	19.7	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	26/04/2021	10:45	19.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	26/04/2021	11:25	19.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	26/04/2021	11:50	20	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	26/04/2021	11:00	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	26/04/2021	11:20	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	26/04/2021	11:15	19.5	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	26/04/2021	11:45	19.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	26/04/2021	11:40	20.1	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	26/04/2021	10:50	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	26/04/2021	11:00	19.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	26/04/2021	11:00	9.62	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	26/04/2021	11:00	0.015	g/m³	(.4 - .4)
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	26/04/2021	11:00	19.4	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	26/04/2021	11:00	9.89	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	26/04/2021	11:00	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	26/04/2021	11:00	1.61	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	26/04/2021	11:00	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	26/04/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	26/04/2021	11:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	26/04/2021	11:00	0.2	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	26/04/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	26/04/2021	11:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	26/04/2021	11:00	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	26/04/2021	10:50	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	26/04/2021	10:45	0.008	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	26/04/2021	11:25	0.009	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	26/04/2021	11:50	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	26/04/2021	11:00	0.126	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	26/04/2021	11:20	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	26/04/2021	11:15	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	26/04/2021	11:45	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	26/04/2021	11:40	0.008	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	26/04/2021	11:00	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	26/04/2021	10:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	26/04/2021	10:45	<0.0002	g/m³	(.004 - .004)

	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	26/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	26/04/2021	11:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	26/04/2021	11:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	26/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	26/04/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	26/04/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	26/04/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	26/04/2021	10:50	0.0008	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	26/04/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	26/04/2021	11:25	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	26/04/2021	11:50	0.0014	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	26/04/2021	11:00	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	26/04/2021	11:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	26/04/2021	11:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	26/04/2021	11:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	26/04/2021	11:40	0.0012	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	26/04/2021	10:50	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	26/04/2021	10:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	26/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	26/04/2021	11:50	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	26/04/2021	11:00	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	26/04/2021	11:20	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	26/04/2021	11:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	26/04/2021	11:45	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	26/04/2021	11:40	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	26/04/2021	10:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	26/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	26/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	26/04/2021	11:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	26/04/2021	11:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	26/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	26/04/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	26/04/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	26/04/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	26/04/2021	10:50	0.0037	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	26/04/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	26/04/2021	11:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	26/04/2021	11:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	26/04/2021	11:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	26/04/2021	11:15	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	26/04/2021	11:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	26/04/2021	11:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	26/04/2021	10:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	26/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	26/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	26/04/2021	11:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	26/04/2021	11:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	26/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	26/04/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	26/04/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	26/04/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	26/04/2021	10:50	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	26/04/2021	10:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	26/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	26/04/2021	11:50	0.003	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	26/04/2021	11:00	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	26/04/2021	11:20	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	26/04/2021	11:15	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	26/04/2021	11:45	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	26/04/2021	11:40	0.003	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	26/04/2021	10:50	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	26/04/2021	10:45	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	26/04/2021	11:25	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	26/04/2021	11:50	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	26/04/2021	11:00	7.9		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	26/04/2021	11:20	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	26/04/2021	11:15	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	26/04/2021	11:45	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	26/04/2021	11:40	7.9		

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	26/04/2021	10:50	10.4	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	26/04/2021	10:45	11.4	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	26/04/2021	11:25	13.3	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	26/04/2021	11:50	13.4	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	26/04/2021	11:00	10.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	26/04/2021	11:20	12.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	26/04/2021	11:15	7.9	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	26/04/2021	11:45	13.2	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	26/04/2021	11:40	10.9	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	26/04/2021	10:50	7.4	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	26/04/2021	10:45	7.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:25	7.6	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:50	7.9	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:00	8.4	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:20	7.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:15	8.7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:45	7.3	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	26/04/2021	11:40	7.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	26/04/2021	10:45	0.89	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	26/04/2021	11:25	0.46	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	26/04/2021	11:50	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	26/04/2021	11:20	0.48	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	26/04/2021	11:15	0.09	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	26/04/2021	11:45	0.94	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	26/04/2021	11:40	0.69	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	26/04/2021	10:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	26/04/2021	11:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	26/04/2021	10:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	26/04/2021	11:50	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	26/04/2021	10:50	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	26/04/2021	10:45	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	26/04/2021	11:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	26/04/2021	11:50	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	26/04/2021	11:00	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	26/04/2021	11:20	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	26/04/2021	11:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	26/04/2021	11:45	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	26/04/2021	11:40	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	27/04/2021	10:45	7.8		(1 - 14)
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	27/04/2021	10:50	7.7		(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	27/04/2021	10:55	7.7		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	27/04/2021	10:45	15	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	27/04/2021	10:50	110	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	27/04/2021	10:55	194	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	27/04/2021	10:45	<1	mL/L	
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	27/04/2021	10:50	40	mL/L	
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	27/04/2021	10:55	70	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	27/04/2021	10:45	153	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	27/04/2021	10:50	153	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	27/04/2021	10:55	174	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	27/04/2021	10:40	70	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	27/04/2021	10:35	70	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	27/04/2021	11:25	69	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	27/04/2021	11:45	70	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	27/04/2021	10:45	71	g CaCO3/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	27/04/2021	10:50	76	g CaCO3/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	27/04/2021	10:55	79	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	27/04/2021	11:20	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	27/04/2021	11:15	70	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	27/04/2021	11:40	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	27/04/2021	11:35	71	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	27/04/2021	10:45	24.4	mS/m (243.6 x .1)	
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	27/04/2021	10:50	24.2	mS/m (242.4 x .1)	
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	27/04/2021	10:55	24.3	mS/m (243 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	27/04/2021	10:40	20.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	27/04/2021	10:35	19.6	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	27/04/2021	11:25	19.6	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	27/04/2021	11:45	19.8	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	27/04/2021	10:45	19.2	g/m³	

	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	27/04/2021	10:50	19.2	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	27/04/2021	10:55	19.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	27/04/2021	11:20	19.7	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	27/04/2021	11:15	19.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	27/04/2021	11:40	19.9	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	27/04/2021	11:35	19.9	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	27/04/2021	10:40	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	27/04/2021	10:45	20.8	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	27/04/2021	10:50	21.4	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	27/04/2021	10:55	21.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	27/04/2021	10:45	10.1	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	27/04/2021	10:50	10.2	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	27/04/2021	10:55	10.3	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	27/04/2021	10:45	0.023	g/m³	(.4 - .4)
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	27/04/2021	10:50	0.184	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	27/04/2021	10:55	0.271	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	27/04/2021	10:45	19.6	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	27/04/2021	10:50	19.7	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	27/04/2021	10:55	19.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	27/04/2021	10:45	10	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	27/04/2021	10:50	9.96	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	27/04/2021	10:55	10.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	27/04/2021	10:45	<0.005	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	27/04/2021	10:50	<0.005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	27/04/2021	10:55	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	27/04/2021	10:45	2.72	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	27/04/2021	10:50	20.4	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	27/04/2021	10:55	29.9	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	27/04/2021	10:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	27/04/2021	10:50	0.003	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	27/04/2021	10:55	0.004	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	27/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	27/04/2021	10:50	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	27/04/2021	10:55	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	27/04/2021	10:45	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	27/04/2021	10:50	0.0031	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	27/04/2021	10:55	0.0044	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	27/04/2021	10:45	0.38	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	27/04/2021	10:50	2.6	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	27/04/2021	10:55	3.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	27/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	27/04/2021	10:50	0.0006	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	27/04/2021	10:55	0.0009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	27/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	27/04/2021	10:50	0.005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	27/04/2021	10:55	0.0045	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	27/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	27/04/2021	10:50	0.003	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	27/04/2021	10:55	0.007	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	27/04/2021	10:40	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	27/04/2021	10:35	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	27/04/2021	11:25	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	27/04/2021	11:45	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	27/04/2021	10:45	0.202	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	27/04/2021	10:50	0.011	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	27/04/2021	10:55	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	27/04/2021	11:20	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	27/04/2021	11:15	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	27/04/2021	11:40	0.008	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	27/04/2021	11:35	0.008	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	27/04/2021	10:45	<0.001	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	27/04/2021	10:50	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	27/04/2021	10:55	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	27/04/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	27/04/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	27/04/2021	11:25	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	27/04/2021	11:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	27/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	27/04/2021	10:50	<0.0002	g/m³	

	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	27/04/2021	10:55	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	27/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	27/04/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	27/04/2021	11:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	27/04/2021	11:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	27/04/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	27/04/2021	10:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	27/04/2021	11:25	0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	27/04/2021	11:45	0.0021	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	27/04/2021	10:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	27/04/2021	10:50	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	27/04/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	27/04/2021	11:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	27/04/2021	11:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	27/04/2021	11:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	27/04/2021	11:35	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	27/04/2021	10:40	0.08	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	27/04/2021	10:35	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	27/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	27/04/2021	11:45	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	27/04/2021	10:45	0.01	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	27/04/2021	10:50	<0.01	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	27/04/2021	10:55	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	27/04/2021	11:20	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	27/04/2021	11:15	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	27/04/2021	11:40	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	27/04/2021	11:35	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	27/04/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	27/04/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	27/04/2021	11:25	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	27/04/2021	11:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	27/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	27/04/2021	10:50	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	27/04/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	27/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	27/04/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	27/04/2021	11:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	27/04/2021	11:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	27/04/2021	10:40	0.0017	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	27/04/2021	10:35	0.0006	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	27/04/2021	11:25	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	27/04/2021	11:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	27/04/2021	11:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	27/04/2021	11:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	27/04/2021	11:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	27/04/2021	11:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	27/04/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	27/04/2021	10:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	27/04/2021	11:25	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	27/04/2021	11:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	27/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	27/04/2021	10:50	0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	27/04/2021	10:55	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	27/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	27/04/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	27/04/2021	11:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	27/04/2021	11:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	27/04/2021	10:40	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	27/04/2021	10:35	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	27/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	27/04/2021	11:45	0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	27/04/2021	10:45	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	27/04/2021	10:50	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	27/04/2021	10:55	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	27/04/2021	11:20	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	27/04/2021	11:15	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	27/04/2021	11:40	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	27/04/2021	11:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	27/04/2021	10:40	7.8		

	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	27/04/2021	10:35	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	27/04/2021	11:25	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	27/04/2021	11:45	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	27/04/2021	10:45	7.8		
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	27/04/2021	10:50	7.8		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	27/04/2021	10:55	7.9		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	27/04/2021	11:20	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	27/04/2021	11:15	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	27/04/2021	11:40	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	27/04/2021	11:35	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	27/04/2021	10:40	10.3	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	27/04/2021	10:35	11.7	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	27/04/2021	11:25	12.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	27/04/2021	11:45	12.7	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	27/04/2021	10:45	10.2	Deg C	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	27/04/2021	10:50	10.1	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	27/04/2021	10:55	10.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	27/04/2021	11:20	12.8	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	27/04/2021	11:15	12.7	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	27/04/2021	11:40	12.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	27/04/2021	11:35	12.3	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	27/04/2021	10:40	8.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	27/04/2021	10:35	7.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:25	7.2	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:45	7.7	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	27/04/2021	10:45	9.3	g O2/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	27/04/2021	10:50	9.5	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	27/04/2021	10:55	9.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:20	6.8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:15	6.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:40	7.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	27/04/2021	11:35	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	27/04/2021	10:35	1.3	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	27/04/2021	11:25	0.57	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	27/04/2021	11:45	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	27/04/2021	11:20	0.49	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	27/04/2021	11:15	0.29	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	27/04/2021	11:40	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	27/04/2021	11:35	0.91	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	27/04/2021	10:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	27/04/2021	11:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1204	Sampling / Inspection 60 Mins	27/04/2021	10:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1204	Sampling / Inspection 60 Mins	27/04/2021	11:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	27/04/2021	10:40	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	27/04/2021	10:35	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	27/04/2021	11:25	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	27/04/2021	11:45	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	27/04/2021	10:45	Completed		
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	27/04/2021	10:50	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	27/04/2021	10:55	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	27/04/2021	11:20	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	27/04/2021	11:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	27/04/2021	11:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	27/04/2021	11:35	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	28/04/2021	13:45	7.8		(1 - 14)
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	28/04/2021	13:48	7.7		(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	28/04/2021	13:50	7.6		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	28/04/2021	13:45	9	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	28/04/2021	13:48	62	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	28/04/2021	13:50	228	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	28/04/2021	13:45	<1	mL/L	
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	28/04/2021	13:48	18	mL/L	
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	28/04/2021	13:50	80	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	28/04/2021	13:45	200	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	28/04/2021	13:48	221	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	28/04/2021	13:50	384	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	28/04/2021	13:35	75	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	28/04/2021	13:30	71	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	28/04/2021	14:20	73	g CaCO3/m³	

	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	28/04/2021	14:40	73	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	28/04/2021	13:45	73	g CaCO3/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	28/04/2021	13:48	77	g CaCO3/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	28/04/2021	13:50	84	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	28/04/2021	14:15	74	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	28/04/2021	14:10	73	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	28/04/2021	14:35	72	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	28/04/2021	14:30	73	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	28/04/2021	13:45	24.4	mS/m (243.7 x .1)	
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	28/04/2021	13:48	24.4	mS/m (244 x .1)	
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	28/04/2021	13:50	24.5	mS/m (244.9 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	28/04/2021	13:35	19.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	28/04/2021	13:30	19.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	28/04/2021	14:20	19.2	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	28/04/2021	14:40	19.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	28/04/2021	13:45	19	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	28/04/2021	13:48	19.1	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	28/04/2021	13:50	19.2	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	28/04/2021	14:15	19.1	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	28/04/2021	14:10	19.4	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	28/04/2021	14:35	19	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	28/04/2021	14:30	19	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	28/04/2021	13:35	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	28/04/2021	13:45	20.5	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	28/04/2021	13:48	21.3	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	28/04/2021	13:50	22.3	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	28/04/2021	13:45	9.97	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	28/04/2021	13:48	10.2	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	28/04/2021	13:50	10.3	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	28/04/2021	13:45	0.013	g/m³	(.4 - .4)
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	28/04/2021	13:48	0.072	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	28/04/2021	13:50	0.31	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	28/04/2021	13:45	20.4	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	28/04/2021	13:48	22.2	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	28/04/2021	13:50	21.2	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	28/04/2021	13:45	9.88	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	28/04/2021	13:48	10.6	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	28/04/2021	13:50	10.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	28/04/2021	13:45	<0.005	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	28/04/2021	13:48	<0.005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	28/04/2021	13:50	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	28/04/2021	13:45	1.63	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	28/04/2021	13:48	10.1	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	28/04/2021	13:50	41.1	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	28/04/2021	13:45	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	28/04/2021	13:48	0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	28/04/2021	13:50	0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	28/04/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	28/04/2021	13:48	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	28/04/2021	13:50	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	28/04/2021	13:45	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	28/04/2021	13:48	0.0017	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	28/04/2021	13:50	0.0063	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	28/04/2021	13:45	0.22	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	28/04/2021	13:48	1.36	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	28/04/2021	13:50	5.05	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	28/04/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	28/04/2021	13:48	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	28/04/2021	13:50	0.0009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	28/04/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	28/04/2021	13:48	0.0017	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	28/04/2021	13:50	0.0033	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	28/04/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	28/04/2021	13:48	0.003	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	28/04/2021	13:50	0.006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	28/04/2021	13:35	0.005	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	28/04/2021	13:30	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	28/04/2021	14:20	0.006	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	28/04/2021	14:40	0.008	g/m³	

	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	28/04/2021	13:45	0.284	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	28/04/2021	13:48	0.267	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	28/04/2021	13:50	0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	28/04/2021	14:15	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	28/04/2021	14:10	0.006	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	28/04/2021	14:35	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	28/04/2021	14:30	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	28/04/2021	13:45	<0.001	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	28/04/2021	13:48	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	28/04/2021	13:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	28/04/2021	13:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	28/04/2021	13:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	28/04/2021	14:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	28/04/2021	14:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	28/04/2021	13:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	28/04/2021	13:48	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	28/04/2021	13:50	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	28/04/2021	14:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	28/04/2021	14:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	28/04/2021	14:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	28/04/2021	14:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	28/04/2021	13:35	0.0009	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	28/04/2021	13:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	28/04/2021	14:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	28/04/2021	14:40	0.0014	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	28/04/2021	13:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	28/04/2021	13:48	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	28/04/2021	13:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	28/04/2021	14:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	28/04/2021	14:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	28/04/2021	14:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	28/04/2021	14:30	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	28/04/2021	13:35	0.13	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	28/04/2021	13:30	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	28/04/2021	14:20	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	28/04/2021	14:40	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	28/04/2021	13:45	0.02	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	28/04/2021	13:48	0.01	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	28/04/2021	13:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	28/04/2021	14:15	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	28/04/2021	14:10	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	28/04/2021	14:35	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	28/04/2021	14:30	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	28/04/2021	13:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	28/04/2021	13:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	28/04/2021	14:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	28/04/2021	14:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	28/04/2021	13:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	28/04/2021	13:48	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	28/04/2021	13:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	28/04/2021	14:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	28/04/2021	14:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	28/04/2021	14:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	28/04/2021	14:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	28/04/2021	13:35	0.0085	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	28/04/2021	13:30	0.001	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	28/04/2021	14:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	28/04/2021	14:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	28/04/2021	14:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	28/04/2021	14:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	28/04/2021	14:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	28/04/2021	14:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	28/04/2021	13:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	28/04/2021	13:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	28/04/2021	14:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	28/04/2021	14:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	28/04/2021	13:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	28/04/2021	13:48	0.0036	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	28/04/2021	13:50	<0.0005	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	28/04/2021	14:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	28/04/2021	14:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	28/04/2021	14:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	28/04/2021	14:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	28/04/2021	13:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	28/04/2021	13:30	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	28/04/2021	14:20	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	28/04/2021	14:40	0.003	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	28/04/2021	13:45	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	28/04/2021	13:48	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	28/04/2021	13:50	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	28/04/2021	14:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	28/04/2021	14:10	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	28/04/2021	14:35	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	28/04/2021	14:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	28/04/2021	13:35	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	28/04/2021	13:30	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	28/04/2021	14:20	8		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	28/04/2021	14:40	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	28/04/2021	13:45	7.9		
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	28/04/2021	13:48	7.9		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	28/04/2021	13:50	7.8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	28/04/2021	14:15	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	28/04/2021	14:10	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	28/04/2021	14:35	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	28/04/2021	14:30	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	28/04/2021	13:35	8.7	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	28/04/2021	13:30	10.8	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	28/04/2021	14:20	12.5	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	28/04/2021	14:40	12.8	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	28/04/2021	13:45	10	Deg C	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	28/04/2021	13:48	9.3	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	28/04/2021	13:50	9.2	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	28/04/2021	14:15	12.6	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	28/04/2021	14:10	16.5	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	28/04/2021	14:35	12.9	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	28/04/2021	14:30	16.4	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	28/04/2021	13:35	8.8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	28/04/2021	13:30	8.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:20	7.5	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:40	7.2	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	28/04/2021	13:45	8.7	g O2/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	28/04/2021	13:48	8.9	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	28/04/2021	13:50	9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:15	7.7	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:10	6.5	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:35	8.1	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	28/04/2021	14:30	6.6	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	28/04/2021	13:30	1.2	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	28/04/2021	14:20	0.73	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	28/04/2021	14:40	1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	28/04/2021	14:15	0.66	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	28/04/2021	14:10	0.59	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	28/04/2021	14:35	0.92	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	28/04/2021	14:30	0.89	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	28/04/2021	13:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	28/04/2021	14:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	28/04/2021	13:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1205	Sampling / Inspection 2 hours	28/04/2021	14:40	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	28/04/2021	13:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	28/04/2021	13:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	28/04/2021	14:20	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	28/04/2021	14:40	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	28/04/2021	13:45	Completed		
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	28/04/2021	13:48	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	28/04/2021	13:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	28/04/2021	14:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	28/04/2021	14:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	28/04/2021	14:35	Completed		

	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	28/04/2021	14:30	Completed			
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	29/04/2021	08:40	7.8			(1 - 14)
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	29/04/2021	08:45	7.7			(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	29/04/2021	08:50	7.6			(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	29/04/2021	08:40	<6	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	29/04/2021	08:45	152	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	29/04/2021	08:50	267	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	29/04/2021	08:40	<1	mL/L		
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	29/04/2021	08:45	70	mL/L		
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	29/04/2021	08:50	140	mL/L		
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	29/04/2021	08:40	130	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	29/04/2021	08:45	335	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	29/04/2021	08:50	453	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	29/04/2021	08:35	73	g CaCO3/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	29/04/2021	08:30	70	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	29/04/2021	12:50	71	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	29/04/2021	13:10	72	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	29/04/2021	08:40	72	g CaCO3/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	29/04/2021	08:45	79	g CaCO3/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	29/04/2021	08:50	84	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	29/04/2021	12:45	71	g CaCO3/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	29/04/2021	12:40	72	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	29/04/2021	13:05	73	g CaCO3/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	29/04/2021	13:00	73	g CaCO3/m³		
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	29/04/2021	08:40	24.7	mS/m (246.7 x .1)		
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	29/04/2021	08:45	24.6	mS/m (245.7 x .1)		
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	29/04/2021	08:50	24.6	mS/m (245.8 x .1)		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	29/04/2021	08:35	20.1	g/m³		
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	29/04/2021	08:30	19.7	g/m³		
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	29/04/2021	12:50	19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	29/04/2021	13:10	20	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	29/04/2021	08:40	19.6	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	29/04/2021	08:45	19.6	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	29/04/2021	08:50	19.4	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	29/04/2021	12:45	19.5	g/m³		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	29/04/2021	12:40	19.6	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	29/04/2021	13:05	20	g/m³		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	29/04/2021	13:00	19.8	g/m³		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	29/04/2021	08:35	$100			
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	29/04/2021	08:40	20.9	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	29/04/2021	08:45	21.7	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	29/04/2021	08:50	22.1	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	29/04/2021	08:40	10	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	29/04/2021	08:45	10.2	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	29/04/2021	08:50	10.2	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	29/04/2021	08:40	0.01	g/m³		(.4 - .4)
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	29/04/2021	08:45	0.263	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	29/04/2021	08:50	0.37	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	29/04/2021	08:40	21.3	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	29/04/2021	08:45	20.7	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	29/04/2021	08:50	20.7	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	29/04/2021	08:40	11.2	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	29/04/2021	08:45	10.9	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	29/04/2021	08:50	10.9	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	29/04/2021	08:40	<0.005	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	29/04/2021	08:45	<0.005	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	29/04/2021	08:50	<0.005	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	29/04/2021	08:40	1.07	g/m³		
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	29/04/2021	08:45	34.8	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	29/04/2021	08:50	48.7	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	29/04/2021	08:40	<0.001	g/m³		(.01 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	29/04/2021	08:45	0.005	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	29/04/2021	08:50	0.006	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	29/04/2021	08:40	<0.0002	g/m³		(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	29/04/2021	08:45	<0.0002	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	29/04/2021	08:50	<0.0002	g/m³		
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	29/04/2021	08:40	<0.0005	g/m³		(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	29/04/2021	08:45	0.0051	g/m³		
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	29/04/2021	08:50	0.0066	g/m³		

	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	29/04/2021	08:40	0.13	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	29/04/2021	08:45	4.15	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	29/04/2021	08:50	5.42	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	29/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	29/04/2021	08:45	0.0007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	29/04/2021	08:50	0.0009	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	29/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	29/04/2021	08:45	0.0062	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	29/04/2021	08:50	0.0035	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	29/04/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	29/04/2021	08:45	0.008	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	29/04/2021	08:50	0.006	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	29/04/2021	08:35	0.004	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	29/04/2021	08:30	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	29/04/2021	12:50	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	29/04/2021	13:10	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	29/04/2021	08:40	0.064	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	29/04/2021	08:45	0.013	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	29/04/2021	08:50	0.012	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	29/04/2021	12:45	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	29/04/2021	12:40	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	29/04/2021	13:05	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	29/04/2021	13:00	0.008	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	29/04/2021	08:40	<0.001	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	29/04/2021	08:45	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	29/04/2021	08:50	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	29/04/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	29/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	29/04/2021	12:50	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	29/04/2021	13:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	29/04/2021	08:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	29/04/2021	08:45	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	29/04/2021	08:50	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	29/04/2021	12:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	29/04/2021	12:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	29/04/2021	13:05	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	29/04/2021	13:00	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	29/04/2021	08:35	0.001	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	29/04/2021	12:50	0.0007	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	29/04/2021	13:10	0.0017	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	29/04/2021	08:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	29/04/2021	08:45	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	29/04/2021	08:50	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	29/04/2021	12:45	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	29/04/2021	12:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	29/04/2021	13:05	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	29/04/2021	13:00	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	29/04/2021	08:35	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	29/04/2021	08:30	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	29/04/2021	12:50	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	29/04/2021	13:10	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	29/04/2021	08:40	<0.01	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	29/04/2021	08:45	<0.01	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	29/04/2021	08:50	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	29/04/2021	12:45	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	29/04/2021	12:40	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	29/04/2021	13:05	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	29/04/2021	13:00	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	29/04/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	29/04/2021	12:50	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	29/04/2021	13:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	29/04/2021	08:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	29/04/2021	08:45	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	29/04/2021	08:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	29/04/2021	12:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	29/04/2021	12:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	29/04/2021	13:05	<0.0005	g/m³	(.005 - .01)

	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	29/04/2021	13:00	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	29/04/2021	08:35	0.0037	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	29/04/2021	08:30	0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	29/04/2021	12:50	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	29/04/2021	13:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	29/04/2021	12:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	29/04/2021	12:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	29/04/2021	13:05	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	29/04/2021	13:00	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	29/04/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	29/04/2021	12:50	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	29/04/2021	13:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	29/04/2021	08:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	29/04/2021	08:45	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	29/04/2021	08:50	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	29/04/2021	12:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	29/04/2021	12:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	29/04/2021	13:05	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	29/04/2021	13:00	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	29/04/2021	08:35	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	29/04/2021	08:30	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	29/04/2021	12:50	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	29/04/2021	13:10	0.003	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	29/04/2021	08:40	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	29/04/2021	08:45	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	29/04/2021	08:50	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	29/04/2021	12:45	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	29/04/2021	12:40	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	29/04/2021	13:05	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	29/04/2021	13:00	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	29/04/2021	08:35	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	29/04/2021	08:30	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	29/04/2021	12:50	8.1		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	29/04/2021	13:10	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	29/04/2021	08:40	7.9		
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	29/04/2021	08:45	7.8		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	29/04/2021	08:50	7.8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	29/04/2021	12:45	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	29/04/2021	12:40	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	29/04/2021	13:05	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	29/04/2021	13:00	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	29/04/2021	08:35	8.8	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	29/04/2021	08:30	10	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	29/04/2021	12:50	12.5	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	29/04/2021	13:10	12.7	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	29/04/2021	08:40	9	Deg C	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	29/04/2021	08:45	9	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	29/04/2021	08:50	9	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	29/04/2021	12:45	12.5	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	29/04/2021	12:40	15.1	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	29/04/2021	13:05	12.8	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	29/04/2021	13:00	15.2	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:35	8	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:30	7.5	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	29/04/2021	12:50	7.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	29/04/2021	13:10	7.8	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:40	8.7	g O2/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:45	8.4	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:50	8.8	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	29/04/2021	12:45	8.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	29/04/2021	12:40	6.7	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	29/04/2021	13:05	7.9	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	29/04/2021	13:00	6.5	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/04/2021	08:30	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	29/04/2021	12:50	0.66	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	29/04/2021	13:10	1.1	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	29/04/2021	12:45	0.47	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	29/04/2021	12:40	0.31	g/m³	(.2 - 5)

	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	29/04/2021	13:05	0.8	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	29/04/2021	13:00	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	29/04/2021	08:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	29/04/2021	13:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	29/04/2021	08:35	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1205	Sampling / Inspection 2 hours	29/04/2021	13:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	29/04/2021	08:35	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	29/04/2021	08:30	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	29/04/2021	12:50	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	29/04/2021	13:10	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	29/04/2021	08:40	Completed		
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	29/04/2021	08:45	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	29/04/2021	08:50	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	29/04/2021	12:45	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	29/04/2021	12:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	29/04/2021	13:05	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	29/04/2021	13:00	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	29/04/2021	09:15	<6	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	29/04/2021	08:30	<6	g/m³	
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	29/04/2021	11:55	72	g CaCO3/m³	
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	29/04/2021	10:40	72	g CaCO3/m³	
	Karitane Bowls	52	Alkalinity - Total	29/04/2021	10:46	72	g CaCO3/m³	
	Waikouaiti Golf Club	52	Alkalinity - Total	29/04/2021	12:20	72	g CaCO3/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	52	Alkalinity - Total	29/04/2021	09:30	72	g CaCO3/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	29/04/2021	11:30	72	g CaCO3/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	29/04/2021	08:35	73	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	29/04/2021	09:15	72	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	29/04/2021	08:30	71	g CaCO3/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	29/04/2021	09:10	73	g CaCO3/m³	
	Catchment - Waikouaiti River - Pump Station Intake	55	Conductivity at 25°C - mS/m unit	29/04/2021	09:15	24.6	mS/m (245.6 x .1)	
	Waikouaiti WTP - Post Treated Water Reservoir	55	Conductivity at 25°C - mS/m unit	29/04/2021	08:30	25	mS/m (249.5 x .1)	
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	29/04/2021	11:55	20	g/m³	
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	29/04/2021	10:40	19.9	g/m³	
	Karitane Bowls	0440D	Dissolved Inorganic Carbon	29/04/2021	10:46	20.2	g/m³	
	Waikouaiti Golf Club	0440D	Dissolved Inorganic Carbon	29/04/2021	12:20	19.9	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	0440D	Dissolved Inorganic Carbon	29/04/2021	09:30	19.7	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	29/04/2021	11:30	20	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	29/04/2021	08:35	20.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	29/04/2021	09:15	20.3	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	29/04/2021	08:30	19.8	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	29/04/2021	09:10	20.1	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	29/04/2021	09:15	14.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	29/04/2021	08:30	16.1	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	29/04/2021	09:15	21	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	29/04/2021	08:30	18.6	g/m³	(250 - 250)
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	29/04/2021	09:15	111	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	29/04/2021	08:30	135	g/m³	(1000 - 1000)
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	29/04/2021	08:30	0.008	g/m³	(.1 - .1)
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	29/04/2021	08:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	29/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	29/04/2021	08:30	22.5	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	29/04/2021	08:30	<0.0005	g/m³	(1 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	29/04/2021	08:30	<0.01	g/m³	(.2 - .2)
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	29/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	29/04/2021	08:30	9.51	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	29/04/2021	08:30	0.0036	g/m³	(.04 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	29/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	29/04/2021	08:30	<0.002	g/m³	(1.5 - 1.5)
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	29/04/2021	09:15	0.015	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	29/04/2021	09:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	29/04/2021	09:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	29/04/2021	09:15	20.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	29/04/2021	09:15	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	29/04/2021	09:15	0.2	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	29/04/2021	09:15	<0.001	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	29/04/2021	09:15	9.5	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	29/04/2021	09:15	0.023	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	29/04/2021	09:15	<0.001	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	29/04/2021	09:15	<0.005	g/m³	

	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	29/04/2021	11:55	0.006	g/m³	
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	29/04/2021	10:40	0.007	g/m³	
	Karitane Bowls	6701	Aluminium - Dissolved	29/04/2021	10:46	0.007	g/m³	
	Waikouaiti Golf Club	6701	Aluminium - Dissolved	29/04/2021	12:20	0.008	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6701	Aluminium - Dissolved	29/04/2021	09:30	0.007	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	29/04/2021	11:30	0.007	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	29/04/2021	08:35	0.004	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	29/04/2021	09:15	0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	29/04/2021	08:30	0.006	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	29/04/2021	09:10	0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	29/04/2021	09:15	<0.001	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	29/04/2021	08:30	<0.001	g/m³	(.01 - .01)
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	29/04/2021	11:55	<0.0002	g/m³	(.004 - .004)
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	29/04/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Karitane Bowls	6708	Cadmium - Dissolved	29/04/2021	10:46	<0.0002	g/m³	(.004 - .004)
	Waikouaiti Golf Club	6708	Cadmium - Dissolved	29/04/2021	12:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6708	Cadmium - Dissolved	29/04/2021	09:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	29/04/2021	11:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	29/04/2021	08:35	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	29/04/2021	09:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	29/04/2021	08:30	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	29/04/2021	09:10	<0.0002	g/m³	(.004 - .004)
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	29/04/2021	09:15	22.1	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	29/04/2021	08:30	21.6	g/m³	
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	29/04/2021	11:55	0.001	g/m³	(2 - 2)
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	29/04/2021	10:40	0.0006	g/m³	(2 - 2)
	Karitane Bowls	6713	Copper - Dissolved	29/04/2021	10:46	0.0056	g/m³	(2 - 2)
	Waikouaiti Golf Club	6713	Copper - Dissolved	29/04/2021	12:20	0.0112	g/m³	(2 - 2)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6713	Copper - Dissolved	29/04/2021	09:30	0.0008	g/m³	(2 - 2)
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	29/04/2021	11:30	0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	29/04/2021	08:35	0.0012	g/m³	(2 - 2)
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	29/04/2021	09:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	29/04/2021	09:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	29/04/2021	11:55	<0.01	g/m³	
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	29/04/2021	10:40	<0.01	g/m³	
	Karitane Bowls	6717	Iron - Dissolved	29/04/2021	10:46	<0.01	g/m³	(.2 - .2)
	Waikouaiti Golf Club	6717	Iron - Dissolved	29/04/2021	12:20	<0.01	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6717	Iron - Dissolved	29/04/2021	09:30	<0.01	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	29/04/2021	11:30	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	29/04/2021	08:35	0.12	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	29/04/2021	09:15	0.16	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	29/04/2021	08:30	<0.01	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	29/04/2021	09:10	0.12	g/m³	
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	29/04/2021	11:55	<0.0005	g/m³	(.005 - .01)
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	29/04/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Karitane Bowls	6718	Lead - Dissolved	29/04/2021	10:46	<0.0005	g/m³	(.005 - .01)
	Waikouaiti Golf Club	6718	Lead - Dissolved	29/04/2021	12:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6718	Lead - Dissolved	29/04/2021	09:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	29/04/2021	11:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	29/04/2021	08:35	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	29/04/2021	09:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	29/04/2021	09:10	<0.0005	g/m³	(.005 - .01)
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	29/04/2021	09:15	10.2	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	29/04/2021	08:30	9.95	g/m³	
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	29/04/2021	11:55	<0.0005	g/m³	(.4 - .4)
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	29/04/2021	10:40	<0.0005	g/m³	(.4 - .4)
	Karitane Bowls	6721	Manganese - Dissolved	29/04/2021	10:46	<0.0005	g/m³	(.4 - .4)
	Waikouaiti Golf Club	6721	Manganese - Dissolved	29/04/2021	12:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6721	Manganese - Dissolved	29/04/2021	09:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	29/04/2021	11:30	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	29/04/2021	08:35	0.0052	g/m³	(.4 - .4)
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	29/04/2021	09:15	0.0214	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	29/04/2021	08:30	0.0006	g/m³	(.4 - .4)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	29/04/2021	09:10	0.0207	g/m³	(.4 - .4)
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	29/04/2021	11:55	<0.0005	g/m³	(.08 - .08)
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	29/04/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Karitane Bowls	6724	Nickel - Dissolved	29/04/2021	10:46	<0.0005	g/m³	(.08 - .08)

	Waikouaiti Golf Club	6724	Nickel - Dissolved	29/04/2021	12:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6724	Nickel - Dissolved	29/04/2021	09:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	29/04/2021	11:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	29/04/2021	08:35	<0.0005	g/m³	(.08 - .08)
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	29/04/2021	09:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	29/04/2021	08:30	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	29/04/2021	09:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	29/04/2021	11:55	<0.002	g/m³	
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	29/04/2021	10:40	<0.002	g/m³	
	Karitane Bowls	6738	Zinc - Dissolved	29/04/2021	10:46	0.006	g/m³	
	Waikouaiti Golf Club	6738	Zinc - Dissolved	29/04/2021	12:20	0.029	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	6738	Zinc - Dissolved	29/04/2021	09:30	<0.002	g/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	29/04/2021	11:30	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	29/04/2021	08:35	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	29/04/2021	09:15	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	29/04/2021	08:30	<0.002	g/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	29/04/2021	09:10	<0.002	g/m³	
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	29/04/2021	09:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	29/04/2021	08:30	Completed		
	Karitane School	C-O1420	Sampler Observation	29/04/2021	00:00:00	No	Sample	
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	29/04/2021	11:55	7.8		
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	29/04/2021	10:40	8		
	Karitane Bowls	D-0001F	pH - Field	29/04/2021	10:46	7.9		
	Waikouaiti Golf Club	D-0001F	pH - Field	29/04/2021	12:20	8		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0001F	pH - Field	29/04/2021	09:30	7.9		
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	29/04/2021	11:30	7.8		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	29/04/2021	08:35	7.8		
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	29/04/2021	09:15	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	29/04/2021	08:30	7.8		
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	29/04/2021	09:10	7.8		
	Waikouaiti SS - 192 Main Rd	D-0053F	Temperature - Field	29/04/2021	11:55	12.2	Deg C	
	Karitane SS - 99 Stornoway St	D-0053F	Temperature - Field	29/04/2021	10:40	11.7	Deg C	
	Karitane Bowls	D-0053F	Temperature - Field	29/04/2021	10:46	9.7	Deg C	
	Waikouaiti Golf Club	D-0053F	Temperature - Field	29/04/2021	12:20	11.2	Deg C	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0053F	Temperature - Field	29/04/2021	09:30	11.1	Deg C	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0053F	Temperature - Field	29/04/2021	11:30	12.8	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	29/04/2021	08:35	8.8	Deg C	
	Catchment - Waikouaiti River - Pump Station Intake	D-0053F	Temperature - Field	29/04/2021	09:15	9	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	29/04/2021	08:30	10	Deg C	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0053F	Temperature - Field	29/04/2021	09:10	9	Deg C	
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	29/04/2021	11:55	7.9	g O2/m³	
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	29/04/2021	10:40	7.8	g O2/m³	
	Karitane Bowls	D-0056F	Dissolved Oxygen - Field	29/04/2021	10:46	8.5	g O2/m³	
	Waikouaiti Golf Club	D-0056F	Dissolved Oxygen - Field	29/04/2021	12:20	7.5	g O2/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0056F	Dissolved Oxygen - Field	29/04/2021	09:30	7.2	g O2/m³	
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	29/04/2021	11:30	8.4	g O2/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:35	8	g O2/m³	
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	29/04/2021	09:15	8.3	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	29/04/2021	08:30	7.5	g O2/m³	
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	29/04/2021	09:10	8.4	g O2/m³	
	Karitane Puketeraki Marae 520 Apes Road	D-0058H	Free Available Chlorine	29/04/2021	11:05	0.58	g/m³	(.2 - 5)
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	29/04/2021	11:55	1.1	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	29/04/2021	10:40	1.1	g/m³	(.2 - 5)
	Karitane Bowls	D-0058H	Free Available Chlorine	29/04/2021	10:46	1.1	g/m³	(.2 - 5)
	Waikouaiti Golf Club	D-0058H	Free Available Chlorine	29/04/2021	12:20	0.85	g/m³	
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	D-0058H	Free Available Chlorine	29/04/2021	09:30	1	g/m³	(.2 - 5)
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	29/04/2021	11:30	1.1	g/m³	(.2 - 5)
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	29/04/2021	08:30	1.1	g/m³	(.2 - 5)
	Karitane Puketeraki Marae 520 Apes Road	D-0084	Turbidity	29/04/2021	11:05	0.33	NTU	
	Karitane Puketeraki Marae 520 Apes Road	D-1201	Sampling / Inspection 15 Mins	29/04/2021	11:05	Completed		
	Karitane Puketeraki Marae 520 Apes Road	D-1310	Temperature on arrival	29/04/2021	11:05	6.9	Deg C	
	Karitane Puketeraki Marae 520 Apes Road	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	29/04/2021	11:05	<1	MPN/100mL	(0 - 0)
	Karitane Puketeraki Marae 520 Apes Road	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	29/04/2021	11:05	<1	MPN/100ml	(0 - 0)
	Catchment - Waikouaiti River - Pump Station Intake	P1855	Aqueous Total Metal Digestion for ICPMS codes	29/04/2021	09:15	Completed		
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	29/04/2021	11:55	Completed		
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	29/04/2021	10:40	Completed		
	Karitane Bowls	P1859	Sample Filtration	29/04/2021	10:46	Completed		
	Waikouaiti Golf Club	P1859	Sample Filtration	29/04/2021	12:20	Completed		
	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd	P1859	Sample Filtration	29/04/2021	09:30	Completed		

	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	29/04/2021	11:30	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	29/04/2021	08:35	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	29/04/2021	09:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	29/04/2021	08:30	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	29/04/2021	09:10	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO001	Geosmin by SPME	29/04/2021	08:35	2.5	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO001	Geosmin by SPME	29/04/2021	09:15	2.7	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO001	Geosmin by SPME	29/04/2021	08:30	3.4	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO002	2-Methylisoborneol by SPME	29/04/2021	08:35	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO002	2-Methylisoborneol by SPME	29/04/2021	09:15	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO002	2-Methylisoborneol by SPME	29/04/2021	08:30	<1	ng/L	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	W-TO003	2,4,6-Trichloroanisole by SPME	29/04/2021	08:35	<1	ng/L	
	Catchment - Waikouaiti River - Pump Station Intake	W-TO003	2,4,6-Trichloroanisole by SPME	29/04/2021	09:15	<1	ng/L	
	Waikouaiti WTP - Post Treated Water Reservoir	W-TO003	2,4,6-Trichloroanisole by SPME	29/04/2021	08:30	<1	ng/L	
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	30/04/2021	11:20	7.9		(1 - 14)
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	30/04/2021	11:30	7.9		(1 - 14)
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	30/04/2021	11:25	7.8		(1 - 14)
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	30/04/2021	11:20	<6	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	30/04/2021	11:30	9	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	30/04/2021	11:25	21	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	30/04/2021	11:20	<1	mL/L	
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	30/04/2021	11:30	<1	mL/L	
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	30/04/2021	11:25	<1	mL/L	
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	30/04/2021	11:20	201	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	30/04/2021	11:30	211	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	30/04/2021	11:25	228	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	30/04/2021	11:15	71	g CaCO3/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	30/04/2021	11:10	69	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	30/04/2021	10:20	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	30/04/2021	10:45	72	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	30/04/2021	11:20	74	g CaCO3/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	30/04/2021	11:30	73	g CaCO3/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	30/04/2021	11:25	75	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	52	Alkalinity - Total	30/04/2021	10:15	72	g CaCO3/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	52	Alkalinity - Total	30/04/2021	10:10	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	52	Alkalinity - Total	30/04/2021	10:40	71	g CaCO3/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	52	Alkalinity - Total	30/04/2021	10:35	72	g CaCO3/m³	
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	30/04/2021	11:20	24.7	mS/m (246.9 x .1)	
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	30/04/2021	11:30	24.6	mS/m (246.3 x .1)	
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	30/04/2021	11:25	24.6	mS/m (246 x .1)	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	30/04/2021	11:15	20.4	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	30/04/2021	11:10	20	g/m³	
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	30/04/2021	10:20	20.2	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	30/04/2021	10:45	19.8	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	30/04/2021	11:20	20	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	30/04/2021	11:30	20	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	30/04/2021	11:25	19.9	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	0440D	Dissolved Inorganic Carbon	30/04/2021	10:15	20.3	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	0440D	Dissolved Inorganic Carbon	30/04/2021	10:10	19.7	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	0440D	Dissolved Inorganic Carbon	30/04/2021	10:40	20	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	0440D	Dissolved Inorganic Carbon	30/04/2021	10:35	20.3	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	30/04/2021	11:15	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	30/04/2021	11:20	21	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	30/04/2021	11:30	21.5	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	30/04/2021	11:25	21.2	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	30/04/2021	11:20	10.1	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	30/04/2021	11:30	10.4	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	30/04/2021	11:25	10.2	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	30/04/2021	11:20	0.008	g/m³	(.4 - .4)
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	30/04/2021	11:30	0.015	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	30/04/2021	11:25	0.018	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	30/04/2021	11:20	22.4	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	30/04/2021	11:30	22.9	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	30/04/2021	11:25	22.6	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	30/04/2021	11:20	10.8	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	30/04/2021	11:30	11	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	30/04/2021	11:25	11	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	30/04/2021	11:20	<0.005	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	30/04/2021	11:30	<0.005	g/m³	

	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	30/04/2021	11:25	<0.005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	30/04/2021	11:20	0.756	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	30/04/2021	11:30	1.47	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	30/04/2021	11:25	1.91	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	30/04/2021	11:20	<0.001	g/m³	(.01 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	30/04/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	30/04/2021	11:25	<0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	30/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	30/04/2021	11:30	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	30/04/2021	11:25	<0.0002	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	30/04/2021	11:20	0.0006	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	30/04/2021	11:30	0.0007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	30/04/2021	11:25	0.0007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	30/04/2021	11:20	0.1	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	30/04/2021	11:30	0.21	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	30/04/2021	11:25	0.27	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	30/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	30/04/2021	11:30	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	30/04/2021	11:25	<0.0005	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	30/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	30/04/2021	11:30	0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	30/04/2021	11:25	0.001	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	30/04/2021	11:20	0.003	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	30/04/2021	11:30	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	30/04/2021	11:25	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	30/04/2021	11:15	0.003	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	30/04/2021	11:10	0.006	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	30/04/2021	10:20	0.006	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	30/04/2021	10:45	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	30/04/2021	11:20	0.103	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	30/04/2021	11:30	0.074	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	30/04/2021	11:25	0.085	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6701	Aluminium - Dissolved	30/04/2021	10:15	0.007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6701	Aluminium - Dissolved	30/04/2021	10:10	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6701	Aluminium - Dissolved	30/04/2021	10:40	0.007	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6701	Aluminium - Dissolved	30/04/2021	10:35	0.007	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	30/04/2021	11:20	<0.001	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	30/04/2021	11:30	<0.001	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	30/04/2021	11:25	<0.001	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	30/04/2021	11:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	30/04/2021	11:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	30/04/2021	10:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	30/04/2021	10:45	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	30/04/2021	11:20	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	30/04/2021	11:30	<0.0002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	30/04/2021	11:25	<0.0002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6708	Cadmium - Dissolved	30/04/2021	10:15	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6708	Cadmium - Dissolved	30/04/2021	10:10	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6708	Cadmium - Dissolved	30/04/2021	10:40	<0.0002	g/m³	(.004 - .004)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6708	Cadmium - Dissolved	30/04/2021	10:35	<0.0002	g/m³	(.004 - .004)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	30/04/2021	11:15	0.0007	g/m³	(2 - 2)
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	30/04/2021	11:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	30/04/2021	10:20	0.0006	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	30/04/2021	10:45	0.0018	g/m³	(2 - 2)
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	30/04/2021	11:20	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	30/04/2021	11:30	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	30/04/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6713	Copper - Dissolved	30/04/2021	10:15	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6713	Copper - Dissolved	30/04/2021	10:10	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6713	Copper - Dissolved	30/04/2021	10:40	<0.0005	g/m³	(2 - 2)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6713	Copper - Dissolved	30/04/2021	10:35	<0.0005	g/m³	(2 - 2)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	30/04/2021	11:15	0.11	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	30/04/2021	11:10	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	30/04/2021	10:20	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	30/04/2021	10:45	<0.01	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	30/04/2021	11:20	<0.01	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	30/04/2021	11:30	<0.01	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	30/04/2021	11:25	<0.01	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6717	Iron - Dissolved	30/04/2021	10:15	<0.01	g/m³	

	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6717	Iron - Dissolved	30/04/2021	10:10	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6717	Iron - Dissolved	30/04/2021	10:40	<0.01	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6717	Iron - Dissolved	30/04/2021	10:35	<0.01	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	30/04/2021	11:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	30/04/2021	11:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	30/04/2021	10:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	30/04/2021	10:45	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	30/04/2021	11:20	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	30/04/2021	11:30	<0.0005	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	30/04/2021	11:25	<0.0005	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6718	Lead - Dissolved	30/04/2021	10:15	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6718	Lead - Dissolved	30/04/2021	10:10	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6718	Lead - Dissolved	30/04/2021	10:40	<0.0005	g/m³	(.005 - .01)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6718	Lead - Dissolved	30/04/2021	10:35	<0.0005	g/m³	(.005 - .01)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	30/04/2021	11:15	0.0052	g/m³	(.4 - .4)
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	30/04/2021	11:10	0.0007	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	30/04/2021	10:20	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	30/04/2021	10:45	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6721	Manganese - Dissolved	30/04/2021	10:15	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6721	Manganese - Dissolved	30/04/2021	10:10	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6721	Manganese - Dissolved	30/04/2021	10:40	<0.0005	g/m³	(.4 - .4)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6721	Manganese - Dissolved	30/04/2021	10:35	<0.0005	g/m³	(.4 - .4)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	30/04/2021	11:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	30/04/2021	11:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	30/04/2021	10:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	30/04/2021	10:45	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	30/04/2021	11:20	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	30/04/2021	11:30	0.0007	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	30/04/2021	11:25	0.0007	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6724	Nickel - Dissolved	30/04/2021	10:15	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6724	Nickel - Dissolved	30/04/2021	10:10	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6724	Nickel - Dissolved	30/04/2021	10:40	<0.0005	g/m³	(.08 - .08)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6724	Nickel - Dissolved	30/04/2021	10:35	<0.0005	g/m³	(.08 - .08)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	30/04/2021	11:15	<0.002	g/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	30/04/2021	11:10	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	30/04/2021	10:20	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	30/04/2021	10:45	0.004	g/m³	
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	30/04/2021	11:20	<0.002	g/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	30/04/2021	11:30	<0.002	g/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	30/04/2021	11:25	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	6738	Zinc - Dissolved	30/04/2021	10:15	<0.002	g/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	6738	Zinc - Dissolved	30/04/2021	10:10	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	6738	Zinc - Dissolved	30/04/2021	10:40	<0.002	g/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	6738	Zinc - Dissolved	30/04/2021	10:35	<0.002	g/m³	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	30/04/2021	11:15	7.8		
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	30/04/2021	11:10	7.8		
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	30/04/2021	10:20	7.9		
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	30/04/2021	10:45	7.9		
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	30/04/2021	11:20	7.9		
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	30/04/2021	11:30	7.9		
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	30/04/2021	11:25	7.9		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0001F	pH - Field	30/04/2021	10:15	8		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0001F	pH - Field	30/04/2021	10:10	8		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0001F	pH - Field	30/04/2021	10:40	7.9		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0001F	pH - Field	30/04/2021	10:35	7.9		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	30/04/2021	11:15	10	Deg C	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	30/04/2021	11:10	10.3	Deg C	
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	30/04/2021	10:20	12.2	Deg C	
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	30/04/2021	10:45	12.3	Deg C	
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	30/04/2021	11:20	11	Deg C	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	30/04/2021	11:30	10.1	Deg C	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	30/04/2021	11:25	10.1	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0053F	Temperature - Field	30/04/2021	10:15	12.2	Deg C	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0053F	Temperature - Field	30/04/2021	10:10	12.3	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0053F	Temperature - Field	30/04/2021	10:40	12.4	Deg C	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0053F	Temperature - Field	30/04/2021	10:35	12.5	Deg C	
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	30/04/2021	11:15	8.1	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	30/04/2021	11:10	8.2	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:20	7.7	g O2/m³	

	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:45	7.6	g O2/m³	
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	30/04/2021	11:20	8.9	g O2/m³	
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	30/04/2021	11:30	9	g O2/m³	
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	30/04/2021	11:25	8.9	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:15	8.1	g O2/m³	
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:10	7.5	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:40	7.8	g O2/m³	
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0056F	Dissolved Oxygen - Field	30/04/2021	10:35	7.7	g O2/m³	
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	30/04/2021	11:10	0.59	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	30/04/2021	10:20	0.54	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	30/04/2021	10:45	0.86	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	D-0058H	Free Available Chlorine	30/04/2021	10:15	0.57	g/m³	(.2 - 5)
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	D-0058H	Free Available Chlorine	30/04/2021	10:10	0.4	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	D-0058H	Free Available Chlorine	30/04/2021	10:40	0.85	g/m³	(.2 - 5)
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	D-0058H	Free Available Chlorine	30/04/2021	10:35	0.83	g/m³	(.2 - 5)
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	30/04/2021	11:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	30/04/2021	10:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	30/04/2021	11:15	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1205	Sampling / Inspection 2 hours	30/04/2021	10:45	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	30/04/2021	11:15	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	30/04/2021	11:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	30/04/2021	10:20	Completed		
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	30/04/2021	10:45	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	30/04/2021	11:20	Completed		
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	30/04/2021	11:30	Completed		
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	30/04/2021	11:25	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap	P1859	Sample Filtration	30/04/2021	10:15	Completed		
	Waikouaiti SS - 210 Edinburgh St - Plastic tap - Pre Flush	P1859	Sample Filtration	30/04/2021	10:10	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic tap	P1859	Sample Filtration	30/04/2021	10:40	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Plastic Tap - Preflush	P1859	Sample Filtration	30/04/2021	10:35	Completed		
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	30/04/2021	09:50	0.9	g/m³	(.2 - 5)
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	30/04/2021	09:50	1	g/m³	
	Karitane SS - 99 Stornoway St	D-0084	Turbidity	30/04/2021	09:50	0.04	NTU	
	Karitane SS - 99 Stornoway St	D-1310	Temperature on arrival	30/04/2021	09:50	5.3	Deg C	
	Karitane SS - 99 Stornoway St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	30/04/2021	09:50	<1	MPN/100mL	(0 - 0)
	Karitane SS - 99 Stornoway St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	30/04/2021	09:50	<1	MPN/100ml	(0 - 0)

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
	Waikouaiti Pumping Main	1	pH	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	52	Alkalinity - Total	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	55	Conductivity at 25°C - mS/m unit	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	605	Nitrate - Nitrogen - Add P1859 Filtration	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	1024	Total Dissolved Solids by Evaporation	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	1610	Calcium - Acid Soluble by OES	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	1622	Magnesium - Acid Soluble by OES	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	1642	Total Hardness by OES requires Ca and Mg by ICPOES	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	1644	Calcium Hardness by OES requires Ca by ICPOES	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	2088	Dissolved Reactive Phosphorus - Add P1859 Filtration	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	P1859	Sample Filtration	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH001	2,4-D in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH004	2,4-DB in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH007	2,4,5-T in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH010	Acifluorfen in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH013	Bentazone in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH016	Bromoxynil in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH019	Dicamba in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH022	Dichlorprop in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH025	Dinoseb in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH028	Fenoprop in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH031	MCPA in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH034	MCPB in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH037	Mecoprop in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH040	Pentachlorophenol in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH043	Picloram in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-AH046	Triclopyr in water	01/05/2021	00:00:00			
	Waikouaiti Pumping Main	W-PRZ001	Pesticide 1080	01/05/2021	00:00:00			
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	01/05/2021	08:57:16			

	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:30			

	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	01/05/2021	08:57:07	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:57:28			

	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:57:30			

	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:57:07			

	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	01/05/2021	08:57:31			
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	01/05/2021	08:57:25			
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	01/05/2021	08:57:25			
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	01/05/2021	08:57:24			

	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	01/05/2021	08:57:24			
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	01/05/2021	08:57:15			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	01/05/2021	08:57:24			
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	01/05/2021	08:57:31			

	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	01/05/2021	08:57:12			

	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	01/05/2021	08:57:24			

	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:57:07	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	01/05/2021	08:57:09	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:57:10	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	01/05/2021	08:57:10	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:57:11	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	01/05/2021	08:57:12	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	01/05/2021	08:57:13	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	01/05/2021	08:57:15	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	01/05/2021	08:57:16	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	01/05/2021	08:57:18	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	01/05/2021	08:57:21	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	01/05/2021	08:57:24	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:57:28	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	01/05/2021	08:57:29	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:57:30	Completed		
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	01/05/2021	08:57:31	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	01/05/2021	08:57:09			

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0001F	pH - Field	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0001F	pH - Field	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0001F	pH - Field	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	01/05/2021	08:57:12			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	01/05/2021	08:57:21			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	01/05/2021	08:57:29			

	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	01/05/2021	08:57:31			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	01/05/2021	08:57:07	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/05/2021	08:57:10			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	01/05/2021	08:57:07			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	01/05/2021	08:57:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	01/05/2021	08:57:10			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	01/05/2021	08:57:10			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	01/05/2021	08:57:11			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	01/05/2021	08:57:12			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	01/05/2021	08:57:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/05/2021	08:57:15			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	01/05/2021	08:57:16			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	01/05/2021	08:57:18			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/05/2021	08:57:21			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	01/05/2021	08:57:24			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	01/05/2021	08:57:28			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	01/05/2021	08:57:29			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	01/05/2021	08:57:30			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	01/05/2021	08:57:31			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	01/05/2021	08:57:25			
	Waikouaiti SS - 192 Main Rd - Preflush	2	Suspended Solids - Total	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	2	Suspended Solids - Total	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	2	Suspended Solids - Total	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	2	Suspended Solids - Total	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	2	Suspended Solids - Total	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	2	Suspended Solids - Total	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	2	Suspended Solids - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	2	Suspended Solids - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	2	Suspended Solids - Total	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	2	Suspended Solids - Total	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	2	Suspended Solids - Total	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	2	Suspended Solids - Total	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	2	Suspended Solids - Total	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	2	Suspended Solids - Total	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	2	Suspended Solids - Total	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	52	Alkalinity - Total	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	52	Alkalinity - Total	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	52	Alkalinity - Total	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	52	Alkalinity - Total	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	52	Alkalinity - Total	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	52	Alkalinity - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	52	Alkalinity - Total	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	52	Alkalinity - Total	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	52	Alkalinity - Total	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	52	Alkalinity - Total	01/05/2021	08:58:21			

	Waikouaiti SS - 319 Bendigo Rd - Preflush	52	Alkalinity - Total	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	602	Chloride - Add P1859 Filtration	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	607	Sulphate - Add P1859 Filtration	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:10			

	Karitane SS - 99 Stornoway St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	1024	Total Dissolved Solids by Evaporation	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	1214	Surcharge Fee	01/05/2021	08:58:08	$100		
	Waikouaiti SS - 192 Main Rd - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6001	Aluminium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6001	Aluminium - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6001	Aluminium - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6001	Aluminium - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6001	Aluminium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6001	Aluminium - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6001	Aluminium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6001	Aluminium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6003	Arsenic - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6003	Arsenic - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6003	Arsenic - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6003	Arsenic - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6003	Arsenic - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6003	Arsenic - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6003	Arsenic - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6003	Arsenic - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6008	Cadmium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6008	Cadmium - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6008	Cadmium - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6008	Cadmium - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6008	Cadmium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6008	Cadmium - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6008	Cadmium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6008	Cadmium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6010	Calcium - Acid Soluble	01/05/2021	08:58:09			

	Waikouaiti SS - 210 Edinburgh St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6010	Calcium - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6010	Calcium - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6010	Calcium - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6010	Calcium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6010	Calcium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6010	Calcium - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6010	Calcium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6010	Calcium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6013	Copper - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6013	Copper - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6013	Copper - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6013	Copper - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6013	Copper - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6013	Copper - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6013	Copper - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6013	Copper - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6017	Iron - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6017	Iron - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6017	Iron - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6017	Iron - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6017	Iron - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6017	Iron - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6017	Iron - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6017	Iron - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6018	Lead - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6018	Lead - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6018	Lead - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6018	Lead - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6018	Lead - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6018	Lead - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6018	Lead - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6018	Lead - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6020	Magnesium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6020	Magnesium - Acid Soluble	01/05/2021	08:58:10			

	Karitane SS - 99 Stornoway St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6020	Magnesium - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6020	Magnesium - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6020	Magnesium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6020	Magnesium - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6020	Magnesium - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6020	Magnesium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6020	Magnesium - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6021	Manganese - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6021	Manganese - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6021	Manganese - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6021	Manganese - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6021	Manganese - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6021	Manganese - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6021	Manganese - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6021	Manganese - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6021	Manganese - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6022	Mercury - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6022	Mercury - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6022	Mercury - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6022	Mercury - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6022	Mercury - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6022	Mercury - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6022	Mercury - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6022	Mercury - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6022	Mercury - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6024	Nickel - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6024	Nickel - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6024	Nickel - Acid Soluble	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	6024	Nickel - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6024	Nickel - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6024	Nickel - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6024	Nickel - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6024	Nickel - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6038	Zinc - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6038	Zinc - Acid Soluble	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6038	Zinc - Acid Soluble	01/05/2021	08:58:11			

	Waikouaiti WTP - Containerised Plant Filtrate	6038	Zinc - Acid Soluble	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6038	Zinc - Acid Soluble	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6038	Zinc - Acid Soluble	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6038	Zinc - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6038	Zinc - Acid Soluble	01/05/2021	08:58:23			
	Waikouaiti WTP - Settling Ponds Sediment	6201	Aluminium - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6203	Arsenic - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6208	Cadmium - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6210	Calcium - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6213	Copper - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6217	Iron - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6218	Lead - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6220	Magnesium - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6221	Manganese - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6222	Mercury - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6224	Nickel - Total	01/05/2021	08:58:20			
	Waikouaiti WTP - Settling Ponds Sediment	6238	Zinc - Total	01/05/2021	08:58:20			
	Catchment - Waikouaiti River - Pump Station Intake	6601	Aluminium - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6601	Aluminium - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6601	Aluminium - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6603	Arsenic - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6603	Arsenic - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6603	Arsenic - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6608	Cadmium - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6608	Cadmium - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6608	Cadmium - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6610	Calcium - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6610	Calcium - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6610	Calcium - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6613	Copper - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6613	Copper - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6613	Copper - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6617	Iron - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6617	Iron - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6617	Iron - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6618	Lead - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6618	Lead - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6618	Lead - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6620	Magnesium - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6620	Magnesium - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6620	Magnesium - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6621	Manganese - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6621	Manganese - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6621	Manganese - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6622	Mercury - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6622	Mercury - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6622	Mercury - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6624	Nickel - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6624	Nickel - Total	01/05/2021	08:58:14			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6624	Nickel - Total	01/05/2021	08:58:19			
	Catchment - Waikouaiti River - Pump Station Intake	6638	Zinc - Total	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6638	Zinc - Total	01/05/2021	08:58:14			

	Waikouaiti WTP - Waikouaiti River ? Upstream	6638	Zinc - Total	01/05/2021	08:58:19			
	Waikouaiti SS - 192 Main Rd - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6701	Aluminium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6701	Aluminium - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6701	Aluminium - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6701	Aluminium - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6701	Aluminium - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6701	Aluminium - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6701	Aluminium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6703	Arsenic - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6703	Arsenic - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6703	Arsenic - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6703	Arsenic - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6703	Arsenic - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6703	Arsenic - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6703	Arsenic - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6703	Arsenic - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6703	Arsenic - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6703	Arsenic - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6703	Arsenic - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6708	Cadmium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6708	Cadmium - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6708	Cadmium - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6708	Cadmium - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6708	Cadmium - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6708	Cadmium - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6708	Cadmium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6710	Calcium - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6710	Calcium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6710	Calcium - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:58:11			

	Karitane SS - 99 Stornoway St	6710	Calcium - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6710	Calcium - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6710	Calcium - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6710	Calcium - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6710	Calcium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6710	Calcium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6710	Calcium - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6710	Calcium - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6710	Calcium - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6710	Calcium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6710	Calcium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6713	Copper - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6713	Copper - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6713	Copper - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6713	Copper - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6713	Copper - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6713	Copper - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6713	Copper - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6713	Copper - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6713	Copper - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6713	Copper - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6713	Copper - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6717	Iron - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6717	Iron - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6717	Iron - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6717	Iron - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6717	Iron - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6717	Iron - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6717	Iron - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6717	Iron - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6717	Iron - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6717	Iron - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6717	Iron - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6718	Lead - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6718	Lead - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6718	Lead - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6718	Lead - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6718	Lead - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6718	Lead - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6718	Lead - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	01/05/2021	08:58:16			

	Waikouaiti WTP - Waikouaiti River ? Upstream	6718	Lead - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6718	Lead - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6718	Lead - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6718	Lead - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6720	Magnesium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6720	Magnesium - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6720	Magnesium - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6720	Magnesium - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6720	Magnesium - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6720	Magnesium - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6720	Magnesium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6720	Magnesium - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6720	Magnesium - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6720	Magnesium - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6720	Magnesium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6720	Magnesium - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6721	Manganese - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6721	Manganese - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6721	Manganese - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6721	Manganese - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6721	Manganese - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6721	Manganese - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6721	Manganese - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6721	Manganese - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6721	Manganese - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6721	Manganese - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6722	Mercury - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6722	Mercury - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6722	Mercury - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6722	Mercury - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6722	Mercury - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6722	Mercury - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6722	Mercury - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6722	Mercury - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6722	Mercury - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6722	Mercury - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6722	Mercury - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6722	Mercury - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6722	Mercury - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6722	Mercury - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6724	Nickel - Dissolved	01/05/2021	08:58:08			

	Waikouaiti SS - 192 Main Rd	6724	Nickel - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6724	Nickel - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6724	Nickel - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6724	Nickel - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6724	Nickel - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6724	Nickel - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6724	Nickel - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6724	Nickel - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	6738	Zinc - Dissolved	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	6738	Zinc - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	6738	Zinc - Dissolved	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	6738	Zinc - Dissolved	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	6738	Zinc - Dissolved	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	6738	Zinc - Dissolved	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	6738	Zinc - Dissolved	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	6738	Zinc - Dissolved	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	6738	Zinc - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:58:08	Completed		
	Waikouaiti SS - 192 Main Rd	9402	ICP-MS - 2 Elements	01/05/2021	08:58:09	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:58:09	Completed		
	Waikouaiti SS - 210 Edinburgh St	9402	ICP-MS - 2 Elements	01/05/2021	08:58:10	Completed		
	Karitane SS - 99 Stornoway St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:58:11	Completed		
	Karitane SS - 99 Stornoway St	9402	ICP-MS - 2 Elements	01/05/2021	08:58:11	Completed		
	Catchment - Waikouaiti River - Pump Station Intake	9402	ICP-MS - 2 Elements	01/05/2021	08:58:13	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	9402	ICP-MS - 2 Elements	01/05/2021	08:58:14	Completed		
	Waikouaiti WTP - Containerised Plant Filtrate	9402	ICP-MS - 2 Elements	01/05/2021	08:58:15	Completed		
	Waikouaiti WTP - Supernatant Tube Settler	9402	ICP-MS - 2 Elements	01/05/2021	08:58:16	Completed		
	Waikouaiti WTP - Post Treated Water Reservoir	9402	ICP-MS - 2 Elements	01/05/2021	08:58:16	Completed		
	Waikouaiti WTP - Waikouaiti River ? Upstream	9402	ICP-MS - 2 Elements	01/05/2021	08:58:19	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:58:20	Completed		
	Waikouaiti SS - Intersection Beach St/Stewart St	9402	ICP-MS - 2 Elements	01/05/2021	08:58:21	Completed		
	Waikouaiti SS - 319 Bendigo Rd - Preflush	9402	ICP-MS - 2 Elements	01/05/2021	08:58:23	Completed		
	Waikouaiti SS - 319 Bendigo Rd	9402	ICP-MS - 2 Elements	01/05/2021	08:58:23	Completed		
	Waikouaiti SS - 192 Main Rd - Preflush	D-0001F	pH - Field	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	D-0001F	pH - Field	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0001F	pH - Field	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0001F	pH - Field	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	D-0001F	pH - Field	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	D-0001F	pH - Field	01/05/2021	08:58:13			

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0001F	pH - Field	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0001F	pH - Field	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0001F	pH - Field	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0001F	pH - Field	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0001F	pH - Field	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	D-0058H	Free Available Chlorine	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	D-0058H	Free Available Chlorine	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0058H	Free Available Chlorine	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	D-0058H	Free Available Chlorine	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0058H	Free Available Chlorine	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0058H	Free Available Chlorine	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	D-0066H	Total Chlorine	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	D-0066H	Total Chlorine	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-0066H	Total Chlorine	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	D-0066H	Total Chlorine	01/05/2021	08:58:11			
	Waikouaiti WTP - Containerised Plant Filtrate	D-0066H	Total Chlorine	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	D-0066H	Total Chlorine	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0066H	Total Chlorine	01/05/2021	08:58:16			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	D-0066H	Total Chlorine	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	D-0066H	Total Chlorine	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	D-0066H	Total Chlorine	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	D-0066H	Total Chlorine	01/05/2021	08:58:23			
	Waikouaiti SS - 192 Main Rd - Preflush	D-1208	Sampling / Inspection 5 hours	01/05/2021	08:58:08	Completed		
	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-M0411A	E. coli by Colilert-18-MPN 51 Wells - Drinking Water	01/05/2021	08:58:10			

	Waikouaiti SS - 210 Edinburgh St - Preflush	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	D-M0412A	Total Coliforms by Colilert-18 MPN-51 Wells-Drinking Water	01/05/2021	08:58:10			
	Waikouaiti SS - 192 Main Rd - Preflush	P1859	Sample Filtration	01/05/2021	08:58:08			
	Waikouaiti SS - 192 Main Rd	P1859	Sample Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St - Preflush	P1859	Sample Filtration	01/05/2021	08:58:09			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	01/05/2021	08:58:10			
	Karitane SS - 99 Stornoway St - Preflush	P1859	Sample Filtration	01/05/2021	08:58:11			
	Karitane SS - 99 Stornoway St	P1859	Sample Filtration	01/05/2021	08:58:11			
	Catchment - Waikouaiti River - Pump Station Intake	P1859	Sample Filtration	01/05/2021	08:58:13			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/05/2021	08:58:14			
	Waikouaiti WTP - Containerised Plant Filtrate	P1859	Sample Filtration	01/05/2021	08:58:15			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/05/2021	08:58:16			
	Waikouaiti WTP - Waikouaiti River ? Upstream	P1859	Sample Filtration	01/05/2021	08:58:19			
	Waikouaiti SS - Intersection Beach St/Stewart St - Preflush	P1859	Sample Filtration	01/05/2021	08:58:20			
	Waikouaiti SS - Intersection Beach St/Stewart St	P1859	Sample Filtration	01/05/2021	08:58:21			
	Waikouaiti SS - 319 Bendigo Rd - Preflush	P1859	Sample Filtration	01/05/2021	08:58:23			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	01/05/2021	08:58:23			
	Waikouaiti WTP - Settling Ponds Sediment	P1861	Metals Digestion - Soil/Sludge	01/05/2021	08:58:20			
	Waikouaiti WTP - Supernatant Tube Settler	1	pH	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1	pH	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1	pH	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	2	Suspended Solids - Total	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	2	Suspended Solids - Total	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	2	Suspended Solids - Total	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	9	Settleable Solids	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	9	Settleable Solids	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	9	Settleable Solids	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	49	Total Solids - g/m3 units	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	49	Total Solids - g/m3 units	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	49	Total Solids - g/m3 units	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	52	Alkalinity - Total	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	52	Alkalinity - Total	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	52	Alkalinity - Total	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	52	Alkalinity - Total	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	52	Alkalinity - Total	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	52	Alkalinity - Total	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	52	Alkalinity - Total	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	55	Conductivity at 25°C - mS/m unit	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	55	Conductivity at 25°C - mS/m unit	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	0440D	Dissolved Inorganic Carbon	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	1214	Surcharge Fee	01/05/2021	09:02:47	$100		
	Waikouaiti WTP - Supernatant Tube Settler	1610	Calcium - Acid Soluble by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1610	Calcium - Acid Soluble by OES	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1610	Calcium - Acid Soluble by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	1622	Magnesium - Acid Soluble by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	01/05/2021	09:02:51			

	Waikouaiti WTP-Middle Sample Tube Settler	1622	Magnesium - Acid Soluble by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	1623	Manganese - Acid Soluble by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1623	Manganese - Acid Soluble by OES	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1623	Manganese - Acid Soluble by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	1810	Calcium - Dissolved by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1810	Calcium - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1810	Calcium - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	1822	Magnesium - Dissolved by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1822	Magnesium - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1822	Magnesium - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	1823	Manganese - Dissolved by OES	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	1823	Manganese - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	1823	Manganese - Dissolved by OES	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6001	Aluminium - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6001	Aluminium - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6001	Aluminium - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6003	Arsenic - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6003	Arsenic - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6003	Arsenic - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6008	Cadmium - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6008	Cadmium - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6008	Cadmium - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6013	Copper - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6013	Copper - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6013	Copper - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6017	Iron - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6017	Iron - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6017	Iron - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6018	Lead - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6018	Lead - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6018	Lead - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6024	Nickel - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6024	Nickel - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6024	Nickel - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6038	Zinc - Acid Soluble	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6038	Zinc - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6038	Zinc - Acid Soluble	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6701	Aluminium - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6701	Aluminium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6701	Aluminium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6701	Aluminium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6701	Aluminium - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6701	Aluminium - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6701	Aluminium - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Supernatant Tube Settler	6703	Arsenic - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6703	Arsenic - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6703	Arsenic - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6708	Cadmium - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6708	Cadmium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6708	Cadmium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6708	Cadmium - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6708	Cadmium - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6708	Cadmium - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6708	Cadmium - Dissolved	01/05/2021	09:02:51			

	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6713	Copper - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6713	Copper - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6713	Copper - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6713	Copper - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6713	Copper - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6713	Copper - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6713	Copper - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6717	Iron - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6717	Iron - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6717	Iron - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6717	Iron - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6717	Iron - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6717	Iron - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6717	Iron - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6718	Lead - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6718	Lead - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6718	Lead - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6718	Lead - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6718	Lead - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6718	Lead - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6718	Lead - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6721	Manganese - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6721	Manganese - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6721	Manganese - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6721	Manganese - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6724	Nickel - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6724	Nickel - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6724	Nickel - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6724	Nickel - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6724	Nickel - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6724	Nickel - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6724	Nickel - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	6738	Zinc - Dissolved	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	6738	Zinc - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	6738	Zinc - Dissolved	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	6738	Zinc - Dissolved	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	6738	Zinc - Dissolved	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	6738	Zinc - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	6738	Zinc - Dissolved	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0001F	pH - Field	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0001F	pH - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	D-0001F	pH - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	D-0001F	pH - Field	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0001F	pH - Field	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	D-0001F	pH - Field	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	D-0001F	pH - Field	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0053F	Temperature - Field	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0053F	Temperature - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	D-0053F	Temperature - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	D-0053F	Temperature - Field	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0053F	Temperature - Field	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	D-0053F	Temperature - Field	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	D-0053F	Temperature - Field	01/05/2021	09:02:51			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:47			

	Waikouaiti WTP - Post Treated Water Reservoir	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	D-0056F	Dissolved Oxygen - Field	01/05/2021	09:02:51			
	Waikouaiti WTP - Post Treated Water Reservoir	D-0058H	Free Available Chlorine	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	D-0058H	Free Available Chlorine	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	D-0058H	Free Available Chlorine	01/05/2021	09:02:48			
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1202	Sampling / Inspection 30 Mins	01/05/2021	09:02:47	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1202	Sampling / Inspection 30 Mins	01/05/2021	09:02:48	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	D-1205	Sampling / Inspection 2 hours	01/05/2021	09:02:47	Completed		
	Waikouaiti SS - 319 Bendigo Rd	D-1205	Sampling / Inspection 2 hours	01/05/2021	09:02:48	Completed		
	Waikouaiti WTP - Raw Water Reservoir Feed to Plant	P1859	Sample Filtration	01/05/2021	09:02:47			
	Waikouaiti WTP - Post Treated Water Reservoir	P1859	Sample Filtration	01/05/2021	09:02:48			
	Waikouaiti SS - 210 Edinburgh St	P1859	Sample Filtration	01/05/2021	09:02:48			
	Waikouaiti SS - 319 Bendigo Rd	P1859	Sample Filtration	01/05/2021	09:02:48			
	Waikouaiti WTP - Supernatant Tube Settler	P1859	Sample Filtration	01/05/2021	09:02:50			
	Waikouaiti WTP-Upper Sample Tube Settler	P1859	Sample Filtration	01/05/2021	09:02:51			
	Waikouaiti WTP-Middle Sample Tube Settler	P1859	Sample Filtration	01/05/2021	09:02:51			
10	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	01/05/2021	10:35	<0.0005	mg/l	
10	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	01/05/2021	10:40	<0.0005	mg/l	
10	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	01/05/2021	10:55	<0.0005	mg/l	
10	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	01/05/2021	10:55	<0.0005	mg/l	
10	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	01/05/2021	12:00	<0.0005	mg/l	
10	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	01/05/2021	12:20	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	02/05/2021	08:35	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	02/05/2021	08:40	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	02/05/2021	08:45	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	02/05/2021	08:45	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	02/05/2021	09:15	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	02/05/2021	09:30	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	03/05/2021	12:44	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	03/05/2021	12:44	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	03/05/2021	12:46	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	03/05/2021	12:46	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	03/05/2021	13:01	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	03/05/2021	13:01	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	03/05/2021	13:03	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	03/05/2021	13:03	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	03/05/2021	13:48	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	03/05/2021	14:04	<0.0005	mg/l	
8	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	04/05/2021	13:04	<0.0005	mg/l	
8	Karitane Bowls		Lead - Acid Soluble	04/05/2021	13:06	<0.0005	mg/l	
8	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	04/05/2021	13:07	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	04/05/2021	13:09	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	04/05/2021	13:09	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	04/05/2021	13:09	<0.0005	mg/l	
2	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	04/05/2021	13:11	<0.0005	mg/l	
2	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	04/05/2021	13:11	<0.001	mg/l	
8	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	04/05/2021	13:12	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	04/05/2021	13:13	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	04/05/2021	13:14	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	04/05/2021	13:16	<0.0005	mg/l	

3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	04/05/2021	13:16	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	04/05/2021	13:17	0.0007	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	04/05/2021	13:17	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	04/05/2021	13:18	0.0007	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	04/05/2021	13:18	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	04/05/2021	13:48	<0.0005	mg/l	
4	Waikouaiti Golf Club		Lead - Acid Soluble	04/05/2021	14:04	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	04/05/2021	14:22	<0.0005	mg/l	
8	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	04/05/2021	14:38	<0.0005	mg/l	
8	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	04/05/2021	15:05	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	05/05/2021	10:57	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	05/05/2021	11:01	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	05/05/2021	11:09	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	05/05/2021	11:09	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	05/05/2021	11:16	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	05/05/2021	11:16	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	05/05/2021	11:22	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	05/05/2021	11:22	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	05/05/2021	11:57	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	05/05/2021	12:17	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	06/05/2021	07:20	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	06/05/2021	07:33	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	06/05/2021	07:59	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	06/05/2021	08:03	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	06/05/2021	08:10	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	06/05/2021	08:10	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	06/05/2021	08:14	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	06/05/2021	08:14	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	06/05/2021	08:18	<0.0005	mg/l	
3	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	06/05/2021	08:18	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	07/05/2021	10:30	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	07/05/2021	10:50	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	07/05/2021	10:50	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	07/05/2021	11:30	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	07/05/2021	11:35	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	07/05/2021	12:00	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	09/05/2021	10:40	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	09/05/2021	10:53	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	09/05/2021	11:06	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	09/05/2021	11:06	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	09/05/2021	11:38	<0.0005	mg/l	
8	Waikouaiti Golf Club		Lead - Acid Soluble	09/05/2021	13:04	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	09/05/2021	09:38	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	09/05/2021	09:41	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	09/05/2021	09:46	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	09/05/2021	09:46	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	09/05/2021	10:05	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	09/05/2021	10:16	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	10/05/2021	13:09	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	10/05/2021	13:09	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	10/05/2021	13:13	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	10/05/2021	13:16	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	10/05/2021	13:38	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	10/05/2021	13:54	<0.0005	mg/l	

4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	11/05/2021	13:19	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	11/05/2021	13:31	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	11/05/2021	13:55	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	11/05/2021	13:56	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	11/05/2021	14:01	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	11/05/2021	14:01	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	12/05/2021	10:11	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	12/05/2021	10:11	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	12/05/2021	10:12	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	12/05/2021	10:12	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	12/05/2021	10:32	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	12/05/2021	10:45	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	13/05/2021	10:54	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	13/05/2021	10:54	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	13/05/2021	10:55	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	13/05/2021	11:01	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	13/05/2021	11:02	<0.0005	mg/l	
4	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	13/05/2021	11:14	<0.0005	mg/l	
4	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	13/05/2021	11:14	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	13/05/2021	11:17	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	13/05/2021	11:17	<0.0005	mg/l	
4	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	13/05/2021	11:19	<0.0005	mg/l	
4	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	13/05/2021	11:19	<0.0005	mg/l	
7	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	13/05/2021	11:32	<0.0005	mg/l	
4	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	13/05/2021	11:35	<0.0005	mg/l	
4	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	13/05/2021	11:35	<0.001	mg/l	
7	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	13/05/2021	11:49	<0.0005	mg/l	
7	Karitane Bowls		Lead - Acid Soluble	13/05/2021	12:18	<0.0005	mg/l	
7	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	13/05/2021	12:22	<0.0005	mg/l	
7	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	13/05/2021	12:51	<0.0005	mg/l	
7	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	13/05/2021	13:16	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	13/05/2021	13:40	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	13/05/2021	14:09	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	14/05/2021	10:55	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	14/05/2021	11:05	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	14/05/2021	11:22	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	14/05/2021	11:22	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	14/05/2021	11:59	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	14/05/2021	12:27	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	15/05/2021	09:53	<0.0005	mg/l	
4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	15/05/2021	10:02	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	15/05/2021	10:14	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	15/05/2021	10:14	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	15/05/2021	11:01	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	15/05/2021	11:28	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	16/05/2021	08:45	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	16/05/2021	08:50	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	16/05/2021	08:50	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	16/05/2021	09:00	<0.0005	mg/l	
8	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	16/05/2021	09:00	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	16/05/2021	09:10	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	16/05/2021	09:20	<0.0005	mg/l	
4	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	17/05/2021	12:12	<0.0005	mg/l	
4	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	17/05/2021	12:23	<0.0005	mg/l	

4	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	17/05/2021	12:44	<0.0005	mg/l	
4	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	17/05/2021	12:47	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	17/05/2021	12:54	<0.0005	mg/l	
1	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	17/05/2021	12:54	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	18/05/2021	11:44	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	18/05/2021	11:48	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	18/05/2021	11:52	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	18/05/2021	11:52	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	18/05/2021	12:23	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	18/05/2021	12:32	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	19/05/2021	10:27	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	19/05/2021	10:35	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	19/05/2021	10:59	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	19/05/2021	11:10	<0.0005	mg/l	
3	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	20/05/2021	10:34	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	20/05/2021	10:38	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	20/05/2021	10:38	<0.0005	mg/l	
3	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	20/05/2021	10:57	<0.0005	mg/l	
3	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	20/05/2021	10:57	<0.001	mg/l	
3	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	20/05/2021	10:59	<0.0005	mg/l	
7	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	20/05/2021	11:14	<0.0005	mg/l	
7	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	20/05/2021	11:29	<0.0005	mg/l	
7	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	20/05/2021	11:58	<0.0005	mg/l	
2	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	20/05/2021	12:06	<0.0005	mg/l	
7	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	20/05/2021	12:31	<0.0005	mg/l	
2	Waikouaiti Golf Club		Lead - Acid Soluble	20/05/2021	12:32	<0.0005	mg/l	
7	Karitane Bowls		Lead - Acid Soluble	20/05/2021	13:35	<0.0005	mg/l	
7	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	20/05/2021	13:42	0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	21/05/2021	10:38	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	21/05/2021	10:41	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	21/05/2021	10:45	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	21/05/2021	10:45	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	21/05/2021	11:10	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	21/05/2021	11:19	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	22/05/2021	10:42	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	22/05/2021	11:10	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	22/05/2021	11:10	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	22/05/2021	11:10	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	22/05/2021	11:46	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	22/05/2021	12:08	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	23/05/2021	09:08	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	23/05/2021	09:15	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	23/05/2021	09:21	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	23/05/2021	09:21	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	23/05/2021	09:41	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	23/05/2021	09:57	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	24/05/2021	09:58	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	24/05/2021	10:01	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	24/05/2021	10:05	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	24/05/2021	10:05	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	24/05/2021	10:25	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	24/05/2021	10:35	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	25/05/2021	10:22	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	25/05/2021	10:22	<0.001	mg/l	

5	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	25/05/2021	10:23	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	25/05/2021	10:36	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	25/05/2021	10:36	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	25/05/2021	10:37	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	25/05/2021	10:40	<0.0005	mg/l	
5	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	25/05/2021	10:41	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	25/05/2021	10:52	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	25/05/2021	10:52	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	25/05/2021	10:53	0.001	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	25/05/2021	10:53	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	25/05/2021	10:53	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	25/05/2021	10:53	<0.0005	mg/l	
7	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	25/05/2021	11:11	<0.0005	mg/l	
7	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	25/05/2021	11:37	<0.0005	mg/l	
7	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	25/05/2021	12:01	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	25/05/2021	12:17	<0.0005	mg/l	
7	Waikouaiti Golf Club		Lead - Acid Soluble	25/05/2021	12:32	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	25/05/2021	12:43	<0.0005	mg/l	
7	Karitane Bowls		Lead - Acid Soluble	25/05/2021	13:37	<0.0005	mg/l	
7	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	25/05/2021	13:44	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	26/05/2021	13:32	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	26/05/2021	13:44	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	26/05/2021	14:10	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	26/05/2021	14:13	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	26/05/2021	14:18	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	26/05/2021	14:18	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	27/05/2021	12:22	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	27/05/2021	12:40	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	27/05/2021	13:11	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	27/05/2021	13:11	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	27/05/2021	14:01	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	27/05/2021	14:04	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	28/05/2021	11:12	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	28/05/2021	11:19	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	28/05/2021	11:28	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	28/05/2021	11:28	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	28/05/2021	11:49	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	28/05/2021	11:59	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	29/05/2021	09:56	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	29/05/2021	10:05	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	29/05/2021	10:15	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	29/05/2021	10:15	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	29/05/2021	10:53	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	29/05/2021	11:10	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	30/05/2021	10:00	<0.0005	mg/l	
7	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	30/05/2021	10:15	<0.0005	mg/l	
7	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	30/05/2021	10:20	0.002	mg/l	
7	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	30/05/2021	10:20	<0.0005	mg/l	
7	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	30/05/2021	10:30	<0.0005	mg/l	
7	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	30/05/2021	10:40	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	31/05/2021	12:30	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	31/05/2021	12:34	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	31/05/2021	12:41	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	31/05/2021	12:41	<0.0005	mg/l	

3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	31/05/2021	13:04	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	31/05/2021	13:16	<0.0005	mg/l	

Sample ID/Notes	Sample Point	Test Code	Description	Sample Date	Time	Result	Units	Range
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	01/06/2021	13:45	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	01/06/2021	13:45	<0.001	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	01/06/2021	13:57	<0.0005	mg/l	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	01/06/2021	14:00	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	01/06/2021	14:31	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	01/06/2021	14:41	<0.0005	mg/l	
7	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	02/06/2021	10:19	<0.0005	mg/l	
2	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	02/06/2021	10:38	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	02/06/2021	10:38	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	02/06/2021	10:38	<0.0005	mg/l	
5	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	02/06/2021	10:49	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	02/06/2021	10:50	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	02/06/2021	10:53	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	02/06/2021	10:53	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	02/06/2021	11:04	0.002	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	02/06/2021	11:04	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	02/06/2021	11:04	0.0022	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	02/06/2021	11:04	<0.0005	mg/l	
7	Karitane Bowls		Lead - Acid Soluble	02/06/2021	11:21	<0.0005	mg/l	
5	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	02/06/2021	11:22	<0.0005	mg/l	
7	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	02/06/2021	11:27	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	02/06/2021	11:34	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	02/06/2021	11:34	<0.001	mg/l	
7	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	02/06/2021	12:04	<0.0005	mg/l	
7	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	02/06/2021	12:35	<0.0005	mg/l	
7	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	02/06/2021	12:58	<0.0005	mg/l	
2	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	02/06/2021	13:59	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	03/06/2021	14:14	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	03/06/2021	14:28	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	03/06/2021	15:17	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	03/06/2021	15:17	<0.001	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	03/06/2021	15:30	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	03/06/2021	15:33	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	03/06/2021	15:41	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	03/06/2021	15:41	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	04/06/2021	11:15	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	04/06/2021	11:18	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	04/06/2021	11:23	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	04/06/2021	11:23	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	04/06/2021	11:35	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	04/06/2021	11:35	<0.001	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	04/06/2021	11:58	<0.0005	mg/l	

3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	04/06/2021	12:09	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	05/06/2021	09:04	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	05/06/2021	09:14	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	05/06/2021	09:36	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	05/06/2021	09:36	<0.001	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	05/06/2021	09:44	<0.0005	mg/l	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	05/06/2021	09:47	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	06/06/2021	09:30	<0.0005	mg/l	
7	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	06/06/2021	09:35	<0.0005	mg/l	
7	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	06/06/2021	09:40	<0.0005	mg/l	
7	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	06/06/2021	09:40	<0.0005	mg/l	
7	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	06/06/2021	10:00	<0.0005	mg/l	
7	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	06/06/2021	10:10	<0.0005	mg/l	
8	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	07/06/2021	09:10	<0.0005	mg/l	
8	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	07/06/2021	09:15	<0.0005	mg/l	
8	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	07/06/2021	09:45	<0.0005	mg/l	
8	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	07/06/2021	10:00	<0.0005	mg/l	
5	Waikouaiti WTP - Waikouaiti River ? Upstream		Lead - Acid Soluble	08/06/2021	10:24	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	08/06/2021	10:25	<0.0005	mg/l	
5	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	08/06/2021	10:25	<0.001	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Dissolved	08/06/2021	10:38	<0.0005	mg/l	
7	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	08/06/2021	10:38	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	08/06/2021	10:38	<0.0005	mg/l	
5	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	08/06/2021	10:44	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	08/06/2021	10:44	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	08/06/2021	10:56	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	08/06/2021	10:56	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Dissolved	08/06/2021	10:57	0.0007	mg/l	
5	Waikouaiti WTP - Tube Settler Upper Sample		Lead - Acid Soluble	08/06/2021	10:57	<0.0005	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Dissolved	08/06/2021	10:59	0.0008	mg/l	
5	Waikouaiti WTP - Tube Settler Middle Sample		Lead - Acid Soluble	08/06/2021	10:59	<0.0005	mg/l	
7	Waikouaiti SS - Kiatoa Reservoir ? 449 Ramrock Rd		Lead - Acid Soluble	08/06/2021	11:13	<0.0005	mg/l	
7	Waikouaiti SS - Intersection Beach St/Stewart St		Lead - Acid Soluble	08/06/2021	11:32	<0.0005	mg/l	
7	Waikouaiti SS - 192 Main Rd		Lead - Acid Soluble	08/06/2021	12:00	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	08/06/2021	12:14	<0.0005	mg/l	
7	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	08/06/2021	12:28	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	08/06/2021	12:37	<0.0005	mg/l	
7	Karitane Bowls		Lead - Acid Soluble	08/06/2021	13:26	<0.0005	mg/l	
7	Karitane SS - 99 Stornoway St		Lead - Acid Soluble	08/06/2021	13:33	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	09/06/2021	13:19	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	09/06/2021	13:39	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	09/06/2021	15:20	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	09/06/2021	15:20	<0.001	mg/l	

3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	09/06/2021	15:28	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	09/06/2021	15:32	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	09/06/2021	15:35	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	09/06/2021	15:35	<0.0005	mg/l	
1	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	10/06/2021	11:50	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	10/06/2021	12:00	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	10/06/2021	12:55	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	10/06/2021	13:17	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	10/06/2021	23:25	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	10/06/2021	23:25	<0.001	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	11/06/2021	10:26	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	11/06/2021	10:26	<0.001	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	11/06/2021	10:41	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	11/06/2021	10:41	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	11/06/2021	10:48	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	11/06/2021	10:48	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	11/06/2021	11:11	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	11/06/2021	11:27	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	12/06/2021	08:43	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	12/06/2021	08:56	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	12/06/2021	09:16	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	12/06/2021	09:16	<0.001	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	12/06/2021	09:26	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	12/06/2021	09:31	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	12/06/2021	09:35	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	12/06/2021	09:35	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	13/06/2021	10:37	0.001	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	13/06/2021	11:04	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	13/06/2021	11:04	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	13/06/2021	11:29	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	13/06/2021	11:29	<0.001	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	13/06/2021	12:16	<0.0005	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	13/06/2021	12:32	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	13/06/2021	15:08	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	14/06/2021	10:23	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	14/06/2021	10:24	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	14/06/2021	10:28	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	14/06/2021	10:28	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	14/06/2021	10:40	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	14/06/2021	10:40	<0.001	mg/l	
3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	14/06/2021	10:59	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	14/06/2021	11:09	<0.0005	mg/l	
3	Waikouaiti SS - 319 Bendigo Rd		Lead - Acid Soluble	15/06/2021	13:40	<0.0005	mg/l	

3	Waikouaiti SS - 210 Edinburgh St		Lead - Acid Soluble	15/06/2021	13:54	<0.0005	mg/l	
2	Waikouaiti WTP - Raw Water Reservoir Feed to Plant		Lead - Acid Soluble	15/06/2021	14:15	<0.0005	mg/l	
3	Waikouaiti WTP - Post Treated Water Reservoir		Lead - Acid Soluble	15/06/2021	14:22	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Dissolved	15/06/2021	14:30	<0.0005	mg/l	
2	Waikouaiti WTP - Tube Settler Supernatant		Lead - Acid Soluble	15/06/2021	14:30	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Acid Soluble	15/06/2021	14:43	<0.0005	mg/l	
1	Catchment - Waikouaiti River - Pump Station Intake		Lead - Total	15/06/2021	14:43	<0.001	mg/l	