

John Sule

From: Chelsea McGaw
Sent: Friday, 17 August 2018 09:54 a.m.
To: John Sule
Subject: RE: Request for comments - LUC-2018-428 - otago boys hostel expansion

Hi John.

Sorry I only just realised I didn't get back to you about this one, has been an absolutely insane week.

Building control has said that any private drainage matters will be dealt with through the building consent. There is just one thing from us which I'm not sure if it can be conditioned or just an advice note:

- The applicant must design a drainage system for the new carpark which includes sumps installed with filters to control the quality of discharge from the car park site.

Regards

Kia pai tō mutunga wiki
(have a good weekend)

Chelsea McGaw BAppScEnv PGDipComm
Policy Analyst, Three Waters
Dunedin City Council

50 The Octagon, Dunedin; P O Box 5045, Moray Place, Dunedin 9058, New Zealand
Telephone: 03 477 4000; Fax: 03 474 3789.
Email: Chelsea.McGaw@dcc.govt.nz



DUNEDIN CITY
COUNCIL

Te Kaitiaki o Te ōhanga



Please consider the environment before printing this e-mail

From: John Sule
Sent: Tuesday, 31 July 2018 11:15 a.m.
To: Logan Copland <Logan.Copland@dcc.govt.nz>; Grant Fisher <Grant.Fisher@dcc.govt.nz>; Chelsea McGaw <Chelsea.McGaw@dcc.govt.nz>; MWH Hazards Team (MWHHazardsTeam@stantec.com) <MWHHazardsTeam@stantec.com>; Environmental Health Administration <healthadmin@oa.dcc.govt.nz>; Urban Design <Urban.Design@dcc.govt.nz>
Cc: Shane Roberts <shane.roberts@wsp-opus.co.nz>
Subject: Request for comments - LUC-2018-428 - otago boys hostel expansion