From: Lauren Riddle
To: Lauren Riddle
Subject: Fw: FW: Local Government Official Information request - 1320275 - St Clair Handrail
Date: Friday, 16 October 2026 03:27:11 p.m.
Attachments:

From: Jenny Lapham
Sent: Monday, October 12, 2026 14:08
To: 'Newzealand.tbs@gmail.com'
Subject: Fw: FW: Local Government Official Information request - 1320275 - St Clair Handrail

Kia Ora

I refer to your e-mail of 9 October 2026. The information requested is provided below.

Material: 316 Stainless Steel

Weld spec: fillet TIG weld using 1.2 316 filler wire, cleaned by electropolishing.

If you have any further questions please contact James Tyson, Capital Delivery, Transport via the Customer Services Agency 477 4000.

Kâ mihi

Jennifer Lapham

LGOIMA Officer
Governance Group

P 03 477 4000 | **E** Jenny.Lapham@dcc.govt.nz

Te Kaunihera a Rohe o Ôtepoti - Dunedin City Council

PO Box 5045, Dunedin 9054

New Zealand

www.dunedin.govt.nz

From: webmaster@dcc.govt.nz<webmaster@dcc.govt.nz>
Sent: Friday, 9 October 2026 12:57 a.m.
To: Official Information <officialinformation@dcc.govt.nz>
Subject: Local Government Official Information request - 1320275

has submitted a LGOIMA request - 1320275.

Below are the details of the request

Request details:
I request material and weld specifications for the st clair handrail contract.

File attachment (file name **)**
No file uploaded

Name

Email address

Mailing address
Newzealand.tbs@gmail.com

Contact phone number

DUNEDIN CITY COUNCIL | kaunihera ā-rohe o Ōtepoti

If this message is not intended for you please delete it and notify us immediately; you are warned that any further use, dissemination, distribution or reproduction of this material by you is prohibited..

---

kā mihi