
From: Kristy Rusher
Sent: Monday, 14 August 2017 6:53 p.m.
To: Brian Miller
Subject: FW: Local Government Official Information request - 603198

Hi Brian,

Our water team provides the following information on the pump at Hagart Alexander Drive PS during the wet weather event on the 21-22/07/17 is provided below:

According to our spreadsheet, these are the recorded pump hours on Scada.

	Time (21/07/17)	Time (23/07/17)	Total Hours
Pump 1	1815	1949	8 hours, 14 minutes
Pump 2	1940	1710	8 hours, 1 minute

Pump hour run meter readings as recorded

	Hour Run Meter (18/07/17)	Hour Run Meter (25/07/17)	Total Hours
Pump 1	74.61	82.12	7.51 (7 hours, 31 minutes)
Pump 2	71.12	78.35	7.23 (7 hours, 14 minutes)

- During this period, only 1 pump was called to run at a time. Both pumps were available.
- We had no high level alarms from this station
- We had a brief power failure on the 22/07/17 from 06.46 for 26 seconds. No issues.
- Site was not checked during the wet weather event.
- The difference in Scada hours to the switchboard pump hour run meters, can be attributed to comms issues causing delays to the change of state (pump off/on) resulting in slightly inaccurate run times.
- No flow meter on either of the discharge pipes, so we do not have a measure of the volume

Regards,

Kristy Rusher

From: Brian Miller
Sent: Thursday, 27 July 2017 7:46 p.m.
To: Official Information
Subject: Local Government Official Information request - 603198

Brian has submitted a LGOIMA request - 603198.

Below are the details of the request

Request details:

I request the following data of the operation times of the Centre St pumping station that pumps stormwater from the Hagart / Alexander Drive , Centre St catchment into the Silver Stream. for the period from 6pm 21/07/2017 to 6pm on the 22/07/2017. also if data is available of the amount of storm water pumped during that time.

File attachment

No file uploaded

Name

Brian Miller

Email address

[REDACTED]

Mailing address

Contact phone number

[REDACTED]

